

PRE-QUALIFICATION CRITERIA FOR SIGNAL CABLES FOR HPCL VIZAG PROJECT - OPEN TENDER:

Suppliers shall fulfil all the following criteria and submit documentary evidence as proof along with offer for acceptance.

1. Vendor should be a manufacturer of 600/1100V Grade XLPE Insulated, Cu conductor, Armoured, Individual & Overall shielded NON-IS single/multi pair signal/Triad cables and LDPE Insulated, Cu conductor, Armoured, Individual & Overall shielded Intrinsically safe single/multi pair signal/Triad cables as per as per IS 7098-I for Non-IS cables; LDPE as per IS-6474 for IS (Intrinsic Safe) cables (For each line item manufacturing standard is mentioned in Annexure-CC, BIS certificates as per respective standard shall be submitted for offered items) as defined in specification PY56286 Rev 01
2. Availability of In-house test reports duly witnessed by third party on offered all SIGNAL cables to establish in-house capability to carry out all routine, type & acceptance tests as per relevant IS/ International Standards.
3. Supplier to furnish following documents for earlier executed purchase orders for the Power plant SIGNAL cable requirements. The PO shall be not more than five (5) years old from the date of this tender for establishing continuity in business. Manufactured and supplied at least one (1) km of each of type of cable.
years
 - a) Valid BIS certificate, NSIC certificate/Chartered engineer certificate (Equivalent certificate).
 - b) Two (2) no. of P.O. copies, their invoices and approved data sheets
 - c) P.O. copies and their invoices
 - d) Type test, Routine & Acceptance tests reports.
 - e) Dispatch details (LR details/Invoices/ MDCC/Inspection report)
4. Type test certificates from recognized testing house such as CPRI, CMRI, and BASEEFA, UL or Equivalent shall be submitted for below mentioned Signal cables. If in-house type test reports are submitted, same should have been witnessed by Client. Type test certificates should not be older than five years. For each line item, Vendor shall submit type test reports within the size range as per respective manufacturing standard for offered cable.
 - a) In case of first time vendors, Vendor shall submit vendor evaluation form on line at bhel.com under supplier registration link before due date of tender close with all necessary attachments. BHEL reserves the provision to verify the documents and vendor manufacturing facilities.
 - b) Vendor shall confirm to supply the required Signal cables as per BHEL technical specification (PY56286 Rev 01) sent along with present tender.
 - c) Vendor offer acceptance by BHEL is also subjected to end customer approval- EIL & HPCL
 - d) If any information given by the vendor is found incorrect at later stage, BHEL reserves the right to reject the bid submitted by bidder / cancel the award of order.