

Technical pre-qualifying requirements & Experience
for
220kV Voltage Class Surge Arrester

The bidder shall be original equipment manufacturer (OEM) for Surge Arrester(s) and should have manufactured and supplied 220kV Class or above class Surge Arrester, which are in satisfactory operation[#] for at least 2 (two) years as on the originally scheduled date of technical bid opening.

Note:

- (i) *[#]Satisfactory operation means certificate/ commissioning report issued by the customer certifying the operation without any adverse remark(s). The surge arrester offered shall be same type, for which certificate/ commissioning report as mentioned above shall be submitted.*