

ANNEXURE- A

TECHNICAL PRE QUALIFICATION REQUIREMENT (PQR)

Name of Project :- ROURKELA PP-II EXPANSION PROJECT (1X250MW)

Name Of Item :- LT POWER & CONTROL CABLES

PQR Sr. No	PQR Description	Supporting Document to be attached
01	Sub-Qualifying Requirements for LT Control Cables: Bidder should have manufactured and supplied as on date on date of bid opening (original techno-commercial bid opening i.e. 02.04.15) of the following: a) At least 300 km of PVC insulated, PVC sheathed stranded copper conductor of 1.1 kV grade cables in one single contract b) At least one (1) km of Flame retardant low smoke cables.	a). PO Copy b). Inspection/ dispatch clearance c). LR details
02	Sub-Qualifying Requirement for LT Power Cables Bidder should have manufactured and supplied as on date on date of bid opening (original techno-commercial bid opening i.e. 02.04.15) of the following: a) At least 100 Kms of aluminium conductor, XLPE insulated, PVC sheathed power cables of 1.1 kV or higher grade in one single contract. b) At least 100 km of aluminium conductor, PVC insulated, PVC sheathed power cables of 1.1 kV or higher grade in one single contract. c) At least one (1) km of flame retardant low smoke cables. d) 1.1 kV or higher grade power cable of minimum 630 sq.mm. Conductor size.	a). PO Copy b). Inspection/ dispatch clearance c). LR details