

PRE-QUALIFYING (PQ) CRITERIA FOR ENQUIRY E1893148

PROJECT – PUNATSANGCHHU-II HEP, BHUTAN

- 1) Vendor shall furnish unpriced PO copy / Delivery Challan / any other relevant documentary evidence as proof of supplying similar equipment in last 2 years.
- 2) The Vendor must have following capabilities :
 - a) Test setup / facilities for testing of PP Set & Piston accumulator as per our specification. Confirmation of same must be provided along with the Offer.
 - b) After sales service facility at their works in India for any servicing /rectification required. Confirmation of same must be provided along with the Offer.
 - c) Vendor must have supplied the following equipment as per rating specified herein:
 - i) P.P. Set for Hydro Turbine Governor system with Pressure Rating (100 Kg /Cm² or more) and Pump Flow Rate (42 LPM or more at 100 Kg /Cm²).
 - AND
 - ii) Piston Accumulator for Hydro Turbine Governors of capacity 180 Liters (or more) suitable for 100 kg/cm² (or above).

Necessary documentary evidence in form of unpriced Purchase Order copy/Delivery Challan/ any other relevant document must be provided along with offer.
- 3) Vendor to furnish audited balance sheet and profit & loss account for the last three financial years ending March 2019. Foreign vendors to furnish latest BIR (Business information report) issued by a reputed third party business rating agency like Dun & Bradstreet, Creditreform etc. or empanelled third party business rating agency by BHEL, if any. Average turnover in last 3 years ending on 31.03.2019 should not be less than Rs 60 Lakhs.

BHEL reserves the right to Verify or ask for further related details regarding the information provided above.