

PRE QUALIFICATION CRITERIA FOR HT CABLES

INDENT NO: IND: 16: PS: 0005: FEX: 9 DATED: 01.06.2017

BIDDER SHALL MEET ALL THE FOLLOWING REQUIREMENTS

- MINIMUM 500 METERS OF 11KV OR HIGHER THAN 11KV HT POWER CABLES OF SIZE RANGING FROM 185 SQMM OR HIGHER ALUMINIUM ARMoured XLPE INSULATED CABLES AS PER CUSTOMER TECHNICAL SPECIFICATION CONFORMING TO IS7098 SHOULD HAVE BEEN MANUFACTURED AND SUPPLIED BY OEM OR SUPPLIED BY THEIR APPROVED AGENCIES AND SUPPLIED ANY WHERE IN INDIA DURING THE LAST 5 YEARS.

- TEST REPORT AND WARRENTY CERTIFICATE FOR THE ABOVE MENTIONED CABLES SHOULD BE FURNISHED BY THE BIDDER.

N. Gargay
01/06/17

SR. ENGINEER/FEX