

PRE QUALIFICATION CRITERIA FOR NON METALLIC EXPANSION JOINTS

ELIGIBILITY

- a) Vendor / his principal should have experience in supplying NMEJs for at least two coal fired power stations of capacity 270 MW or more where the design and material chosen for this contract is working satisfactorily for more than 20,000 operating hours. This is w.r.t pressure temp size operating conditions and dust burden as called for in the enclosed data sheets.
- b) Vendor should submit performance certificate from these two coal fired power stations.
- c) Vendor to establish that the design offered is same as that of the reference contracts by submitting drawing and data of the same. This should confirm the design arrangement of bolster selection and material data for all the layers of the composite fabric and bolster.