

BHEL-PEM-MAUX
PRE-QUALIFICATION CRITERIA

	PACKAGE: HVAC FOR FGD PROJECT: 2X490 MW DADRI-FGD (JOB NO. 436)		PE-PQ-999-(571-13000-A)-A001
			DATE 10/05/2018
	PRE-QUALIFICATION REQUIREMENT		REV NO 00

1.0	Supplier should have capabilities for design and having in-house / out-sourced testing facility for both the following system: - - AC system: - Minimum installed capacity of AC system shall be 20 TR (Chiller/Precision package AC/Condensing unit/Package AC). - Ventilation System: - Minimum installed capacity of single UAF/AIR WASHER unit shall be 50,000 CMH for complete Ventilation system.
2.0	HVAC system should have been successfully in use in power plant or other industries e.g. refinery/steel/process/commercial/hospital etc. The supplier has to submit either of following supporting documents meeting above mentioned pre-qualifying requirement as per clause 1.0 above. a. Copy of minimum one (1) performance certificate in English from end user along with copy of related Purchase Order (PO) or letter of intent (LOI) or letter of award (LOA) or work order (WO) specifying that the product / equipment is running successfully for one (1) year from date of commissioning meeting the minimum pre-qualifying requirement. OR b. Minimum two PO/ LOI /LOA/ WO placed with a minimum gap of one (1) year from same purchaser meeting the minimum pre-qualifying requirement. OR c. Minimum one PO/ LOI /LOA/ WO after commissioning of first order from same purchaser meeting the minimum pre-qualifying requirement. OR d. In case, vendor has executed contract (s) for BHEL-PEM, internal assessment by BHEL-PEM shall be followed for evaluation for satisfactory performance. For this, vendor to submit the request along-with relevant documents. OR e. Minimum three commissioning certificates meeting the minimum pre-qualifying requirement.
3.0	Minimum two (2) nos. Purchase orders, shall be submitted which should not be more than twenty (20) years old as on date of bid submission, for establishing continuity in business.

Note: -

- Notwithstanding anything stated above, NTPC/BHEL reserves the rights to satisfy himself on the provenness of the equipment and capability and capacity of the manufacturers.
- Notwithstanding anything stated above, NTPC/BHEL reserves the right to assess the capabilities and capacity of the Bidder/his collaborators/ licenser/ his subcontractors to perform the contract, should the circumstances warrant such assessment in the overall interest of the Employer.
- Bidder shall provide all necessary data such as type, design, make, capacity, duty conditions, date of commissioning/ operation etc.