

Prequalifying Criteria (PQR)

TECHNICAL QUALIFICATION:

1. Vendor should have successfully completed similar works in either of the following categories during last 7 years ending 31.12.2016.

(a) Three similar completed works costing not less than the amount equal to Rs.16.55.

OR

(b) Two similar completed works costing not less than the amount equal to Rs. 20.68 Lacs.

OR

(c) One similar completed work costing not less than the amount equal to Rs.33.10 Lacs.

Note:- Copy of work order / purchase order along with performance certificate from vendor's customer for similar works shall be submitted in Techno-commercial bid. BHEL reserves the right to verify the contents of given certificate. Complete postal address, name of contact person, phone no. & email address of issuing vendor's customer is to be submitted by the vendor in Techno-commercial bid. In case BHEL intends to visit vendor's customer, the same shall be facilitated by vendor (expenditure of visit of BHEL official shall be borne by BHEL).

Similar works means "supply of high voltage power cable 11 KV (E) or above".

2. FINANCIAL QUALIFICATION:

Vendor should have an average annual financial turnover of 12.41 Lacs or more during the last 03 financial years 2013-14, 2014-15 & 2015-16. Vendor has to submit the audited financial balance sheets by Chartered Accountant as a proof.



Indent no: S/6390/2016/5738/U

Annexure-1


Supply of HT XLPE 11 KV (E), Armoured Aluminium Cable, size 3x70 Sq.mm as per IS 7098 PART-2 1985 with upto date Amendments:

Technical Specifications:

SL.no	Description	Vendor comment	Remarks
1	11 kV (E) HT cable of size 3 X 70 sq. mm with Stranded Compact Circular Aluminium Conductor		
2	Conductor Screened with Extruded Semi-conducting compound		
3	XLPE Insulated, Insulation Screened with extruded semi-conducting compound in combination with copper tape.		
4	inner sheath of PE /PVC type		
5	Fillers of vulcanized or un-vulcanized rubber or thermoplastic materials.		
6	Galvanized flat steel wire armoring over inner sheath.		
7	overall PVC Sheathed cable conforming to IS:7098/II/85 with latest amendments		
8	Acceptable make:- Torrent/CCI/Havells/RPG/Universal/paramount/HVPL		
Note			
1	Cable must be supplied in one length (without any joint) of 1000 Meters $\pm$ 5%.		
2	The cable drums shall be non-returnable steel drums.		
3	TC & GC required.		
4	Inspection shall be done at BHEL Hardwar.		
5	Technical particulars shall be supplied with offer.		

11/12/16

Sr. Manager (WEX-ESX & DG)


Engineer (WEX-ESX)

Indent No: S/6390/2016/5738/U

Annexure-2

Supply of HT XLPE 11 KV (E), Armoured Aluminium Cable, size 3x300 Sq.mm as per IS 7098 PART-2 1985 with upto date Amendments:
Technical Specifications:

SL.no	Description	Vendor comment	Remarks
1	11 kV (E) HT cable of size 3 X 300 sq. mm with Stranded Compact Circular Aluminium Conductor		
2	Conductor Screened with Extruded Semi-conducting compound		
3	XLPE Insulated, Insulation Screened with extruded semi-conducting compound in combination with copper tape.		
4	inner sheath of PE /PVC type		
5	Fillers of vulcanized or un-vulcanized rubber or thermoplastic materials.		
6	Galvanized flat steel wire armoring over inner sheath.		
7	overall PVC Sheathed cable conforming to IS:7098/II/85 with latest amendments		
8	Acceptable make:- Torrent/CCI/Havells/RPG/Universal/paramount/HVPL		
Note			
1	Cable must be supplied in one length (without any joint) of 500 Meters $\pm$ 5%.		
2	The cable drums shall be non-returnable steel drums.		
3	TC & GC required.		
4	Inspection shall be done at BHEL Hardwar.		
5	Technical particulars shall be supplied with offer.		

Sign & seal of bidder

Sr. Manager (WEX-ESX & DG)

Engineer (WEX-ESX)