

PRE-QUALIFICATION REQUIREMENT FOR THE SUPPLY OF SCOTCH YOKE TYPE PNEUMATIC ACTUATORS

The prospective supplier should meet the following Pre-Qualification requirements,

- 1) Should have supplied Scotch Yoke Type Pneumatic Actuators (Min output Torque- 5500 NM to 8500 NM) for power plant or process industry applications
- 2) Supplied pneumatic actuator should be successfully operating for least One-year period (Prior to the date of submission of offer for the present tender).
- 3) The torque rating should be equivalent or of higher capacity than the present individual project requirements.
- 4) The vendor should provide suitable End User Certificate from their customers for their satisfactory performance indicating Date of supply and commissioning of the above, torque ratings, quantity of supply and other details.
- 5) Authorized service centres should be there in India.