

22

**PRE-QUALIFICATION REQUIREMENT (PQR) FOR VENDORS FOR SUPPLY OF
REFILLING CO2 CYLINDER AND CO2 GAS CARTRIDGE OF INDENT NO. 20181259**

Dated: 07/06/2018

Pre-Qualification Criteria for Vendors for Refilling of Co2 Cylinder and Co2 gas cartridge.

The Bidders meeting following criteria would only be considered: -

1. Suppliers having successfully completed similar supply ending 07/06/2018 of either of the following: -

- a) Three similar completed supplies costing not less than the amount equal to Rs. 2,95,000/- (excluded from any service tax)

OR

- b) Two similar completed supplies costing not less than the amount equal to Rs. 4,72,000/- (excluded from any service tax)

OR

- c) One similar completed supplies costing not less than the amount equal to Rs. 9.44,000/- (excluded from any service tax)

Similar supply means supply for Co2 refilling of Co2 cylinder and co2 cartridge to any Indian public sector unit or any Indian govt. organization or any Indian private sector.

- d) Bidders shall provide purchase order/work order copy and performance certificate for satisfactory supply from his customer along with name, address & contact details. BHEL reserves the right to verify the information provided.

2. Vendor should be manufacture or his authorised dealer.


Coy. Commander/Fire 11/07/18

ASSTT.COMMANDANT/FIRE  11/07/18

S DGM/HR


12.07.2018

TERMS & CONDITIONS

1. Refilling of Co2 extinguishers including hydraulic test should be as per norms given in IS: 2878/IS: 2190. Hydraulic Test Certificates of all type of extinguishers should be in prescribed Performa given by authorized manufacturer/dealer.
2. Valve & other necessary spares of the extinguishers will be replaced during refilling if damaged and certificate should also be provided.
3. Damaged /replaced spare parts shall be returned to BHEL Haridwar.
4. Material will be collected by the Party from BHEL fire Station (through proper gate pass) and the same will be returned to BHEL store after refilling /completion of work.
5. CO2 Gas shall be filled in extinguishers by weight not by topical pressure.
6. Material shall be supplied by the Party within 45 Days along with all necessary certificates/documents.
7. Inspection of material will be carried out jointly by CISF fire wing in charge and BHEL management representative at BHEL plant Store.
8. Fire CO2 extinguishers shall be painted with red paint after removing of previous paint and CO2 gas cartridge shall be painted with aluminums paints.
9. Sticker should be affixed only on extinguishers.



Asstt. Commandant / Fire
CISF Unit BHEL Haridwar