


	PROJECT:3x660 MW NABINAGAR STPP (FGD PKG) PRE-QUALIFICATION REQUIREMENT- MISCELLANEOUS TANKS (SITE FABRICATED) FOR FGD SYSTEM	PE-PQ-457-167-A001	
		DATE	21/02/2020
		REV NO	00

1.0	The bidder is required to meet the provenness criteria and /or qualification requirement for Miscellaneous Tanks(Site fabricated) as per criteria stipulated below: a) Bidder should have engineered/ got engineered, supplied, erected, tested and commissioned at least one (1) number of vertical cylindrical storage tank of capacity not less than 500cum. The above system/tank should have been in successful operational for minimum one (1) year as on date of bid opening .
2.0	The supplier has to submit following supporting documents meeting above mentioned pre-qualifying requirement Copy of minimum one (1) performance certificate in English from end user along with copy of related Purchase Order (PO) or letter of intent (LOI) or letter of award (LOA) or work order (WO) in support of PQR clause mentioned at S.No. 1.0 above.
3.0	Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
4.0	Minimum one (1) no. Purchase order shall be submitted which should not be more than seven (7) years old as on date of bid submission, for establishing continuity in business. This is over and above the requirement of PO mentioned at S.No. 2.0 above.
5.0	Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a translation of its pertinent passages in English language in which case, for purposes of interpretation of the bid, the translation shall govern. The English Translation of the documents shall be carried out by professional translators and the translator shall certify that he is proficient in both languages in order to translate the document and that the translation is complete and accurate. Further, translation shall be authenticated by the Indian Consulate located in the Country where the documents have been issued or the Embassy of that Country in India.
6.0	Notwithstanding anything stated above, BHEL/NPGCL reserve the right to assess the capabilities and capacity of the bidder/ collaborator to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL/NPGCL.
7.0	Consideration of offer shall be subject to customer's approval of bidder, if applicable.
8.0	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all other terms of the tender.

NOTE:

The qualification requirement for the rubber lining has been mentioned in the specification. Bidder to follow the same while proposing the manufacturer for rubber lining during detail engineering. Bidder has to give notarized affidavit (format attached as Annexure-1 to this PQR) along with the bid confirming the same. Bidder not giving the same shall not be qualified.



21/02/2020

Prepared By


21.02.2020

Reviewed By

SK Bhattacharya



Approved By

AFFIDAVIT

-----TO BE PRODUCED ON INR 10 NON-JUDICIAL STAMP PAPER-----

We, the undersigned, do hereby solemnly affirm and declare that:

We accept and confirm that the offered rubber lining against your RFQ/NIT Reference _____ for _____ for 3x660 MW NABINAGAR STPP MISCELLANEOUS TANKS FOR FGD SYSTEM shall be supplied from such manufacturer who have supplied rubber lining (Bromo Butyl lining) application for coal based thermal power station for Wet Limestone based FGD application or similar application in other process industry. The lining shall be guaranteed for uninterrupted minimum life of 25,000 hrs. Proof of such guarantee to be established from performance certificate/Test Certificates.