

	PRE-QUALIFICATION REQUIREMENTS FOR SCREENED CONTROL CABLE	PE-PQ-999-507-E016
		REVISION NO. 04 DATE 29/09/2017
		SHEET NO. 1 OF 1




ITEMS : Screened Control Cable

SCOPE : Supply : YES; Erection & Commissioning : NO;

1.0	Vendor should be a manufacturer of screened/ instrumentation control cables.
2.0	Availability of test reports of tests on FRLS screened control cables to establish in-house Capability to carry out all routine, type acceptance as per relevant IS/ International Standards (except UV radiation & hydrolytic stability Test which can be conducted at Govt. Lab/ Govt. approved Independent lab).
3.0	Capacity of manufacturing 200 km of screened control cables per month.
4.0	Manufactured and supplied at least one (1) km of FRLS cables.
5.0	Manufactured and supplied screened control cables up to 20 pairs.
6.0	Manufactured and supplied at least 1000 Km of Screened Control cables in one or more orders and at least 200 Km in one single order.
7.0	Minimum two (2) nos. purchase orders for screened control cables shall be submitted which should not be more than five (5) years old from the date of application for registration or date of techno-commercial bid opening (as applicable) for establishing continuity in business.

Notes (General points):

1. Consideration of offer shall be subject to customer's approval of bidders, if applicable.
2. Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
3. Any other project specific requirement shall be as per Annexure-I and bidder shall submit relevant supporting documents.
4. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
5. After satisfactory fulfillment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

PREPARED BY  ABHISHEK, MANAGER (CONVENOR)	REVIEWED BY  MANISH SHUKLA, DGM (APPROVER)	APPROVED BY  MEENA KESRI, GM (DH)
---	--	---

BHEL PEM-ELECTRICAL

PRE QUALIFYING REQUIREMENTS FOR SCREENED CONTROL CABLES

ANNEXURE-I

PROJECT: 2X660 MW ENNORE STPP

PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY

-NIL-

[DEALING ENGINEER]

Vikas
14/06/19

[CONTROLLING OFFICER-CO]

Vikas
14/06/19

[SECTION HEAD-SH]

Sh
14/6/19

[DEPARTMENT HEAD]

Kan
14/6/19