


PRE QUALIFICATION CRITERIA FOR LT CABLES

INDENT NO: IND: 17: PS: 0005: FEX: 21 DATED: 02.11.2017

BIDDER SHALL MEET ALL THE FOLLOWING REQUIREMENTS

- **MINIMUM 500 METERS OF 1.1 KV LT POWER CABLE OF SIZE 185 SQMM OR HIGHER SIZE 3.5CORE ALUMINIUM ARMOURED XLPE INSULATED CABLES AS PER CUSTOMER TECHNICAL SPECIFICATION CONFORMING TO IS 7098 SHOULD HAVE BEEN MANUFACTURED BY OEM OR SUPPLIED BY THEIR APPROVED AGENCIES AND SUPPLIED ANY WHERE IN INDIA DURING THE LAST 5 YEARS.**

- **TEST REPORT AND WARRENTY CERTIFICATE FOR THE ABOVE MENTIONED CABLES SHOULD BE FURNISHED BY THE BIDDER.**



SR.ENGINEER/FEX