

PRE QUALIFICATION CRITERIA FOR HT CABLES

INDENT NO: IND: 17: PS: 0005: FEX: 20 DATED: 01.11.2017

BIDDER SHALL MEET ALL THE FOLLOWING REQUIREMENTS

- MINIMUM 500 METERS OF 11KV OR HIGHER THAN 11KV HT POWER CABLES OF SIZE RANGING FROM 185SQMM TO HIGHER SIZE 3CORE ALUMINIUM ARMoured XLPE INSULATED CABLES AS PER CUSTOMER TECHNICAL SPECIFICATION CONFORMING TO IS 7098 SHOULD HAVE BEEN MANUFACTURED BY OEM OR THEIR APPROVED AGENCIES AND SUPPLIED ANY WHERE IN INDIA DURING THE LAST 5 YEARS.

- TEST REPORT AND WARRENTY CERTIFICATE FOR THE ABOVE MENTIONED CABLES SHOULD BE FURNISHED BY THE BIDDER.

H. Raju

SR. ENGINEER/FEX