

Pre-qualification criteria for supply of Lube Oil System to float open tender

Vendors who satisfy the following criteria can only quote:

1. Should offer Lube Oil System(LOS) as per BHEL specification and LOS scheme drawing without any deviation.
2. Should have supplied similar capacity of LOS for FD,ID and PA fan application for 210 MW and above rating thermal power plants and it should have been in operation at least one year at the time of offer submission.
3. Should provide full technical details and years of operation of supplied LOS.
4. Should submit credentials of supply i.e. customers name, contact person, phone number, E-mail etc. as a part of reference along with offer.
5. Should submit purchase order copy and/or commissioning report to substantiate supply of LOS.
6. Should have dedicated team of experts for after sales service.