

PRE-QUALIFICATION REQUIREMENT

The elevator offered shall be in satisfactory operation for boiler application in fossil fuel fired thermal power plants of unit rating 250MW or above. Vendor shall submit a list of reference thermal plants (with elevator capacity, landing levels and travel) where their elevator is in satisfactory operation for more than one year. Commissioning and service support for the elevator shall be available in India

OFFER WILL BE CONSIDERED ONLY ON FULFILLING THE ABOVE PQR. VENDOR TO SUBMIT THE
REFERENCE LIST