



2X660 MW ENORE SEZ STPP

ANNEXURE-B

PRICE FORMAT FOR INDIAN BIDDERS FOR OIL FILLED SERVICE TRANSFORMERS

ENQUIRY NO. - PE/PG/EN1/E-5638/2017 DTD. 01/06/2017

Sr. No.	Item code	Item description	Unit	ORDER QUANTITY	UNIT EX WORKS PRICE (Rs.)	TOTAL EX WORKS PRICES (Rs.)	EXCISE DUTY @...% (FOR SELF MANUFACTURED ITEMS ONLY) (Rs.)	CST@...% AGAINST FORM C-1/E2 OR VAT@...% AS APPLICABLE (Rs.)	FREIGHT@...% OF EX WORKS INCLUDING SERVICE TAX (Rs.)	TOTAL FOR SITE PRICES (Rs.)
1	2	3	4	5	6	7=5*6	8	9	10	11=7+8+9+10
		MANDATORY SPARES FOR EACH TYPE AND RATING OF TRANSFORMER								
		302-11000-B								
1		Bushing								
1(a)		HV Bushing	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
1(b)		LV Bushing	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
1(c)		LV Neutral Bushing	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
2		Winding temperature indicator with contacts	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
3		Tap Changer contacts	Set	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
4		Magnetic oil gauge/oil level indicator with contacts	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
5		Oil temperature indicator with contacts	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
6		Buchholz Relay	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
7		Floater with contact for Buchholz Relay	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
8		Set of gaskets (other than that with bushing)	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
9		Set of valves	Set	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
10		Pressure relief device	NOS.	1 FOR EACH TYPE/RATING OF TRANSFORMERS						
TOTAL										

BIDDERS SIGN AND STAMP

PRICE FORMAT FOR INDIAN BIDDERS FOR OIL FILLED SERVICE TRANSFORMERS

ENQUIRY NO. - PE/PG/EN1/E-5638/2017 DTD. 01/06/2017

Sr. No.	Item code	Item description	Unit	ORDER QUANTITY	UNIT EX WORKS PRICE (Rs.)	TOTAL EX WORKS PRICES (Rs.)	EXCISE DUTY @...% (FOR SELF MANUFACTURED ITEMS ONLY) (Rs.)	CST @...% AGAINST FORM C-EL/E2 OR VAT @...% AS APPLICABLE (Rs.)	FREIGHT @...% OF EX WORKS INCLUDING SERVICE TAX (Rs.)	TOTAL FOR SITE PRICES (Rs.)
1	2	3	4	5	6	7=5*6	8	9	10	11=7+8+9+10
1	302-11015-A	8000KVA, 11KV/3.6KV, 3 PHASE, 2 WINDING, OUTDOOR, ONAN, Z=9.0%, DYN1, OFF CIRCUIT TAPS, 5% IN STEPS OF 2.5% (WITH CABLE BOX TYPE HV AND WITH BUS-DUCT TYPE LV TERMINATION)	NOS.	2						
2	302-11014-A	6300KVA, 11KV/3.6KV, 3 PHASE, 2 WINDING, OUTDOOR, ONAN, Z=6.0%, DYN1, OFF CIRCUIT TAPS, 5% IN STEPS OF 2.5% (WITH CABLE BOX TYPE HV AND WITH BUS-DUCT TYPE LV TERMINATION)	NOS.	4						
3	302-11012-A	3500KVA, 11KV/6.9KV, 3 PHASE, 2 WINDING, OUTDOOR, ONAN, Z=5.0%, DYN1, OFF CIRCUIT TAPS, 5% IN STEPS OF 2.5% (WITH CABLE BOX TYPE HV AND WITH BUS-DUCT TYPE LV TERMINATION)	NOS.	2						
4	302-11045-A	10 % EXTRA TRANSFORMER OIL IN SEALED NON RETURNABLE STANDARD DRUMS FOR 8000KVA, 11KV/3.6KV, 3 PHASE, 2 WINDING, OUTDOOR, ONAN, Z=9.0%, DYN1	NOS.	2						
5	302-11045-A	10 % EXTRA TRANSFORMER OIL IN SEALED NON RETURNABLE STANDARD DRUMS FOR 6300KVA, 11KV/3.6 KV, 3 PHASE, 2 WINDING, OUTDOOR, ONAN, Z=6.0%, DYN1	NOS.	4						
6	302-11045-A	10 % EXTRA TRANSFORMER OIL IN SEALED NON RETURNABLE STANDARD DRUMS FOR 3500 KVA, 11KV/3.6 KV, 3 PHASE, 2 WINDING, OUTDOOR, ONAN, Z=5.0%, DYN1	NOS.	2						
7	302-11000-B	MANDATORY SPARE (DETAILED BREAK-UP TO BE FILLED IN ANNEXURE-B)	LOT	1						
TOTAL										

Notes:

- EXCISE DUTY FOR TRANSFORMER OIL (IF DIFFERENT FROM MAIN PRODUCT) @.....% (PERCENTAGE W.R.T. EX WORKS OF TRANSFORMER OIL)
- BIDDER SHALL SUPPLY 10% EXTRA OIL AS PER THE QUOTED PRICE. QUANTITY OF EXTRA OIL SHALL BE SUBJECT TO APPROVAL DURING DETAIL ENGINEERING.
- BIDDER TO NOTE THAT THE COST OF TRANSFORMER SHALL INCLUDE THE COST OF ROUTINE TEST, SPECIAL TESTS & TYPE TESTS. THESE TESTS SHALL BE CARRIED OUT ON TRANSFORMERS WITHOUT ANY ADDITIONAL COST. BIDDER SHALL QUOTE ACCORDINGLY. SPECIAL / TYPE TESTS SHALL BE CONDUCTED AT THIRD PARTY LAB/ VENOR WORKS IN PRESENCE OF CLIENT/ EMPLOYERS REPRESENTATIVE AND VENDOR TO SUBMIT THE REPORTS FOR APPROVAL.
- BOQ-CUM-PRICE SCHEDULE MAIN ITEMS (ANNEXURE-A), MANDATORY SPARES (ANNEXURE-B) WILL BE CONSIDERED FOR PRICE EVALUATION PURPOSE.
- CHARGES FOR CARRYING OUT SHORT CIRCUIT TEST SHALL BE PAYABLE BASED ON ACTUAL INVOICE FROM DESIGNATED LABORATORIES (CPRI, BHPAL/ CPRI, BANGLORE / ERDA, VADODARA) WITH AN ADDITIONAL LUMP SUM AMOUNT OF 5% OF EX-WORKS PRICE OF TRANSFORMER BEING TESTED TO COVER HANDLING COSTS (TRANSPORTATION, INSURANCE ETC.).

Signature

BIDDERS SIGN AND STAMP