


Qualifying requirements for Nitrogen Injection Fire Prevention & Extinguishing System for 100 MVA and 160 MVA 220 KV Class Oil Filled Transformers

S. no	Remarks for Qualifying requirements	Vendor Comments/ Confirmation
1.	The bidder must furnish their list of supplies. The bidder must have supplied at least 1 NIFPES system for power transformer in India (copy of purchase order from reputed customer to be enclosed). OR In case of bidder has obtained the license (or sale agreement) from the principal for manufacture of NIFPES, their principal must have supplied least 1 NIFPES system for power transformer in India (copy of purchase order from reputed customer to be enclosed). Copy of license or sale agreement has to be enclosed with bid in such case.	Confirmed/ Not Confirmed
2.	The vendor must submit the convincing evidence and technical write-up for the satisfactory performance of their system.	Confirmed/ Not Confirmed
3.	The vendor must submit the certificate of all the test conducted on the system and the components used in the system.	Confirmed/ Not Confirmed
4.	The bidder have in-house facility for conducting the functional test of the system at their works excluding the fire ignition/extinguishing arrangement.	Confirmed/ Not Confirmed
5.	The offered system must be guaranteed as a complete system for all the associated and in-built components.	Confirmed/ Not Confirmed
6.	The scope of work will include supply, erection, commissioning and civil work of the system at Customer site.	Confirmed/ Not Confirmed
7.	Any items which is required for successful erection and commission of the system will be in the scope of supplier viz. hose pipe, valves, cables, cable lugs, plugs, connectors, hardware etc.	Confirmed/ Not Confirmed
8.	Vendors from foreign countries must have their authorised service centres in India and skilled manpower to undertake the activities relating to supply/erection/commissioning/ service of the system.	Confirmed/ Not Confirmed
9.	These systems are for POWERGRID Projects in India. Order will be placed on suppliers which get themselves approved from POWERGRID.	Confirmed/ Not Confirmed


 22/07/17
 (VISHAL SRIVASTAVA)
 Sr Engineer (TRE)
 R. H. E. L., Jhansi