

QUALIFYING REQUIREMENTS FOR GLASS FLAKE LINING

The Bidder is required to meet the qualification requirement for Glass Flake Lining as per criteria stipulated below:

Glass Flake Lining for the Wet Limestone based Flue Gas Desulphurisation (FGD) System offered by the Bidder shall be only from such bidders(s) who has previously executed this lining application for coal based thermal power station for Wet Limestone based FGD application such that the lining should have been in successful operation in at least one (1) plant for a period not less than two (2) year reckoned as on the date of bid opening.

The Bidder should provide reference list and performance certificates from End User along with bid.