



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date: 08 Oct 2021

CORRIGENDUM- 02

PROJECT	:	2 X 500MW TUTICORIN TPP-FGD SYSTEM
PACKAGE	:	HVAC FOR FGD
ENQUIRY NO	:	PE/PG/NTF/E-6776/2021 Dated 28.09.2021
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

Please note the following:

Clarification Required	BHEL's clarification
We request you to confirm us the distance between Condensing Unit to AHU location.	Air cooled out door shall be located at roof of the AHU room as shown drawing enclosed with technical specification. Bidder is to consider distance in between condensing unit to AHU location accordingly.

Measuring units may be considered as below regarding price schedule;

- 1.0 clause no. A-AC system, 3*c* & d*- unit may be considered as Rmt*
- 2.0 clause no. A-AC system, 4*b*- unit may be considered as Nos*

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Sharad Chandra
Manager/BOP