

Specification No.		7751		
Item No.		SP/MISC/7751/1 TO 4		
Location		M.T.Lab.		
SCOPE:				
SUPPLY, INSTALLATION & COMMISSIONING OF 1.5 TON SPLIT WALL MOUNTED TYPE AIR CONDITIONER AS PER SPECIFICIFICATION				
NOT E:	1. Vendor must submit complete information against clause No. 6.0 (Qualifying condition). The offer meeting would only be processed.			
	2. The " offered" Column and where applicable, the " Deviations" Column of this format shall be filled in by the VI submitted along with the offer. Technical details also submitted with the offer. Inadequate / incomplete, ambiguous unsustainable information against any of the clauses of the specification / requirements shall be treated as non -Compliance			
	3. The offer and all documents enclosed with offer should be in English language only.			
SUPPLY, INSTALLATION & COMMISSIONING OF 1.5 TON SPLIT WALL MOUNTED TYPE AIR CONDITIONER AS PER SPECIFICIFICATION				
S.NO.	DESCRIPTION FOR BHEL REQUIREMENT	SPECIFIED /TO BE CONFIRMED BY VENDOR	OFFERED	DEVIATIONS
1	PURPOSE			
1.1	Split Wall mounted type A/C is required for M.T.Lab. capacity -- 1.5 Ton	VENDER TO CONFIRM		
2	WORK PIECE MATERIAL			
2.1	supply, installation and commissioning of Split wall mounted type 1.5 TON capacity air conditioner (rating of A/C should be not less than 3 star) along with stabilizer and mounting bracket (for out door unit). Make- LLOYD/VOLTAS/SAMSUNG/LG/HITACHI/DAIKIN/BLUE STAR/CARRIER/O'GENERAL/VIDEOCON/VESTAR/GODREJ/ONIDA/WIRLPOOL/ELECTROLUX ONLY. Quantity - 04 Nos.	VENDER TO CONFIRM		
3	TECHNICAL DETAILS-SPLIT WALL MOUNTED A/C- 1.5 TON			
3.1	Tonnage - 1.5 TR	VENDER TO CONFIRM		
3.2	Star rating (not less than 3 star)	VENDER TO SPECIFY & CONFIRM		
3.3	Rated current -	VENDER TO SPECIFY		
3.4	Supply voltage - 230 Volt 50HZ	VENDER TO CONFIRM		
3.5	Noise level	VENDER TO SPECIFY		
3.6	Compressor type -	VENDER TO SPECIFY		
3.7	Make of offered air conditioner	VENDER TO SPECIFY		
3.8	Model of offered air conditioner	VENDER TO SPECIFY		
3.9	Dimension of Indoor unit in mm	VENDER TO SPECIFY		
3.10	Dimension of Outdoor unit in mm	VENDER TO SPECIFY		
3.11	Weight of Indoor unit in kg.	VENDER TO SPECIFY		
3.12	Weight of Outdoor unit in kg	VENDER TO SPECIFY		
3.13	Capacity of voltage stabilizer-5.0 KVA	VENDER TO CONFIRM		
3.14	Make of voltage stabilizer	VENDER TO SPECIFY		
4	INSTALLATION			
4.1	Vender to take full responsibility to carryout the installation, commissioning & start up of supplied air conditioner with his own tools & labour .	VENDER TO CONFIRM		
5	MISCELLANEOUS			
5.1	Detailed catalogues, sketch/ photograph of the A/C and accessories/attachments should be submitted with the offer.	VENDER TO SUBMIT		
5.2	The air conditioner shall be guaranteed for trouble free performance for a period of 24 month from the date of commissioning.	VENDER TO CONFIRM		
5.3	Notwithstanding anything, the details in this specification, if any thing else is required for its functioning, the same shall be Specifically brought out & indicated.	VENDER TO CONFIRM		
6	QUALIFYING CONDITION			
6.1	Only those vendor who are authorized dealer of the air conditioner OR Manufacturer should quote. Authorizations certificate to be Submitted with the offer.	VENDER TO CONFIRM & Submit		
7	BHEL reserves the right to verify information submitted by vendor. In case the information is found to be false / incorrect, the offer shall be rejected.	VENDER TO CONFIRM		

Y.K.Dhingra
Dy.Mgr.WEX)

Inder Mathur
D.G.M.(WEX)

S.J.Chakraborty
A.G.M.(WEX)