


 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR ELECTRICAL WORKSHOP EQUIPMENTS TESTING DEVICES		SPECIFICATION NO. EM-MHDA-MAN-16	
			Rev. No	01
	4 x 180 MW MANGDECHHU HEP		Date	13.12.16

SPECIFIC TECHNICAL SPECIFICATIONS

 K. K. Gyanchandani Sr Engineer BOP	 Mandvi Gupta Manager BOP
PREPARED BY	APPROVED BY

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR ELECTRICAL WORKSHOP EQUIPMENTS TESTING DEVICES		SPECIFICATION NO. EM-MHDA-MAN-16	
			Rev. No	01
	4 x 180 MW MANGDECHHU HEP		Date	13.12.16

(1)Details of Equipments

Bidder must quote the make, model No, material description & quantity offered in their quotation /bid, as specified below. Bidder's alternate description can also be given in separate column.

Completeness of Equipment

Each of the equipment listed shall be complete with applicable accessories like power supply main leads, screened guard leads, screened line test leads, earth leads, connectors and clips, leather carrying case and any other accessories required for completing the equipment. Bidder has to mention technical details & quantity of each item under this category along with offer.

Sl.No	Item specification	Qty	Details of Equipment offered by the Bidder	
			Make & Model No	Catalogue No
1	PORTABLE SOUND LEVEL MEASURING INSTRUMENT. Microphone with linear characteristic in the range of 31.5Hz to 16kHz with: (i)Range: 25...130dB with overlapping zones. (ii)Battery-Check button. (iii)For peak & average value measuring.	1 No.		

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR ELECTRICAL WORKSHOP EQUIPMENTS TESTING DEVICES		SPECIFICATION NO. EM-MHDA-MAN-16	
			Rev. No	01
	4 x 180 MW MANGDECHHU HEP		Date	13.12.16

(3) Technical Deviation Statement (if any)

Sr No.	Item	Deviation	Justification for Deviation

Note: Bidder has to indicate clearly the deviations if any w.r.t. specification. Bidder has to indicate all the deviations on this sheet only, deviations mentioned elsewhere in Bidder's offer will not be considered.