

	EPD-1901-TS-RC-NFLPBS
1	LPBS TYPE-A (Emg. Stop) shall be supplied as per Drawing no: EP-3-GA-107-012 R00
2	LPBS TYPE-B (Start & Emg. Stop) shall be supplied as per Drawing no: EP-3-GA-107-013 R00
3	LPBS TYPE-BB(Open & Close) shall be supplied as per drawing no : EP-3-GA-107-013 R00 except stop push button shall be without mushroom type
4	Capacity Requirement: Minimum Capacity of the vendor per month shall be 300Nos of Push Buttons station .
5	Terminal blocks should be melamine type
6	Manufacturer to submit relevant type test reports, test certificates along with the technical quotation.
7	All items shall be of type tested quality. The bidder shall submit for owner's approval of all the type tests carried out within last five years from the date of bid opening.
8	Vendor will be evaluated on the overall package basis.

	PRICE FORMAT
1	EMERGENCY LOCAL PUSH BUTTON STATION-NON FLAME PROOF TYPE-A(STOP) - 3500 EA
2	EMERGENCY LOCAL PUSH BUTTON STATION-NON FLAME PROOF TYPE-B(START & STOP) - 3500 EA
3	EMERGENCY LOCAL PUSH BUTTON STATION-NON FLAME PROOF TYPE-BB(OPEN & CLOSE) - 2000 EA