




BHARAT HEAVY ELECTRICALS LIMITED

TRANSMISSION BUSINESS HVDC ENGINEERING & SYSTEMS

COPYRIGHT AND CONFIDENTIALITY

The information on this document is the property of BHARAT HEAVY ELECTRICALS LTD.
It must not be used directly or indirectly in anyway detrimental to the interest of the company

DOCUMENT No.	TB-397-316-020	Rev. No.	00	Prepared	Checked	Approved
TYPE OF DOC.	TECHNICAL SPECIFICATION			SIGN		
TITLE	ILLUMINATION SYSTEM			NAME	NS	SKS
				DATE	31/07/19	31/07/19
				GROUP	HVDC	W.O. No
						87009
CUSTOMER	Patratu Vidyut Utpadan Nigam Ltd. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)					
PROJECT	400kV GIS at Patratu Super Thermal Power Project Expansion Phase-I (3 X 800 MW)					
NOA NO.	01/PVUNL-CS-9585-001-2/NOA-FC Dated 08-Mar-2018 01/PVUNL-CS-9585-001-2/NOA-SC Dated 08-Mar-2018 01/PVUNL-CS-9585-001-2/NOA-TC Dated 08-Mar-2018					
Station	Patratu, Jharkhand					
CONTENTS						
Section	Description					No. of Sheets
1	Scope, Bill of Quantity, Specific Technical Requirement, Qualifying Requirement					12+6+5
2	Equipment Specification					16
3	Project Details and General Technical Requirements					1+33
4	Guaranteed Technical Particulars					1+4
5	Enclosures To The Specifications					1+6+4
Rev No.	Date	Altered	Checked	Approved	REVISION DETAILS	
Distribution	To			HVDC	TBMM	TBQM
	Copies			1	1	1
						4



SECTION-1

Scope, Bill of Quantity, Specific Technical Requirements & Qualifying Requirement

1.1 Scope

- 1.1.1 This technical specification covers the requirements of **design, manufacture, inspection and testing at manufacturer's works, proper packing and delivery to project site, material reconciliation at site, supervision of ETC works** for Illumination System for GIS Building, Control Room Building, outdoor Switchyard & street lighting complete in line with specification. Performance test is in the scope of bidder.
- 1.1.2 This section covers the specific technical requirements of Illumination System for GIS Building, Control Room Building, Outdoor Switchyard & street lighting. This constitutes minimum technical parameters for the above system as specified by the customer. The offered system shall also comply with the Section-3 of this specification.
- 1.1.3 The Contract shall be on Bill of Quantity basis for the package. The detailed design shall be submitted by bidder and subject to approval by Customer. The BOQ quantities which are finalized after approval has to be supplied. BHEL reserves the right for quantity variation due to any reason up to $\pm 30\%$ of total value at same unit rate and terms & conditions during execution of contract. The quantity of individual items may however vary up to any extent. However, the bidder shall be responsible for the design and verification of the complete illumination system, demonstration of lux levels and other criterion at site. Any additional item required for completion of the work shall be supplied by bidder without any implication to BHEL.
- 1.1.4 After placement of order, the bidder has to design the system as per relevant standard/codes to the satisfaction of BHEL/NTPC.
- 1.1.5 It is not the intent to specify herein all the details of design and manufacturing. The equipment and the system shall conform in all respects to high standards of design, engineering and workmanship and shall be capable of performing the required duties in a manner acceptable to BHEL/NTPC, who will interpret the meaning of drawings and specifications and shall be entitled to reject material, which in his judgment is not in full accordance herewith.



- 1.1.6 The bidder shall have deemed to have understood completely all the tender drawings and documents and quoted accordingly.
- 1.1.7 The term "Owner" appearing in this specification shall refer to ultimate customer, the term "Purchaser" shall refer to BHEL and the term "Contractor" shall refer to the successful Bidder.
- 1.1.8 It is the responsibility of the successful Bidder to obtain necessary approval/clearance from statutory organizations wherever applicable for the equipment/systems under the scope specified.
- 1.1.9 No deviation from the requirements specified in various clauses of this specification shall be allowed.
- 1.1.10 The equipment is required for the following project:

Name of the customer : **Patratu Vidyut Utpadan Nigam Ltd. (PVUNL)**
(A Subsidiary of NTPC in Joint Venture with JBVNL)

Name of the project : **400kV GIS at Patratu Super Thermal Power Project**
Expansion Phase –I (3X800 MW)

Site : **Patratu, Jharkhand**

***Note: The terms used in this specification namely, “Employer/Purchaser” refers to PVUNL , “Contractor” refers to BHEL.**

Refer section-3 of this document for project details and general specification.

In case of any conflict among the various sections of this specification, the order of precedence shall be section 1, section 2 & the section 3.

- 1.1.11 The scope of supplies shall be as per commercial terms and conditions enclosed separately with enquiry.



1.2 Specific Technical Requirements

1.2.1 Illumination System Requirement

Illumination system, illumination system design, Lux levels for various areas, luminaries' type and low voltage power services for following areas shall be required,

- (i) Switchyard control room building & GIS building
- (ii) Outdoor switchyard area & street light

The illumination system for transformer yard area is not in the scope of bidder, it is under the scope of power plant package illumination contractor.

1.2.2 Refer section 2 for equipment specification.

1.2.3 Reference Drawings:

Sl. No.	NTPC Drawing No.	Drawing Title
1.	9585-001-572-PVC-C-0497	Switchyard Control Room Building - Architectural Plan and Elevation
2.	9585-001-572-PVC-C-0249	GA & Architectural Plan, Elevation And Sections for 400KV GIS building
3.	9585-001-572-PVE-F-0013	Layout Plan & Section

1.2.4 The steel structures for the switchyard shall be hot dip galvanized with zinc coating not less than 610 gm/Sq.m.

1.2.5 Detailed Illumination Design Calculation shall be submitted by bidder for approval of BHEL/NTPC.

1.2.6 The illumination system shall be designed on the basis of best engineering practice and shall ensure uniform, reliable, aesthetically pleasing and glare free illumination. The lighting fixtures shall be designed for minimum glare. The design shall prevent glare/luminous patch



seen on VDU/ Large video screens, when viewed from an angle. The finish of the fixtures shall be such that no bright spots are produced either by direct light source or by reflection. The diffusers/ louvers used in fixtures shall be made of impact resistant polystyrene sheet and shall have no yellowing property over a prolonged period. The Lux levels to be adopted for various area are indicated in section 2.

- 1.2.7 All lighting fixtures and control gears shall be powder coated. All outdoor fixtures shall be weather proof and of min. IP55 degree of protection. Lighting panels shall be powder coated with color shade RAL9002. Lighting panels shall have min. IP55 degree of protection.
- 1.2.8 Lighting panel (LP) for controlling lights with additional provision for manual control shall be provided:
- o Indoor lighting panel: Without Timer
 - o Outdoor lighting panel: With Timer

1.3 Scope of Supplies and Services

- (i) System Design Engineering is included in vendor's scope, which includes design of complete lighting system for indoor and outdoor areas. Please refer the list of reference drawings as per annexure for the tentative areas to be covered by the lighting system. The aspect of engineering covers preparation of electrical distribution and control schemes, quantity estimation, luminaire layout drawings, conduit layout drawings, wiring schemes up to luminaires, cable schedules and all associated design work not specifically mentioned in the specification. The quantity estimation to include all items required for the complete lighting system viz. lighting fixtures, lamps, Lighting DBs, Welding DBs, lighting panels, conduits, wires, mounting hardware etc. complete in all respect.
- (ii) The main items to be furnished for switchyard under this contract are detailed in Bill of Quantity (Annexure-BOQ) and shall be read in conjunction with other clauses of this specification.
- (iii) Supervision of Erection & Commissioning (as required by site) of lighting system is included in vendor's scope.
- (iv) Civil design for lighting mast / pole is included in vendor's scope.



- (v) Design rectification engineering (if any) is included in vendor's scope. In case of revised inputs or site feedback, preparation and submission of revised engineering outputs shall also be in the scope of vendor.
- (vi) Although Erection and Commissioning is not included in vendor's scope, the vendor shall be fully responsible for establishing the correctness of engineering and equipment at site.
- (vii) Review of sub-vendor's documents by the purchaser shall not relieve the vendor from the responsibility of design & supply.
- (viii) All associated items, though not specifically mentioned but required for safe and satisfactory operation of equipment/ system shall also be deemed to be included and the same shall be supplied at NO EXTRA COST to BHEL.
- (ix) Further, in case any type of luminaire/ panels etc. not included below but are required to meet the technical specification shall be specifically brought out in the offer/ shall be deemed to be included in offer.
- (x) Lighting Panel/ Junction Box: The bidder shall supply junction boxes complete with terminals as required. The supports, brackets, bolts, nuts, screws etc. required for erection are also included in scope of the bidder.
- (xi) The junction boxes shall be provided with two earthing terminals suitable for 14 SWG GI Earthing Wires.
- (xii) Junction box for indoor lighting shall be made of fire retardant material. Material of JB shall be Thermoplastic or thermosetting or FRP type.
- (xiii) Junction boxes for street lighting poles and lighting mast, shall be deep drawn or fabricated type made of min. 1.6 mm thick CRCA Sheet. The box shall be hot dip galvanized.
- (xiv) Junction boxes shall have following indelible markings:

Circuit nos. on top

Circuit nos. with ferrules (inside) as per drawing



DANGER sign in case of 415V circuit

- (xv) Lighting panel shall have min. IP 55 degree of protection for indoor and IP-55 with canopy for outdoor.
- (xvi) The Street Light system and peripheral lighting shall be designed generally in line with design guidelines. The Poles shall be mounted above ground using base plate and minimum height of pole shall be 8 mtrs. The poles shall be hot-dip galvanized as per IS2629/ IS2633/ IS4759. The average coating thickness of galvanizing shall be min. 70 micron. The System shall be capable of withstanding the appropriate wind load etc. as per IS 875 considering prevailing soil/ site condition considering all accessories mounting on pole.
- (xvii) Bidder shall indicate in his offer, make and catalogue nos. of all equipment offered.
- (xviii) The continuous conductor of specified GI wire shall be run all along each conduit run. The conductor shall be connected to each panel ground bus. All junction boxes, receptacles, switches, lighting fixtures etc. shall be connected to specified GI wire. Supply of GI ground wire shall be included in bidder's scope.
- (xix) Supply of all other items such as wires, steel wire, lugs, cable glands, earthing material etc. required to complete the work is in bidder's scope.
- (xx) Cable gland plate in all the panels shall be minimum 3.0 mm.
- (xxi) The documents shall be in English language and MKS system of units.
- (xxii) All accessories shall be wired up to a terminal block or a separate weather proof metallic terminal box suitable for 2.5 sq. mm. copper wire termination.
- (xxiii) Single line diagrams of power distribution up to Lighting Panels. Separate drawing for complete lighting distribution shall also be prepared by vendor.
- (xxiv) Preparation of As-Built drawing and submission of the same in hard copy 5 set & in CD ROM – 2 numbers.
- (xxv) Conducting of lux level measurement as per approved designs to the satisfaction of owner / purchaser shall be under bidder's scope.
- (xxvi) Bidder shall ensure that sufficient quantity of commissioning spares is made available for timely completion of commissioning of the system. The bidder shall furnish a list



of Commissioning spares that will be provided by him. The unused commissioning spares shall be returnable to the bidder.

1.4 Special Technical Requirement for Poles and High Mast

1.4.1 Lighting Poles

The Street Light system and peripheral lighting shall be designed generally in line with design guidelines. The Poles shall be mounted above ground using base plate and minimum height of pole shall be 8 mtrs. The poles shall be hot-dip galvanized as per relevant IS2629/ IS2633/ IS4759. The average coating thickness of galvanizing shall be min. 70 micron. The System shall be capable of withstanding the appropriate wind load etc as per IS 875 considering prevailing soil/ site condition considering all accessories mounting on pole.

The street light poles shall have loop in loop out arrangement for cable entry and light fixture / wiring protected with suitably rated MCB.

1.4.2 Lighting Masts

Lighting Mast shall be of continuously tapered polygonal cross section hot dip galvanised. The Mast shall be of 30 M or suitable height with lantern carriage to enable raising/lowering for ease of maintenance, including the Head Frame, Double Drum Winch, continuous stainless steel wire rope, in built power tool, luminaires, suitable aviation warning light, lightning along-with necessary power cables within the mast. The mast shall be delivered in not more than three sections & shall be joined together by slip stressed fit method at site. No site welding or bolted joints shall be done on the mast.

The Mast together with the fixtures shall be capable of withstanding the appropriate wind loads as per IS:875. The Mast shall be fabricated from special steel plates conforming to BS-EN10-025 and folded to form a polygonal section.

Suitable feeder pillar with TPN MCB, contactors, timer, MCB and other necessary accessories for operation & protection of the mast and fixtures shall be provided.

1.5 Exclusion/BHEL Issued Items For Illumination

Following items are supplied by BHEL for illumination system. Remaining all items required for successful completion of illumination system is under scope of bidder. Bidder to however submit estimate and calculation sheet BHEL supplied item during contract stage.

- i. 415V Main Lighting Distribution Board
- ii. 415V AC Emergency Lighting Distribution Board
- iii. Lighting Transformers for MLDB & ELDB



iv. Multicore armoured power & control cable cables of the following sizes:

1	1C X 630 sq mm XLPE/Aluminium, FRLS, Armoured Auxiliary Power Cable
2	3.5C X 300 sq mm XLPE/Aluminium, FRLS, Armoured Auxiliary Power Cable
3	3.5C X 150 sq mm XLPE/Aluminium, FRLS, Armoured Auxiliary Power Cable
4	1C X 150 sq mm XLPE/Aluminium, FRLS, Armoured Auxiliary Power Cable
5	3.5 C X 70 sq mm PVC/Aluminium, FRLS, Armoured Auxiliary Power Cable
6	3.5 C X 35 sq mm PVC/Aluminium, FRLS, Armoured Auxiliary Power Cable
7	4 C X 16 sq mm PVC/Aluminium, FRLS, Armoured Auxiliary Power Cable
8	4 C X 6 sq mm PVC/Aluminium, FRLS, Armoured Auxiliary Power Cable
9	2 C X 6 sq mm PVC/Aluminium, FRLS, Armoured Auxiliary Power Cable
10	19 C X 2.5 sq mm PVC/Copper, FRLS, Armoured Control Cables
11	14 C X 2.5 sq mm PVC/Copper, FRLS, Armoured Control Cables
12	10 C X 2.5 sq mm PVC/Copper, FRLS, Armoured Control Cables
13	5 C X 2.5 sq mm PVC/Copper, FRLS, Armoured Control Cables
14	2 C X 2.5 sq mm PVC/Copper, FRLS, Armoured Control Cables
15	4 C X 10 sq mm PVC/Copper, FRLS, Armoured Control Cables

- v. 75x12 & 50x6mm GI flat for earthing works, however GI flat of size less than 50X6 shall be supplied by bidder.
- vi. 100mm/50mm GI pipe for cabling works.
- vii. 40mm dia MS rod for earthing works.

1.6 Bill of Quantities

Please refer “Annexure – BOQ”.

1.7 System Parameters For Illumination Design

S. No.	Description	Unit	Value
1.0	SYSTEM DESIGN DATA		
1.1	Design ambient	^o C	50
1.2	AC Supply		
a)	Rated voltage	V	415



b)	Rated frequency	Hz	50
c)	Voltage variation (permissible)	%	+10% to -10%
d)	Frequency variation (permissible)	%	+3% to -5%
e)	Combined voltage & frequency variation (sum of absolutes permissible)	%	10%
f)	System fault level & duration	kA, sec.	50kA for 1 sec.
1.3	DC Supply		
a)	Rated voltage	V	220
b)	Voltage variation (permissible)	%	+10% to -15%

1.8 Qualifying Requirement

Technical qualifying requirement shall be as per “**Annexure-QR**” attached.

1.9 Type Tests

1.9.1 For LED Fixtures

a) The contractor shall **carry out** the type tests as listed in this specification on the following types of LED fixtures to be supplied under this contract. The bidder shall indicate the charges for each of these type tests separately in the relevant price schedule of bid document and the same shall be considered for the evaluation of the bids.

LED fixtures – As Applicable:

(Type test shall be conducted on one rating each of following type of LED fixtures. Rating for test conduction shall be decided by the employer during detailed engineering)

- a) High bay fixture
- b) Well glass fixture
- c) Street light fixture
- d) Surface mounted type fixture.
- e) Recessed mounted type fixture.

The type tests charges shall be paid only for the test(s) actually conducted successfully under this contract and upon certification by the employer’s engineer.



b) The type tests shall be carried out in presence of the employer's representative, for which minimum 15 days' notice shall be given by the Bidder. The Bidder shall obtain the employer's approval for the type test procedure before conducting the type test. The type test procedure shall clearly specify the test set-up, instruments to be used, procedure, acceptance norms, recording of different parameters, interval of recording, precautions to be taken etc. for the type test(s) to be carried out.

c) In case the contractor has conducted such specified type test(s) within last ten years as on the date of bid opening i.e 03-Mar-2017, he may submit during detailed engineering the type test reports to the owner for waiver of conductance of such type test(s). These reports should be for the tests conducted on the equipment similar to those proposed to be supplied under this contract and test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client. The owner reserves the right to waive conducting of any or all the specified type test(s) under this contract. In case type tests are waived, the type test charges shall not be payable to the contractor.

1.9.2 For All Other Station Lighting Equipment

a) All equipment to be supplied shall be of type tested design. During detail engineering, the contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last ten years from the date of bid opening i.e 03-Mar-2017. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.

b) However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening i.e 03-Mar-2017, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client/owners representative and submit the reports for approval.

1.9.3 All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.

1.9.4 Details of testing shall be as per Section II of this specification.

1.10 Quality Plan

Bidder to follow valid NTPC approved manufacturing and field quality plan at contract stage. In case the bidder does not have NTPC approved QP, it will be the bidder's responsibility to get its QP approved from NTPC.



1.11 Packing

The material shall be packed in such a way to ensure protection against damage during transit, storage for prolonged periods (at least 1 year) at site and handling.

1.12 Performance Test

It will be bidder's responsibility to demonstrate performance of system fulfilling design / operational requirement. Bidder to arrange testing instrument on returnable basis. Contractor shall assist BHEL to hand over the system supplied by them to owner.



COMPLIANCE CERTIFICATE

The bidder shall confirm compliance to the following by signing/ stamping this compliance certificate and furnishing same with the offer.

1. The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusion/ deviation with regard to same.
2. There are no deviation with respect to specification other than those furnished in the 'schedule of deviations'.
3. Only those technical submittals which are specifically asked for in NIT to be submitted at tender stage shall be considered as part of offer. Any other submission, even if made, shall not be considered as part of offer.
4. Any comments/ clarifications on technical/ inspection requirements furnished as part of bidder's covering letter shall not be considered by BHEL, and bidder's offer shall be construed to be in conformance with the specification.
5. Any changes made by the bidder in the price schedule with respect to the description/ quantities from those given in BOQ-Cum-Price schedule of the specification shall not be considered (i.e. technical description & quantities as per specification shall prevail).

Signature of Authorized Signatory _____

Name and Designation _____

Phone / Mobile Number _____

Email ID _____



Annexure-BOQ

Bill of Quantity for Illumination System

S.No.	Item Description	Unit	Quantity	Remarks
1	SUPPLY- ILLUMINATION EQUIPMENT : LIGHTING SYSTEM - CONTROL ROOM	Lot	1	
2	SUPPLY- ILLUMINATION EQUIPMENT : LIGHTING SYSTEM – GIS HALL	Lot	1	
3	SUPPLY- ILLUMINATION EQUIPMENT : LIGHTING SYSTEM - OUTDOOR	Lot	1	
4	SUPPLY- ILLUMINATION EQUIPMENT : LIGHTING SYSTEM – STREET LIGHT	Lot	1	
5	SPARES- ILLUMINATION EQUIPMENT : LAMPS OF EACH TYPE & RATING OFFERED	Lot	1	2% or 3 nos. whichever is more
6	SPARES- ILLUMINATION EQUIPMENT : FRONT GLASS OF EACH TYPE OFFERED	Lot	1	2% or 3 nos. whichever is more
7	SPARES- ILLUMINATION EQUIPMENT : LAMP HOLDERS OF EACH TYPE OFFERED	Lot	1	2% or 3 nos. whichever is more
8	SPARES- ILLUMINATION EQUIPMENT : DRIVERS:-LED FIXTURE	Lot	1	2% or 3 nos. whichever is more
9	SPARES- ILLUMINATION EQUIPMENT : LIGHTING PANELS:- TIMER 24 HRS	NOS	5	
10	SPARES- ILLUMINATION EQUIPMENT : LIGHTING RECEPTACLES:- 20 A RECEPTACLES WITH PLUG	NOS	15	
11	SPARES- ILLUMINATION EQUIPMENT : LIGHTING CONTROL SWITCH:- 20 A ROTARY SWITCHES	NOS	15	
12	SPARES- ILLUMINATION EQUIPMENT : JUNCTION BOXES:- TYPE – F 2 – TERMINAL STRIPS	NOS	75	
13	SERVICES- ILLUMINATION EQUIPMENT : SUPERVISION OF ERECTION TESTING & COMMISSIONING FOR ILLUMINATION SYSTEM ON PER MANDAY BASIS	Man-day	30	
14	SERVICES- ILLUMINATION EQUIPMENT : LUX LEVEL MEASUREMENT AND DEMONSTRATION TO CUSTOMER AT SITE INCLUDING ARRANGEMENT OF NECESSARY TEST EQUIPMENT ON RETURNABLE BASIS	Lot	1	
15	SERVICES- ILLUMINATION EQUIPMENT : TYPE TEST, LED LIGHTING FIXTURE: HIGH BAY FIXTURE	NOS	1	



S.No.	Item Description	Unit	Quantity	Remarks
16	SERVICES- ILLUMINATION EQUIPMENT : TYPE TEST, LED LIGHTING FIXTURE: WELL GLASS FIXTURE	NOS	1	
17	SERVICES- ILLUMINATION EQUIPMENT : TYPE TEST, LED LIGHTING FIXTURE: STREET LIGHT FIXTURE	NOS	1	
18	SERVICES- ILLUMINATION EQUIPMENT : TYPE TEST, LED LIGHTING FIXTURE: SURFACE MOUNTED INDOOR TYPE FIXTURE	NOS	1	
19	SERVICES- ILLUMINATION EQUIPMENT : TYPE TEST, LED LIGHTING FIXTURE: RECESSED MOUNTED INDOOR TYPE FIXTURE	NOS	1	

Note:

1. The detailed design shall be submitted by bidder and subject to approval by Customer. The BOQ quantities which are finalized after approval has to be supplied. BHEL reserves the right for quantity variation due to any reason up to $\pm 30\%$ of total value at same unit rate and terms & conditions during execution of contract. The quantity of individual items may however vary up to any extent.
2. Prices for supply of all applicable illumination erection hardware material shall be included along with above BOQ offer. Any hardware / accessories required for successful completion of the system is to be supplied by vendor. Complete list of hardware to be provided by vendor on contract stage.
3. For items from S.no. 16 to 20, please refer TS clause 1.9.1.
4. For item at S.No. 14 - Price shall be inclusive of charges for lodging, boarding, medical, insurances etc but excluding the followings (1) To & Fro travel charges shall be reimbursed as actual limited to 2nd AC charges for all visits as per site requirement. Local transportation between Hotel and site shall be arranged by BHEL.



Annexure-QR

Technical Qualifying Requirement for Illumination System

1. The bidder should have experience of design and supply of illumination system for at least one project of State Electricity Boards/Central Utilities/State or Central Transmission Utilities/Industrial Installations.
2. Bidder should have successfully supplied the illumination system with order value not less than the followings (Excluding Taxes, duties, F&I etc.) during last five years from the date of bid opening i.e. 03-Mar-2017:
 - Rs 1, 40, 00,000 / - (Rs. One Crore Fourty Lakhs) for single contract or
 - Rs 1,00,00,000 / - (Rs One Crore) each for two contracts

Bidder has to submit the certificate/relevant documents in support of above requirement.


07/08/19
Prepared By

Nishant Singh
Sr Engineer/TBEM


07/08/19
Reviewed By

Sanjeev Shrivastava
DGM/TBEM


07/08/19
Approved By

Aruna Gulati
AGM/TBEM

SUB-SECTION–E-53

STATION LIGHTING

CLAUSE NO.		QUALITY ASSURANCE													
		STATION LIGHTING						SQE_17							
Item Components Sub System Assembly	Attributes Characteristics	Make, Type , Rating/ TC	Dimension	Pre-Treatment of sheat	Paint Shade Thickness Adhesion & Finish	Galvanization Tests	IP Test	Bought Out Items/ Bill of Material	HV & IR	Functional Check as per spec.	Constructional Feature as per NTPC spec.	Routine Test as per relevant std and spec	Acceptance Test as per relevant std and spec	Item to conform to relevant standard	
Luminaries (IS-10322 Part-5 Sec.1 (non –LED type)		Y					Y		Y			Y	Y	Y	
Electronic Ballast		Y										Y	Y	Y	
Lighting Wire (IS-694)		Y										Y			
Fans (IS-374)		Y										Y			
Pole (IS-2713)		Y			Y						Y	Y	Y		
Lamps (IS-9800, IS-9974)		Y										Y	Y		
Lighting Mast (with raise & lower lantern type)		Y	Y			Y					Y	Y	Y		
Wall Mounted Lighting Panel (IS-513, IS-5)		Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
Switch Box/ Junction Box/Receptacles/ Local Push Button Station / Lighting Panel (IS-513, 2629, 2633, 4759, 6745)		Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
Cable Gland (BS-6121)		Y	Y									Y			
Cable Lug (IS-8309)		Y	Y									Y			
Flexible Conduit		Y										Y			
Lighting Transformer (IS-11171)		Y									Y	Y			
Epoxy & Galvanised Conduit (IS-9537, 2629, 2633, 4759, 6745)		Y	Y									Y		Y	
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)		TECHNICAL SPECIFICATION SECTION-VI, PART-B BID DOC NO.:CS-9585-001-2						SUB-SECTION-E-53 STATION LIGHTING						Page 1 of 2	

CLAUSE NO.	QUALITY ASSURANCE			एनटीपीसी NTPC
LED Luminaire quality requirements: 1) LED modules to conform to IS: 16103 part 2. Manufacturer to issue a certificate of compliance for the same. 2) Control gear to conform to IS 15885 part 2 section 13. Manufacturer to issue a certificate of compliance for the same. 3) LED luminaire to conform to IS 16107 part 2 section 1. Manufacturer to issue a certificate of compliance for the same. 4) LED luminaire marking to be as per IS 16107 part 2 section 1. Manufacturer to issue a certificate of compliance for the same. 5) Acceptance tests as per IS 16107 part 2 section 1 to be carried out on LED luminaire except long duration tests i.e. a) Chromaticity coordinates & correlated color temperature (CCT); b) Color rendering index (CRI). Manufacturer will submit a COC for above tests i.e. CCT & CRI 6) LED driver make, model, type & rating may be as per recommendations of LED module manufacturer. Notes: 1. This is an indicative list of tests / checks. The manufacturer is to furnish a detailed Quality Plan indicating the practice and procedure along with relevant supporting documents. 2. Make of all major Bought Out Items will be subject to NTPC approval.				
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)		TECHNICAL SPECIFICATION SECTION-VI, PART-B BID DOC NO.:CS-9585-001-2	SUB-SECTION-E-53 STATION LIGHTING	Page 2 of 2

SUB-SECTION–E-54

SWITCHYARD

CLAUSE NO.	QUALITY ASSURANCE			एनटीपीसी NTPC
SWITCHYARD		SQE_20		
Attributes / Characteristics Items/Components Sub Systems	Make, model, Type & Rating, Test Certificate	Routine & Acceptance Test as per IS / IEC	Functional requirements as per NTPC Specification	
765 KV GIS (IEC:62271-203)	Y	Y	Y	
132 KV GIS (IEC:62271-203)	Y	Y	Y	
Capacitor Voltage Transformer (IEC:186A / 358/IS3156/IEC60044/ IEC: 61869)	Y	Y	Y	
Bus Post Insulator (IEC:168 / 815 / IS:2544)	Y	Y	Y	
Disc, Pin & String Insulator (IEC:383 / IS:731)	Y	Y	Y	
Long Rod Insulator (IEC:433)	Y	Y	Y	
Surge Arrestor (AIS) (IEC:99- 4/IS:3070)	Y	Y	Y	
Hardware fittings for Insulator (IS:2486 / BS:3288)	Y	Y	Y	
Spacers, Clamps & Connector (IS:10162 / 5561/ 617)	Y	Y	Y	
Aluminium Tube (IS:5082 / 2673 / 2678)	Y	Y	Y	
Wave Trap (IEC:353 / IS:8792 / 8793)	Y	Y	Y	
Conductor (IS:398)	Y	Y	Y	
Galvanised Steel Structures (IS:2062/2629/4759/6745)	Y	Y	Y	
Vibration Damper (IS:9708)	Y	Y	Y	
Sag Compensating Spring DIN:2089/2096 IS:3195 / 7906	Y	Y	Y	
Control & Relay Panel / SAS	Y	Y	Y	
SF6 Gas filling & evacuating plant	Y	Y	Y	
SF6 Gas Leak Detector	Y	Y	Y	
Leakage Current Analyser	Y	Y	Y	
Nitrogen Gas Filling Device	Y	Y	Y	
Protection Relays	Y	Y	Y	
Event Logger	Y	Y	Y	
Operation Analyser	Y	Y	Y	
Disturbance Recorder	Y	Y	Y	
Tariff Metering System	Y	Y	Y	
Synchronising Trolley	Y	Y	Y	
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)	TECHNICAL SPECIFICATION SECTION-VI, PART-B BID DOC NO.:CS-9585-001-2	SUB-SECTION-E-54 SWITCHYARD	Page 1 of 2	

CLAUSE NO.	QUALITY ASSURANCE				एनटीपीसी NTPC
	Attributes / Characteristics	Make, Type Rating, and Model, Test Certificates	Routine & Acceptance Test as per relevant IS/IEC	Functional requirements as per NTPC Specification	
	Items/Components Sub Systems				
	Relay Test Kit	Y	Y	Y	
	Lighting Panels	Y	Y	Y	
	Surge Monitor	Y	Y	Y	
	Energy meter	Y	Y	Y	
	Notes : 1) This is an indicative list of test/checks. The manufacture is to furnish a detailed Quality Plan indicating the practice and procedure along with relevant supporting documents during QP finalisation for all items. 2) All major Bought Out Items will be subject to NTPC approval.				
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X 800MW)		TECHNICAL SPECIFICATION SECTION-VI, PART-B BID DOC NO.:CS-9585-001-2		SUB-SECTION-E-54 SWITCHYARD	Page 2 of 2



SECTION-2

2.1 GENERAL

This specification covers the general description of design, manufacture and construction features, testing, supply, supervision of installation and commissioning of the Station Lighting system equipment.

2.2 CODES AND STANDARDS

All standards and codes of practice referred to herein shall be the latest edition including all applicable official amendments & revisions as on date of bid opening i.e 03-Mar-2017. In case of conflict between this specification and those (IS codes, standards etc.) referred to herein, the former shall prevail. All work shall be carried out as per the following standards & codes.

2.2.1 Lighting Fixtures and Accessories

IS:1913	General and safety requirements for luminaires.
IS:2148	Flame proof enclosures of electrical apparatus.
IS:418	Tungsten filament general service electric lamps.
IS:1258	Bayonet lamp holders.
IS:1534	Ballast for fluorescent lamps.
IS:1569	Capacitors for use in tubular fluorescent, high pressure mercury vapour and low pressure sodium vapour discharge lamp circuit.
IS:1777	Industrial luminaire with metal reflectors.
IS:2215	Starters for fluorescent lamps.
IS:2418	Tubular fluorescent lamps for general lighting services.
IS:3323	Bi-pin lamp holders for tubular fluorescent lamps.
IS:3324	Holders for starters for tubular fluorescent lamps.
IS:4013	Dust-tight electric lighting fittings.
IS:8224	Electric Lighting fittings for Division 2 areas.
IS:10276	Edison screw lamp holders.
IS:10322	Luminaires.
IS:13021	AC Supplied Electronic Ballasts for tubular fluorescent lamps.

2.2.2 Lighting Panels, Switch-boxes, Receptacles and Junction Boxes

IS:2147	Degree of protection provided by enclosures for low-voltage switchgear and control gear.
IS:1293	Plugs & socket outlets of rated voltage upto and Including 250volts & rated current upto and including 16 Amps.



IS:2551	Danger notice plates.
IS:13947	Low voltage switchgear and controlgear
IS:3854	Switches for domestic and similar purposes.
IS:6875	Control switches (switching devices for control and auxiliary circuits including contactor relays) for voltages upto and including 1000 V AC and 1200 V DC.
IS:13703	Low voltage fuses for voltages not exceeding 1000V AC or 1500 V DC.

2.2.3 Conduits, Pipes and Accessories

IS:2667	Fittings for rigid steel conduit for electrical wiring.
IS:3837	Accessories for rigid steel conduits for electrical wiring.
IS:9537	Conduits for electrical installations.

2.2.4 Lighting Wires/Cables

IS:694	PVC insulated cables for working voltages upto and including 1100 V
IS:3961	Recommended current ratings for cables.(PVC Insulated and PVC sheathed heavy duty cables and light duty cables).
IS:8130	Conductors for insulated electric cables and flexible cords.
IS:10810	Methods of tests for cables.

2.2.5 LED Luminaries

16101:2012	General Lighting. LEDs and LED modules Terms and definitions
16102(Part 1): 2012	Self Ballasted LED Lamps for General Lighting Services. Part-1 Safety Requirements.
16102(Part 2): 2012	Self Ballasted LED Lamps for General lighting Services. Part-2 Performance Requirements.
16103(Part I): 2012	LED modules for General lighting Safety Requirements.
15885(Part 2/Sec. 13) :2012	Lamp control gear Part 2 particular Requirements Section 13 d.c. or a.c. Supplied Electronic control gear for LED modules
16104:2012	d.c. or a.c. Supplied Electronic control gear for LED modules - Performance Requirements.
16105:2012	Method of Measurement of Lumen maintenance of Solid-state Light (LED) Sources.
16106:2012	Method of Electrical and photometric Measurements of Solid State Lighting (LED) Products
16107:2012	Luminaires Performance
16108:2012	Photobiological safety of Lamps and Lamp Systems
IS 513	Cold rolled low carbon steel sheets and strips
IS 12063	Classification of degree of protection provided by enclosures.



IS 14700	Electro magnetic compatibility (EMC) – Limits (Part 3/Sec. 2) for Harmonic current emission – THD < 15% (equipment, input current < 16 Amps. per phase.
IS 9000	(Part 6) Environment testing: Test Z – AD: composite temperature/humidity cyclic test.
IS 15885	Lamp control gear: particular requirements for (Part 2/Sec. 13) DC or AC supplied electronic control gear IS 16004 – 1 and 2) for LED modules.
IS 4905	Method for random sampling.

2.2.6 Electrical Installation Practices & Miscellaneous

IS:1944	Code of practice for lighting of public thorough fare
IS:3646	Code of practice for interior illumination.
IS:5572	Classification of Hazardous areas (other than Mines) having flammable gases and Vapours for electrical installation
S:6665	Code of practice for industrial lighting. - National Electrical Code - Indian Electricity Rules. Indian Electricity Act
IS:5	Colour for ready mixed paints & enamels.
IS:280	Mild steel wires for general engineering purposes.
IS:374	Electric ceiling type fans & regulators.
IS:732	Code of practice for electrical wiring installations.
IS:1255	Code of practice for installation and maintenance of power cables Upto and including 33KV rating.
IS:2062	Steel for general structural purposes
IS:2629	Recommended practice for hot-dip galvanizing of iron and steel.
IS:2633	Methods for testing uniformity of coating of zinc coated articles.
IS:2713	Tubular steel poles for overhead power lines.
IS:3043	Code of practice for earthing
IS:5216	Guide for safety procedures and practices in electrical work.
IS:5571	Guide for selection of electrical equipments for hazardous areas.
BS:6121	Mechanical cable glands

2.3 LIGHTING SYSTEM DESCRIPTION

2.3.1 The illumination of various indoor and outdoor areas in the main plant & offsite area shall be provided as described here. The lighting system of various areas shall comprise of the following systems as identified in Annexure-B:

- (a) Normal AC Lighting System
- (b) Emergency AC Lighting System
- (c) DC Lighting System



2.3.2.1 Normal AC Lighting System

Normal AC lighting system 415V, 3Phase, 4wire, will be fed from lighting panels (LPs) which in turn will be fed from the lighting distribution boards (LDBs)/Switch board MCC.

2.3.2.2 Emergency AC Lighting System

This system shall be provided for certain important areas in the main plant. The lighting fixtures connected to this system shall be normally "ON" along with the normal AC system. These will be fed from emergency lighting panels (ELPs) which in turn will be fed 3-phase, 4-wire supply from the emergency lighting distribution boards (ELDB'S). These lights will go off for a few seconds in case of AC supply failure at Emergency Switchgear, but shall be automatically restored when Emergency Switchgear is energised by Diesel generator set.

2.3.3 DC Lighting System

2.3.3.1 At strategic locations in the main plant, a few lighting fixtures fed from 220V, DC supply, shall be provided to enable safe movement of operating personnel and access to important control points during an emergency, when both the normal AC and Emergency Lighting system fail. These lighting fixtures will be fed from 220V DC LDBs which in turn will be fed from DC lighting panels.

2.3.3.2 The supply to the DC lighting panels shall be automatically switched ON in case of loss of AC supply at station service switchgear as well as Emergency switch-gear. The DC supply will be automatically switched OFF after about 3 minutes following the restoration of supply to normal AC or emergency AC lighting system.

2.3.3.3 Emergency DC lighting is to be provided, through self-contained DC emergency fixtures with four hours back-up duration, at strategic locations, in auxiliary/offsite buildings wherever DC supply system is not available. The fixtures shall be switched 'ON' automatically in case of failure of AC supply.

2.4 DESIGN PHILOSOPHY

- a. A comprehensive illumination system shall be provided in the entire project areas under bidder's scope.
- b. All outdoor lighting system shall be automatically controlled by synchronous timer. Provision to bypass the timer shall be provided in the panel.
- c. The system shall include distribution boards, normal/ emergency lighting panels, lighting fixtures, junction boxes, receptacles, switch boards, lighting pole/masts, conduits, cables and wires, etc. The system shall cover all interior and exterior lighting such as area



lighting, including Transformer yard & Switch yard area, aviation obstruction lighting, Street lighting, security lighting, etc. The constructional features of lighting distribution boards shall be similar to AC/DC distribution boards described in chapter of LT Switchgear. Outgoing circuits in LPs shall be provided with MCBs of adequate ratings.

- d. The illumination system shall be designed on the basis of best engineering practice and shall ensure uniform, reliable, aesthetically pleasing and glare free illumination. The lighting fixtures shall be designed for minimum glare. The design shall prevent glare/luminous patch seen on VDU/ Large video screens, when viewed from an angle. The finish of the fixtures shall be such that no bright spots are produced either by direct light source or by reflection. The diffusers/ louvers used in fixtures shall be made of impact resistant polystyrene sheet and shall have no yellowing property over a prolonged period. The Lux levels to be adopted for various area are indicated at Annexure - A.
- e. Different Lighting Systems envisaged for various plant areas are indicated in Annexure-B: While finalizing the detailed layout of lighting fixtures, the position/location and layout of equipments should be taken into account to have adequate illumination at desired locations.

f. LED Luminaires:

LED Luminaires shall be used for the lighting of all the indoor & outdoor areas in bidder's scope. However for DC lighting, hazardous areas & aviation lighting etc. conventional type luminaires shall be used. However, aviation light in Lighting Mast shall be of LED type. In false ceiling area LED luminaires shall be recessed mounting type & in non-false ceiling area the LED luminaires shall be surface mounting type.

The individual lamp wattage for LED shall be upto 3 watt. Fractional wattage LEDs are also acceptable. The LED chip efficacy shall be min 120 Lm/W. The luminaire efficacy shall be not less than 80 Lm/W. Suitable heat sink shall be designed & provided in the luminaire. The LED used in the luminaires shall have colour rendering index (CRI) of Min 80. Colour designation of LED shall be "cool day light" (min 5700K) type for indoor areas. However for outdoor areas, the colour temperature of LED shall be min. 4000K, including rough & dust prone areas. LED shall conform to the LM 80 requirements.

The max. junction temperature of LED shall be 85 deg C. Further the lumen maintenance at this temperature shall be min 90%. The THD of LED Luminaires shall be less than 10%. Further the EMC shall be as per IS 14700. The power factor of the luminaire shall not be less than 0.9. The marking on luminaire & safety requirements of luminaire shall be as per IS standards. Suitable heat sink with proper thermal management shall be designed & provided in the luminaire.

The connecting wires used inside the system, shall be low smoke halogen free, fire retardant type and fuse protection shall be provided in input side specifically for LED luminaires.



Care shall be taken in the design that there is no water stagnation anywhere in the housing of luminaire. The entire housing shall be dust and water proof protection as per IS 12063.

g. Driver Circuit

LED modules and drivers shall be compatible to each other. The LED module driver's ratings and makes shall be as recommended by corresponding LED chip manufacturer.

LED Drivers shall have following control & protections:-

- Suitable precision current control of LED.
- Open Circuit Protection
- Short Circuit Protection
- Over Temperature Protection
- Overload Protection
- Surge Protection

h. Apart from maintenance factor as given below, Temperature correction factor shall be considered in the lighting design for fixtures located in non-air conditioned area.

(a.) Office area (air conditioned):	0.8
(b.) Office area (non air conditioned): and other indoor area	0.7
(c.) Dust prone indoor and outdoor area:	0.6
(d.) Coal Handling area, Ash Handling: Conveyor /Transfer Points etc.	0.5
(e.) Boiler Area:	0.5

Reflectance Factor:-

Ceiling:	0.8
Wall:	0.5
Floor:	0.2

i. All lighting fixtures and control gears shall be powder coated. All outdoor fixtures shall be weather proof and of min. IP65 degree of protection.

For Indoor type of fixtures:

- a. Surface/Pendent Mounting: IP 54 Class of protection.
 - b. Recess Mounting (False Ceiling): IP20 Class of protection.
- j. Lighting panels shall be powder coated with color shade RAL9002. Lighting panels shall have min. IP55 degree of protection.**
- a. Lighting panels shall be constructed out of 2 mm thick CRCA sheet steel. The door shall be hinged and the panel shall be gasketed to achieve specified degree of protection.



- b. All MCBs/Isolators/Switches/Contactors etc. shall be mounted inside the panel and a fibre glass sheet shall be provided inside the main door such that the operating knobs of MCBs etc., shall project out of it for safe operation against accidental contact.
- c. Terminal blocks shall be 1100 V grade, clip-on stud type, made up of polyimide 6.6 or better suitable for terminating multicore 35 or 70 Sq. mm. stranded aluminium conductor incoming cable and 10 Sq. mm. stranded aluminium conductor for each outgoing circuits voltage. All terminals shall be shrouded, numbered and provided with identification strip for the feeders.
- d. MCB's shall be current limiting type with magnetic and thermal release suitable for manual closing and automatic tripping under fault condition. MCB's shall have short circuit interrupting capacity of 9 KA rms. MCB knob shall be marked with ON/OFF indication. A trip free release shall be provided to ensure tripping on fault even if the knob is held in ON position. MCB terminal shall be shrouded to avoid accidental contact.
- e. Contactors of AC lighting panels shall be 3 no's, 32 A, 3 pole continuous duty MCB, load make-break type suitable for 415 V, 3 phase 4 wire system. HRC fuses with suitable mounting base of 125A shall be provided in the incomer of Contactors in the LP.
- f. DC switches shall be rotary type, 2 pole, continuous duty, load break type, quick make quick break, suitable for 220 V DC, 2 wire system. Switch knob shall be provided with ON/OFF indication.
- g. Programmable Digital Timer shall be Electronic Astronomical Almanac Time switch with battery back up of min. TEN years, 4 Digit LED display, 24 hours range, manual override facility, 10 Amp 3 relay output, with NO/NC Contacts suitable for operation on 240V single phase AC supply.
- h. Each lighting panel (LP-3) shall be fed from a 415V/42V, 3 phase-4 wire, 3 KVA transformer. The transformer shall be located inside the lighting panel itself. Transformers shall be dry type, natural air cooled with class F insulation or better. Impedance of transformer shall be 5%. Transformers shall be tested as per IS:11171. Off-circuit tap changer with +/- 5% in steps of +/- 1.25% tapping shall be provided. One minute power frequency withstands voltage for lighting transformer shall be 2.5 KV.
- i. Lighting Panels shall be of following types:

Type	Incomer Feeder	Outgoing Feeder	Detail of Contents
LP-1	3No. 415V, 32 A, TP MCB (31/2Cx70sq.mm cable)	18Nos.,20A, 240V MCB	415V, 63A(min.), AC2 duty contactor and Programmable Digital Timer of 24 hour range 10A, 240V selector switch, fuse, etc. outdoor type and IP:55 degree of protection
LP-2	3No. 415V, 32 A, TP MCB	9 Nos.,20A, 240V MCB	415V, 63A(min.), AC2 duty contactor and



	(31/2Cx35sq.mm cable)		Programmable Digital Timer of 24 hour range 10A, 240V selector switch, fuse, etc. outdoor type and IP:55 degree of protection
LP-3	1 No., 4A fuse 3 KVA transformer, 40A TPN MCB	24 Nos., 16A, 45V MCB	IP 55 degree of protection. Incomer shall be suitable for receiving 4Cx16 sq. mm cable and outgoing circuit shall be suitable for 2Cx16 sq. mm cable.
LP-D1	1No. 220V, 32 A, DP Isolator (2Cx35sq.mm cable)	6Nos., 16A, 220V DP Switch & Fuse	220V, 32A DC Fuse, etc. outdoor type IP:55 degree of protection.

- k. Wires of different phase shall normally run in separate conduit.
- l. Power supply shall be fed from 415 / 240 V normal AC supply, emergency AC supply and 220V DC supply through suitable number of conveniently located lighting distribution boards (LDB) and lighting panels (LP). AC lighting supply shall be isolated from main supply by isolation transformers of max. rating of 100KVA and fault level restricted to 3 KA at Lighting Panels.
- m. Atleast one 6/16A, 240V AC universal socket outlet with switch shall be provided in offices, cabins, etc. Further 20A, 240V AC industrial receptacle with switch shall be provided strategically in all industrial areas. Suitable number of 63A, 3ph, 415V AC industrial receptacles shall be provided for entire plant for welding purposes, particularly near all major equipment and at an average distance of 50m. Atleast one 63A, 3ph, 415V AC receptacle shall be provided in each floor of off-site buildings/ structures.

Receptacles boxes shall be fabricated out of 2 mm thick MS steel hot dip galvanized or of not less than 2.5 mm thick die-cast aluminium alloy or fabricated out of 2 mm thick CRCA sheet with electro static powder coating. IP-degree of protection shall be applicable to receptacles Type 'RA &' 'RC' only.



Receptacles shall be of following types:

Type	Switch Rating	Socket and Plug Rating	Type and Make of Plug Socket	Terminal Block Size
RA	20 A, SP240V AC(Industrial)	20A, 3 pin240 V AC	NTPC appd. make	1-4 way, suitable for loop-in loop- out of 10 sq.mm. Al. Conductor
RB	16A, S.P240V AC	6A+16A6 Pin decorative Piano-key Type Switch	NTPC appd.make	1-4 way, suitable for loop-in loop- out of upto 10 sq.mm. Al. Conductor
RC	20 A, SP24 V AC(Industrial)	20A, 3 pin24 V AC	NTPC appd. make	1-4 way, suitable for loop-in loop- out of 2 core -16 sq.mm. Al. Cable.

- n. In the hazardous areas like Hydrogen generation plant, fuel oil handling areas or any other gas/ liquid fuel storage/ handling areas in bidder's scope, lighting shall be flame proof.
- o. Switch boxes shall be made of 1.6 mm thick MS sheet with 3 mm thick decorative, Perspex cover. Switch box shall be hot dip galvanized.

Switch Boxes shall be of following types:

Type No.	Switch	Fan Regulator*	Socket
SWB 1	5 A - 2 Nos.	-	-
SWB 2	5 A - 3 Nos.	-	5A - 1.No.
SWB 3*	5 A - 5 Nos.	1	5A - 1.No
SWB 4*	5 A - 7 Nos	3	5A - 1.No.
SWB 5**	5 A - 5 Nos	-	5A - 1.No.

* Space provision shall be kept for fan regulator in switch boxes.

** Shall have the provision for mounting the 16 A contactor.

- p. The type of fixtures, LP, JB, and receptacle used in Hydrogen generation plant building shall be suitable for group II C as per IS: 2148 or class I, Division II as per NEC 70-428.



- q. All fluorescent lamps shall be have "Cool day light" colour designation. The mirror optics type fluorescent fixtures shall have no iridescence effect. Fixtures with better efficiency and upgraded proven system may also be considered In candescent lamps may be used only with DC Lighting.
- r. Aviation warning lights shall be provided as per the recommendations of ICAO and Director General of civil aviation, India. The arrangement of light should be marked such that the object is indicated from every angle in azimuth. The aviation warning lighting system shall also conform to the latest Indian standard IS 4998.
- s. Contractor shall demonstrate the average lux level achieved for different areas as per specification requirements, after completion of the lighting work, at site to the satisfaction of engineer-in-charge.
- t. The illumination level for outdoor switchyard shall be 20 lux in general and minimum 50lux on equipment boxes. No lighting fixture shall be mounted on gantries, they shall be mounted on lighting masts only.

2.4.1 Ballasts

2.4.1.1 All fluorescent fixtures except for Class-I, Div-II fittings/ increased safety fittings (Div-II/Hazardous Area) shall be provided with electronic ballasts.

2.4.2 All luminaires and their accessories and components shall be of type readily replaceable by available Indian makes.

2.4.3 Fans & Regulator

2.4.3.1 Ceiling Fans, to be provided in non-air-conditioned office/control room area. Further tentatively one (1) no. ceiling fan shall be provided for 10 sq.m area, at suitable mounting height. The ceiling fans shall be suitable for operation on 240 V +/-10%, 50 Hz, AC supply comprising of class 'E' or better insulated copper wound single phase motor, 1200mm sweep, aerodynamically designed well balanced AL blades (3 Nos.), down rod, die cast aluminium housing, capacitor, suspension hook, canopies etc. finished in stove enameled white or with electro static powder coating. Power factor of fans shall not be less than 0.9. Fan regulators shall be stepped electronic type suitable for operation on 240V +/- 10% AC supply.



2.4.4 Junction Boxes, Conduits, Fitting & Accessories, Pull Out Boxes:

Junction box for indoor lighting shall be made of fire retardant material. Material of JB shall be Thermoplastic or thermosetting or FRP type.

Junction boxes for street lighting poles and lighting mast if applicable, shall be deep drawn or fabricated type made of min. 1.6 mm thick CRCA Sheet. The box shall be hot dip galvanized. The degree of protection shall be IP55.

All switches and receptacles upto 16A shall be modular type. These shall be provided with pre-galvanized/galvanized modular switchbox & plate.

Conduits, Pipes and Accessories Galvanised heavy duty steel conduits for normal area and galvanised heavy duty steel conduits with an additional epoxy coating for corrosive area shall be offered. Alternatively glass reinforced epoxy conduits with comparable compressive and impact strength with that of heavy duty steel conduits may be offered.

Rigid steel conduits shall be heavy duty type, hot dip galvanised conforming to IS : 9537 Part-I & II shall be suitable for heavy mechanical stresses, threaded on both sides and threaded length shall be protected by zinc rich paint. Conduits shall be smooth from inside and outside.

Flexible conduit shall be water proof and rust proof made of heat resistant **TERNE** coated steel.

Pull out boxes shall be provided at suitable interval in a conduit run. Boxes shall be suitable for mounting on Walls, Columns, Structures, etc. Pull-out boxes shall have cover with screw and shall be provided with good quality gasket lining. Pull out boxes used outdoor shall be weather proof type suitable for IP: 55 degree of protection and those used indoor shall be suitable for IP: 52 degree of protection. Pull out box & its cover shall be hot dip galvanized.

Conduits in walls and ceilings in buildings with RCC and masonry structure such as Administrative, Service, Canteen, Time Office, Auditorium, IT building etc shall be concealed.

2.4.5 Lighting Wires

2.4.5.1 Lighting wires shall be 1100 V grade, light duty PVC insulated unsheathed, stranded copper/aluminium wire for fixed wiring installation. Colour of the PVC insulation of wires shall be Red, Yellow, Blue and Black for R, Y, B phases & neutral, respectively and white & grey for DC positive & DC negative circuits, respectively. Minimum size of wire shall not be less than 1.5 sq.mm. for copper and 4 sq.mm. for aluminium.

2.4.6 Lighting Poles

2.4.6.1 The Street Light system and peripheral lighting shall be designed generally in line with design guidelines. The Poles shall be mounted above ground using base plate and minimum



height of pole shall be 8 mtrs. The poles shall be hot-dip galvanized as per IS2629/ IS2633/ IS4759. The average coating thickness of galvanizing shall be min. 70 micron. The System shall be capable of withstanding the appropriate wind load etc as per IS 875 considering prevailing soil/ site condition considering all accessories mounting on pole.

The street light poles shall have loop in loop out arrangement for cable entry and light fixture / wiring protected with suitably rated MCB.

2.4.7 Lighting Masts

2.4.7.1 Lighting Mast shall be of continuously tapered polygonal cross section hot dip galvanized. The Mast shall be of 30 M or suitable height with lantern carriage to enable raising/lowering for ease of maintenance, including the Head Frame, Double Drum Winch, continuous stainless steel wire rope, in built power tool, luminaires, suitable aviation warning light, lightning along with necessary power cables within the mast. The mast shall be delivered in not more than three sections & shall be joined together by slip stressed fit method at site. No site welding or bolted joints shall be done on the mast The Mast together with the fixtures shall be capable of withstanding the appropriate wind loads as per IS: 875. The Mast shall be fabricated from special steel plates conforming to BS-EN10-025 and folded to form a polygonal section. Suitable feeder pillar with TPN MCB, contactors, timer, MCB and other necessary accessories for operation & protection of the mast and fixtures shall be provided.

2.4.8 Lighting fixtures shall generally be group controlled directly from lighting panel. However, in office areas, control shall be provided through switch boxes. Each switch shall control a maximum of three fluorescent fixtures.

2.4.9 A.C. normal, AC emergency and DC system wiring shall run throughout in separate conduits. Wires of different phase shall run in different conduits.

2.4.10 Lighting panels, etc. shall be earthed by two separate and distinct connections with earthing system. Switch boxes, junction boxes, lighting fixtures, fans, single phase receptacles etc. shall be earthed by means of separate earth continuity conductor. The earth continuity conductor 14 SWG GI wire shall be run along with each conduit run. Cable armours shall be connected to earthing system at both the ends.

2.4.11 Alternately Vendor may offer technically superior and proven product subject to approval of employer.

2.4.12 Occupancy based Passive Infra-red sensors

The sensors shall be recess mounted, programmable type suitable for lighting load of 6A with variable off delay settings. The detection area shall be minimum 5 metres for standard room height of 3mt. All the calibrated settings shall be stored in non-volatile memory of PIR sensor which shall be unaffected by power supply fluctuations. Necessary 16A contactor shall be supplied along with each sensor & shall be located inside the switch box.



2.5 TESTS

2.5.1 For LED Fixture

a) The contractor shall carry out the type tests as listed in this specification on the following types of LED fixtures to be supplied under this contract. The bidder shall indicate the charges for each of these type tests separately in the relevant price schedule of bid document and the same shall be considered for the evaluation of the bids.

LED fixtures (Type test shall be conducted on one rating each of following type of LED fixtures. Rating for test conduction shall be decided by the employer during detailed engineering)

- a) High bay fixture.
- b) Well glass fixture.
- c) Street light fixture
- d) Surface mounted type fixture.
- e) Recessed mounted type fixture.

The type tests charges shall be paid only for the test(s) actually conducted successfully under this contract and upon certification by the employer's engineer.

b) The type tests shall be carried out in presence of the employer's representative, for which minimum 15 days' notice shall be given by the contractor. The contractor shall obtain the employer's approval for the type test procedure before conducting the type test. The type test procedure shall clearly specify the test set-up, instruments to be used, procedure, acceptance norms, recording of different parameters, interval of recording, precautions to be taken etc. for the type test(s) to be carried out.

c) In case the contractor has conducted such specified type test(s) within last ten years as on the date of bid opening i.e 03-Mar-2017, he may submit during detailed engineering the type test reports to the owner for waiver of conductance of such type test(s). These reports should be for the tests conducted on the equipment similar to those proposed to be supplied under this contract and test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client. The owner reserves the right to waive conducting of any or all the specified type test(s) under this contract. In case type tests are waived, the type test charges shall not be payable to the contractor.



2.5.2 For all other Station lighting equipment:

a) All equipment to be supplied shall be of type tested design. During detail engineering, the contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last ten years from the date of bid opening i.e 03-Mar-2017. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.

b) However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening i.e 03-Mar-2017, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client/owners representative and submit the reports for approval.

2.5.3 All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.

2.5.4 Selection of samples for type test, acceptance test & routine test and acceptance criteria for all the items shall be as per relevant I.S.

2.5.5 Type test reports of the following items as per technical specification requirements/ standards shall be submitted for approval.

SL NO.	DESCRIPTION
i.	Lighting fixtures of each type
ii.	Lighting panel of each type (Degree of Protection)
iii.	Junction Box of each type.

Type test reports for LED as per standards for following shall be submitted for approval.

1. Visual and Dimension check
2. Proof of procurement of LEDs
3. Safety tests
 - a) Marking
 - b) Construction
 - c) Provision for Earthing
 - d) External and Internal wiring
 - e) Protection against electrical shock
 - f) Endurance and Thermal
 - g) Insulation resistance & electrical strength
 - h) Resistance to heat fire & tracking
 - i) Resistance to Humidity



4. Fire Retardant test
5. Performance tests (electrical, Photometric color and Life)
6. Burn-in Test
7. Power Cycling
8. Temperature rise test
9. Emission Tests
 - a) Radiated & conducted emission
 - b) Harmonics & flickers
10. Immunity tests

In addition, following test reports to be submitted for LED chip/LED luminaire:

- a) LED parameters like Lumen per watt, CRI, Beam angle from manufacturer.
- b) LM 80/IS: 16105 report.
- c) LM 79/IS: 16106 report.

2.5.6 Acceptance Test and Routine Test

2.5.6.1 All lighting fixtures, lamps and other items shall be subjected to acceptance and routine test, as per relevant specified standards.

2.5.6.2 Junction boxes, switch boxes, receptacle enclosure etc. shall be subjected to physical and dimensional checks also.

2.5.7 Galvanizing Tests

2.5.7.1 The quality of galvanizing shall be smooth, continuous, free from flux stains and shall be inspected visually.

2.5.7.2 In addition following tests shall be conducted as acceptance tests.

(a) Uniformity of coating - The coating of any article shall withstand for one (1) minute dips in standard copper sulphate solution without the formation of an adherent red spot of metallic copper upon the basic metal.

(b) The quality of cadmium/zinc plating on items with screw threads shall be free from visible defects such as unplated areas, blisters and modules and shall be inspected visually.

(c) In addition, the plating thickness shall be determined microscopically/ chemically or electronically.



2.6 COMMISSIONING CHECKS

1. On completion of installation work, the Contractor shall request the Project manager for inspection and test with minimum of fourteen (14) days advance notice.
2. The Project manager shall arrange for joint inspection of the installation for completeness and correctness of the work. Any defect pointed out during such inspection shall be promptly rectified by the Contractor.
3. The installation shall be then tested and commissioned in presence of the Project manager.
4. The contractor shall provide all material and equipment required to carry out the tests.
5. All rectifications, repair or adjustment work found necessary during inspection, testing and commissioning shall be carried out by the Contractor without any extra cost. The handing over the lighting installation shall be effected only after the receipt of written instruction from the Employer/his authorized representative.
6. The testing shall be done in accordance with the applicable Indian Standards and codes of practices. The following tests shall be specifically carried out for all lighting installation.
 - (a) Insulation Resistance.
 - (b) Testing of earth continuity path.
 - (c) Polarity test of single phase switches.
 - (d) Functional checks.
7. The lighting circuits shall be tested in the following manner:
 - (a) All switches ON and consuming devices in circuit, both poles connected together to obtain resistance to earth.
 - (b) Insulation resistance between poles with lamps and other consuming devices removed and switches ON.

The above checks are for information. All checks shall be as per NTPC approved field quality plan (FQP) which needs to be submitted for approval during contract execution stage.

CLAUSE NO.	TECHNICAL REQUIREMENTS			एनटीपीसी NTPC
	ANNEXURE-A			
	SI No.	Location**	Average Illumination Level (Lux)	Type of Fixture
	(a)	Turbine Hall operating floor	200	High/medium bay LED luminaire
	(b)	Turbine Hall Other Platforms	200	LED high/medium bay, LED well glass fixtures
	(c)	Switchgear rooms, Charger, Rectifier room	200	Industrial type LED Luminaire
	(d)	Control room, computer room, control equipment room	350	LED luminaire equivalent to Mirror optics with anti-glare features or downlighter.
	(e)	Offices, conference rooms, etc.	300	Decorative mirror optics Type LED luminaire or LED downlighter
	(f)	Battery rooms	100	Totally enclosed corrosion Proof LED Luminaire
	(g)	Transformer yard	20 (general) 50 (on equipment)	LED Luminaire
	(h)	Boiler platforms	100	LED well glass fixtures,
	(i)	Diesel generating room /enclosure, Compressor room, pump house etc.	150	LED medium bay/ Industrial type LED Luminaire
	(j)	Fuel oil pump house	150	Flame proof fluorescent fixtures suitable for division-2 hazardous area
	(k)	Cable galleries/vault	50	Industrial type LED Luminaire
	(l)	Street lighting- primary roads secondary roads	20 10	LED street lights
	(m)	Outdoor storage handling and unloading area	20	LED Luminaire
	(n)	Cement stores	150	Industrial dust proof type LED Luminaire
	(o)	Chemical stores/House	150	Corrosion proof LED Luminaire

EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE –I (3X 800MW)	TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.: CS-9585-001-2	SUBSECTION-B-10 STATION LIGHTING	Page 14 of 17
---	---	-------------------------------------	------------------

CLAUSE NO.	TECHNICAL REQUIREMENTS			एनटीपीसी NTPC
	(p)	Permanent stores	150	LED high/medium bay / Industrial trough LED Luminaire
	(q)	Workshop. Building	150	LED high/medium bay / Industrial trough LED Luminaire
	(r)	Laboratory General Analysis area	150 300	Corrosion proof LED Luminaire
	(s)	Garage/Car Parking	50	Industrial type LED Luminaire
	(u)	AIS Switchyard and Substation	20(general 50(on strategic equipment)	LED Luminaire
	(v)	Transfer points, Sheds, tunnels, bunker house, Crusher house, Conveyor Gallery etc. in bidders scope	100	LED Dust tight/Well glass type Luminaire
	(w)	Facility building, canteen etc	150	Industrial type LED Luminaire
	(x)	Hydrogen Plant Building	150	Explosion proof HPMV/ Flourcent fittings suitable for class-I and Division –IIC
	(y)	DC Lighting- Control room	-	In candescent down light fixtures, Decorative recessed type with cylindrical reflector
	(z)	DC Lighting- Other Area	-	Incandescent Industrial Bulkhead
	(aa)	Corridors, Walkways	50	LED Luminaire
	(ab)	Building Periphery Lighting	10	LED Street Light fixture/ LED Luminaire
	(ac)	Security Lighting along Boundary	10	LED Street Light fixture/ LED Luminaire
	(ad)	ESP platform	150	LED well glass fixtures
	(ae)	Gate complex/Time Office	150	LED Luminaire
	(af)	GIS Hall	150	LED medium bay/ Luminaire
	(n)	DM plant, water treatment plant CW Pump house, Raw water PH, Fire Water PH	150	LED high/medium bay / Industrial trough LED Luminaire
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE –I (3X 800MW)		TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.: CS-9585-001-2		SUBSECTION-B-10 STATION LIGHTING
				Page 15 of 17

CLAUSE NO.	TECHNICAL REQUIREMENTS						एनटीपीसी NTPC
	ANNEXURE-B						
	Sl.	Plant Areas	Normal AC Lighting System	Emergency AC Lighting System	220 V DC Lighting System	Portable DC Fixtures	
	1	TG Building(turbine hall, switchgear room etc)	80%	20%	√	—	
	2.	Boiler Platform	80%	20%	√		
	3	DG Area/ Room	80%	20%			
	4	Compressor Room				√	
	5	ESP Control Room	80%	20%		√	
	6	Unit Control Room	70%	30%			
	7	Switchyard Control Room	80%	20%			
	8	Battery Room	80%	20%			
	9	Cable Spreader Room/ Vault	80%	20%	√		
	10	Make Up Water Pump House	100%			√	
	11	Chemical House	100%			√	
	12	Fuel Oil Pump House	100%			√	
	13	Ash Handling Plant	100%			√	
	14	Water Treatment Plant	100%			√	
	15	CT Switchgear Room	100%			√	
	16	Cooling Towers	100%				
	17	Workshop	100%			√	
	18	Service Building	100%				
	19	Area Lighting	100%				
	20	Street Lighting	100%				
	21	Transformer Yard and Storage Yard	100%				
	22	Coal Handling Plant	100%		√		
	23	GIS Hall	80%	20%			
	24	AIS Switchyard	80%	20%			
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE –I (3X 800MW)		TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.: CS-9585-001-2		SUBSECTION-B-10 STATION LIGHTING		Page 16 of 17	

CLAUSE NO.	TECHNICAL REQUIREMENTS		एनटीपीसी NTPC
	DC Emergency Lighting:		
	Area	Average Lux Level	
1	Unit Control Room	100	
2	Control Equipment Room	100	
3	Switchyard Control Room	20	
4	Strategic Control Points (In TG Building & Boiler Area, Switchgear room, SWAS, Battery Room, UPS Area, TG Hall, Luboil Room etc	20	
5	Cable Vault & Galleries	1 fixture at every 20 metres spacing along walkways	
6	Boiler Stair Case	1 fixture at every 20 metres spacing along walkways	
7	Exit/ Entry of Main Plant Building	1 fixture	
8	Fire Exit Sign	1 fixture	



SECTION-3

Refer document

General Technical Requirements – TB-397-316-000 Rev 00.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

SECTION- 3

PROJECT DETAILS AND GENERAL SPECIFICATIONS

3.0 GENERAL

This section stipulates the General Technical Requirements under the Contract and will form an integral part of the Technical Specification.

The provisions under this section are intended to supplement general requirements for the materials, equipment and services covered under other sections of tender documents and are not exclusive. However in case of conflict between the requirements specified in this section and requirements specified under other sections, the requirements specified under respective sections shall prevail.

3.1 PROJECT DETAILS

	Particular	Details															
a)	Customer	Patratu Vidyut Utpadan Nigam Ltd (PVUNL) – A Subsidiary of NTPC in Joint Venture with JBVNL.															
b)	Engineer/Consultant/ Inspector	NTPC Ltd.															
c)	Project Title	Patratu Super Thermal Power Project Expansion Phase – I (3X 800MW) – 400kV GIS Switchyard at Patratu STPP															
d)	Project Location	Place: Patratu District: Ramgarh State: Jharkhand															
e)	Latitude & Longitude	Latitudes and Longitudes of the site are as follows: <table border="1" style="margin-top: 5px;"> <thead> <tr> <th>Corner name</th><th>Latitude</th><th>Longitude</th></tr> </thead> <tbody> <tr> <td>Top Corner</td><td>23° 38 ' 60'' N</td><td>85° 17' 51.5" E</td></tr> <tr> <td>Bottom Corner</td><td>23° 38 ' 12.5'' N</td><td>85° 17' 27" E</td></tr> <tr> <td>Left Corner</td><td>23° 38 ' 22.5'' N</td><td>85° 17' 10.6'' E</td></tr> <tr> <td>Right Corner</td><td>23° 38 ' 40'' N</td><td>85° 17' 57'' E</td></tr> </tbody> </table>	Corner name	Latitude	Longitude	Top Corner	23° 38 ' 60'' N	85° 17' 51.5" E	Bottom Corner	23° 38 ' 12.5'' N	85° 17' 27" E	Left Corner	23° 38 ' 22.5'' N	85° 17' 10.6'' E	Right Corner	23° 38 ' 40'' N	85° 17' 57'' E
Corner name	Latitude	Longitude															
Top Corner	23° 38 ' 60'' N	85° 17' 51.5" E															
Bottom Corner	23° 38 ' 12.5'' N	85° 17' 27" E															
Left Corner	23° 38 ' 22.5'' N	85° 17' 10.6'' E															
Right Corner	23° 38 ' 40'' N	85° 17' 57'' E															
f)	Nearest Railway Station	Patratu – At a distance of about 4 km on Barkakhana-Barwadih Railway Line.															
g)	Distance of project location from the Railway station	4 km (approx.)															
h)	Nearest Major Town	Ranchi															
i)	Distance of the town from the project site	45 km															
j)	Nearest commercial airport	Birsa Munda Airport, Ranchi.															
k)	Distance of airport from the project site	45 km															
<u>SITE CONDITIONS</u> (for design purposes)																	
a)	Design ambient temperature	50°C															
b)	Maximum Relative humidity	95 %															
c)	Height above mean sea level	Less than 1000 meters															
d)	Pollution Severity	Heavily polluted															

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

e)	Criteria for Wind Resistant design of structures and equipment	Standard Applicable - IS 875 (Part 3)
f)	Basic Wind speed “Vb” at ten meters above the mean ground level.	39 m/ sec
g)	Category of terrain	Cat -2
h)	Risk Coefficient “K1”	1.06

3.1.1 SYSTEM PARAMETERS:

Sl.No.	Parameters	400 kV
1	Highest system voltage	420 kV rms
2	Lightning Impulse voltage	±1425kVp
3	Switching impulse voltage	±1050kVp
4	Power frequency withstand for 1 min (rms)	650 kV(rms)
5	Max. fault level (1 sec.)	63 kA
6	Minimum creepage distance	10500 mm

3.1.2 AUXILIARY POWER:

Sl.No.	Nominal Connection Voltage	Variations in Voltage	Frequency	Phase	Neutral
1	415V	±10%	50 (+3% -5%)	3Phase , 4 Wire	Solidly Earthed
2	240V	±10%	50 (+3% -5%)	1 phase	Solidly Earthed

Combined variation of voltage and frequency shall be + 10%. Design fault level of 415V system shall be restricted to 50kA rms for 1 second.

The operational limits for variation of DC voltage are (+) 10% to (-) 15%.

3.1.3 The various minimum heights of the AIS switchyard shall be as given below from plinth level:

Voltage	Equipment /1st Level	Line Take Off Gantry Height	Peak
400kV	8000mm	23000mm	8500mm

The minimum vertical distance from the bottom of the lowest porcelain part of the bushing, porcelain enclosures or support insulators to the bottom of the equipment structure, where it rests on the foundation pad shall be 2550mm.

The minimum height of intermediate gantry tower for 400kV wherever required shall be 25 m and the peak (s) shall be of 8.5 m. The gantry width for 400kV AIS shall be minimum 27m or as required to meet the specified clearances.

3.1.4 The minimum clearances for 400kV switchyards shall be as given below:

	400kV
Phase to earth clearance	3500 mm
Phase to phase clearance	4000 mm
Section clearance	6500 mm

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

3.2 INSTRUCTION TO BIDDERS:

The bidders shall submit the technical requirements, data and information as per the technical data sheets, provided in Section-4.

The bidders shall furnish catalogues, engineering data, technical information, design documents, drawings etc fully in conformity with the technical specification.

The supplier should be approved by Employer. If not, it is the responsibility of the vendor to be assessed and approved Employer, before placement of order by BHEL. Any cost involved in vendor assessment/approval must be borne by the vendor himself.

The Bidder's proposal shall be based upon the use of equipment and material complying fully with the requirements specified herein. It is recognized that the Bidder may have standardized on the use of certain components, materials, processes or procedures different than those specified herein. Alternate proposals offering similar equipment based on the manufacturer's standard practice will also be considered, provided the base offer is in line with technical specifications and such proposals meet the specified design standards and performance requirement and are acceptable to the Purchaser. Sufficient amount of information for justifying such proposals shall be furnished to Purchaser alongwith the bid to enable the Purchaser to determine the acceptability of these proposals.

Wherever a material or article is specified or defined by the name of a particular brand, Manufacturer or Vendor, the specific name mentioned shall be understood to be indicative of the function and quality desired and not restrictive. Other manufacturer's products may be considered provided sufficient information is furnished to enable the Employer to determine that the products proposed are equivalent to those named.

Equipment furnished shall be complete in every respect with all mountings, fittings, fixtures and standard accessories normally provided with such equipment and/ or needed for erection, completion and safe operation of the equipment as required by applicable codes, though they may not have been specifically detailed in the Technical Specifications unless included in the list of exclusions. Materials and components not specifically stated in the specification but which are necessary for commissioning and satisfactory operation of the switchyard unless specifically excluded shall be deemed to be included in the scope of the specification and shall be supplied without any extra cost. All similar standard components/parts of similar standard equipment under supply shall be inter-changeable with one another.

The bidder shall supply type tested (including special tests as per tech. specification) equipment and materials. The test reports shall be furnished by the bidder along with equipment/ material drawings. In the event of any discrepancy in the test reports, (i.e., if any test report is not acceptable due to any design/ manufacturing changes or due to non-compliance with the Technical Specification and/ or applicable standard), the tests shall be carried out without any additional cost implication to the BHEL. BHEL reserves the right to get any or all type/tests conducted/repeated.

3.3 CODES AND STANDARDS

In addition to the codes and standards specifically mentioned in the relevant technical specifications for the equipment / plant / system, all equipment parts, systems and works covered under this specification shall comply with all currently applicable statutory regulations and safety codes of the Republic of India as well as of the locality where they will be installed, including the following :

- a) Indian Electricity Act
- b) Indian Electricity Rules

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- c) Indian Explosives Act
- d) Indian Factories Act and State Factories Act
- e) Indian Boiler Regulations (IBR)
- f) Regulations of the Central Pollution Control Board, India
- g) Regulations of the Ministry of Environment & Forest (MoEF), Government of India
- h) Pollution Control Regulations of Department of Environment, Government of India
- i) State Pollution Control Board.
- (j.) Rules for Electrical installation by Tariff Advisory Committee (TAC).
- (k.) Building and other construction workers (Regulation of Employment and Conditions of services) Act, 1996
- (l.) Building and other construction workers (Regulation of Employment and Conditions of services) Central Rules, 1998
- (m.) Explosive Rules, 1983
- (n.) Petroleum Act, 1984
- (o.) Petroleum Rules, 1976,
- (p.) Gas Cylinder Rules, 1981
- (q.) Static and Mobile Pressure Vessels (Unified) Rules, 1981
- (r.) Workmen's Compensation Act, 1923
- (s.) Workmen's Compensation Rules, 1924
- (t.) NTPC Safety Rules for Construction and Erection
- (u.) NTPC Safety Policy
- (v.) Any other statutory codes / standards / regulations, as may be applicable.

Unless covered otherwise in the specifications, the latest editions (as applicable as on date of bid opening: 03-March-2017), of the codes and standards given below shall also apply:

- a) Bureau of Indian standards (BIS)
- b) Japanese Industrial Standards (JIS)
- c) American National Standards Institute (ANSI)
- d) American Society of Testing and Materials (ASTM)
- e) American Society of Mechanical Engineers (ASME)

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- f) American Petroleum Institute (API)
- g) Standards of the Hydraulic Institute , U.S.A.
- h) International Organization for Standardization (ISO)
- i) Tubular Exchanger Manufacturer's Association (TEMA)
- j) American Welding Society (AWS)
- k) National Electrical Manufacturers Association (NEMA)
- l) National Fire Protection Association (NFPA)
- m) International Electro-Technical Commission (IEC)
- n) Expansion Joint Manufacturers Association (EJMA)
- o) Heat Exchange Institute (HEI)
- p) IEEE standard
- q) JEC standard

Other International/ National standards such as DIN, VDI, BS, GOST etc. shall also be accepted for only material codes and manufacturing standards, subject to the Employer's approval, for which the Bidder shall furnish, adequate information to justify that these standards are equivalent or superior to the standards mentioned above. In all such cases the Bidder shall furnish specifically the variations and deviations from the standards mentioned elsewhere in the specification together with the complete word to word translation of the standard that is normally not published in English.

As regards highly standardized equipment such as Steam Turbine and Generator, National /International standards such as JIS, DIN, VDI, ISO, SEL, SEW, VDE, IEC & VGB shall also be considered as far as applicable for Design, Manufacturing and Testing of the respective equipment. However, for those of the above equipment not covered by these National / International standards, established and proven standards of manufacturers shall also be considered.

In the event of any conflict between the codes and standards referred to in the above clauses and the requirement of this specification, the requirement of Technical Specification shall govern.

In case of any change in codes, standards & regulations between 03-March-2017 and the date when vendors proceed with fabrication, the Employer shall have the option to incorporate the changed requirements or to retain the original standard. It shall be the responsibility of the Contractor to bring to the notice of the Employer such changes and advise Employer of the resulting effect.

3.4 SERVICES TO BE PERFORMED BY THE EQUIPMENT BEING FURNISHED

The 400 kV system is being designed to limit the power frequency over voltage of 1.5 p.u. and the switching surge over voltage to 2.5 p.u. In 400 kV system the initial value of temporary over voltage could be 2.0 p.u. for 1-2 cycles. All the equipment/materials covered in this specification shall perform all its function satisfactorily without undue strain, restrike etc. under such over voltage conditions.

All equipment shall also perform satisfactorily under various other electrical, electromechanical and meteorological conditions of the site of installation. All equipment shall be able to withstand all

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

external and internal mechanical, thermal and electromechanical forces due to various factors like wind load, temperature variation, ice & snow (not applicable for this project), short circuit etc for the equipment.

3.5 ENGINEERING DATA

3.5.1 Drawings

All drawings submitted by the supplier including those submitted at the time of bid shall be in sufficient detail to indicate the type, size, arrangement, material description, Bill of Materials, weight of each component, break-up for packing and shipment, the external connections, fixing arrangement required. The dimensions required for installation and interconnections with other equipment and materials, clearances and spaces required for installation and interconnections between various portions of equipment and any other information specifically requested in the specifications.

Each drawing submitted by the bidder (including those of sub-vendors) shall bear a title block at the right hand bottom corner with clear mention of the name of the Employer, the system designation, the specifications title, the specification number, the name of the Project, drawing number and revisions. If standard catalogue pages are submitted, the applicable items shall be indicated therein. All titles, noting, markings and writings on the drawing shall be in English. All the dimensions should be in metric units.

After the approval of the drawings, further work by the bidder shall be in strict accordance with these drawings and no deviation shall be permitted without the written approval of the Purchaser, if so required.

The review of these document/data/drawings by the purchaser will cover only general conformance of the document/data/drawings to the specification and contract, interfaces with the equipment provided under specification, external connections and of the dimensions which might affect plan layout. This review by the purchaser may not indicate a thorough review of the dimensions, quantities and details of the equipment, material, any devices or items indicated or the accuracy of the information submitted. The review and/or approval by the purchaser shall not be considered by the bidder, as limiting any of his responsibilities and liabilities for mistakes and deviations from the requirements, specified under these specifications and documents.

All manufacturing, fabrication and execution of work in connection with the equipment/system prior to the approval of the drawings shall be at the bidder's risk. The bidder is expected not to make any changes in the design of the equipment /system, once they are approved by the Purchaser. However, if some changes are necessitated in the design of the equipment/system at a later date, the bidder may do so, but such changes shall promptly be brought to the notice of the Purchaser indicating the reasons for the change and get the revised drawing approved again in strict conformance to the provisions of the Technical Specification. Approval of bidder's drawing or work by the Purchaser shall not relieve the bidder of any of his responsibilities and liabilities under the Contract.

All engineering data submitted by the contractor after final process including review and approval by the purchaser shall form part of the contract document and the entire work performed under these specifications shall be performed in strict conformity with technical specification, unless otherwise expressly requested by the purchaser in writing.

3.5.2 Bidder's Drawing Submission and Approval Procedure

The following procedure for submission and review/approval of the drawings, data reports, information, etc. shall be followed by the bidder:

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- a. All data/information furnished by Vendor in the form of drawings, documents, Catalogues or in any other form for Employer's information/interface and/or review and approval are referred by the general term "drawings".
- b. The 'Master drawings list' indicating titles, Drawing Number, Date of submission and approval etc. shall be furnished by the bidder. This list shall be updated if required at suitable interval during detailed engineering.
- c. All drawings (including those of sub-vendor) shall bear at the right hand bottom corner the 'title plate' with all relevant information duly filled in. The bidder shall furnish this format to his sub-vendor along with his purchase order for sub-vendor's compliance.
- d. Contractor shall submit all the drawings in five (5) copies for review of Employer. Employer shall forward their comments within four (4) weeks of receipt of drawings.
- e. Upon review of each drawings, depending on the correctness and completeness of the drawings, the same will be categorised and approval accorded in one of the following categories:

CATEGORY I	Approved
CATEGORY II	Approved, subject to incorporation of comments/modification as noted. Resubmit revised drawing incorporating the comments
CATEGORY III	Not approved. Resubmit revised drawings for Approval after incorporating comments/modifications as noted
CATEGORY IV	For information and records

- f. Bidder shall resubmit the drawings approved under Category II, III within one (1) week of receipt of comments on the drawings, incorporating all comments. Every revision of the drawing shall bear a revision index wherein such revisions shall be highlighted in the form of description or marked up in the drawing identifying the same with relevant revision number enclosed in a triangle (e.g 1.2.3. etc.).
- g. In case Bidder does not agree with any specific comment, he shall furnish the explanation for the same to Employer for consideration. In all such cases Bidder shall necessarily enclose explanations along with the revised drawing (taking care of balance comments) to avoid any delay and/or duplication in review work.
- h. It is the responsibility of the Bidder to get all the drawings approved in the Category I or IV (as the case may be) and complete engineering activities within the agreed schedule. Any delay arising out of submission and modification of drawings shall not alter the contract completion schedule.
- i. Bidder shall not make any changes in the portions of the drawing other than those commented. If changes are required to be made in the portions already approved, the Bidder shall resubmit the drawings identifying the changes (along with reasons for changes) for Employer's review and approval. **Drawings resubmitted shall show clearly the portions where the same are revised marking the relevant revision numbers and Employer shall review only such revised portion of documents.**
- j. As Built Drawings

After final acceptance of individual equipment / system by the Employer, the Bidder will update all original drawings and documents for the equipment / system to "as built" conditions and submit no. of copies as per clause 3.5.5.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- k. Approval of drawings will not in any way relieve the Bidder of his obligations of furnishing the equipment in accordance with the specification and shall not prevent subsequent rejection if such equipment is later found to be defective.

3.5.3 Erection Drawings.

- a. Contractor shall furnish erection drawings for the guidance or commencement of erection or the first shipment, whichever is earlier. These shall generally comprise of fabrication/assembly drawings, various component/part details drawing, assembly, clearance data requirements, etc. The drawings shall contain details of components/ equipment with identification number, match marks, bill of materials, assembly procedures etc.
- b. For all major equipment apart from above details, assembly sequence and instructions with check-lists shall be furnished in the form of erection manuals.

3.5.4 Instruction Manual

- a. The Contractor shall submit to the Employer preliminary instruction manuals for all the equipments for review. The final instructions manuals incorporating Employer's comments and complete in all respect shall be submitted at least sixty (60) days before the first shipment of the equipment. The instruction manuals shall contain full details and drawings of all the equipments, the transportation, storage, installation, testing, commissioning, operation and maintenance procedures, etc. separately for each component/equipment along with log record format. These instruction manuals shall be submitted in five (5) copies for approval.
- b. If after commissioning and initial operation of the plant, the instruction manuals require any modifications/additions/changes, the same shall be incorporated and the updated final instruction manuals shall be submitted.
- c. The operating and maintenance instructions together with drawings (other than shop drawings) of the equipment, as completed, shall have sufficient details to enable the Employer to maintain, dismantle, reassemble and adjust all parts of the equipment. They shall give a step by step procedure for all operations likely to be carried out during the life of the plant/equipment, including erection, testing, commissioning, operation, maintenance dismantling and repair. Each manual shall also include a complete set of approved drawings together with performance/rating curves of the equipment and test certificates, wherever applicable. The contract shall not be considered completed for purpose of taking over until such instructions and drawings have been supplied to the Employer.
- d. A separate section of the manual shall be for each size/type of equipment and shall contain a detailed description of construction and operation, together with all relevant pamphlets.
- e. The manuals shall include the following
 - a) List of spare parts along with their drawing and catalogues and procedure for ordering spares.
 - b) Lubrication Schedule including charts showing lubrication checking, testing and replacement procedure to be carried daily, weekly, monthly & at longer intervals to ensure trouble free operation.
- f. Where applicable, fault location charts shall be included to facilitate finding the cause of mal-operation or break down.
- g. A collection of the manufacturer's standard leaflets will not accepted to be taken as a compliance of this clause. The manual shall be specifically compiled for the concerned project.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

The Instruction Manuals shall comprise of the following:

3.5.4.1 Erection Manuals

The erection manuals shall be submitted atleast three (3) months prior to the commencement of erection activities of particular equipment/system. The erection manual should contain the following as a minimum.

- a) Erection strategy.
- b) Sequence of erection.
- c) Erection instructions.
- d) Critical checks and permissible deviation/tolerances.
- e) List of tool, tackles, heavy equipments like cranes, dozers, etc.
- f) Bill of Material
- g) Procedure for erection and General Safety procedures to followed during erection/installation.
- h) Procedure for initial checking after erection.
- i) Procedure for testing and acceptance norms.
- j) Procedure / Check list for pre-commissioning activities.
- k) Procedure / Check list for commissioning of the system.
- l) Safety precautions to be followed in electrical supply distribution during erection.

3.5.4.2 Operation and Maintenance Manuals

- a) The manual shall be a two rim PVC bound stiff sided binder able to withstand constant usage or where a thicker type is required it shall have locking steel pins, the size of the manual shall not be larger than international size A3. The cover shall be printed with the Project Name, Services covered and Volume / Book number Each section of the manual shall be divided by a stiff divider of the same size as the holder. The dividers shall clearly state the section number and title. All written instructions within the manual not provided by the manufacturers shall be typewritten with a margin on the left hand side.
- b) The arrangement and contents of O & M manuals shall be as follows :
 - 1) Chapter 1 - Plant Description : To contain the following sections specific to the equipment/system supplied
 - (a) Description of operating principle of equipment / system with schematic drawing / layouts.
 - (b) Functional description of associated accessories / controls. Control interlock protection write up.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- (c) Integrated operation of the equipment along-with the intended system. (This is to be given by the supplier of the Main equipment by taking into account the operating instruction given by the associated suppliers).
 - (d) Exploded view of the main equipment, associated accessories and auxiliaries with description. Schematic drawing of the equipment along-with its accessories and auxiliaries.
 - (e) Design data against which the plant performance will be compared.
 - (f) Master list of equipment, Technical specification of the equipment/ system and approved data sheets.
 - (g) Identification system adopted for the various components, (it will be of a simple process linked tagging system).
 - (h) Master list of drawings (as built drawing - Drawings to be enclosed in a separate volume).
- 2) Chapter 2 - Plant Operation : To contain the following sections specific to the equipment supplied
- (a) Protection logics provided for the equipment along-with brief philosophy behind the logic, Drawings etc.
 - (b) Limiting values of all protection settings.
 - (c) Various settings of annunciation/interlocks provided.
 - (d) Start-up and shut down procedure for equipment along-with the associated systems in step mode.
 - (e) Do's and Don'ts related to operation of the equipment.
 - (f) Safety precautions to be taken during normal operation. Emergency instruction on total power failure condition/lubrication failure/any other conditions.
 - (g) Parameters to be monitored with normal value and limiting values.
 - (h) Equipment isolating procedures.
 - (i) Trouble shooting with causes and remedial measures.
 - (j) Routine testing procedure to ascertain healthiness of the safety devices along-with schedule of testing.
 - (k) Routine Operational Checks, Recommended Logs and Records
 - (l) Change over schedule if more than one auxiliary for the same purpose is given.
 - (m) Preservation procedure on long shut down.
 - (n) System/plant commissioning procedure.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- 3) Chapter 3 - Plant Maintenance : To contain the following sections specific to the equipment supplied
- (a) Exploded view of each of the equipments. Drawings along-with bill of materials including name, code no. & population.
 - (b) Exploded view of the spare parts and critical components with dimensional drawings (In case of Electronic cards, the circuit diagram to be given) and spare parts catalogue for each equipment.
 - (c) List of Special T/ P required for Overhauling /Trouble shooting including special testing equipment required for calibration etc.
 - (d) Stepwise dismantling and assembly procedure clearly specifying the tools to be used, checks to be made, records to be maintained etc. Clearance to be maintained etc.
 - (e) Preventive Maintenance schedules linked with running hours/calendar period along-with checks to be carried out.
 - (f) Overhauling schedules linked with running hours/calendar period along-with checks to be done.
 - (g) Long term maintenance schedules
 - (h) Consumables list along-with the estimated quantity required during normal running and during maintenance like Preventive Maintenance and Overhauling.
 - (i) List of lubricants with their Indian equivalent, Lubrication Schedule including charts showing lubrication checking, testing and replacement procedure to be carried daily, weekly, monthly & at longer intervals to ensure trouble free operation and quantity required for complete replacement.
 - (j) Tolerance for fitment of various components.
 - (k) Details of sub vendors with their part no. in case of bought out items.
 - (l) List of spare parts with their Part No, total population, life expediency & their interchangeability with already supplied spares to NTPC.
 - (m) List of mandatory and recommended spare list along with manufacturing drawings, material specification & quality plan for fast moving consumable spares.
 - (n) Lead time required for ordering of spares from the equipment supplier, instructions for storage and preservation of spares.
 - (o) General information on the equipment such as modification carried out in the equipment from its inception, equipment population in the country / foreign country and list of utilities where similar equipments have been supplied.

After finalization and approval of the Employer, the O & M Manuals shall be submitted as indicated in table below. The Contract shall not be considered to be completed for purposes of taking over until the final Instructions manuals (both erection and O & M manuals have been supplied to the Employer.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

If after the commissioning and initial operation of the plant, the instruction manuals (Erection and /or O &M manuals) require modifications/additions/ changes, the same shall be incorporated and the updated final instruction manuals shall be submitted by the Contractor to the Employer for records and number of copies shall be as mentioned in table below:

S.No.	Description of Drgs/Docs	No. of Prints	No. of CD ROMs/DVDs/Portable Hard Disk
1	Erection Manual	4 Sets	2
2	Operation & Maintenance manual i) First Submission	1 Set	1
	ii) Final Submission	4 Sets	2

3.5.5 Final Submission of drawings and documents:

The Bidder shall furnish the following after approval of all drawings /documents and test reports:

- List of drawings bearing the Employer's and Contractor's drawing number.
- Six (6) bound sets along-with two (2) sets of CD-ROMs/ DVD/Portable hard disk of all final drawings/documents.
- Bidder shall also furnish six (6) bound sets of all as-built drawings including the list of all as-built drawings bearing drawing numbers. The Contractor shall also furnish two (2) sets of CD-ROMs/ DVD/Portable hard disk of all as-built drawings as decided by the Employer.
- The Bidder shall also furnish four (4) copies and two (2) sets of CD-ROMs/ DVD/Portable hard disk of instruction/ operations & maintenance manuals (after approval) for all the equipments.

3.5.6 TEST REPORTS

Two (2) copies of all test reports shall be supplied for approval before shipment of Equipment. The report shall indicate clearly the standard value specified for each test to facilitate checking of the reports. After final approval six (6) bound copies and two (2) sets of CD-ROMs/ DVD/Portable hard disk of all type and routine test reports shall be submitted to Employer.

3.6 MATERIAL /WORKMANSHIP

Where the specification does not contain references to workmanship, equipment, materials and components of the covered equipment, it is essential that the same must be new, of highest grade of the best quality of their kind, conforming to best engineering practice and suitable for the purpose for which they are intended and shall ensure satisfactory performance throughout the service life.

In case where the equipment, materials or components are indicated in the specification as "similar" to any special standard the purchaser shall decide upon the question of similarity. When required by the specification or when required by the purchaser the contractor shall submit, for approval, all the information concerning the materials or components to be used in manufacture. Machinery, equipment, materials and components supplied, installed or used without such approval shall run the risk of subsequent rejection, it being understood that the cost as well as the time delay associated with the rejection shall be borne by the Contractor.

The design of the Works shall be such that installation, future expansions, replacements and general maintenance may be undertaken with a minimum of time and expenses. Each component shall be

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

designed to be consistent with its duty and suitable factors of safety subject to mutual agreements. All joints and fastenings shall be devised, constructed and documented so that the component parts shall be accurately positioned and restrained to fulfill their required function. In general, screw threads shall be standard metric threads. The use of other thread forms will only be permitted when prior approval has been obtained from the Purchaser.

Whenever possible, all similar part of the works shall be made to gauge and shall also be made interchangeable with similar parts. All spare parts shall also be interchangeable and shall be made of the same materials and workmanship as the corresponding parts of the equipment supplied under the specification. Where feasible, common component units shall be employed in different pieces of equipment in order to minimize spare parts stocking requirements. All equipment of the same type and rating shall be physically and electrically interchangeable.

The equipment offered in the bid only shall be accepted for supply, with the minimum modifications as agreed/accepted.

3.7 PROVISIONS FOR EXPOSURE TO HOT AND HUMID CLIMATE

Outdoor equipment supplied under the specification shall be suitable for service and storage under tropical conditions of high temperature, high humidity' heavy rainfall and environment favorable to the growth of fungi and mildew. The indoor equipment located in non-air-conditioned areas shall also be of same type.

SPACE HEATERS

The heaters shall be suitable for continuous operation at 240 V as supply voltage. On –off switch and fuse shall be provided.

One or more adequately rated thermostatically connected heaters shall be supplied to prevent condensation in any compartment. The heaters shall be installed in the compartment and electrical connections shall be made sufficiently away from below the heaters to minimize deterioration of supply wire insulation. The heaters shall be suitable to maintain the compartment temperature to prevent condensation.

The heaters shall be suitably designed to prevent any contact between the heater wire and the air and shall consist of coiled resistance wire centered in a metal sheath and completely encased in a highly compacted powder of magnesium oxide or other material having equal heat conducting and electrical insulation properties or they shall consist of resistance wire wound on a ceramic and completely covered with a ceramic material to prevent any contact between the wire and the air. Alternatively, they shall consist of a resistance wire mounted into a tubular ceramic body built into an envelope of stainless steel or the resistance wire is wound on a tubular ceramic body and embedded in vitreous glaze. The surface temperature of the heaters shall be restricted to a value which will not shorten the life of the heater sheaths or that of insulated wire or other component in the compartments.

Control cubicles installed in air-conditioned area need not be provided with space heaters. These cubicles shall, however, have space heaters in case of storage of cubicles for long duration.

FUNGI STATIC VARNISH

Besides the space heaters, special moisture and fungus resistance varnish shall be applied on parts which may be subjected or predisposed to the formation of fungi due to the presence or deposit of nutrient substances. The varnish shall not be applied to any surface of part where the treatment will interfere with the operation or performance of the equipment. Such surfaces or parts shall be protected against the application of the varnish.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

Ventilation opening

In order to ensure adequate ventilation, compartments shall have ventilation openings provided with fine wire mesh of brass to prevent the entry of insects and to reduce to a minimum the entry of dirt and dust. Outdoor compartment openings shall be provided with shutter type blinds.

Degree of Protection

The enclosure of the Control Cabinets, Junction boxes and Marshalling Boxes, panels etc. to be installed shall provide degree of protection as detailed here under:

- a. Installed outdoor: IP- 55
- b. Installed indoor in air conditioned area: IP-32
- c. Installed in covered area: IP-52
- d. Installed indoor in non air-conditioned area where possibility of entry of water is limited: IP-41.
- e. For LT Switchgear (AC & DC distribution Boards) : IP-52

The degree of protection shall be in accordance with IS: 13947 (Part –I) / IEC-947 (Part-I) / IS 12063/IEC 529. Type test report for degree of protection test, on each type of the box shall be submitted for approval.

PRESERVATIVE SHOP COATING

All exposed metallic surfaces subject to corrosion shall be protected by shop application of suitable coatings. All surfaces which will not be easily accessible after the shop assembly, shall be treated beforehand and protected for the life of the equipment. All surfaces shall be thoroughly cleaned of all mill scales, oxides and other coatings and prepared in the shop. The surfaces that are to be finish-painted after installation or require corrosion protection until installation, shall be shop painted as per the requirements covered in the relevant part of the Technical Specification.

Transformers and other electrical equipments, if included shall be shop finished with one or more coats of primer and two coats of high grade resistance enamel. The finished colors shall be as per manufacturer's standards, to be selected and specified by the Employer at a later date.

Shop primer for all steel surfaces which will be exposed to operating temperature below 95 degrees Celsius shall be selected by the Bidder after obtaining specific approval of the Employer regarding the quality of primer proposed to be applied. Special high temperature primer shall be used on surfaces exposed to temperature higher than 95 degrees Celsius and such primer shall also be subject to the approval of the Employer.

3.8 RATING PLATES, NAME PLATES AND LABELS

- 3.8.1 Each equipment shall have permanently attached to it in a conspicuous position, a rating plate of non-corrosive material upon which shall be engraved manufacturer's name, equipment, type or serial number together with details of the ratings, service conditions under which the item of plant in question has been designed to operate, and such diagram plates as may be required by the Employer.
- 3.8.2 Such nameplates or labels shall be of white non-hygroscopic material with engraved black lettering or alternately, in the case of indoor circuit breakers, starters, etc. of transparent plastic material with suitably coloured lettering engraved on the back.
- 3.8.3 Each equipment shall be provided with nameplate or label designating the service of the particular equipment. The inscriptions shall be approved by the Employer or as detailed in appropriate section of the technical specifications.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- 3.8.4 The rated current, extended current rating and rated thermal current shall be clearly indicated in the name plate in case of current transformer.
- 3.8.5 Rated voltage, voltage factor and intermediate voltage shall be clearly indicated on the nameplate in case of capacitor voltage transformer.
- 3.8.6 Each switch shall have a clear inscription identifying its function. Switches shall also have a clear inscription of each position indication.
- 3.8.7 All such plates, instruction plates, etc. shall be bilingual with Hindi inscription first, followed by English. Alternatively, two separate plates one with Hindi and the other with English inscriptions may be provided.
- 3.8.8 All segregated phases of conductors or bus ducts, indoor or outdoor, shall be provided with coloured phase plates to clearly identify the phase of the system.

3.9 GALVANISING:

- 3.9.1 All exposed ferrous parts shall be hot dip galvanised as per IS:2629 & IS:2633, Galvanising shall be uniform, clean, smooth continuous and free from acid spots. Should the galvanising of the sample be found defective, the entire batch of steel shall have to be re-galvanised at bidder's cost.
- 3.9.2 The amount of zinc deposit over threaded portion of the bolts, nuts and screws shall not be less than 300 gms. per sq. meter of surface area. The amount of zinc deposit on washers shall not be less than 340 gms. per sq. meter of surface area or a minimum of 30 microns. The threads shall have extra deposit of zinc which shall be removed by die cutting after the completion of galvanising. The removal of extra zinc shall be carefully done so that threads shall have the required deposits of zinc on them as specified.

3.10 PAINTING

Unless explicitly stated in relevant chapters of the specification, the painting of all electrical equipment shall be as follows:

Epoxy based with suitable additives. The thickness of finish coat shall be minimum 50 microns (minimum total DFT shall be 100 microns). However in case electrostatic process of painting is offered for any electrical equipment, minimum paint thickness of 50 microns shall be acceptable for finish coat. Paint shade shall be as per technical specification.

3.11 QUALITY ASSURANCE PROGRAMME

- 3.11.1 The Bidder shall adopt suitable quality assurance programme to ensure that the equipment and services under the scope of contract whether manufactured or performed within the Bidder's works or at his subcontractor's premises or at the Employer's site or at any other place of work are in accordance with the specifications. Such programmes shall be outlined by the Contractor and shall be finally accepted by the Employer/authorised representative after discussions before the award of the contract. The QA programme shall be generally in line with ISO-9001/IS-14001.

A quality assurance programme of the contractor shall generally cover the following:

- i. His organisation structure for the management and implementation of the proposed quality assurance programme.
- ii. Quality System Manual

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- iii. Design Control System
- iv. Documentation Data Control System
- v. Qualification data for Bidder's key Personnel.
- vi. The procedure for purchase of materials, parts, components and selection of sub-contractor's services including vendor analysis, source inspection, incoming raw-material inspection, verification of materials purchased etc.
- vii. System for shop manufacturing and site erection controls including process controls and fabrication and assembly controls.
- viii. Control of non-conforming items and system for corrective actions and resolution of deviations.
- ix. Inspection and test procedure both for manufacture and field activities.
- x. Control of calibration and testing of measuring testing equipments.
- xi. System for Quality Audits.
- xii. System for identification and appraisal of inspection status.
- xiii. System for authorising release of manufactured product to the Employer.
- xiv. System for handling storage and delivery.
- xv. System for maintenance of records, and
- xvi. Furnishing quality plans for manufacturing detailing out the specific quality control procedure adopted for controlling the quality characteristics relevant to each item of equipment/component as per format enclosed as Annexure-I.

3.12 GENERAL REQUIREMENTS - QUALITY ASSURANCE

- 3.12.1 All materials, components and equipment covered under this specification shall be procured, manufactured, erected, commissioned and tested at all the stages, as per a comprehensive Quality Assurance Programme. An indicative programme of inspection/tests to be carried out by the Bidder for some of the major items is given in the respective technical specification. This is, however, not intended to form a comprehensive programme as it is the Bidder's responsibility to draw up and implement such programme duly approved by the Employer. The detailed Quality Plans for manufacturing and field activities should be drawn up by the Bidder and will be submitted to Employer for approval.
- 3.12.2 Manufacturing Quality Plan will detail out for all the components and equipment, various tests/inspection, to be carried out as per the requirements of this specification and standards mentioned therein and quality practices and procedures followed by Bidder's/ Sub-contractor's/ sub-supplier's Quality Control Organisation, the relevant reference documents and standards, acceptance norms, inspection documents raised etc., during all stages of materials procurement, manufacture, assembly and final testing/performance testing. The Quality Plan shall be submitted on electronic media e.g. E-mail in addition to hard copy, for review. Once the same is finalised, hard copies shall be submitted for approval. After approval the same shall be submitted in compiled form on CD ROM.
- 3.12.3 The Bidder shall also furnish copies of the reference documents/plant standards/acceptance norms/tests and inspection procedure etc., as referred in Quality Plans along with Quality Plans. These Quality Plans and reference documents/standards etc. will be subject to Employer's approval without which manufacturer shall not proceed.
- 3.12.4 These approved documents shall form a part of the contract. In these approved Quality Plans, Employer shall identify customer hold points (CHP), i.e. test/checks which shall be carried out in presence of the Employer's Project Manager or his authorised representative and beyond which the work will not proceed without consent of Employer/Authorised representative in writing. All deviations to this specification, approved quality plans and applicable standards must be documented and referred to Employer along with technical justification for approval and dispositioning.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- 3.12.5 No material shall be despatched from the manufacturer's works before the same is accepted subsequent to pre-despatch final inspection including verification of records of all previous tests/inspections by Employer's Project Manager/Authorised representative and duly authorised for despatch by issuance of Material Dispatch Clearance Certificate (MDCC).
- 3.12.6 All material used for equipment manufacture including casting and forging etc. shall be of tested quality as per relevant codes/standards. Details of results of the tests conducted to determine the mechanical properties, chemical analysis and details of heat treatment procedure recommended and actually followed shall be recorded on certificates and time temperature chart. Tests shall be carried out as per applicable material standards and/or agreed details.
- 3.12.7 All welding and brazing shall be carried out as per procedure drawn and qualified in accordance with requirements of ASME Section IX/BS-4870 or other International equivalent standard acceptable to the Employer.
- 3.12.8 All welding/brazing procedures shall be submitted to the Employer or its authorised representative for approval prior to carrying out the welding/brazing.
- 3.12.9 All brazers, welders and welding operators employed on any part of the contract either in Bidder's/his sub-contractor's works or at site or elsewhere shall be qualified as per ASME Section-IX or BS-4871 or other equivalent International Standards acceptable to the Employer.
- 3.12.10 Test results or qualification tests and specimen testing shall be furnished to the Employer for approval. However, where required by the Employer, tests shall be conducted in presence of Employer/authorised representative.
- 3.12.11 For all pressure parts and high pressure piping welding, the latest applicable requirements of the IBR (Indian Boiler Regulations) shall also be essentially complied with. Similarly, any other statutory requirements for the equipments/systems shall also be complied with. On all back-gauged welds MPI/LPI shall be carried before seal welding.
- 3.12.12 All the heat treatment results shall be recorded on time temperature charts and verified with recommended regimes.
- 3.12.13 No welding shall be carried out on cast iron components for repair.
- 3.12.14 Unless otherwise proven and specifically agreed with the Employer, welding of dissimilar materials and high alloy materials shall be carried out at shop only.
- 3.12.15 All non-destructive examination shall be performed in accordance with written procedures as per International Standards. The NDT operator shall be qualified as per SNT-TC-IA (of the American Society of non-destructive examination). NDT shall be recorded in a report which includes details of methods and equipment used, result/evaluation, job data and identification of personnel employed and details of co-relation of the test report with the job. In general all plates of thickness greater than 40mm & for pressure parts plates of thickness equal to or greater than 25mm shall be ultrasonically tested otherwise as specified in respective equipment specification. All bar stock/Forging of diameter equal to or greater than 40mm shall be ultrasonically tested.
- 3.12.16 The Bidder shall list out all major items/ equipment/ components to be manufactured in house as well as procured from sub-contractors (BOI). All the subcontractor proposed by the Contractor for procurement of major bought out items including castings, forging, semi-finished and finished components/equipment etc., list of which shall be drawn up by the Bidder and finalised with the Employer, shall be subject to Employer's approval. The Bidder's proposal shall include vendor's facilities established at the respective works, the process

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

capability, process stabilization, QC systems followed, experience list, etc. along with his own technical evaluation for identified subcontractors enclosed and shall be submitted to the Employer for approval within the period agreed at the time of pre-awards discussion and identified in "DR" category prior to any procurement. Such vendor approval shall not relieve the Bidder from any obligation, duty or responsibility under the contract.

- 3.12.17 For components/equipment procured by the Bidders for the purpose of the contract, after obtaining the written approval of the Employer, the Bidder's purchase specifications and inquiries shall call for quality plans to be submitted by the suppliers. The quality plans called for from the subcontractor shall set out, during the various stages of manufacture and installation, the quality practices and procedures followed by the vendor's quality control organisation, the relevant reference documents/standards used, acceptance level, inspection of documentation raised, etc.
- 3.12.18 Employer reserves the right to carry out quality audit and quality surveillance of the systems and procedures of the Bidder's or their sub-contractor's quality management and control activities. The Bidder shall provide all necessary assistance to enable the Employer carry out such audit and surveillance.
- 3.12.19 The Bidder shall carry out an inspection and testing programme during manufacture in his work and that of his sub-contractor's and at site to ensure the mechanical accuracy of components, compliance with drawings, conformance to functional and performance requirements, identity and acceptability of all materials parts and equipment. Bidder shall carry out all tests/inspection required to establish that the items/equipments conform to requirements of the specification and the relevant codes/standards specified in the specification, in addition to carrying out tests as per the approved quality plan.
- 3.12.20 Quality audit/surveillance/approval of the results of the tests and inspection will not, however, prejudice the right of the Employer to reject the equipment if it does not comply with the specification when erected or does not give complete satisfaction in service and the above shall in no way limit the liabilities and responsibilities of the Bidder in ensuring complete conformance of the materials/equipment supplied to relevant specification, standard, data sheets, drawings, etc.
- 3.12.21 For all spares and replacement items, the quality requirements as agreed for the main equipment supply shall be applicable.
- 3.12.22 Repair/rectification procedures to be adopted to make the job acceptable shall be subject to the approval of the Employer/ authorised representative.
- 3.12.23 Environmental Stress Screening

All solid state electronic system / equipment / sub assembly shall be free from infant mortile components. For establishing the compliance to this requirement, the Bidder / sub – contractor should meet the following.

1. The Bidder / Sub – contractor shall furnish the established procedure being followed for eliminating infant mortile components. The procedure followed by the Contractor / Sub – contractor should be substantiated along with the statistical figures to validate the procedure being followed. The necessary details as required under this clause shall be furnished at the stage of QP finalization.

Or

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

In case the Bidder / Sub – contractor do not have any established procedure to eliminate infant mortile components then two or 10% whichever is less, most densely populated Panels shall be tested for Elevated Temperature Cycle Test as per the following procedure.

Elevated Temperature Test Cycle

During the elevated temperature test which shall be for 48 hours, the ambient temperature shall be maintained at 50° C. The equipment shall be interconnected with devices and kept under energized conditions so as to repeatedly perform all operations it is expected to perform in actual service with load on various components being equal to those which will be experienced in actual service.

During the elevated temperature test the cubicle doors shall be closed (or shall be in the position same as they are supposed to be in the field) and inside temperature in the zone of highest heat dissipating components / modules shall be monitored. The temperature rise inside the cubicle should not exceed 10° C above the ambient temperature at 50° C.

In case of any failure during the test cycle, the further course of action should be mutually discussed for demonstrating the intent of the above requirement.

Burn In Test Cycle

The test shall be conducted on all the panels fully assembled and wired including the panels having undergone the above mentioned elevated temperature test.

The period of Burn in Test Cycle shall be 120 hrs and process shall be similar to the elevated temperature test as above except that the temperature shall be reduced to the ambient temperature prevalent at that time.

During the above tests, the process I/O and other load on the system shall be simulated by simulated inputs and in the case of control systems, the process which is to be controlled shall also be simulated. Testing of individual components or modules shall not be acceptable.

During the Burn in Test the cubicle doors shall be closed (or shall be in the position same as they are supposed to be in the field) and inside temperature in the zone of highest heat dissipating components / modules shall be monitored. The temperature rise inside the cubicle should not exceed 10° C above the ambient temperature.

The Bidder / Sub-contractor shall carry out routine test on 100% item at Bidder's / sub-contractor's works. The quantum of check / test for routine & acceptance test by employer shall be generally as per criteria / sampling plan defined in referred standards. Wherever standards have not been mentioned quantum of check / test for routine / acceptance test shall be as agreed during detailed engineering stage.

3.13 QUALITY ASSURANCE DOCUMENTS

The Contractor shall be required to submit two hard copies and two sets on CDROM of the following Quality Assurance Documents as identified in respective quality plan with tick (✓) mark.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

Each QA Documentation shall have a project specific Cover Sheet bearing name & identification number of equipment and including an index of its contents with page control on each document.

The QA Documentation file shall be progressively completed by the Supplier's sub-supplier to allow regular reviews by all parties during the manufacturing.

The final quality document will be compiled and issued at the final assembly place of equipment before dispatch. However CD-Rom may be issued not later than three weeks.

3.13.1 Typical contents of Quality Assurance Document are as below:-

- i) Quality Plan,
- ii) Material mill test reports on components as specified by the specification and approved Quality Plans.
- iii) Manufacturer / works test reports/results for testing required as per applicable codes and standard referred in the specification and approved Quality Plans.
- iv) Non-destructive examination results /reports including radiography interpretation reports. Sketches/drawings used for indicating the method of traceability of the radiographs to the location on the equipment.
- v) Heat Treatment Certificate/Record (Time- temperature Chart)
- vi) All the accepted Non-conformance Reports (Major/Minor) / deviation, including complete technical details / repair procedure).
- vii) CHP / Inspection reports duly signed by the Inspector of the Employer and Contractor for the agreed Customer Hold Points.
- viii) Certificate of Conformance (COC) whoever applicable.
- ix) MDCC

3.13.2 Before dispatch/ commissioning of any equipment, the Supplier shall make sure that the corresponding quality document or in the case of protracted phased deliveries, the applicable section of the quality document file is completed. The supplier will then notify the Inspector regarding the readiness of the quality document (or applicable section) for review.

- i) If the result of the review carried out by the Inspector of the Quality document (or applicable section) is satisfactory, the Inspector shall stamp the quality document (or applicable section) for release.
- ii) If the quality document is unsatisfactory, the Supplier shall endeavour to correct the incompleteness, thus allowing to finalize the quality document (or applicable section) by time compatible with the requirements as per contract documents. When it is done, the quality document (or applicable section) is stamped by the Inspector.
- iii) If a decision is made for dispatch, whereas all outstanding actions cannot be readily cleared for the release of the quality document by that time, the supplier shall immediately, upon shipment of the equipment, send a copy of the quality document Review Status signed by the Supplier Representative to the Inspector and notify of the committed date for the completion of all outstanding actions & submission. The Inspector shall stamp the quality document for applicable section when it is effectively completed. The submission of QA documentation package shall not be later than 3 weeks after the dispatch of equipment.

3.14 TRANSMISSION OF QUALITY DOCUMENTS

As a general rule, two hard copies of the quality document and Two CD ROMs shall be issued to the Employer on release of QA Documentation by Inspector. One set of quality document

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

shall be forwarded to Corporate Quality Assurance Department and other set to respective Site.

For the particular case of phased deliveries, the complete quality document to the Employer shall be issued not later than 3 weeks after the date of the last delivery similarly as stated above.

3.15 INSPECTION, TESTING & INSPECTION CERTIFICATE

- 3.15.1 The word 'Inspector' shall mean the Project Manager and/or his authorised representative and/or an outside inspection agency acting on behalf of the Employer to inspect and examine the materials and workmanship of the works during its manufacture or erection.
- 3.15.2 The Project Manager or his duly authorised representative and/or an outside inspection agency acting on behalf of the Employer shall have access at all reasonable times to inspect and examine the materials and workmanship of the works during its manufacture or erection and if part of the works is being manufactured or assembled on other premises or works, the Bidder shall obtain for the Project Manager and for his duly authorised representative permission to inspect as if the works were manufactured or assembled on the Bidder's own premises or works.
- 3.15.3 The Bidder shall give the Project Manager/Inspector fifteen (15) days written notice of any material being ready for testing. Such tests shall be to the Bidder's account except for the expenses of the Inspector's. The Project Manager/Inspector, unless the witnessing of the tests is virtually waived and confirmed in writing, will attend such tests within fifteen (15) days of the date on which the equipment is noticed as being ready for test/inspection failing which the Bidder may proceed with test which shall be deemed to have been made in the inspector's presence and he shall forthwith forward to the inspector duly certified copies of test reports in two (2) copies.
- 3.15.4 The Project Manager or Inspector shall within fifteen (15) days from the date of inspection as defined herein give notice in writing to the Bidder, or any objection to any drawings and all or any equipment and workmanship which is in his opinion not in accordance with the contract. The Bidder shall give due consideration to such objections and shall either make modifications that may be necessary to meet the said objections or shall inform in writing to the Project Manager/Inspector giving reasons therein, that no modifications are necessary to comply with the contract.
- 3.15.5 When the factory tests have been completed at the Bidder's or subcontractor's works, the Project Manager /Inspector shall issue a certificate to this effect fifteen (15) days after completion of tests but if the tests are not witnessed by the Project Manager /Inspectors, the certificate shall be issued within fifteen (15) days of the receipt of the Contractor's test certificate by the Project Manager /Inspector. Project Manager /Inspector to issue such a certificate shall not prevent the Bidder from proceeding with the works. The completion of these tests or the issue of the certificates shall not bind the Employer to accept the equipment should it, on further tests after erection be found not to comply with the contract.
- 3.15.6 In all cases where the contract provides for tests whether at the premises or works of the Bidder or any sub-contractor, the Bidder, except where otherwise specified shall provide free of charge such items as labour, material, electricity, fuel, water, stores, apparatus and instruments as may be reasonably demanded by the Project Manager /Inspector or his authorised representatives to carry out effectively such tests on the equipment in accordance with the Bidder and shall give facilities to the Project Manager/Inspector or to his authorised representative to accomplish testing.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- 3.15.7 The inspection by Project Manager / Inspector and issue of Inspection Certificate thereon shall in no way limit the liabilities and responsibilities of the Contractor in respect of the agreed Quality Assurance Programme forming a part of the contract.
- 3.15.8 To facilitate advance planning of inspection in addition to giving inspection notice, the Bidder shall furnish quarterly inspection programme indicating schedule dates of inspection at Customer Hold Point and final inspection stages. Updated quarterly inspection plans will be made for each three consecutive months and shall be furnished before beginning of each calendar month.
- 3.15.9 All inspection, measuring and test equipments used by contractor shall be calibrated periodically depending on its use and criticality of the test/measurement to be done. The Bidder shall maintain all the relevant records of periodic calibration and instrument identification, and shall produce the same for inspection by NTPC. Wherever asked specifically, the contractor shall re-calibrate the measuring/test equipments in the presence of Project Manager / Inspector.

3.16 PACKAGING & TRANSPORTATION

All the equipments shall be suitably protected, coated, covered or boxed and crated to prevent damage or deterioration during transit, handling and storage at Site till the time of erection. While packing all the materials, the limitation from the point of view of the sizes of railway wagons available in India should be taken account of. The Bidder shall be responsible for any loss or damage during transportation, handling and storage due to improper packing. The Bidder shall ascertain the availability of Railway wagon sizes from the Indian Railways or any other agency concerned in India well before effecting despatch of equipment. Before despatch it shall be ensured that complete processing and manufacturing of the components is carried out at shop, only restricted by transport limitation, in order to ensure that site works like grinding, welding, cutting & preassembly to bare minimum. The Employer's Inspector shall have right to insist for completion of works in shops before despatch of materials for transportation.

3.17 CLAMPS AND CONNECTORS INCLUDING TERMINAL CONNECTORS

- 3.17.1 The material of clamps and connectors shall be Aluminium alloy casting conforming to designation A6 of IS:617 for connecting to equipment terminals and conductors of aluminium. In case the terminals are of copper, the same clamps/connectors shall be used with 2mm thick bimetallic liner.
- 3.17.2 The material of clamps and connectors shall be Galvanised mild steel for connecting to shield wire.
- 3.17.3 Bolts, nuts and plain washers shall be hot dip galvanised mild steel for sizes M12 and above. For sizes below M12, they shall be electro-galvanised mild steel. The spring washers shall be electro-galvanised mild steel.
- 3.17.4 All castings shall be free from blow holes, surface blisters, cracks and cavities. All sharp edges and corners shall be rounded off to meet specified corona and radio interference requirements.
- 3.17.5 They shall have same current rating as that of the connected equipment. All current carrying parts shall be at least 10 mm thick. The connectors shall be manufactured to have minimum contact resistance.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

- 3.17.6 Flexible connectors, braids or laminated strips shall be made up of copper/aluminium.
- 3.17.7 Current rating and size of terminal/conductor for which connector is suitable shall be put on a suitable sticker on each component which should last atleast till erection time.

3.18 SPACERS

- 3.18.1 Spacers shall conform to IS: 10162. They shall be of non-magnetic material except nuts and bolts, which shall be of hot dip galvanised mild steel.
- 3.18.2 Spacers shall generally meet the requirements of clamps and connectors as specified above. Its design shall take care of fixing and removing during installation and maintenance.
- 3.18.3 In addition to the type tests as per IS: 10162, clamp slip test should have been conducted. In this test the sample shall be installed on test span of twin/quad bundle string at a tension of 44.2kN (4500 kg). One of the clamps when subjected to a longitudinal pull of 2.5kN (250 kg) parallel to the axis of conductor shall not slip, i.e. permanent displacement between conductor and clamp after test shall not exceed 1.0 mm. This test should have been performed on all other clamps of the sample.

3.19 BUSHINGS, HOLLOW COLUMN INSULATORS, SUPPORT INSULATORS, AND DISC INSULATORS

- 3.19.1 Bushings shall be manufactured and tested in accordance with IS: 2099 & IEC: 60137 while hollow column insulators shall be manufactured and tested in accordance with IEC62155/IS 5284. The support insulators shall be manufactured and tested as per IS: 2544/IEC 60168/IEC 60273. The insulators shall also conform to IEC 60815 as applicable having alternate long and short sheds.
Support insulators/ bushings/ hollow column insulators shall be designed to have ample insulation, mechanical strength and rigidity for the conditions under which they will be used.
- 3.19.2 Porcelain used shall be homogenous, free from laminations, cavities and other flaws or imperfections that might affect the mechanical or dielectric quality and shall be thoroughly vitrified, tough and impervious to moisture.
- 3.19.3 Glazing of the porcelain shall be uniform brown in colour, free from blisters, burns and other similar defects.
- 3.19.4 The design of the insulator shall be such that stresses due to expansion and contraction in any part of the insulator shall be lead to deterioration. All ferrous parts shall be hot dip galvanised.
- 3.19.5 Post type insulators shall consist of a porcelain part permanently secured in metal base to be mounted on supporting structures. They shall be capable of being mounted upright. They shall be designed to withstand all shocks to which they may be subjected to during operation of the associated equipment.
- 3.19.6 Bushing porcelain shall be robust and capable of withstanding the internal pressures likely to occur in service. The design and location of clamps, the shape and the strength of the porcelain flange securing the bushing to the tank shall be such that there is no risk of fracture. All portions of the assembled porcelain enclosures and supports other than gaskets, which may in any way be exposed to the atmosphere shall be composed of completely non hygroscopic material such as metal or glazed porcelain.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

3.19.7 All iron parts shall be hot dip galvanised and all joints shall be air tight. Surface of joints shall be trued, porcelain parts by grinding and metal parts by machining. Insulator/ bushing design shall be such as to ensure a uniform compressive pressure on the joints.

3.19.8 In accordance with the requirement stipulated elsewhere, bushing, hollow column insulators and support insulators shall conform to type tests and shall be subjected to routine tests and acceptance test/sample test in accordance with relevant standards.

3.20 CONTROL CABINETS, JUNCTION BOXES, TERMINAL BOXES & MARSHALLING BOXES FOR OUTDOOR EQUIPMENT.

3.20.1 All types of control cabinets, junction boxes, marshaling boxes, lighting panels, terminal boxes, operating mechanism boxes, Kiosks etc. shall generally conform to IS:5039, IS:8623 and IEC:60439 as applicable.

3.20.2 They shall be of Stainless steel or Aluminium. The thickness of Stainless steel shall be minimum 1 mm. The thickness of aluminium shall be minimum 3 mm and shall provide rigidity. Top of the boxes shall be sloped towards the rear of the box.

3.20.3 BAY MARSHALLING BOX

Bay Marshaling Box located at a convenient location to receive and distribute cables shall be provided as required. It shall meet all the requirements as specified for cabinets/boxes.

It shall have three separate distinct compartments for following purposes:

- To receive two incoming 415V, three phase, AC supplies controlled by 100A four pole MCBs with auto changeover provision, and to distribute five (5) three phase ac supplies controlled by 32A four pole MCBs. It shall also be provided with 63A, 3 phase 4 pin industrial grade receptacle with rotary switch.

- To receive three phase incoming from first compartment and to distribute ten (10) single phase ac supplies controlled by 16A two pole MCBs.

- 150 nos. terminal blocks in vertical formation for interlocking facility.

3.20.4 AUXILIARY SWITCH

The auxiliary switch shall conform of following type tests:

- a) Electrical endurance test - A minimum of 1000 operations for 2A. D.C. with a time constant greater than or equal to 20 milliseconds with a subsequent examination of mV drop/ visual defects/ temperature rise test.
- b) Mechanical endurance test - A minimum of 5000 operations with a subsequent checking of contact pressure test/ visual examination
- c) Heat run test on contacts
- d) IR/HV test, etc.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

3.21 CABLE GLANDS AND LUGS/FERRULES

- 3.21.1 Cable shall be terminated using double compression type cable glands. Testing requirements of Cable glands shall conform to BS:6121 and gland shall be of robust construction capable of clamping cable and cable armour (for armoured cables) firmly without injury to insulation. Cable glands shall be made of heavy duty brass machine finished and nickel chrome plated. Thickness of plating shall not be less than 10 micron. All washers and hardware shall also be made of brass with nickel chrome plating Rubber components shall be of neoprene or better synthetic material and of tested quality. Cable glands shall be suitable for the sizes of cable supplied/erected.
- 3.21.2 Cable lugs/ferrules for power cables shall be tinned copper solderless crimping type suitable for aluminium compacted conductor cables. Cable lugs and ferrules for control cables shall be tinned copper type. The cable lugs for control cables shall be provided with insulating sleeve and shall suit the type of terminals provided on the equipments. Cable lugs and ferrule shall conform to DIN standards.

3.22 CONDUITS, PIPES AND ACCESSORIES

- 3.22.1 The bidder shall supply and install all rigid conduits, mild steel pipes, flexible conduits, hume pipes, etc. including all necessary sundry materials, such as tees, elbows, check nuts, bushing reduces, enlargers, wooden plugs, coupling caps, nipples, gland sealing fittings, pull boxes, etc.
- 3.22.2 The size of the conduit/pipe shall be selected to limit the fill to a maximum of 40%. All conduits/pipes shall have their ends closed by caps until cables are pulled. After cables are pulled, the ends of conduits/pipes shall be sealed in an approved manner to prevent damage to threaded portions and entrance of moisture and foreign materials.
- 3.22.3 PVC conduits shall be of high impact, heavy gauge (at least class 2) conduit conforming to BS-4607.
- 3.22.4 The outer surface of the steel conduits shall be coated with hot-dip zinc and chromate conversion coatings. The inner surface shall have silicone epoxy ester coating for easy cable pulling. Mild steel pipes shall be hot-dip galvanized. All rigid conduits/pipes shall be of a reputed make.
- 3.22.5 The hume pipes and accessories shall be of reinforced concrete conforming to class NP2 of IS-458. All tests on hume pipes shall be conducted as per IS-458.
- 3.22.6 Flexible conduits shall be of heat-resistant lead coated steel, water-leak, fire and rust proof.

3.23 MOTORS

The voltage level for motors shall be as follows:

- | | |
|----------------------------------|--|
| a) Upto 0.2 KW | : Single phase 240V AC / 3 phase 415V AC |
| b) Above 0.2 KW and upto 200 KW | : 3 phase, 415V AC |
| c) Above 200 KW and upto 1500 KW | : 3 phase, 3.3 kV AC |
| d) Above 1500 KW | : 11 kV |

The bidder may adopt 415V/3.3 KV for the drives rated in the range of 160-210 KW.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

The voltage rating of the drives indicated above is for basic guideline.

- 3.23.1 All motors shall conform to IEC-60034-5 / IS Standard and with principal dimensions in accordance with IEC 60072-1 (1991), IEC 60072-2 (1990) and IEC 60072-3 (1994).
- 3.23.2 All equipment shall be suitable for rated frequency of 50 Hz with a variation of +3% & -5%, and 10% combined variation of voltage and frequency unless specifically brought out in the specification
- 3.23.3 Paint shade shall be as per RAL 5012 (Blue) for indoor and outdoor equipment.
- 3.23.4 Degree of Protection

Degree of protection for various enclosures as per IEC60034-05 shall be as follows:

Indoor motors - IP 54
Outdoor motors - IP 55
Cable box-indoor area - IP 54
Cable box-Outdoor area - IP 55

- 3.23.5 Type:

AC Motors:

- a) Squirrel cage induction motor suitable for direct-on-line starting.
- b) Continuous duty LT motors upto 200 KW Output rating (at 50 deg.C ambient temperature), shall be Premium Efficiency class-IE3, conforming to IS 12615, or IEC:60034-30.
- c) Crane duty motors shall be squirrel cage Induction motor as per the requirement.
- d) Motor operating through variable frequency drives shall be suitable for inverter duty. Also these motors shall comply the requirements stipulated in IEC: 60034-18-41 and IEC: 60034-18-42 as applicable.

DC Motors Shunt wound

3.24 AUXILIARY SWITCH

The auxiliary switch shall conform of following type tests:

- a) Electrical endurance test - A minimum of 1000 operations for 2A. D.C. with a time constant greater than or equal to 20 milliseconds with a subsequent examination of mV drop/ visual defects/ temperature rise test.
- b) Mechanical endurance test - A minimum of 5000 operations with a subsequent checking of contact pressure test/ visual examination
- c) Heat run test on contacts
- d) IR/HV test, etc.

3.25 LAMPS AND SOCKETS

3.25.1 Lamps:

All incandescent lamps shall use a socket base as per IS-1258, except in the case of signal lamps.

3.25.2 Sockets

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

All sockets (convenience outlets) shall be suitable to accept both 5 Amp & 15 Amp pin round Standard Indian plugs. They shall be switched sockets with shutters.

3.25.3 Hand Lamp:

A 240 Volts, single Phase, 50 Hz AC plug point shall be provided in the interior of each cubicle with ON-OFF Switch for connection of hand lamps.

3.26 SWITCHES & FUSES:

Each control panel shall be provided with necessary arrangements for receiving, distributing, isolating and fusing of DC and AC supplies for various control, signaling, lighting and space heater circuits. The incoming and sub-circuits shall be separately provided with switch-fuse units. Selection of the main and sub-circuit fuse ratings shall be such as to ensure selective clearance of sub-circuit faults. Potential circuits for relaying and metering shall be protected by HRC fuses.

All fuses shall be of HRC cartridge type conforming to IS 9228 mounted on plug-in type fuse bases. Miniature circuit breakers with thermal Protection and alarm contacts will also be accepted. All accessible live connection to fuse bases shall be adequately shrouded. Fuses shall have operation indicators for indicating blown fuse condition. Fuse carrier base shall have imprints of the fuse rating and voltage.

All control switches shall be of rotary type. Toggle/piano switches shall not be accepted.

3.27 TYPE, ROUTINE & ACCEPTANCE TESTS:

3.10.1 TYPE TEST REQUIREMENTS FOR EQUIPMENTS OTHER THAN GIS

- a) All equipments to be supplied shall be of type tested design. During detail engineering, the bidder shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out not earlier than ten years prior to the date of techno-commercial bid opening (03-March-2017). These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a Client.
- b) However if contractor is not able to submit report of the type test(s) conducted not earlier than ten years prior to the date of techno-commercial bid opening (03-March-2017)., or in the case of type test report(s) are not found to be meeting the specification requirements, the bidder shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client/ owners representative and submit the reports for approval.
- c) All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.

3.28 CORONA AND RIV TESTS AND SEISMIC WITHSTAND TEST:

- a) The corona and RIV tests shall confirm to the requirements as per Annexure A.
- b) The seismic withstand test shall conform to requirements as per Annexure B.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

3.29 Enclosures:

1. ANNEXURE- A - CORONA AND RADIO INTERFERENCE VOLTAGE (RIV) TEST
2. ANNEXURE- B - SEISMIC WITHSTAND TEST
3. ANNEXURE- I – MQP (NTPC format)
4. ANNEXURE- II – QUALITY ASSURANCE FOR SWITCHYARD

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

ANNEXURE – A

CORONA AND RADIO INTERFERENCE VOLTAGE (RIV) TEST

1.0 General

Unless otherwise stipulated, all equipment together with its associated connectors where applicable shall be tested for external corona both by observing the voltage level for the extinction of visible corona under falling power frequency voltage and measurement of radio interference voltage (RIV).

2.0 Test Levels

The test voltage levels for measurement of external RIV and for corona extinction voltage are listed under the relevant clauses of the specification.

3.0 Test Methods for RIV (400kV):

3.1 RIV tests shall be made according to measuring circuit as per International Special committee on Radio Interference (CISPR) Publication 16 -1 (1993) Part – I. The measuring circuit shall preferably be tuned to frequency with 10 % of 0.5 MHz but other frequencies in the range of 0.5 MHZ to 2 MHz may be used, the measuring frequency being recorded. The result shall be in microvolts.

3.2 Alternatively, RIV tests shall be in accordance with NEMA standard Publication No. 107 – 1964 except otherwise noted herein.

3.3 In measurement of RIV temporary additional external corona shielding may be provided. In measurement of RIV only standard fittings of identical type supplied with the equipment and a simulation of the connections as used in the actual installation will be permitted in the vicinity within 3.5 meters of terminals.

3.4 Ambient noise shall be measured before and after each series of tests to ensure that there is no variation in ambient noise level. If variation is present, the lowest ambient noise level will form basis for the measurements. RIV levels shall be measured at increasing and decreasing voltages of 85%, 100%, 115% and 130% for the specified RIV test voltage for all equipment unless otherwise specified. The specified RIV test voltage for 765kV, 400kV, 220kV & 132kV is listed in the detailed specification together with maximum permissible RIV level in microvolts.

3.5 The metering instruments shall be as per CISPR recommendations or equivalent device so long as it has been used by other testing authorities.

3.6 The RIV measurement may be made with a noise meter. A calibration procedure of the frequency to which noise meter shall be tuned shall establish the ratio of voltage at the high voltage terminal to the voltage read by the noise meter.

4.0 Test Methods for visible Corona (400kV AIS only)

The purpose of this test is to determine the corona extinction voltage of the apparatus, connectors etc. The test shall be carried out in the same manner as RIV test described above with the exception that RIV measurements are not required during test and a search technique shall be used near the onset and extinction voltage, when the test voltage is raised and lowered to determine their precise values. The test voltage shall be raised to 130 % of RIV test voltage

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

ANNEXURE – A

and maintained there for five minutes. In case corona inception does not take place at 130 %, the voltage level shall be raised till inception of corona or rated voltage whichever is lower. The voltage will then be decreased slowly until all visible corona disappears. The test procedure shall be repeated at least 4 times with corona inception and extinction voltage recorded each time. The corona extinction voltage for purposes of determining compliance with the specification shall be the lowest of the four values at which the visible corona (negative or positive polarity) disappears.

PROJECT: PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3X 800MW)	
CUSTOMER: PATRATU VIDYUT UTPADAN NIGAM LTD. (PVUNL) (A Subsidiary of NTPC in Joint Venture with JBVNL)	
Technical Specification	TB-397-316-000 Rev 00
Section-3: Project Details and General Specification	

ANNEXURE – B

SEISMIC WITHSTAND TEST (400kV AIS only)

- a.) The seismic withstand test on the complete equipment (except BPI) shall be carried out along with supporting structure.
- b.) The supplier shall arrange to transport the structure from his purchaser's premises / owner's sites for purpose of seismic withstand test only.
- c.) The seismic level specified shall be applied at the base of the structure. The accelerometers shall be provided at the terminal pad of the equipment and at any other point as agreed by the owner. The seismic test shall be carried out in all possible combinations of the equipment. The seismic test procedure shall be furnished for approval of the purchaser.

ANNEXURE-I

MFGR.'s LOGO	MANUFACTURER'S NAME AND ADDRESS	MANUFACTURING QUALITY PLAN		PROJECT :
		ITEM :	QP NO.:	PACKAGE :
		SUB-SYSTEM:	REV.NO.:	CONTRACT NO. :
			DATE:	MAIN-SUPPLIER:
			PAGE: OF....	

SL. NO	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD		AGENCY			REMARKS
					M	C / N						M	C	
1.	2.	3.	4.	5.	6.		7.	8.	9.	D*	**	10.		11.

		LEGEND: * RECORDS, IDENTIFIED WITH "TICK" (✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION. ** M: MANUFACTURER/SUB-SUPPLIER C: MAIN SUPPLIER, N: NTPC P: PERFORM W: WITNESS AND V: VERIFICATION. AS APPROPRIATE, CHP: NTPC SHALL IDENTIFY IN COLUMN "N" AS 'W'	 FOR NTPC USE	DOC. NO.:		REV..... CAT.....	
MANUFACTURER/ SUB-SUPPLIER	MAIN-SUPPLIER						
SIGNATURE				REVIEWED BY	APPROVED BY	APPROVAL SEAL	

FORMAT NO.: QS-01-QAI-P-09/F1-R1

1/1

ENGG. DIV./QA&I

EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800MW)	TECHNICAL SPECIFICATION SECTION – VI, PART-C BID DOC. NO.: CS-9585-001-2	GENERAL TECHNICAL REQUIREMENT	PAGE 78 OF 111
---	--	-------------------------------	----------------

ANNEXURE-II

SUPPLIER'S LOGO	SUPPLIER'S NAME AND ADDRESS	FIELD QUALITY PLAN		PROJECT :
		ITEM :	QP NO.:	PACKAGE :
		SUB-SYSTEM:	REV. NO.:	CONTRACT NO. :
			DATE:	MAIN-SUPPLIER:
			PAGE: OF....	

SL. NO	ACTIVITY AND OPERATION	CHARACTERISTICS / INSTRUMENTS	CLASS OF CHECK #	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD		REMARKS
1.	2.	3.	4.	5.	6.	7.	8.	9.	D*	10.

		LEGEND: * RECORDS, IDENTIFIED WITH “TICK” (✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION. LEGEND TO BE USED: CLASS # : A = CRITICAL, B=MAJOR, C=MINOR; ‘A’ SHALL BE WITNESSED BY NTPC FQA, ‘B’ SHALL BE WITNESSED BY NTPC ERECTION / CONSTRUCTION DEPTT. AND ‘C’ SHALL BE WITNESSED BY MAIN SUPPLIER (A & B CHECK SHALL BE NTPC CHP STAGE)		DOC. NO.:			REV.....		
MANUFACTURER/ SUB-SUPPLIER	MAIN-SUPPLIER								
SIGNATURE				FOR NTPC USE	REVIEWED BY	APPROVED BY	APPROVAL SEAL		

FORMAT NO.: QS-01-QAI-P-09/F2-R1

1/1

ENGG. DIV./QA&I

EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800MW)	TECHNICAL SPECIFICATION SECTION – VI, PART-C BID DOC.NO.: CS-9585-001-2	GENERAL TECHNICAL REQUIREMENT	PAGE 79 OF111
---	---	-------------------------------	---------------



400kV GIS at Patratu Super Thermal Power Project
Expansion Phase –I (3X800 MW).
Illumination System
Doc. No. : TB-397-316-020 Rev. 00

SECTION-4

GUARANTEED TECHNICAL PARTICULARS

Refer NTPC format: SUB-SECTION-DB10, STATION LIGHTING (4 Sheets).

SUB-SECTION-DB10

STATION LIGHTING

**EPC PACKAGE FOR
PATRATU SUPER THERMAL POWER STATION EXPANSION
PHASE –I (3X 800MW)**

**TECHNICAL SPECIFICATION
SECTION – VI, PART-G
BID DOC NO. : CS-9585-001-2**

CLAUSE NO.	Bidder's Name				
1.00.00	Lighting Panel a) Make b) Applicable standard c) Enclosure d) Degree of protection i) Indoor ii) Outdoor				
2.00.00	Miniature circuit Breaker a) Make b) Type designation c) Applicable standard d) Rated current/ voltage e) Breaking capacity at 0.6 p.f. f) Catalogue attached as annexure no.				
3.00.00	Lighting fixtures & Accessories a) Make of lighting fixture & accessories b) Catalogue for each type of fixture attached as annexure no c) Applicable Standard				
4.00.00	Receptacles/Sockets a) Make b) Type c) Applicable standard				
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)		BID DOC. NO.: CS-9585-001-2	TECHNICAL DATA SHEET SECTION –VI, PART-G	DB-10: STATION LIGHTING	Page 1 of 3


CLAUSE NO.	Bidder's Name				
5.00.00	Junction Boxes a) Make b) Type c) Material d) Applicable standard				
6.00.00	Rigid steel Conduits/Fittings & Accessories a) Make b) Material c) Applicable standard				
7.00.00	Flexible steel standard a) Make b) Applicable standard				
8.00.00	Lighting poles a) Make b) Applicable standard c) Type d) Pole height				
9.00.00	Lighting masts a) Make b) Type c) Overall height d) Applicable standard e) Catalogue attached as annexure no.				
EPC PACKAGE FOR PATRATU SUPER THERMAL POWER STATION EXPANSION PHASE-I (3X800 MW)		BID DOC. NO.: CS-9585-001-2	TECHNICAL DATA SHEET SECTION –VI, PART-G	DB-10: STATION LIGHTING	Page 2 of 3



SECTION-5


ENCLOSURES TO THE SPECIFICATION

Sl. No.	NTPC Drawing No.	Drawing Title
1.	9585-001-572-PVC-C-0497	Switchyard Control Room Building - Architectural Plan and Elevation
2.	9585-001-572-PVC-C-0249	GA & Architectural Plan, Elevation And Sections for 400KV GIS building
3.	9585-001-572-PVE-F-0013	Layout Plan & Section



LEGEND :-	
RL	REDUCED LEVEL
FGL	FINISHED GROUND LEVEL
FFL	FINISHED FLOOR LEVEL
BOB	BOTTOM OF BEAM
TOC	TOP OF CONCRETE
TOP	TOP OF PARAPET WALL
PCC	PLAIN CEMENT CONCRETE
TOT	TOP OF BEAM
FC	FALSE CEILING
UDI	UNDER DECK INSULATION
DPC	DAMP PROOF COURSE
RS	ROLLING SHUTTER
D	DOOR
W	WINDOW
V	VENTILATOR
EF	EXHAUST FAN
FG	FIX GLAZING

230 230 THICK BRICK WALL
115 115 THICK BRICK WALL



TYP. RWP FIXING DETAIL

NTPC REFERENCE DRGS.


- 400kv GIS SWITCHYARD SINGLE LINE DIAGRAM.
DRG. NO. - 9585-001-572-PVE-P-0002
- SWITCHYARD CONTROL ROOM BUILDING - EQUIPMENT LAYOUT
DRG. NO. - 9585-001-572-PVC-F-0047

NOTES:

- ALL DIMENSION ARE IN MILLIMETRE & ELEVATIONS ARE METRE.
- SIZE OF COLUMNS ARE TENTATIVE AND SUBJECT TO CHANE AS PER STRUCTURAL DRAWING.
- DOOR WIDTH ARE CLEAR MASONARY OPENING AND DOOR HEIGHTS ARE FROM FFL TO BOTTOM OF LINTEL.
- ALL DIMENSIONS ARE READ AS UNPLATERED MASONARY & CONCRETE UNLESS NOTED OTHERWISE.
- READ THIS DRAWING IN CONJECTION WITH TECHNICAL SPECIFICATION AND TENDOR DRAWING.

CA NO.		आह्वान/परियोजना का नाम			
ADDITIONAL INFORMATION W.O.No.		NAME OF CUSTOMER/PROJECT			
STATUS OF DRAWING		BHEL			
DISTRIBUTION OF PRINTS		भारत हेवी इलेक्ट्रिकल्स लिमिटेड दूरस्थितियन परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION			
REV.	DATE	DRN DESIGN CHECKED APPROVED	TR DU VG BVG/PLK	विभाग /NAME	हस्ता./SIGN.
				DEPT.	दि./DATE
01	06.06.19			उत्तुपात / SCALE	कॉड कोड CARD CODE
REVISED AS PER COMMENTS		BHEL		ड्राईंग.क्र./BHEL DRAWING NO.	पुनः/REV.
				TB-397-607-640	01
				ड्राईंग.क्र./NTPC DRAWING NO.	पुनः/REV.
				9585-001-572-PVC-C-0497	01
				पृष्ठ क्र./SHEET No. 01	अगला पृष्ठ/NEXT SHEET 02


INVENTORY No.



HIGH SOLID CONTENT LIQUID APPLIED ELASTOMERIC WATER PROOFING MEMBRANE WITH SEPARATE WEARING COAT AS PER ASTM C-898. THICKNESS OF THE MEMBRANE SHALL BE 1.5 MM. THIS TREATMENT SHALL INCLUDE APPLICATION OF POLYMERISED MASTIC OVER THE ROOF TO ACHIEVE SMOOTH SURFACE AND PRIMER COAT. WEARING COAT ON THE TOP OF MEMBRANE SHALL CONSIST OF 40MM. THICK PCC (1:2:4) CAST IN PANELS OF MAX. 1200X1200 SIZE AND REINFORCED WITH 0.56 MM. DIA. GALVANIZED CHICKEN WIRE MESH AND SEALING OF JOINTS USING SEALING COMPOUND/ ELASTOMERIC WATER PROOFING MEMBRANE.

REV.	DATE	ALTERED CHECKED APPROVED		REV.	DATE	ALTERED CHECKED APPROVED		REV.	DATE	ALTERED CHECKED APPROVED		REV.	DATE	ALTERED CHECKED APPROVED		REV.	DATE	DNR ALTERED CHECKED APPROVED
70MF				70MF				70MF				70MF				70MF		

mark type
of glass



1.0 BRICK WORK:
1.1 230mm THK. BRICK MASONRY IN C.M. (1:6)
USING FLY ASH BRICK/ (IS 12894).


- 2.0 PLASTER:**
- 2.1 INTERNAL:
12mm THK. PLASTER (1:6 CEMENT : SAND) MORTOR
- 2.2 EXTERNAL:
18mm THK. PLAIN PLASTER (1:6 CEMENT : SAND)
- 2.4 CEILING EXCEPT FOR WHERE PLATE CEILING WILL BE PROVIDED:
6mm THK. PLAIN PLASTER (1:4 CEMENT : SAND)
- 3.0 FLOORING:**
- 3.1 OFFICE, RECEPTION, PASSAGE, AC RM, LAB RM, CONFERENCE RM
VITRIFIED TILE FLOORING.
- 3.2 BATTERY ROOM
25 THK. ACID RESISTANT TILES FLOORING:
ACID RESISTANT TILES UP TO 2100 HEIGHT
AND ACID RESISTANT PAINT FOR BALANCE HEIGHT.
- 3.3 CABLE GALLERY, LT SWITCH GEAR RM, GIS RELAY RM
STORE RM
CEMENT CONCRETE WITH METALLIC HARDENER TOPPING.
- 3.4 STAIRCASE
COMBINATION OF 18MM THK. MARBLE AND GRANITE STONE
FOR TREAD & RISER RESPECTIVELY.
- 3.5 TOILET
NON SLIPPERY TILES FLOORING AND 2100 DADO HIGH
GLAZED TILES WITH BORDER TILES.
- 3.6 SKIRTING:
150 HIGH SKIRTING MATCHING WITH THE FLOOR SHALL BE PROVIDED

5.0 PAINTING:

5.1 INSIDE FACES OF BRICK WALL WILL HAVE 2-COATS OF ACRYLIC EMULSION PAINT IN ALL AC AREA, ACRYLIC DISTEMPER IN ALL OTHER AND IN TOILET WILL HAVE ABOVE DADO WHITE WASH.

5.2 OUTSIDE FACES OF WALL BE PREMIUM ACRYLIC SMOOTH EXTERIOR PAINT OVER PLASTER SURFACE.

5.3 CEILING TO HAVE 2 COATS OF WHITE WASH, IN BATTERY RM HAVE ACID RESISTANT PAINT.

CA NO.					
ADDITIONAL INFORMATION W.O.No.		ग्राहक/परियोजना का नाम			
STATUS OF DRAWING		NAME OF CUSTOMER/PROJECT			
DISTRIBUTION OF PRINTS		 भारत हेवी इलेक्ट्रिकल्स लिमिटेड भारतीयावल परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION			
		ड्रॉइंग DRAWING जाँच CHECKED स्वीकृत APPROVED	नाम /NAME TR DU/VG BVG/PLK	हस्ता./SIGN. —SD— —SD— —SD—	दि./DATE 29-03-19 29-03-19 29-03-19
REV.	DATE	DRN	TR		
01	06.06.19	DESN CHECKED	DU VG	विभाग DEPT. कोड CODE	उन्पात / SCALE  कार्ड कोड CARD CODE
ZONE		REVISED AS PER COMMENTS		कोड CODE	ड्राइंग.नं./BHEL DRAWING NO. TB-397-607-640
		शीर्षक/TITLE SWITCHYARD CONTROL ROOM BUILDING-ARCHITECTURAL PALN & ELEVATION-FIRST FLOOR PLAN		ड्राइंग.नं./NTPC DRAWING NO. 9585-001-572-PVC-C-0497	पुनः/REV. 01
				पुनः क./SHEET No.02	उगला पुनः/NEXT SHEET 03

COPY RIGHT AND CONFIDENTIAL
The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED
it must not be used directly or indirectly in anyway detrimental to the interest of the company.



COMPUTER DRG. PATH NAME :

REF. DRG. No.


SIGN. & DATE

INVENTORY No.


DRAWING No. 9585-001-572-PVC-C-0497




PLINTH PROTECTION ALONG BUILDING
WITH DRAIN-TYPICAL




TYP. DETAIL OF PARAPET




50MM THICK DPC IN CEMENT CONCRETE (1:1.5:3) WITH WATER PROOFING COMPOUND FOLLOWED BY TWO LAYERS OF BITUMNE COATING BS/IS GRADE AS PER IS:702 @1.7 KG/M SHALL BE PROVIDED AS PLINTH LEVEL BEFORE STARTING MASONRY WORK.

CA NO.																											
ADDITIONAL INFORMATION W.O.No.		ग्राहक/परियोजना का नाम																									
STATUS OF DRAWING		NAME OF CUSTOMER/PROJECT																									
DISTRIBUTION OF PRINTS		भारत हेवी इलेक्ट्रिकल्स लिमिटेड दूरस्थितन परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION <table><tr><td>आवृत्ति DRAWN</td><td>नाम /NAME</td><td>हस्ता./SIGN.</td><td>दि./DATE</td></tr><tr><td>जांचा CHECKED</td><td>TR</td><td>-SD-</td><td>29-03-19</td></tr><tr><td>स्वीकृत APPROVED</td><td>DU/VG</td><td>-SD-</td><td>29-03-19</td></tr><tr><td></td><td>BVG/PLK</td><td>-SD-</td><td>29-03-19</td></tr></table>										आवृत्ति DRAWN	नाम /NAME	हस्ता./SIGN.	दि./DATE	जांचा CHECKED	TR	-SD-	29-03-19	स्वीकृत APPROVED	DU/VG	-SD-	29-03-19		BVG/PLK	-SD-	29-03-19
आवृत्ति DRAWN	नाम /NAME	हस्ता./SIGN.	दि./DATE																								
जांचा CHECKED	TR	-SD-	29-03-19																								
स्वीकृत APPROVED	DU/VG	-SD-	29-03-19																								
	BVG/PLK	-SD-	29-03-19																								
REV.	DATE	DRN	TR	विभाग DEPT.		उत्पात / SCALE	कॉड कोड CARD CODE	दृष्टांत.क्र./BHEL DRAWING NO.		पुनः/REV.																	
01	06.06.19	DESIGN CHECKED APPROVED	DU VG BVG/PLK	कोड CODE				TB-397-607-640	01																		
ZONE	REVISED AS PER COMMENTS			प्रोशेक्./TITLE SWITCHYARD CONTROL ROOM BUILDING-ARCHITECTURAL PALN & ELEVATION-TERRACE PLAN				दृष्टांत.क्र./NTPC DRAWING NO.		पुनः/REV.																	
								9585-001-572-PVC-C-0497		01																	
								पृष्ठ क्र./SHEET No. 03		अगला पृष्ठ/NEXT SHEET 04																	


DRAWING No. 9585-001-572-PVC-C-0497



SECTION A-A



SECTION B-B



SECTION C-C


COMPUTER DRG. PATH NAME :

REF. DRG. No.

SIGN. & DATE

INVENTORY No.

	REV.	DATE	ALTERED		REV.	DATE	ALTERED		REV.	DATE	ALTERED		REV.	DATE	ALTERED		REV.	DATE	ALTERED		REV.	DATE	ALTERED		REV.	DATE	DRN					
			CHECKED						CHECKED					CHECKED					CHECKED						CHECKED						ALTERED	
			APPROVED						APPROVED					APPROVED					APPROVED						APPROVED						CHECKED	
	ZONE				ZONE					ZONE				ZONE				ZONE				ZONE					APPROVED					

CA NO.																						
ADDITIONAL INFORMATION W.O.No.										ग्राहक/परियोजना का नाम												
STATUS OF DRAWING										NAME OF CUSTOMER/PROJECT												
DISTRIBUTION OF PRINTS										 भारत हेवी इलेक्ट्रिकल्स लिमिटेड दूरस्थित परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION किसम DRAWN नाम / NAME हस्ता./SIGN. दि./DATE जयरा CHECKED DU/VG —SD— 29-03-19 नयंकृत APPROVED BVG/PLK —SD— 29-03-19												
REV.	DATE	DRN	TR	DESIGN	DU	CHECKED	VG	APPROVED	BVG/PLK	विभाग DEPT.	कोड CODE	उत्पात / SCALE	कॉड कोड CARD CODE	डाईग.क्र./BHEL DRAWING NO.	पुनः/REV.							
01	06.06.19	DRN	TR	DESIGN	DU	CHECKED	VG	APPROVED	BVG/PLK					TB-397-607-640	01							
ZONE	REVISED AS PER COMMENTS										शीर्षक/TITLE SWITCHYARD CONTROL ROOM BUILDING-ARCHITECTURAL PALN & ELEVATION-ARCHITECTURAL SECTIONS										डाईग.क्र./NTPC DRAWING NO.	पुनः/REV.
															9585-001-572-PVC-F-0497	01						
															पृष्ठ क्र./SHEET No.04	अगला पृष्ठ/NEXT SHEET 05						

INVENTORY No.




CA NO.											
ADDITIONAL INFORMATION W.O.No.		ग्राहक/परियोजना का नाम									
STATUS OF DRAWING		NAME OF CUSTOMER/PROJECT									
DISTRIBUTION OF PRINTS				भारत हेवी इलेक्ट्रिकल्स लिमिटेड ट्रांसमिशन परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION			अनुपात / SCALE	कार्ड कोड CARD CODE	ड्राईंग नं./BHEL DRAWING NO. TB-397-607-640	हस्ता./SIGN. -SD-	दि./DATE 29-03-19
REV.	DATE	DRN DESN CHECKED APPROVED	TR DU VG BVG/PLK	विभाग DEPT. कोड CODE		अनुपात / SCALE	कार्ड कोड CARD CODE	ड्राईंग नं./BHEL DRAWING NO. TB-397-607-640	हस्ता./SIGN. -SD-	दि./DATE 29-03-19	
01	06.06.19										
ZONE	REVISED AS PER COMMENTS			शीट का/TITLE SWITCHYARD CONTROL ROOM BUILDING-ARCHITECTURAL PALN & ELEVATION-ARCHITECTURAN ELEVATIONS				ड्राईंग नं./NTPC DRAWING NO. 9585-001-572-PVC-C-0497		पृष्ठ नं./SHEET No.05	उग्राग पृष्ठ/NEXT SHEET 06

INVENTORY No.



mark reflected false ceiling plan, mark toilet details

CA NO.											
ADDITIONAL INFORMATION W.O.No.		आहूक/परियोजना का नाम									
STATUS OF DRAWING		NAME OF CUSTOMER/PROJECT									
DISTRIBUTION OF PRINTS		 भारत हेवी इलेक्ट्रिकल्स लिमिटेड दूरसंचालन परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION कलर/ DRAWN ललर /NAME हलरल- /SIGN. दलर./DATE उलरल TR -SD- 29-03-19 रलरलुत DU/VG -SD- 29-03-19 रलरलुत BVG/PLK -SD- 29-03-19									
REV.	DATE	DRN	TR	रलरलल DEPT.		उत्पात / SCALE	गर्ह कोड CARD CODE	दूरललरल.कं./BHEL DRAWING NO. TB-397-607-640	डुलर./REV. 01		
01	06.06.19	CHECKED	DU	कोड							
		APPROVED	VG	BVG/PLK							
ZONE	REVISED AS PER COMMENTS			शीलरल/TITLE		दूरललरल.कं./NTPC DRAWING NO. 9585-001-572-PVC-C-04-97			डुलर./REV. 01		
					SWITCHYARD CONTROL ROOM BUILDING-ARCHITECTURAL PALN & ELEVATION-ARCHITECTURAN ELEVATIONS		पुलर क./SHEET No. 06			उलरलरल डुलर./NEXT SHEET --	



SCHEDULE OF DOORS & WINDOWS					
TYPE	OPENING SIZE	COLL. LEVEL	LINTEL LEVEL	NOS.	DESCRIPTION
RS1	4000x6000	—	6000	1	STEEL ROLLING SHUTTER
D1	2000x2500	—	2500	1	DOUBLE SHUTTER STEEL FRAME DOOR AS PER SPECS.
D2	1200x2500	—	2500	4	SINGLE SHUTTER STEEL FRAME DOOR AS PER SPECS.
W1	2000x1600	900	2500	47	PARTLY FIXED & PARTLY OPENABLE ALUMINIUM FRAME GLAZED SHUTTER WINDOW AS PER SPECS.

1.0 BRICK WORK:

1.1 230mm THK. BRICK MASONRY IN C.M. (1:6)
USING FLY ASH BRICK/ (S 12894).

2.0 PLASTER:

2.1 INTERNAL:
12mm THK. PLASTER (1:6 CEMENT : SAND) MORTOR

2.2 EXTERNAL:
15mm THK. PLAIN PLASTER (1:6 CEMENT : SAND)

3.0 FLOORING:

3.1 GIS BLDG.
CEMENT CONCRETE WITH METALLIC HARDENER TOPPING.

3.2 SKIRTING:
150 HIGH SKIRTING MATCHING WITH THE FLOOR SHALL BE PROVIDED.

5.0 PAINTING:

5.1 INSIDE FACES OF BRICK WALL WILL HAVE 2-COATS OF ACRYLIC
DISTERFER.

5.2 OUTSIDE FACES OF WALL BE PREMIUM ACRYLIC SMOOTH EXTERIOR PAINT
OVER PLASTER SURFACE.

MINIMUM 0.3mm BMT (E.G. INCLUDING THE THICKNESS OF GALVANIZING/
ALUMINIUM ZINC COATING & PAINTING) OF GRADE G350 AS PER AISI397
GRADE SS540 CLASS 4 AS PER ASTM A792M/ GRADE S350GD AS PER
EN 10326 WITH ZINC COATING TO CLASS Z275/ ALUMINIUM ZINC
ALLOY COATING TO CLASS A7150 AND

ROOF SHEETING 50MM THICK PREFABRICATED INSULATED METAL
SANDWICH PANEL AS PER TECHNICAL SPECIFICATIONS.

clear whether the roof sheeting is sandwich panel or Cladding sheet

ALL FINISHES SHALL BE AS PER TECHNICAL SPECIFICATIONS
SAMPLES OF FINISHING ITEM SHALL BE APPROVED BY EIC
BEFORE ORDERING IN BULK.

mark openings pertaining to ventilation system

area of windows shall minimum 10% of floor area,
show calculation

LEGEND :	
RL	REDUCED LEVEL
FGL	FINISHED GROUND LEVEL
FFL	FINISHED FLOOR LEVEL
BOB	BOTTOM OF BEAM
TOC	TOP OF CONCRETE
TOP	TOP OF PARAPET WALL
POC	PLAIN CEMENT CONCRETE
TOB	TOP OF BEAM
FC	FALSE CEILING
UDI	UNDER DECK INSULATION
DPC	DAMP PROOF COURSE
RS	ROLLING SHUTTER
D	DOOR
W	WINDOW
V	VENTILATOR
EF	EXHAUST FAN
FG	FIX GLAZING

1. GIS BUILDING - PLAN LAYOUT
DRG. NO. - 9585-001-572-PVE-F-0283

- NOTES:
1. ALL DIMENSION ARE IN MILLIMETRE & ELEVATIONS ARE METRE.
 2. SIZE OF COLUMNS ARE TENTATIVE AND SUBJECT TO CHANGE AS PER STRUCTURAL DRAWING.
 3. DOOR WIDTH ARE CLEAR MASONRY OPENING AND DOOR HEIGHTS ARE FROM FFL TO BOTTOM OF LINTEL.
 4. ALL DIMENSIONS ARE READ AS UNPLASTERED MASONRY & CONCRETE UNLESS NOTED OTHERWISE.
 5. READ THIS DRAWING IN CONJUNCTION WITH TECHNICAL SPECIFICATION AND TENDER DRAWING.

[illegible]

CA No.																						
ADDITIONAL INFORMATION W.O.No.		ग्राहक/परियोजना का नाम PATRATU VIDYUT UTPADAN NIGAM LTD. NAME OF CUSTOMER/PROJECT PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3x800 MW)																				
STATUS OF DRAWING																						
DISTRIBUTION OF PRINTS		नीएचईएल  भारत हेवी इलेक्ट्रिकल्स लिमिटेड ट्रान्समिशन परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION <table><tr><td>वर्क/</td><td>नाम /NAME</td><td>हस्ता./SIGN.</td><td>दि./DATE</td></tr><tr><td>DRAWN</td><td>NS</td><td></td><td>22-04-19</td></tr><tr><td>CHECKED</td><td>TR</td><td>VG</td><td>22-04-19</td></tr><tr><td>APPROVED</td><td>RDU</td><td>BVG/PLK</td><td>22-04-19</td></tr></table>					वर्क/	नाम /NAME	हस्ता./SIGN.	दि./DATE	DRAWN	NS		22-04-19	CHECKED	TR	VG	22-04-19	APPROVED	RDU	BVG/PLK	22-04-19
वर्क/	नाम /NAME	हस्ता./SIGN.	दि./DATE																			
DRAWN	NS		22-04-19																			
CHECKED	TR	VG	22-04-19																			
APPROVED	RDU	BVG/PLK	22-04-19																			
REV.	DATE	DRN	TR	विभाग/																		
R1	16.05.19	DESN	RDU	DEPT.																		
		CHECKED	VG	कोड																		
		APPROVED	BVG/PLK	CODE																		
ZONE		REVISED AS PER COMMENTS		ड्राइंग/TITLE GA & ARCHITECTURAL PLAN, ELEVATION AND SECTION FOR 400 KV GIS BUILDING		उत्पात / SCALE 																
				कार्ड कोड CARD CODE		ड्राइंग,क्र./BHEL DRAWING NO. TB-397-607-662																
				ड्राइंग,क्र./NTPC DRAWING NO. 9585-001-572-PVC-C-0249		पुनः/RE 01																
				पृष्ठ क्र./SHEET No. 01		पुनः/RE 01																
				उगला पृष्ठ/NEXT SHEET 02																		

COPY RIGHT AND CONFIDENTIAL
The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED
it must not be used directly or indirectly in anyway detrimental to the interest of the company.


COMPUTER DRG. PATH NAME :

REF. DRG. No.

SIGN. & DATE

INVENTORY No.


DRAWING No. 9585-001-572-PVC-C-0249



TERRACE PLAN

It is not clear whether the roof sheeting is sandwich panel or Cladding sheet

Also indicate the provisions for Ventilation in GIS Building.



TERRACE PLAN

CA NO.					
ADDITIONAL INFORMATION W.O.No.	ग्राहक/परियोजना का नाम PATRATU VIDYUT UTPADAN NIGAM LTD. NAME OF CUSTOMER/PROJECT PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3x800 MW)				
STATUS OF DRAWING					
DISTRIBUTION OF PRINTS	निरूपित/अनुमोदित BHEI भारत हेवी इलेक्ट्रिकल्स लिमिटेड दूरस्थान परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION				
REV.	DATE	DRN	TR	विभाग DEPT.	दि./DATE
R1	16.05.19	DESIGN	RDU	NS	22-04-19
		CHECKED	VG	TR	22-04-19
		APPROVED	BVG/PLK	RDU	22-04-19
ZONE	REVISED AS PER COMMENTS			उत्पात / SCALE	कॉड कोड CARD CODE
				ड्राईंग.क्र./BHEL DRAWING NO.	पुनः/REV.
				TB-397-607-662	01
				ड्राईंग.क्र./NTPC DRAWING NO.	पुनः/REV.
				9585-001-572-PVC-C-0249	01
				पृष्ठ क्र./SHEET No.02	अगला पृष्ठ/NEXT SHEET 03

FIRST ANGLE PROJECTION (ALL DIMENSIONS ARE IN MM.)

DRAWING No. 9585-001-572-PVC-C-0249


COPY RIGHT AND CONFIDENTIAL
The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED
it must not be used directly or indirectly in anyway detrimental to the interest of the company.

COMPUTER DRG. PATH NAME :


REF. DRG. No.

SIGN. & DATE

INVENTORY No.



ELEVATION ALONG GRID-D



ELEVATION ALONG GRID-D

COLOUR CODE:-

SL. NO.	LOCATION	COLOUR CODE
1	SIDE CLADDING	(CODE: RAL5012)
2	POLYCARBONATE SHEET FOR CLADDING.	(CODE: RAL9002)


RT

CA NO.									
ADDITIONAL INFORMATION W.O.No.				प्राहक/परियोजना का नाम PATRATU VIDYUT UTPADAN NIGAM LTD. PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3x800 MW)					
STATUS OF DRAWING				NAME OF CUSTOMER/PROJECT					
DISTRIBUTION OF PRINTS				 भारत हेवी इलेक्ट्रिकल्स लिमिटेड भारतमिश्रण परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION खसका DRAWN नाम / NAME हस्ता / SIGN. दि./DATE प्रीता CHECKED TR VG 22-04-19 नयप्रित APPROVED RDU BVG/PLK 22-04-19					
REV.	DATE	DRN	TR	सिमांता DEPT.		उत्पात / SCALE	कार्ड कोड CARD CODE	ड्राईंग. क्र./BHEL DRAWING NO.	पुनः/REV.
R1	16.05.19	DESIGN	RDU	कोड CODE		TB-397-607-662	01		
		CHECKED	VG						
ZONE	REVISED AS PER COMMENTS			शीर्षक/TITLE GA & ARCHITECTURAL PLAN, ELEVATION AND SECTION FOR 400 KV GIS BUILDING				ड्राईंग. क्र./NTPC DRAWING NO. 9585-001-572-PVC-C-0249	पुनः/REV. 01
								पृष्ठ क्र./SHEET No. 03	उगता पृष्ठ /NEXT SHEET 04

INVENTORY No.



DETAIL OF RAMP




CA NO.																							
ADDITIONAL INFORMATION W.O.No.				ग्राहक/परियोजना का नाम		PATRATU VIDYUT UTPADAN NIGAM LTD.																	
STATUS OF DRAWING				NAME OF CUSTOMER/PROJECT		PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3x800 MW)																	
DISTRIBUTION OF PRINTS				नीएचईएल  भारत हेवी इलेक्ट्रिकल्स लिमिटेड द्वाराभित्तल परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION <table><thead><tr><th>वर्षिका DRAWING</th><th>नाम /NAME</th><th>हस्ता./SIGN.</th><th>दि./DATE</th></tr></thead><tbody><tr><td>जिजा CHECKED</td><td>NS</td><td></td><td>22-04-19</td></tr><tr><td>स्वीकृत APPROVED</td><td>TR</td><td>VG</td><td>22-04-19</td></tr><tr><td></td><td>RDU</td><td>BVG/PLK</td><td>22-04-19</td></tr></tbody></table>				वर्षिका DRAWING	नाम /NAME	हस्ता./SIGN.	दि./DATE	जिजा CHECKED	NS		22-04-19	स्वीकृत APPROVED	TR	VG	22-04-19		RDU	BVG/PLK	22-04-19
वर्षिका DRAWING	नाम /NAME	हस्ता./SIGN.	दि./DATE																				
जिजा CHECKED	NS		22-04-19																				
स्वीकृत APPROVED	TR	VG	22-04-19																				
	RDU	BVG/PLK	22-04-19																				
REV.	DATE	DRN	TR	विभाग DEPT.	 अनुपात / SCALE	कार्ड कोड CARD CODE	ड्राईंग.क्र./BHEL DRAWING NO. TB-397-607-662	पृष्ठ/REV 01															
R1	16.05.19	DESN CHECKED APPROVED	RDU VG BVG/PLK	कोड CODE																			
ZONE	REVISED AS PER COMMENTS			शीर्षक/TITLE GA & ARCHITECTURAL PLAN, ELEVATION AND SECTION FOR 400 KV GIS BUILDING	ड्राईंग.क्र./NTPC DRAWING NO. 9585-001-572-PVC-C-0249		पृष्ठ/REV 01																
					पृष्ठ क्र./SHEET No. 05		अगला पृष्ठ /NEXT SHEET --																

ON HOLD AS GT , ST UAT AREA WILL BE
FINALIZED AFTER THE FINALIZATION OF ACC

NOTES:

SL.NO.	DESCRIPTION	400kV	
		CONDUCTOR DETAIL	CONNECTION HEIGHT (ABOVE PLINTH LEVEL)
1.	EQUIPMENT INTERCONNECTION	4.0" IPS (EH) AL. TUBE/ MOOSE CONDUCTOR	10mtr.
2.	JACK BUS ON GT/ST - IN ACC AND INTERCONNECTOR AREA	TWIN ACSR MOOSE CONDUCTOR	25 mtr.
3.	JACK BUS TOWARDS ACC - IN SWYD	TWIN ACSR MOOSE CONDUCTOR	23 mtr.
3.	LINE SIDE DEAD-END STRINGING	*QUAD ACSR MOOSE CONDUCTOR	23 mtr.
4.	EARTHWIRE	7/3.66mm SHIELD WIRE	33.5 mtr / 31.5 mtr.
5.	DROPPER ON CVT, LA	TWIN ACSR MOOSE CONDUCTOR	-

1. ALL DIMENSIONS ARE IN MM.
2. ALL STRUCTURE/CONDUCTOR HEIGHTS ARE ABOVE PLINTH LEVEL. PLINTH LEVEL IS 300 MM ABOVE F.O.L.
3. WAVE TRAP SHALL BE PROVIDED FOR ALL THREE PHASES OF THE LINE AND SHALL BE SUITABLE FOR BR1 ALSO. HOWEVER WAVE TRAP SHALL BE INSTALLED ON TWO PHASES ONLY. STRING INSULATORS SHALL BE PROVIDED FOR ONE PHASE WHEREVER WAVE TRAP IS NOT INSTALLED.
4. TYPE OF GANTRY STRUCTURES SHALL BE AS PER APPROVED STRUCTURAL LAYOUT DRAWING.
5. SWITCHYARD LIGHTNING PROTECTION IS ACHIEVED THROUGH SHIELD WIRES AS PER APPROVED DISLP.
6. ON PRESSURE SIDE OF THE SHIELD WIRE SHALL NOT BE TOWARDS TRANSFORMER SIDE. AN ARRESTMENT KEPT NEAR LIGHTING ARRESTER AND BHEL SHALL ENSURE THE SAME DURING Erection AT SITE.
7. FOR GIS SWITCHYARD IN FENCE AREA, REFER SHEET No. 02
8. FOR SECTION DETAILS, REFER SHEET No. 03.
9. STRINGING UPTO 4/ ST BAYS SHOWN IS TENTATIVE.
10. SIZE OF GIS AND CONTROL ROOM BUILDING IS AS PER RESPECTIVE APPROVED LAYOUTS.
11. DEAD END TOWERS LOCATION TO BE CONFIRMED BY NTPC.
12. SUPPLY AND STRINGING OF 400KV LINE CONDUCTOR, SHIELD WIRE, INSULATOR AND HARDWARE BETWEEN 400KV DEAD END TOWER AND SWITCHYARD TERMINAL GANTRY ARE NOT IN BHEL SCOPE. HOWEVER, JUMPING FOR THE RESPECTIVE EQUIPMENT, JUMPERS & HARDWARE REQUIRED FOR JUMPERS ARE IN SCOPE OF BHEL.




Sl.No.	DESCRIPTION OF PARAMETER	
1	SYSTEM OPERATING VOLTAGE	400kV
2	MAX. OPERATING VOLTAGE OF THE SYSTEM (rms)	420kV
3	RATED FREQUENCY	50Hz
4	NO. OF PHASES	3
5	RATED INSULATION LEVELS	
	i) FULL WAVE IMPULSE WITHSTAND VOLTAGE (1.250microsec.)	± 1425kVp
	ii) SWITCHING IMPULSE WITHSTAND VOLTAGE (250/2500microsec.)	± 1050kVp
	iii) ONE MINUTE POWER FREQUENCY WITHSTAND VOLTAGE (rms)	630kV (rms)
6	CORONA EXTINCTION VOLTAGE (MIN)	320kV (rms)
7	MAX. RADIO INTERFERENCE VOLTAGE FOR FREQUENCY BETWEEN 0.5MHz & 2MHz AT 266Kv rms	1000 microV
8	MIN. CREEPAGE DISTANCE	25MM/kV (10500 MM)
9	MIN. CLEARANCE	
	i) PHASE TO PHASE	4000MM
	ii) PHASE TO EARTH	3500MM
	iii) SECTIONAL CLEARANCE	6500MM
10	RATED SHORT CIRCUIT CURRENT FOR 1SEC DURATION	63kA
11	SYSTEM NEUTRAL EARTHING	EFFECTIVELY EARTHED
12	SUB CONDUCTOR SPACING	450MM
13	CONDUCTOR STATIC TENSION	
	400kV TWIN	6T PER PHASE
	400kV QUAD	6T PER PHASE

LEGEND:

FUTURE/ NOT IN BHEL SCOPE.
PRESENT/ BHEL SCOPE
TO BE CONFIRMED BY CUSTOMER

REFERENCE DRGS.

SN	NTPC Drg. No.		DESCRIPTION						
1	9585-001-999-POC-F-001		PLOT PLAN						
2	9585-001-572-PVE-F-P-0002		400KV SWITCHYARD SINGLE LINE DIAGRAM						
3	9585-001-572-PVE-F-0283		GIS Layout (Plan and Section View)						
NOA NO.			01/PVUNL-CS-9585-001-2/ND&A-FC DATED 08/03/2018 01/PVUNL-CS-9585-001-2/ND&A-SC DATED 08/03/2018 01/PVUNL-CS-9585-001-2/ND&A-TC DATED 08/03/2018						
ADDITIONAL INFORMATION W.O.No.			ग्राहक/परियोजना का नाम PATRATU VIDYUT UTPADAN NIGAM LTD. PATRATU SUPER THERMAL POWER						
STATUS OF DRAWING			NAME OF CUSTOMER/PROJECT PROJECT EXPANSION PHASE-1 (3x800 MW)						
DISTRIBUTION OF PRINTS			भारत हेवी इलेक्ट्रिकल्स लिमिटेड BHH भारत भारी परियोजना विभाग BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION कागज DRAWN रखा CHECKED अनुमोदित APPROVED नाम /NAME NS SKS AG हस्ता./SIGN. -SGD- -SGD- -SGD- दि./DATE 10-08-18 10-08-18 10-08-18						
REV.	DATE	ALTERED	NS	प्रिंटर DEPT.		उत्सृपात / SCALE	ग्राह कोड CARD CODE	VENDOR	
	05-04-19	CHECKED APPROVED	SKS AG	कोड CODE					
ZONE		REVISED AS PER NTPC'S COMMENTS DATED 21.08.18 AND REVISED GIS LAYOUT.			शीट/क/TITLE 400 kV LAYOUT PLAN & SECTION				
					NTPC DRS NO. 9585-001-572-PVE-F-0013 BHEL DRS NO. TB-0-397-316-002 पृष्ठ नं./SHEET No. 01 अंतिम पृष्ठ/NEXT SHEET 02				



S.NO.	DESCRIPTION	SYMBOL	UNIT	QUANTITY
1	125 MVAR, 400kV SHUNT REACTOR - 3PH		NOS.	2
2	336 kV LIGHTNING ARRESTER - INCLUDING GT/ST LIGHTNING ARRESTER - 1PH		NOS.	42
3	400kV, 8800pF LINE CAPACITIVE VOLTAGE TRANSFORMER - 1PH.		NOS.	18
4	400kV, 4400pF CAPACITIVE VOLTAGE TRANSFORMER FOR GT BAYS - 1PH		NOS.	9
5	400kV, 3150A 0.5mH* PEDESTAL MOUNTED WAVE TRAP - 1PH		NOS.	12
6	400kV, 8000 N BUS POST INSULATOR - INCLUDING GT/ST YARD INSULATORS - 1PH		NOS.	84





(As per actual requirement /EKO)

NOA NO.		01/PV/LIN-CCS-9585-001-2/INDA-FC		DATED 08/03/2018	
		01/PV/LIN-CCS-9585-001-2/INDA-SC		DATED 08/03/2018	
		01/PV/LIN-CCS-9585-001-2/INDA-TC		DATED 08/03/2018	
ADDITIONAL INFORMATION W.O.No.		PATRATU VIDYUT UTPADAN NIGAM LTD. PATRATU SUPER THERMAL POWER			
STATUS OF DRAWING		PROJECT EXPANSION PHASE-I (3x800 MW)			
DISTRIBUTION OF PRINTS		 धारातु हेवरी इलेक्ट्रिकल्स लिमिटेड द्वाण्णनिगमन पारिपोजना निगमन BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION			
		 अनुपात / SCALE		कर्ड कोड CARD CODE	
REV.		DATE		VENDOR	
01		05-04-19			
REVISED AS PER NTPC'S COMMENTS DATED 21.08.18 AND REVISED GIS LAYOUT.		ALTERED CHECKED APPROVED		NS SKS AG	
ZONE		सिगममा DEPT. कोड CODE		एनएचएल NS SKS AG	
		धाण्णक/TITLE		ड्राईंग नं./DRAWING NO. NTPC ORG NO. 9585-001-572-PVE-F-0013 BHEL ORG NO. TB-0-397-316-002	
		400 kV LAYOUT PLAN & SECTION		पुनर्मा/REV. 01	
		पृष्ठ नं./SHEET No. 02		कुलपृष्ठ नं./NEXT SHEET 03	

FIRST ANGLE PROJECTION (ALL DIMENSIONS ARE IN MM.)

COPY RIGHT AND CONFIDENTIAL
The information on this document is the property of Bharat Heavy Electricals Limited. It is not to be used or copied in any way without the written consent of the company.

DRAWING No. 9585-001-572-PVE-F-0013



*NOTE: THE SECTIONS OF ACC SHALL BE FINALIZED AFTER FINALIZATION OF ACC YARD.

REV.	DATE	ALTERED	CHECKED	APPROVED	REV.	DATE	ALTERED	CHECKED	APPROVED	REV.	DATE	ALTERED	CHECKED	APPROVED	REV.	DATE	ALTERED	CHECKED	APPROVED	REV.	DATE	ALTERED	CHECKED	APPROVED	REV.	DATE	ALTERED	CHECKED	APPROVED	REV.	DATE	ALTERED	CHECKED	APPROVED
ZONE					ZONE					ZONE					ZONE					ZONE					ZONE					ZONE				

NOA NO.		01/PVUNL-CS-9585-001-2/NOA-FC DATED 08/03/2018 01/PVUNL-CS-9585-001-2/NOA-SC DATED 08/03/2018 01/PVUNL-CS-9585-001-2/NOA-TC DATED 08/03/2018																									
ADDITIONAL INFORMATION W.O.No.		प्रातृतु वीड्युत उत्पदन निगम लि. PATRATU VIDYUT UTPADAN NIGAM LTD.																									
STATUS OF DRAWING		NAME OF CUSTOMER/PROJECT PATRATU SUPER THERMAL POWER PROJECT EXPANSION PHASE-I (3x800 Mw)																									
DISTRIBUTION OF PRINTS		 भारत हेवी इलेक्ट्रिकल्स लिमिटेड भारत वीज एल इलेक्ट्रिकल्स लिमिटेड BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION <table><tr><td>अनुमोदित</td><td>नाम /NAME</td><td>हस्ताक्षर /SIGN</td><td>दि./DATE</td></tr><tr><td>अनुमोदित</td><td>NS</td><td>-SGD-</td><td>10-08-18</td></tr><tr><td>अनुमोदित</td><td>SKS</td><td>-SGD-</td><td>10-08-18</td></tr><tr><td>अनुमोदित</td><td>AG</td><td>-SGD-</td><td>10-08-18</td></tr></table>										अनुमोदित	नाम /NAME	हस्ताक्षर /SIGN	दि./DATE	अनुमोदित	NS	-SGD-	10-08-18	अनुमोदित	SKS	-SGD-	10-08-18	अनुमोदित	AG	-SGD-	10-08-18
अनुमोदित	नाम /NAME	हस्ताक्षर /SIGN	दि./DATE																								
अनुमोदित	NS	-SGD-	10-08-18																								
अनुमोदित	SKS	-SGD-	10-08-18																								
अनुमोदित	AG	-SGD-	10-08-18																								
REV.	DATE	ALTERED	NS	SKS	विभागा		अनुपात / SCALE	कार्ड कोड	VENDOR																		
01	05-04-19	CHECKED	NS	SKS	DEPT.																						
		APPROVED	AG	CODE	कोड																						
ZONE	REVISED AS PER NTPC'S COMMENTS DATED 21.08.18 AND REVISED GIS LAYOUT.				प्रॉजैक्ट/TITLE				ड्राइंग नं./DRAWING NO.			पुनः/REV.															
					400 kV LAYOUT PLAN & SECTION				NTPC DRG NO. 9585-001-572-PVE-F-0013			01															
									BHEL DRG NO. TB-0-397-316-002																		
									पुनः/ SHEET No. 03 (आगत पत्र/NEXT SHEET)																		