

CORRIGENDUM

Sl. No.	Existing Clause			Ammended Clause		
Sl.No. 6 of (I) 765kV Vataman S/s of Annexure-A of Section-I of Technical specification	765kV Bus Bar Protection Panel (with Automation) (1 Set = Single Numerical Busbar Protection system comprising of all present Bays <u>and all Future Bays as shown in SLD</u>)	Set	2	765kV Bus Bar Protection Panel (with Automation) (1 Set = Single Numerical Busbar Protection system comprising of all present Bays <u>and Future Bays under present Bus section and one side of Future Bus sectionalizer CBs as shown in SLD</u>)	Set	2

Rajat
07/08/2024
RAJAT KUMAR
MANAGER (TBEM)

Ranajit
07/08/2024
RANAJIT DEY
SR. MANAGER (TBEM)

Sanjeev
SANJEEV SHRIVASTAVA
AGM (TBEM)

From: Shipra Bhowmick {शिप्रा भौमिक} <shipra@powergrid.in>
Sent: 07 August 2024 14:17
To: rajat.kumar@bhel.in
Cc: ranajitd@bhel.in; sanjeev.shrivastava@bhel.in; 'manvender'; Atul Mathur {अतुल माथुर}; Seema Soni {सीमा सोनी}
Subject: Re: 765kV Bus bar protection for Vataman (New) S/s

Dear sir,

With reference to the trailing mail, please refer cl no. 26 .3 p of Section CRP of Technical specification according to which - "In case of distributed Bus bar Protection, the bay units for future bays may be installed in a separate panel and the same shall be located in switchyard panel room where bus bar protection panel shall be installed"

Accordingly, your understanding that PUs to be provided for bays under Present scope+ Future bays under present bus section + 1 side of Bus section (of both bus) is correct.

Thanks & Regards
Shipra Bhowmick
Ch. Manager Engg (S/s)

From: rajat.kumar@bhel.in <rajat.kumar@bhel.in>
Sent: 07 August 2024 11:13
To: Atul Mathur {अतुल माथुर} <mathur.atul@powergrid.in>
Cc: Shipra Bhowmick {शिप्रा भौमिक} <shipra@powergrid.in>; ranajitd@bhel.in <ranajitd@bhel.in>; sanjeev.shrivastava@bhel.in <sanjeev.shrivastava@bhel.in>; 'manvender' <manvender@bhel.in>
Subject: 765kV Bus bar protection for Vataman (New) S/s

Some people who received this message don't often get email from rajat.kumar@bhel.in. [Learn why this is important](#)

Dear Sir,

With reference to 765kV Bus bar protection for Vataman (New) S/s, we understand that PUs to be provided for bays under Present scope+ Future bays under present bus section + 1 side of Bus section. (SLD attached for reference)

Please confirm our understanding is right.

Regards,
Rajat Kumar
Manager, BHEL TBG
01206748524

Follow us on :



इलेक्ट्रॉनिक ट्रांसमिशन संदेश- ई-मेल के लिए डिस्कलेमर