



**PRODUCT STANDARD
TURBINES & COMPRESSORS**

TC51313

REV 04

PAGE 0 OF 4

VENT FILTER

(For internal Reference only)

Remove this preface sheet before issuing to supplier

DESIGNATION: Vent filter 150 to this standard shall be designated as follows :

ON DRAWING :

Material specification column : TC51313

Description column : VENT FILTER 150

Material code column : TC9051313012

ON INDENTS:

Material specification column : TC51313

Description column : VENT FILTER 150

Material code column : TC9051313012

ON ENQUIRIES

a) A copy of this standard shall be enclosed without preface sheet.

**FORMAT
TD-201
REV -00
REF DOC**

PREPARED BY: DSR

APPROVED BY: DS.RAO

DATE: 16.12.99

COPY RIGHT AND CONFIDENTIAL

The information on this document is the property of BHEL. It must not be used directly or indirectly in any way detrimental of company.

VENT FILTER

- 1.0 : SCOPE: This standard specifies the requirements of vent filter to be used for the venting of oil cylinders and oil tanks.
- 2.0 : TECHNICAL REQUIREMENTS :
- 2.1 : DESIGN & DIMENSIONS : As per shown in fig. And as per given in the table.
- 2.2 : MATERIAL : The filter cartridge shall be made out of a special synthetic resin, which can be cleaned in Benzene and petroleum.
- 2.3 : The vent filter shall be rugged against highly flammable liquids.
- 3.0 : GUARANTEE CERTIFICATE : A guarantee certificate for 24 months of trouble free performance from the date of shipment or 12 months from the date of commissioning whichever is earlier shall be furnished.
- 4.0 : DOCUMENTS : The descriptive leaflets/catalogues giving full details of the vent filter shall be furnished along with the offer and also with consignment.
- 5.0 : PACKING : The material shall be properly packed to ensure it is capable of with standing transit risks without damage.
- 6.0 : MARKING:
- 6.1 : A tag bearing the relevant 12 digit material code of BHEL shall be attached for each item.
- 6.2 : The following details be marked on the packing case.
- 6.2.1: Manufactures name.
- 6.2.2 : BHEL Order Number.
- 6.2.3 : BHEL Standard number : TC51313

**PRODUCT STANDARD
TURBINES & COMPRESSORS**

TC51313

REV 03

PAGE 2 OF 4

7.0 : SIZE : As per table.

SL NO	Flow rate in 1/min (Mic)	A	B	C	D	Wt.in kgs.	Type	Material code
01	150	48	45	8	R 3/8"	0.12	Pi 1410/2*	TC9051313012
02	400	69	67	10	R 1/2"	0.25	Pi 0112 mic*	TC905131020
03	800	108	70	15	R 1"	0.45	Pi 1410/7*	TC905131130
04	150	(Pi 1410/51150)					Pi 1410/5*	TC9051313047
05.	500				R 1/2"			TC9051313055
06.	1500	132	100	18	G2"	0.7		TC9051313063
07.	Vent filter M/s ANSELM F2033 Drg.No. 5-6604-2102-02							TC9051313071
08.	3000	Clamp fixing (pipe OD 76mm) M/S Purolator model Pi 1420/7 New model no : Pi 0153					Pi 0153 *	TC9051313080
09.	2000	142	95	30	40	0.7	Pi 0140 **	TC905131309

*: M/s Puruloator model no.


** : M/s Knecht (Mahle) model no.

FORMAT
TD-202
REV-00

COPY RIGHT AND CONFIDENTIAL

The information on this document is the property of BHEL. It must not be used directly or indirectly in any way detrimental of company.

ALL DIMENSIONS ARE IN MM.



RECORD OF REVISIONS

REV. NO	DATE	REVISION DETAILS	REVISED	APPROVED
01	11/91	SL.NO.07 ADDDED	V N R	B.V.S.N
02	02/96	SL.NO.08 ADDDED	BVSN	CNVR
03	10/98	VAR 06 FLOW RATE 1500 WAS 500.	P.N.S	D.S.RAO
04	12/99	VAR-09 ADDED	DSR	DSR