



**PRE-QUALIFICATION REQUIREMENTS FOR
NEUTRAL GROUNDING RESISTOR**

PE-PQ-999-505-E001

REVISION NO. 02 DATE 29/04/2016

SHEET NO. 1 OF 1

ITEMS : Neutral grounding resistor a/w supporting structure

SCOPE: Supply : YES; Erection & Commissioning : NO;

1	Availability of type test certificates conducted at independent Lab or witnessed by third party as per relevant IS/ International standard.
2	Vendor should have in-house facility for design and manufacturing of neutral grounding resistor.
3	Vendor should have in-house capability to carry out all routine and type tests. In case facilities for type test are not available with the vendor, these tests can be conducted at Govt. Lab/ Govt. approved independent Lab.
4	Manufacturing capacity of at least 10 nos. neutral grounding resistor per month.
5	Supplied at least 20 nos. of neutral grounding resistor in one or more orders.
6	Minimum two (2) nos. purchase orders for neutral grounding resistor shall be submitted which should not be more than five (5) years old from the date of application for registration or date of techno-commercial bid opening (as applicable) for establishing continuity in business.

NOTE:

Supplier to comply to "general points of PQR" available at <http://bhelpem.com/vensection/PMD/PMD.aspx>
In case supplier is not OEM, the offer shall be evaluated as per point no 1 of "general points of PQR".

PREPARED BY

N.N. Jajware
20/05/2016

NAME: N.N. JAJWARE
DESIGNATION: Dy. Mgr.

REVIEWED BY

Rajnish Goyal
28/4/16.

NAME: RAJNISH GOYAL
DESIGNATION: AGM

APPROVED BY

Meena Kesri
29.04.16

NAME: MEENA KESRI
DESIGNATION: AGM & DH(E)

BHEL PEM-ELECTRICAL
PRE-QUALIFYING REQUIREMENTS FOR NEUTRAL GROUNDING RESISTOR

ANNEXURE – I

PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY

PROJECT : 1 X 800 MW NORTH CHENNAI TPS

- NIL -


Sourabh Tiwari
[Sr.Engineer]


Rajnish Goyal
AGM-Electrical


A.K.RAWAT
[Sr. Manager]


Meena Kesri
GM-Electrical