




	PRE-QUALIFICATION REQUIREMENTS FOR LT XLPE FIRE SURVIVAL CABLE	PE-PQ-999-507-E017
		REVISION NO. 03 DATE 29/04/2016
		SHEET NO. 1 OF 1

ITEMS : LT XLPE Fire Survival cable	
SCOPE : Supply : YES; Erection & Commissioning : NO;	
1.0	Vendor should be a manufacturer of LT Power &/or Control cable.
2.0	Availability of test reports of tests on LT XLPE fire survival cables to establish in-house capability to carry out all routine, type & acceptance test as per relevant IS/International standards (except UV radiation , hydrolytic stability & Fire Survival test) which can be conducted at Govt. Lab/ Govt. approved Independent lab.
3.0	Availability of type test certificate for LT-XLPE fire survival cables for fire survival test conducted at independent lab or witnessed by third party as per relevant IS/ International standards.
4.0	Capacity of manufacturing 200 km of power/control cables (including XLPE/PVC/EPR insulated, FS/ non-FS cables) per month.
5.0	Manufactured & supplied at least 5 km of LT XLPE fire survival cables.
6.0	Minimum two (2) nos. purchase orders for Power &/ or Control cable shall be submitted which should not be more than five (5) years old from the date of application for registration or date of techno commercial bid opening (as applicable) for establishing continuity in business.

NOTE:

Supplier to comply to "general points of PQR" available at <http://bhelpem.com/vensection/PMD/PMD.aspx>
In case supplier is not OEM, the offer shall be evaluated as per point no 1 of "general points of PQR".

PREPARED BY  NAME: MANISH SHUKLA DESIGNATION: SR. MGR	REVIEWED BY  NAME: RAJNISH GOYAL DESIGNATION: AGM	APPROVED BY  NAME: MEENA KESRI DESIGNATION: AGM & DH (E)
---	---	--