

BHEL-PEM-MAUX
PRE-QUALIFICATION CRITERIA

	PROJECT: 2X660MW KHURJA STPP		PE-PQ-475-155-A001
	PRE-QUALIFICATION REQUIREMENT		DATE
	PACKAGE: Condensate Polishing Unit		REV NO 00

A)	The Bidder should have designed, supplied, erected and commissioned at least one (1) Condensate Polishing Plant of mixed bed, deep bed type consisting of service vessel of minimum capacity of 500 M3/hr. The plant shall have external regeneration system, incorporating the same resin separation and regeneration process as proposed by the Bidder for this package. The above plant should have been in successful operation for a period of at least one (1) year as on 02/04/2020.
B)	The Bidder who do not meet the qualification requirements stipulated at (A) above, may also participate provided the Bidder is a Contractor in water treatment plant and has executed at least one (1) number ion exchange based demineralising plant of minimum capacity of 60 Cu.m/hr consisting of maximum two (2) streams and associates for this bid with an Associate who in turn fully meets the requirements stipulated (A) above. In such a case, the Bidder shall be required to furnish a letter of technical support from Collaborator / Associate for successful performance of Condensate Polishing Plant, as per the format enclosed in Annexure-A1. This letter of technical support should be submitted to Employer prior to the placement of order on approved sub-vendor.

Notes:

- 1) The supplier has to submit performance certificate in English from end user along with copy of Purchase Order, meeting above mentioned pre-qualifying requirement.
- 2) Bidder to submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
- 3) In case documents submitted for meeting PQR are in language other than English, notarized English translation shall also be submitted.
- 4) Bidder shall provide all necessary data such as type, design, make, capacity, duty conditions, date of commissioning/ operation etc.
- 5) Notwithstanding anything stated above, BHEL/NTPC/Customer reserves the right to assess the capabilities and capacity of the bidders to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL/NTPC/Customer.
- 6) Final acceptance of Bidder is subject to Customer/NTPC approval.

Annexure-A1

**LETTER OF SUPPORT FOR SATISFACTORY PERFORMANCE OF
..... (Name of Plant / System*) FOR KHURJA STPP (2X660MW)**

TO

[EMPLOYER'S NAME & ADDRESS]

Sub: Letter of Technical Support submitted From (name of the Associate*/ Collaborator*/ Technology provider* / Licensor* / Holding Company*) undertaking the responsibility for satisfactory performance of(name of the plant/system*).

Dear Sirs,

1. In accordance with the Award of the Contract by (Name of the Contractor) to M/s. (Name of the sub-vendor), we, the aforesaid Associate*/Collaborator*/Technology provider*/Licensor*/Holding Company, (M/s) shall be fully responsible for the satisfactory performance of the(plant system* name).
2. Further, the manner of achieving the objective set forth in point 1 above shall be as follows
For (Plant/system* name):
 - (a) We shall be fully responsible for design, engineering & commissioning and extending all necessary support for putting in to satisfactory operation and carrying out the Guarantee Tests for(plant/system* name) to the satisfaction of the Employer.
 - (b) We shall depute technical experts to Bidder's/sub-vendor's works for supervision during manufacturing, assembly, inspection, as and when required by Employer. We shall participate in site erection, commissioning and final testing (as and when necessary) of the..... (Plant/system* name).
 - (c) We shall participate in Technical Co-ordination meetings (TCMs) from time to time, as and when required by Employer.
 - (d) We shall promptly carry out all the corrective measures and shall promptly provide corrected design and shall undertake replacements, rectifications or modifications to the plant/system* as and when required by Employer in case the plant/system* fails to demonstrate successful performance as per contract at site.
3. We, the Associate*/Collaborator*/Technology provider*/Licensor*/Holding company* do hereby undertake and confirm that this Letter of Technical Support shall be valid for a period of seven (7) years or up to the end of defect liability period of the contract, whichever is later.

Signature of the Authorised Representative:.....

For M/s

(Associate*/Collaborator*/Technology provider*/Licensor*/Holding company)

Name

Designation

Date:.....

Common Seal of the Company

***: Strike off whichever is not applicable.**