

	PRE-QUALIFYING REQUIREMENTS (TECHNICAL) – INDUCED DRAFT FRP COOLING TOWER	DOCUMENT NO: PE-TS-441-165-N001
		REVISION NO: 00 DATE: 16/10/2019
		SHEET: 1 of 2
FORM NO. PEM 6100-0	ENQUIRY NO.:	
	PROJECT: 3X660 MW NKSTPP FGD (REV-00)	TECH SPEC NO: PE-TS-441-165-N001
	PACKAGE: Induced Draft Fibre Reinforced Plastic (FRP) – Cooling Tower	
	1. The bidder should have designed, manufactured, tested, inspected & supplied the Induced draft FRP-Cooling Tower of cross-flow/counter-flow design with minimum flow of 300 Cum/hr, which have been successfully in use for at least 1 year in thermal power plant or similar industry/ application and bidder is in business of Induced draft FRP-CT on continuous basis.	
	2. The Bidders shall furnish following support documents for assessment of Bidder w.r.t. PQR as indicated at Sl. No. 1 above: A. Bidder's Experience list of Induced draft FRP-CT for last 5 years (as on the enquiry/NIT date) for assessment of bidder for supplying the Induced draft FRP-CT on regular basis for establishing business continuity in enclosed format-Annexure-1. Bidder shall furnish the PO copy of at least one executed Contract as indicated in the experience list. B. Bidder shall furnish any one from below in support of successful performance of Induced draft FRP-CT for one year: i. Satisfactory Performance feedback certificates from End Customer (Owner) (in English) for at least one successfully executed contract which has been in use for at least One year indicating salient features like year of commissioning of Induced draft FRP-CT, rating of project, flow of Induced draft FRP-CT, project name etc., date of issue of certificate and name/ designation of the certificate issuer for power plant/similar application industry. Refer Notes(N1) below also. The time duration of satisfactory performance completion should be before the date of subject enquiry/NIT. OR ii. The bidder has been awarded One repeat contract for Induced draft FRP-CT from End Customer (Owner) / Purchaser (in English) for power plant/similar application industry. Repeat contract shall be considered when the second contract is given by the same purchaser/ owner after lapse of minimum 1 year from execution (viz. commissioning) of first contract. Supporting documents for execution of the first contract like commissioning report or PG test report along with the PO Copy to be furnished, if bidder intends to submit the documents for Repeat Contracts. The date of repeat contract order should not be later than the date of subject enquiry/NIT.	

PREPARED BY:	REVIEWED BY:	APPROVED BY:
NAME: AMIT KR. ORAON DESIGNATION / DEPT.:	NAME: VISHAL KR YADAV DESIGNATION / DEPT.:	NAME: ASHWANI KHANNA DESIGNATION / DEPT.:

	PRE-QUALIFYING REQUIREMENTS (TECHNICAL) – INDUCED DRAFT FRP COOLING TOWER	DOCUMENT NO: PE-TS-441-165-N001
		REVISION NO: 00 DATE:16/10/2019
		SHEET: 2 of 2

	<u>Notes:-</u>
	<u>N1 - Purchase order copy, supporting drgs/technical data sheets etc. are to be submitted along with the bid for which the bidder intends to furnish the performance feedbacks / repeat contracts for reference purpose only.</u>
	<u>Any additional document required in support of above documents to establish the co-relation between the above documents and the supplied item shall be provided by the bidder.</u>
	3. Bidder to submit all supporting documents in English, If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
	4. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
	5. After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

PREPARED BY: NAME: AMIT KR. ORAON DESIGNATION / DEPT.:	REVIEWED BY: NAME: VISHAL KR YADAV DESIGNATION / DEPT.:	APPROVED BY: NAME: ASHWANI KHANNA DESIGNATION / DEPT.:
---	--	---

EXPERIENCE LIST**EQUIPMENT/PACKAGE:** INDUCED DRAFT FRP COOLING TOWER**Vendor:**

SL. NO.	PROJECT NAME	NAME OF CUSTOMER	TOWER CAPACITY CubM/Hr	FILL TYPE	CROSS FLOW OR COUNTER FLOW	DESIGN BY	SITE EXECUTION BY	YEAR OF COMMNG	PG TEST CONDU CTED	APPLICA TION	PERFORMANCE FEEDBACK ENCLOSED (YES/NO)

COMPANY SEAL