

	PRE - QUALIFYING REQUIREMENTS (TECHNICAL)- NDCT DESIGN CONSULTANCY	DOCUMENT NO: PE-TS-415-165-N001
		REVISION NO: 0 DATE: 17/04/2018
		SHEET: 1 of 2
ENQUIRY NO:		
PROJECT: 1 x 660 MW BHUSAWAL TPS		
PACKAGE: NATURAL DRAFT COOLING TOWER (NDCT) DESIGN & ENGINEERING CONSULTANCY		
1. The bidder should have designed the natural draft cooling towers (NDCT) with counter flow with Film type fill in RCC construction with minimum flow of 25000 Cum/hr, which have been successfully in use for at least 1 year as on 13.01.2014 in thermal power plant or similar industry/ application of only one customer and bidder is in business of design of NDCT on continuous basis. 2. The Bidders shall furnish following support documents for assessment of Bidder w.r.t. PQR as indicated at Sl. No. 1 above A. Bidder's Experience list of NDCT for last 10 years for assessment of bidder for designing the NDCT on regular basis in enclosed format- Annexure-1. Bidder shall furnish the PO copy of minimum one executed contract along with the experience list. B. Bidder shall furnish any one from below in support of successful performance of NDCT for one year: i. Satisfactory Performance feedback certificate from End Customer (Owner) (in English) for at least one successfully executed contract which has been in use for at least one year indicating salient features like year of commissioning of NDCT, rating of project, flow of NDCT, project name etc., date of issue of certificate and name/ designation of the certificate issuer for power plant/similar application industry. Refer note 1 below also. The date of satisfactory performance feedback certificate should not be later than the date of subject enquiry/NIT. OR ii. The bidder has been awarded one repeat contract for NDCT from End Customer (Owner) / Purchaser (in English) for power plant/similar application industry. Repeat contract shall be considered when the second contract is given by the same purchaser/ owner after lapse of minimum 1 year from execution of first contract. Supporting documents for execution of the Contract like, commissioning protocol/PG test report along with the PO Copy to be furnished, if bidder intends to submit the documents for Repeat Contracts. The date of repeat contracts should not be later than the date of subject enquiry/NIT. Note:- a. Purchase order copy, approved drgs/technical data sheets etc. are to be submitted along with the bid for which the bidder intends to furnish the performance feedbacks / repeat contracts for reference purpose only.		



PRE - QUALIFYING
REQUIREMENTS
(TECHNICAL)-NDCT DESIGN
CONSULTANCY

DOCUMENT NO: PE-TS-415-165-N001

REVISION NO: 0 DATE: 17/04/2018

SHEET: 2 of 2

- b. The Performance feedback certificate issued to main contractor of Cooling tower from end user shall also be acceptable for meeting the above PQR provided the bidder furnishes the PO copy from main contractor for NDCT design/ Engineering works in bidder's name for the subject performance feedback certificate.

Any additional document required in support of above documents to establish the co-relation between the above documents and the supplied item shall be provided by the bidder.

3. Bidder to submit all supporting documents in English, If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
4. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
5. After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

ANNEXURE I

EXPERIENCE LIST - NDCTS

[illegible]