

REF: SCR/SSWT/001 REV00

TECHNICAL SPECIFICATION OF STAINLESS STEEL WATER TANK

SL NO	PARAMETER	REQUIREMENT
1	Material grade	SS 304
2	Minimum Shell Thickness	0.5 mm
3	Capacity	1000 litre
4	Inlet pipe	1 no
5	Outlet Pipe	2 no
6	Orientation	Vertical
7	Design temperature & Pressure	Atmospheric Temperature & Pressure
8	Corrosion Level	NIL
9	Stand	Required to be supplied as part of tank
10	Painting	2 coats of red oxide on MS parts

DOCUMENTATION

3 sets of hard copies for all the tank related documents, tank file folder and internal QC reports

TRANSPORTATION

Transportation is in the scope of the supplier

WARRANTY

12 months from the date of commissioning or 18 months from the date of supply whichever is earlier.



PRATAP MUKHERJEE
SR. MANAGER (COMPOSITE & SCR)



CHETAN BHAWSAR
DY. MANAGER (SCR)