


		Bharat Heavy Electricals Ltd Boiler Auxiliaries Plant Ranipet-632 406		FLUE GAS DESULPHURISATION DEPT TECHNICAL SPECIFICATION	
00	19-12-2019	Fresh Release	 Pradeep Kumar Behera	 Arun kumar	 V. Kesavan
REV	DATE	DESCRIPTION	PREPARED	CHECKED	APPROVED
Sl.no.	Item	FRP Grating/Screen for Trench			Vendor Acceptance /Comments
1	Scope of supply	FRP Screen as per attached drawing & enquiry			
2	Eligibility Criteria	Bidder shall be a manufacturer of Moulded Abrasion Resistant FRP Grating. Unpriced copy of PO where they have previously supplied similar gratings to be submitted along with the offers.			
3	Application	For screening in return channel of trenches.			
4	Material	Screen/Mesh FRP	Handle CS (Galvanized)/ SS		
5	Documents to be submitted	(a) The Vendor shall furnish point wise reply and submit seal & signed copy of this specification along with drawing. (b) The Vendor shall submit the dimensional drawings indicating materials of construction and weight along with the offer for information.			
6	Inspection	a) Inspection by BHEL or its authorized agency. b) Material Test Certificates shall be submitted.			
7	Packing	Items shall be wrapped in a polythene hessian and the package shall be kept in a cartoon box prior to dispatch.			
8	Outside the box	PO number , vendor name, item, Site address, Quantity inside the box to be mentioned			
9	Destination	BHEL BAP Ranipet (SD Stores), Tamilnadu- 632406			
10	Drawing	Attached (Page2)			

Bidder's seal & sign



S.No	Area	Length (X) mm	Breadth (Y) mm	Min.Thickness (T) mm	Quantity (No's)	Mesh Size (mm)	Material of construction
1	Absorber area drain sump	660	700	25	2	25	1) Screen/Mesh – FRP
2	Limestone area drain sump	560	600	25	1	25	2) Handle- CS
3	Gypsum area drain sump	460	700	25	1	25	

Bidder's seal & sign