

**TELANGANA STATE POWER
GENERATION CORPORATION
LIMITED (TSGENCO)**

**4X270 MW BHADRADRI
THERMAL POWER PROJECT**

VOLUME – II – B

**TECHNICAL SPECIFICATION
FOR
AIR CONDITIONING SYSTEM**


SPECIFICATION NO.: PE-TS-411-553-A001 Rev 0



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA, INDIA**


Arvind


S A Khan


Praveen Kishore


	TITLE	SPECIFICATION NO. PE-TS-411-553-A001
	4X270 MW BHADRADRI TPS	VOLUME : II B
	INDEX	REV 00
	AIR CONDITIONING SYSTEM	SHEET 1 OF 2


VOLUME – IIB

SECTIONS	TITLE	SPECIFICATION NO.	Page
SECTION- A	INTENT OF SPECIFICATIONS	PE-TS-411-553-A001	2 to 4
SECTION- B	PROJECT INFORMATION WITH WIND AND SEISMIC DESIGN CRITERIA		5 to 7
SECTION- C			8
SECTION- C1 - A	SPECIFIC TECHNICAL REQUIREMENT (Scope of supply & services, exclusion and terminal points etc)	PE-TS-411-553-A001	9 to 37
C1 - B	GENERAL TECHNICAL REQUIREMENT (General Technical Requirement, criteria for layout, project management and site services, engineering services, tools and tackles etc.)	PE-TS-411-553-A001	38 to 111
C1 - C	FUNCTIONAL AND ACCEPTANCE TEST	PE-TS-411-553-A001	112 to 114
C1 - D	INSPECTION, TESTING AND QUALITY ASSURANCE	PE-TS-411-553-A001	115 to 130
C1 - E	PAINTING SPECIFICATION	PE-TS-411-553-A001	131 to 143
SECTION-C2	TECHNICAL SPECIFICATION (ELECTRICAL PORTION)	PE-TS-411-553-A001	144 to 174
SECTION-C3	TECHNICAL SPECIFICATION (C & I PORTION)	PE-TS-411-553-A001	175 to 305
SECTION-C4	TECHNICAL SPECIFICATION (MATERIAL HANDLING EQUIPMENT)		306 to 325
	<u>ANNEXURES</u>		
I)	ANNEXURE-I	LIST OF MAKES	326 to 329
II)	ANNEXURE-II	MANDATORY SPARE LIST	330 to 334
III)	ANNEXURE-III	CLARIFIED WATER ANALYSIS	335 to 336
IV)	ANNEXURE-IV	LIST OF TOOLS & TACKLES (minimum)	337 to 338
V)	ANNEXURE-V	DRAWING / DOCUMENT SUBMISSION PROCEDURE	339 to 342
VI)	ANNEXURE-VI	Master Drawing list with schedule of submission	343 to 346
VII)	ANNEXURE-VII	Format for Operation and maintenance Manual	347 to 350
VIII)	ANNEXURE-VIII	Site Storage and preservation	351 to 366
SECTION-D	STANDARD TECHNICAL SPECIFICATIONS		367 to 422


 Arvind


 S A Khan


 Praveen Kishore



SECTIONS	TITLE	SPECIFICATION NO.	Page
1.	List of documents to be submitted with bid	PE-TS-411-553-A001	424
2.	Compliance cum confirmation certificate	PE-TS-411-553-A001	425 to 426
3.	Pre Bid Clarification Schedule	PE-TS-411-553-A001	427
4.	Schedule of Technical Deviation	PE-TS-411-553-A001	428 to 429
5.	Suggestive price format	PE-TS-411-553-A001	430 to 441
6.	Guaranteed power consumption	PE-TS-411-553-A001	442 to 443
7.	INPUT DRAWINGS		
I)	PID for main chilled water plant	PE-DG-411-553-A001 R-0	444
II)	Make up water scheme with battery limit	PE-DG-411-553-A002 R-0	445
III)	Foundation details for AC equipment (Chiller, AHU, Pump, cooling tower, tank, Precession PU ETC.)	PE-DG-411-554-A003 R-0	446
IV)	Plot plan	PE-DG-411-100-M001 R-P0A	447
V)	TG equipment plan at 0.0 m	PE-DG-411-100-M003 R-0A	448
VI)	TG equipment plan at 9 m	PE-DG-411-100-M004 R-0A	449
VII)	TG equipment plan at 15.5 m	PE-DG-411-100-M005 R-0A	450
VIII)	TG equipment plan at 21.0 m	PE-DG-411-100-M006 R-0A	451
IX)	CROSS SECTION OF TG HALL	PE-DG-411-100-M007 R-0	452
X)	ESP CONTROL ROOM	PE-DG-411-100-E008 R-0	453



**TECHNICAL SPECIFICATION
4X270 MW BHADRADRI TPS
AIR CONDITIONING SYSTEM**

SPECIFICATION No: PE-TS-411-553-A001

VOLUME II B

REV. 00

DATE: APRIL 2015

VOLUME II B



TITLE

4x270 MW BHADRADRI TPS

AIR CONDITIONING

INTENT OF SPECIFICATION

SPECIFICATION NO. PE-TS-411-553-A001

VOLUME II B

SECTION A

REV 00


SHEET 1 OF 3

SECTION-A

INTENT OF SPECIFICATION


Arvind


S A Khan


Praveen Kishore

	TITLE 4x270 MW BHADRADRI TPS AIR CONDITIONING INTENT OF SPECIFICATION	SPECIFICATION NO. PE-TS-411-553-A001
		VOLUME II B
		SECTION A
		REV 00
		SHEET 2 OF 3

1.0 INTENT OF SPECIFICATION

- 1.1** The specification covers design, engineering, manufacture, supply / procurement, inspection and testing at vendor's / sub vendor's / manufacturer's works, painting, forwarding, proper packing and shipment and delivery at site, unloading, handling & transportation, storage, preservation , security / safety at site , Erection & Commissioning, minor civil & structural (as applicable) works as required on FOR site basis, Performance and guarantee testing / demonstration testing and handing over to BHEL's customer of **AIR CONDITIONING SYSTEM** as per details in different sections / volumes of this specification for **4x270 MW BHADRADRI TPS** at Manuguru, Telangana.
- 1.2** The contractor shall be responsible for providing all material, equipment & services, which are required to fulfil the intent of ensuring operability, maintainability, reliability and complete safety of the complete work covered under this specification, irrespective of whether it has been specifically listed herein or not. Omission of specific reference to any component / accessory necessary for proper performance of the equipment shall not relieve the contractor of the responsibility of providing such facilities to complete the supply, erection and commissioning, performance and guarantee/demonstration testing of **AIR CONDITIONING SYSTEM**.
- 1.3** It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship and shall be capable of performing the required duties in a manner acceptable to purchaser who will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material which in his judgement is not in full accordance herewith.
- 1.4** The extent of supply under the contract includes all items shown in the drawings, notwithstanding the fact that such items may have been omitted from the specification or schedules. Similarly, the extent of supply also includes all items mentioned in the specification and /or schedules, notwithstanding the fact that such items may have been omitted in the drawing.
- 1.5** The general term and conditions, instructions to tenderers and other attachment referred to elsewhere are made part of the tender specification. The equipment materials and works covered by this specification is subject to compliance to all attachments referred to in the specification. The bidder shall be responsible for and governed by all requirements stipulated herein.
- 1.6** While all efforts have been made to make the specification requirement complete & unambiguous, it shall be bidders' responsibility to ask for missing information, ensure

	TITLE	SPECIFICATION NO. PE-TS-411-553-A001
	4x270 MW BHADRADRI TPS AIR CONDITIONING INTENT OF SPECIFICATION	VOLUME II B
		SECTION A
		REV 00
		SHEET 3 OF 3

completeness of specification, to bring out any contradictory / conflicting requirement in different sections of the specification and within a section itself to the notice of BHEL and to seek any clarification on specification requirement in the format enclosed under Vol-III of the specification **within 10 days of receipt of tender documents**. In absence of any such clarifications, in case of any contradictory requirement, the more stringent requirement as per interpretation of Purchaser / Customer shall prevail and shall be complied by the bidder without any commercial implication on account of the same. Further in case of any missing information in the specification not brought out by the prospective bidders as part of pre-bid clarification, the same shall be furnished by Purchaser/ Customer as and when brought to their notice either by the bidder or by purchaser/ customer themselves. However, such requirements shall be binding on the successful bidder without any commercial & delivery implication.

1.7 The bidder's offer shall not carry any sections like clarification, interpretations and /or assumptions.


1.8 Deviations, if any, should be very clearly brought out clause by clause along with cost of withdrawal in the enclosed schedule (in Vol – III); otherwise, it will be presumed that the vendor's offer is strictly in line with NIT specification. If no cost of withdrawal is given against the deviation, it will be presumed that deviation can be withdrawn without any cost to BHEL/its customer.

1.9 In the event of any conflict between the requirements of two clauses of this specification documents or requirements of different codes and standards specified, Section - C shall prevail over section – D, however more stringent requirement as per the interpretation of the owner shall apply.

1.10 In case all above requirements are not complied with, the offer may be considered as incomplete and would become liable for rejection.

1.11 For definition of word like Contractor, bidder, supplier, vendor, Customer/ Purchaser / Employer, consultant, please referred relevant clause(s) of GCC.





Arvind

S A Khan

Praveen Kishore

Page 4 of 453



**TECHNICAL SPECIFICATION
4X270 MW BHADRADRI TPS
PROJECT INFORMATION**

SPECIFICATION NO. PE-TS-411-553-A001

VOLUME II B

SECTION B

REV. 00

DATE: APRIL 2015

SHEET 1 OF 3

SECTION: B
PROJECT INFORMATION



PROJECT INFORMATION
FOR
4 X 270 MW BHADRADRI TPS

SPECIFICATION NO. PE-TS-411-553-A001

VOLUME II - B

SECTION - B

REV 00

DATE APRIL 2015

PROJECT INFORMATION

INTRODUCTION

4x270 MW Bhadradi TPS is being set up by Telangana State Electricity Corporation Limited (TSGENCO) at Manuguru in the district of Khammam, Telangana, India.

The Bidder shall acquaint himself by a visit to the site, if felt necessary, with the conditions prevailing at site before submission of the bid. The information given here in under is for general guidance and shall not be contractually binding on BHEL/Owner. All relevant site data /information as may be necessary shall have to be obtained /collected by the Bidder.

APPROACH TO SITE

The distance from Manuguru to Major cities in state:

City	Km
Hyderabad	345
Warangal	180
Bhadrachalam	38
Kothagudem	70
Khammam	130
Vijayawada	195

District: KHAMMAM

State : TELANGANA

Nearest Airport: The nearest airport is Vijayawada Airport but the most used airport is the Hyderabad International Airport.

Nearest Railway Station: Manuguru railway station is 10KM from nearby town. However Warangal / Vijaywada railway Station is major railway station near to Manuguru.



PROJECT INFORMATION
FOR
4 X 270 MW BHADRADRI TPS

SPECIFICATION NO. PE-TS-411-553-A001

VOLUME II - B

SECTION - B

REV 00

DATE APRIL 2015

1. Owner : TSGENCO
2. Project Title : 4X270 MW Bhadradri TPS
3. Location : 16 Km from Manuguru Railway station
4. Nearest Railway Stn. : Manuguru
5. Temperature
 - a. Mean daily minimum ambient temperature during oldest month of the year: 11.5 Deg.C
 - b. Mean daily minimum ambient temperature during hottest month of the year: 45.1 Deg.C
6. Rainfall: Intensity of rainfall @ 50 mm/hr considering heaviest fall in 24 hrs
7. Wind Data: Basic wind speed at 10m height : 44 m/sec
8. Wind pressure As per IS: 875 Part III- 1987
9. Seismic Zone: Zone III as defined in IS:1893 (part-1)-2002 according to Indian Standard Seismic Zoning Map

10	Power Supply : The power supplies for distribution and auxiliaries shall be as under:	
	a) In plant generation	16.5kV $\pm 5\%$, 3ph, 50Hz $\pm 5\%$, high resistance earthed.
	b) MV distribution	6.6kV $\pm 6\%$, 3ph, 3w , 50 Hz, + 5 % to - 5%, Non-effectively earthed
	c) LT distribution	415V $\pm 10\%$, 3ph, 4W, 50Hz + 5% to -5%, Effectively earthed
	d) Motor rated above 160kW	6.6kV $\pm 6\%$, 3 ph 50Hz +5% to -5%.
	e) Motor rated 160kW and below all motorized actuators.	415V $\pm 10\%$, 3 ph, 50Hz +5% to -5%.
	f) For motors equal and below 30kW winding heating	24V AC $\pm 10\%$, 50 Hz %, [to be generated in 415V switchgear by vendor]
	g) DC Motors	220V DC + 10% to - 15%, 2 wire ungrounded system
	h) Control supply for relay panel/ 6.6kV breakers/415V breakers and DC emergency lighting.	220V DC + 10% to - 15%, 2 wire ungrounded system
	i) UPS for instrumentation & Control system	240V AC $\pm 1\%$, 1 ph ,50Hz $\pm 0.5\%$ 2 Wire AC system
	j) Control supply for 415V Motor contactors/AC Control circuits [to be generated in MCC /panel by vendor]	110V AC $\pm 10\%$, 50Hz + 5% to -5%.
	k) Diesel Generator emergency supply	415V $\pm 10\%$, 3ph,3W, 50Hz +5%to -5%.
11	Fault levels	
	a) 400kV	40kA rms for 1 sec
	b) 6.6kV	40 kA rms for 1 sec.
	c) 415V	50 kA rms for 1 sec.
	d) DC Supply	25 kA



**TECHNICAL SPECIFICATION
4X270 MW BHADRADRI TPS
TECHNICAL SPECIFICATIONS
AIR CONDITIONING SYSTEM**

SPECIFICATION NO. PE-TS-411-553-A001

VOLUME - IIB

SECTION - C

REV. 00

DATE: APRIL 2015

SECTION: C

TECHNICAL SPECIFICATIONS



**TECHNICAL SPECIFICATION
4X270 MW BHADRADRI TPS
TECHNICAL SPECIFICATIONS
AIR CONDITIONING SYSTEM**

SPECIFICATION No: PE-TS-411-553-A001

VOLUME II B

SECTION C1

REV. 00

DATE: APRIL 2015

SECTION: C1

SPECIFIC TECHNICAL REQUIREMENT

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 1 of 28

1. FUNCTION

The purpose of the system is to provide air-conditioning system for different areas of 4 x 270 MW, BHADRADRI TPS under the scope of BHEL.

2. SYSTEM DESCRIPTION

2.1 MAIN POWER HOUSE BUILDING- Unit I & II (AC PLANT-1)

- a) A Central Chilled water type air conditioning plant shall be provided to cater to the air conditioning requirements of the following areas.
 - Central Control Room.
 - EER Room
 - Computer Room
 - UPS Room
 - SWAS Room (Dry panel)
 - Shift in-charge room
 - Office area, conference room etc.
- b) The air conditioning plant shall comprise of 1 No VAM as working and 1 No Screw Chilling machine as standby. The condenser cooling water shall be circulated through these units by means of 2 Nos (1W +1 SB) horizontal split casing centrifugal pump sets and 2 Nos (1W +1 SB) FRP cooling towers. The chilled water produced by the chilling units shall be circulated to the air handling units by means of 2 Nos (1W +1 SB) horizontal centrifugal pump sets. These AHU shall be located in AHU rooms located adjacent to air-conditioned areas in Power House Building (AHU room shall contain 3 x 50% capacity AHU). The conditioned air from AHUs shall be distributed to the air-conditioned areas by galvanised sheet steel ducting and extruded Aluminium grilles / diffusers with volume control dampers and supporting frames. The return air is led back to the AHU Room in ducts for air conditioned areas at 15.5M level in control tower.
- c) FCU shall be provided for SWAS rooms.
- d) Controls for the AC plant shall be PLC based.

2.2 MAIN POWER HOUSE BUILDING- Unit III & IV (AC PLANT-2)

Similar kind of system as described above shall be provided for unit III & IV

2.3 ESP Control room for Unit-I, II, III & IV (AC PLANT 3, 4, 5 & 6)

The air conditioning plant shall comprise of air Cooled Precision package unit having (n+1) configuration, where n is the no of working units. The conditioned air from Precision AC is distributed to the air-conditioned areas by galvanised sheet steel ducting and extruded Aluminium grilles / diffusers. The return air is collected above the false ceiling and led back to the PAC room which acts as mixing plenum for return and fresh air.

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 2 of 28	

2.4 SERVICE AND ADMINISTRATION BUILDING

Air cooled type Package AC shall be provided for each floor of service and administration buildings.

2.5 SPLIT TYPE AIR CONDITIONERS

Split type air conditioners (air cooled) shall be provided to cater to the air conditioning requirements of Compressor house control room areas having workstation for auxiliary plant. For areas requiring multiple working split ACs, One (1) No. standby (of same capacity) shall be provided. (Only those aux. control rooms which are under scope of BHEL). Local isolator / MCB shall be provided with split units.

Local Distribution Boards containing Switch / MCB shall be provided for Split Air Conditioners, and FCUs. Each split unit shall also be provided with suitable rating stabiliser.

Single phase electrical feeders of following ratings shall be provided for split units. Bidder to ensure the suitability as per these feeder requirement.

Capacity of Split AC	Single phase feeder
1.5 TR	2.2 KW
2TR	3.0 KW

3.0 DESIGN CRITERIA

3.1 SYSTEM DESIGN CRITERIA

A) THE OUTSIDE DESIGN CONDITIONS CONSIDERED ARE AS FOLLOWS:

	Summer	Monsoon	Winter
DBT (°C)	36.9	31	28.8
WBT (°C)	25.6	26.2	22.8

b) The inside design conditions to be maintained shall be as under:

Summer & Monsoon: $24 \pm 1^{\circ}\text{C}$ & RH $55\% \pm 5\%$ for main control room.

- For winter heating load calculation, 50% of combined light load and eqpt / panel load as available in the room shall be considered.
- A design margin of 10% on total sensible and latent heat shall be considered while designing the AC Plant capacity for each area.
- All Condenser cooling water pumps and chilled water pumps, AHUS and FCUS shall have further, 10% margin on their flow capacities.
- Lighting load considered shall be 20 W/m² except shift in charge engineer's room where 15 W/m² shall be considered.

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 3 of 28	

- g) The Occupancy for computer room, control room, EER & SWAS room shall be considered as actual.
- h) Fresh air at the rate of 1.5 air changes per hour for the control rooms and 1 air change per hour for office areas or at least 34 Cu. M/Hr. per person, whichever is higher, should be considered to achieve pressurization of air conditioned space and to meet the ventilation requirement of occupants
- i) Electric power supply shall be 415V $\pm$ 10%, 3 phase, 50 Hz. $\pm$ 5% A.C.

3.2 SYSTEM CAPACITY AND CONFIGURATION:

a) For AC Plant 1:

250 TR Actual capacity VAM as working and 250 TR Actual capacity screw chillers as standby shall be provided.

b) For AC Plant 2:

Same as AC plant 1.

c) For AC Plant 3:

15 TR Actual capacity air cooled Precision type package units having (n+1) configuration, where n is the no of working units shall be provided.

d) For AC Plant 4, 5, 6:

Same as AC plant 3.

3.3 LAYOUT CONSIDERATIONS:

a) AC PLANT-1

- i. The central chilled water plant, Condenser Water & Chilled Water Pumps for AC Plant shall be housed in AC Plant Room at 0.0 M level Power House Building (refer drawing attached elsewhere in the specifications).
- ii. The AHUs for this AC Plant would be located as under:
 - 3 AHUs (3 x 50 %) for areas at 15.5 m i.e CCR, CER unit I & II, computer rooms, shift in-charge, PADO room etc, located in AHU Room at 21M level of Power House Building (refer drawing attached elsewhere in the specifications)..
 - FCUs shall be provided for SWAS (dry panel room).
- iii. The Cooling Towers, Make-up water Storage Tank, Expansion Tank shall be located at 21 M level of Power House Building (refer drawing attached elsewhere in the specifications).
- iv. 5 T Capacity electric hoist with Monorail arrangement shall be provided for the AC Plant room only for maintenance purpose.

b) AC PLANT-2

Same as AC Plant 1

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 4 of 28

c) AC PLANT-3

- i. Air Cooled Precision package units shall be housed in each ESP PAC Room of ESP Building (refer drawing attached elsewhere in the specifications) for Unit-1.
- ii. The outdoor units shall be located at 9m /12m.

d) AC PLANT-4, 5 & 6

Same as AC plant-3

Note: The locations given above are tentative and may change during detail engineering.

3.4 SPECIAL CONSIDERATION

- a) Water flow rate for chilled water pump selection : 0.7 cmh/TR
- b) Water flow rate for condenser water pump selection : 1.0 cmh/TR
- c) Condenser water pumps, chilled water pumps, AHUs and FCUs shall have further 10% margin on their flow capacities.
- d) The IKW/TR of screw chillers shall not be more than 0.7 at 100%
- e) All equipment shall be of high quality and high efficiency meeting the stipulated power consumption as defined elsewhere in the specifications.

4.0 EQUIPMENT DESCRIPTION

4.1 WATER COOLED SCREW CHILLER:

a) COMPRESSOR:

The refrigerant compressors shall be screw type. The compressor may be hermetically/ semi hermetically sealed and shall be designed for direct drive.

The compressor assembly shall be adequately designed for minimum vibration and noise disturbances.

The shaft seal, if applicable, for semi hermetic type shall be of proven design.

All safety devices against high pressure refrigerant, low pressure refrigerant and low oil pressure shall be provided.

The compressor units must be provided with oil pressure regulator. All safety devices should be electronically controlled. The compressor shall also be provided with an oil drain plug. This should be so located that the oil can be drained out without removing the compressor.

Capacity control must be achieved by use of slide valve, which provides fully modulating capacity control from 100% to 10% (20%, at least) of full load. The slide valve shall be actuated by oil pressure controlled by external solenoid valves.

The compressor motor shall be sized for 115% of maximum rated power required for the unit including the drive loss.

The compressors shall be provided with built-in-unloaded starting device. The compressor shall have automatic capacity control device preferably built-in-type to match reduced refrigeration

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 5 of 28

load. The oil separator should be effective enough to incur gravity drop out of oil from the refrigerant gas before it enters the condenser

b) Heat Exchangers (Condensers & Chillers):

All condensers shall be of shell and tube type with water in the tubes and refrigerant in the shell.

All chillers for chilled water plant shall also be of shell and tube type.

The heat exchangers shall be designed for a minimum working pressure of 10.5 kg/Sq.cm gauge (about 150 psig) on the water side and 12.0 Kg/Sq.cm (for R-134a refrigerant) and 17 Kg/Sq.cm 9 for R-22 refrigerant) on the refrigerant side and shall conform to the latest ASME CODE for unfired pressure vessels SECTION-VIII.

The design pressure shall have a reasonable margin over the said working pressure.

The average velocity of water in tubes shall not be more than 2.5 M/Sec. Water heads or refrigerant heads of the heat exchangers shall be designed such as not to allow leakage of fluid from one pass to the other. Tube supports of adequate strength shall be provided to prevent the tubes from sagging and vibrating. The supports shall be as per TEMA Standard.

The condensers shall be designed to provide at least 2°C. sub cooling of refrigerant under rated design condition. The water chillers also shall be designed to superheat the refrigerant by at least 3°C under rated design condition. Testing and other design feature of the heat exchangers shall meet the requirements of TEMA Class-C heat exchangers or approved equal. The heat exchangers shall have open able water boxes for ease in maintenance.

The tube for water chillers shall be of de-oxidized copper with or without integral fins. The tubes for the condensers shall also be of copper with integral fins. The tube wall thickness at any point shall not be less than 18 SWG. The baffle plates and the tube sheets shall be made of steel. The shell shall be made up of seamless steel tube or shall be fabricated from flange quality steel plate (ASTM-A 285 Grade-C). The tube support plates shall be made of flange quality carbon steel plates and shall be as per TEMA Standard (Class C).

The heat exchangers shall be provided with vent valve, relief valve, and or safety fusible plug on refrigerant side and vent valve and drain valve on water side (at every section of the baffled shell of heat exchanger).

The tenderer shall quote packaged unit having compressor, condenser and chiller assembly together in a single frame work and mounted on a common base plate.

Each heat exchanger shall be provided with water flow switch. This shall be interlocked with the control of the individual refrigeration system. All the heat exchangers shall be provided with standard connections like thermo- wells, inspection valve, anti-freeze thermostat for chillers and external equalizer connection for expansion valves for chillers.

c) Refrigerant Piping:

Refrigerant piping shall be either of M.S. Seamless (as per IS- 1239), Part-I heavy grade) or copper tube (IS-5493) or ASA-B-31.5). Pressure drop in hot gas, liquid and suction lines should not exceed the value corresponding to 1.11°C change in saturation temperature of the fluid.

Velocity in the discharge and suction pipe of the refrigerant shall not be so high as to create undue vibration and noise. Velocity in the vertical length of discharge and suction pipe of the refrigerant shall be high enough to carry the entrained oil in the refrigerant, even in case of unit running at lowest partial capacity. An angle type drain valve with male flare outlet

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 6 of 28

connection shall be installed at the bottom end of each vertical riser pipe to drain any accumulated oil.

Instrument piping for gauges, switches etc. shall be of copper only. Capillary tubes shall be used wherever possible.

- d) The IKW/TR of screw chillers shall not be more than **0.7** at 100%.
- e) Accessories (valves, pressure gauges, water flow switches, controls and instruments etc shall be provided with each screw chiller as per customer approved PID
- f) Each Chiller unit shall consist of:

A	Screw Compressor	One (1)/Two (2) Nos. per Screw Chiller Unit (As per Manufacturer's standard)
1	Type	Rotary Screw type, hermetic/semi- hermetic, directly driven, R-134a duty
2	Accessories	Suction and discharge valves, Oil Separator, HP, LP, OP (if applicable) Motor overload cutout, Automatic capacity control arrangement with automatic unloaded starting device, Anti Recycle device, Heater, Setting and Overhauling tools, foundation bolts, vibration isolating device etc
3	Drive motor for above	Adequately sized Induction Motor suitable for AC 415V±10%, 3-Phase, 50Hz ±5% power supply.
B	Refrigerant Condenser	One (1) No
1	Type	Water cooled, horizontal, shell and tube R-134a duty & capacity to match the above compressor with integrally finned copper tubes with steel shell having adequate surface area to cater the requirement of the above compressor & to provide sub-cooling by 2°C at least.
2	Design fouling factor	Not less than 0.0002 Hr.Sq.M.Deg. C/Kcal (0.001 Hr-Sq.ft Deg.F/BTU).
3	Accessories	Relief valve, vent connection with valve, De-scaling connection, charging connection, water flow switch, drain connection with valve. Thermo-well connection on waterside, liquid trap etc.
C	Refrigerant Chiller	One (1) No
1	Type	Horizontal shell and tube direct expansion type R-134a/water duty with copper tube having adequate surface area to provide superheating by 3°C
2	Design fouling factor	Not less than 0.00013 Hr.Sq.M.Deg. C/Kcal (0.00065 Hr-Sq.ft. Deg.F. / BTU)

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 7 of 28

3	Accessories	Liquid and water connection provided with thermo-wells, water flow switch, pressure gauge connections. At least 39 mm thick insulation of Nitrile Rubber foam/XLPE or equal finished with 24G aluminium sheet cladding, with removable type insulated flange cover, water side drain connection with valve in every portion of the chiller isolated by baffle plate
D	Piping & Auxiliaries	Common base frame for compressor, condenser, chiller unit fabricated of M.S. angles, channels etc. anchor bolts, nuts, hot gas piping, cold gas piping, liquid refrigerant piping all of seamless steel or ERW steel pipes, insulation of cold gas piping with minimum 39 mm thick Nitrile Rubber foam/XLPE or equal finished with 24G aluminium sheet cladding liquid valves, muffler if needed, gauges and instrument piping, filters, drier, moisture indicator isolating valves etc. as may be required for safe and trouble free operation. The entire chiller package assembly shall be installed with spring type vibration isolation devices. (One set for each chiller unit)
E	Controls	Electronic expansion valve, solenoid valve in the refrigerant circuit, operating thermostat and anti freeze thermostat. Microprocessor based control panel of each chiller unit shall provide safety against high & low refrigerant pressure, low oil pressure, freezing of chilled water, overload, winding heating and single phasing and phase reversal of compressor by means of high & low pressure transmitter, oil pressure transmitter, temperature sensors & transmitter, O/L relays, thermistor relays, etc. It shall also provide capacity control by sensing low chilled water return temperature through operating thermostat, flow switches for the condensers and chillers, compressor unloaded starting device (One set for each chiller).
F	Oil and Refrigerant	First charge of refrigerant R-134a and oil for the above chiller units.

4.2 VAPOUR ABSORPTION MACHINE

The vapour absorption machine shall be steam fired, packaged, factory assembled and tested and shall be complete in all respects. The steam required for the units shall be tapped off from the auxiliary steam in such a way that even when any of the unit is under shutdown, operation of the unit shall not be jeopardized.

It shall comprise of high temperature generator, low temperature generator/ condenser assembly, Evaporator / absorber assembly with eliminators, regenerative heat exchangers, purge recovery units, absorbent pumps, refrigerant pumps, all interconnecting piping, valves, and other accessories, micro processor based Control panel / PLC panel incorporating controls and safety & interlocks, required charge of lithium bromide solution and refrigerant for all the units, Cooling / heating switch valves, Structural mounting base for all components etc.

High Temperature Generator shall consist of tubes of Stainless Steel or as per manufacturer's standard and shall be supported properly in the shell and complete with required accessories and safety devices. The shell shall be fabricated from MS plate as per IS:2062 and tube sheet

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 8 of 28

coming in contact with steam shall be of boiler quality as per IS:2002 Gr. B/SA-516 and of welded construction.

Low Temperature Generator cum Condenser shall be housed in common welded carbon steel shell with one compartment for generator and the other for condenser with eliminators between the two sections to avoid Lithium bromide carry over, separate tube bundles for each section, required accessories and safety devices etc. The tubes of generator shall be as per manufacturer's standard. The tubes of condenser shall be cupro-nickel or as per manufacturer's standard.

Evaporator cum Absorber shall be complete in all respects with necessary supports and accessories housed in a common fabricated carbon steel shell. The material of construction of evaporator and absorber tubes shall be as per manufacturer's standard. Method of construction shall be similar to that of the high temperature generator. The assembly shall be complete with necessary supports, base and safety provisions.

Regenerative Heat Exchangers shall be designed for maximum heat exchange between the low temperature absorbent from the absorber and the high temperature absorbent released from the generator. There shall be one low temperature and one high temperature heat exchangers as well as one for the condensate drain.

Purge Recovery Unit shall be sized to remove all non-condensable gases by vacuum into the storage provided for this purpose. They should be ejected into the atmosphere by the suitable vacuum pumps (2 x 100% capacity) for each VAM unit. The unit shall include all the necessary piping and valves.

The condensate from the unit shall be collected in a condensate storage tank and shall be disposed off through pumps (2 x 100% capacity).

The refrigerant and absorbent pumps shall be canned motor type and shall be complete with motor of adequate capacity (each of 2 x 100% capacity). The material of construction for shaft and impeller of the pumps shall be as per manufacturer's standard. Both the pumps shall be

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	Page 9 of 28		DATE: APRIL 2015

complete with isolating valves, to enable on-line maintenance. Circulation fluid shall be used as cooling and lubricating medium.

Necessary corrosion inhibitor shall be of non-toxic type. Chromate based inhibitors shall not be used.

The whole unit shall be given anticorrosion (both internal and external) treatment and three coats of epoxy painting over a coating of suitable primer.

Each Vapour absorption machine (VAM) shall comprise of the following:

- a) One (1) No. water cooled condenser complete with all connections etc.
- b) Absorber, Evaporator & generator sections in a single / double shell.
- c) Refrigerant, absorbent and vacuum pumps for VAM shall be of 2 x 100% capacity (1 W +1 S) and switching over to standby pumps shall be automatic.
- d) PRDS to suite the VAM requirement
- e) Lot-Interconnected piping, refrigerant pump, solution pump, heat exchangers, purging system, prewired control system with all instruments, pneumatic tubing, cables, valves interlocking safeties and controls etc.
- f) Lot – Condensate recovery system complete with necessary steam trap, condensate storage tank, condensate pumps(1W + 1SB) for pumping the condensate back to the condensate header and desuperheating pump (1W + 1SB) for spray to PRDS.
- g) Lot-MS structural frame work with anti-vibration pads. Initial fill of Lithium bromide absorber.

Lot-Controls comprising the following: -

- i) All controls and instruments for protection of VAM including anti-freeze protection. ii) Other control equipments as required to fulfil the control philosophy.

4.3 CONDENSER AND CHILLED WATER PUMP SETS

- a) Each pump shall be of horizontally split casing, centrifugal type, directly coupled to electric drive motor and mounted on a common base plate. The pump shall be complete with casing, impeller, renewable type wearing rings, shaft, shaft sleeve, bearings, stuffing box/ mechanical seal as specified, couplings, base plate etc.
- b) Pumps with motor of 6 KW capacity or below can be of mono-block construction. Pump head-capacity characteristics shall gradually rising from operating to shut off point without any zone

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 10 of 28

of instability. The pump BHP-flow characteristics shall preferably be non-overloading type beyond rated capacity point.

- c) Material of the pump shall preferably as follows (all material shall be of tested quality).

Casing : Cast iron, grade 20 as per IS-210

Impeller & Wear Ring : Bronze

Shaft : Carbon steel C-45, IS 1570 or Class- IV, IS 1875

Shaft sleeve : Bronze

- d) Pumps shall be provided with suitable bearings sized adequately to take the maximum possible unbalance load occurring due to all mechanical and hydraulic reasons. The bearings should have a minimum working life of 40000 hours.
- e) Pump and drives shall be directly coupled through a flexible coupling. Suitable coupling guard shall be provided for each pump.
- f) Each pump shall be complete with pressure gauge at the suction and discharge, isolating valves, all integral piping required for sealing and cooling, casing drain and vent connections etc. The pressure gauge of pump shall be connected with a siphon and a two position brass cock.
- g) The rated HP of the motor shall provide 15% margin over the rated BHP of the pump.
- h) The design of the pumps shall conform to the relevant IS Code, standards of hydraulic institution of U.S.A. or approved equivalent.
- i) Major rotating components of the pumps like impellers, balancing drums etc. shall be individually balanced statically.
- j) The critical speed of the pump motor shall be at least 25% above the operating speed.
- k) All pumps and motors shall be aligned properly, and bolted and dowelled to a common base frame. Centrifugal, horizontally split casing, single stage directly coupled to electric motor and mounted on a common base frame.
- l) The pump speed shall preferably not more than 1500 rpm. The pump shall be designed for continuous running.
- m) Accessories : Pressure gauges at suction and discharge, isolating valves, all integral piping, required for sealing, cooling etc. strainers, check valves, flexible coupling guard, foundation bolts and nuts etc. and other standard accessories as may be necessary for successful operation. Vibration isolators shall also be supplied. Accessories (valves, pressure gauges, water flow switches, controls and instruments etc shall be provided with pump as per customer approved PID.
- n) Motor for the above: Adequately sized TEFC, squirrel cage induction motor, suitable for 415 V $\pm$ 10%, 3 pH, 50 Hz $\pm$ 5% supply.
- o) Complete insulation with minimum 39 mm thick Nitrile Rubber foam/XLPE or equal with 24G aluminium sheet cladding shall be provided for chilled water pumps.

4.4 AIR HANDLING UNIT (Double SKIN TYPE)

Fan

The fans shall be DIDW forward curve bladed centrifugal type. The number of fans per unit shall be as per standard of the manufacturer. The impeller and the scroll casing of the fans

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 11 of 28

shall be made of steel and protected with suitable painting. The fan shaft shall be of carbon steel.

Bearing shall be heavy-duty self-aligning type having minimum working life of 40000 hours. The fans shall be dynamically balanced. The motor shall be mounted outside the AHU casing and shall be connected to the common fan shaft by a V-belt drive. The motor shall be adequately designed to prevent overload and shall have minimum 20% margin over maximum BHP in working range.

Drive

Centrifugal fans shall be equipped with V-belt drive and belt tensioning equipped with removable guard to avoid accidental hazards. TEFC squirrel cage Induction motor Suitable for above fan and AC 415V $\pm$ 10%, 3 Ph, 50 Hz $\pm$ 5% supply,.

Dry Panel type HDPE filter

The filter media shall be designed to hold dust, sand and prevent it from being dislodged by vibration or other cause and passing through filter. The filters shall be of cleanable type construction and held corrugated by aluminum spacers.

The filter shall have G.I. frames of adequate thickness but not less than 20 SWG suitable for long use in an industrial plant. The filters may be in panels of size about 600 x 600 for easy handling of the same. Such modules shall be fixed with the ladder frame through Quick release mechanism. The face velocity of air across the filters shall not exceed 2.5 m/Sec. The maximum filter pressure drop shall not exceed 10 mm WG. Panel type dry HDPE filter having an efficiency of 90% down to 10 micron size particles.

Cooling Coils

The cooling coils for either DX or chilled water shall consist of seamless copper tubes with aluminum fins. Each AHU shall be provided preferably with only one number cooling coil. The Cooling coils for chilled water plant shall be equipped with motorized modulating 3-way mixing valve to control the chilled water flow. This cooling coil shall be designed for chilled water/air duty.

Even number of rows like 2,4,6 and 8 etc. shall be selected for any particular coil to facilitate connection of water/refrigerant only on one side of the unit. Fin design shall be chosen for the duty to be performed with special attention to the possibility of lint accumulation. However, in any case, number of fins in the coils shall not exceed 5/Cm. Velocity of air across the coils shall be limited to 2.50 m/Sec. In case of chilled water-cooling coil, arrangement for air purging and water draining from the coil is to be provided. In case of D-X type coil an equalizer connection to be provided for each section of the refrigerant circuit.

Casing

The casing shall be of double skin type and shall be constructed of minimum 0.6 mm gauge GI sheets with Aluminum structure. The outer skin shall be powder coated / pre plasticized. The double skin panel shall be 25mm thick with injected PUF insulation of density 40Kg / Cubm.

Base frames shall be supplied for floor mounted type units. Drain pans shall be of SS construction and may be manufactured of double bottom type or otherwise sufficient insulation shall be pasted with bituminous compound to avoid condensation on the outside surface. The Bidder shall guarantee against condensation of water on the outside of the unit. Panels of the casing shall be reasonably air tight with suitable gaskets with cams or similar fastenings for easy opening. Necessary arrangement shall be provided on the casing for measuring temperature and pressure in a cooling coil and static pressure difference between

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	Page 12 of 28		DATE: APRIL 2015

fan suction and discharge. Waterproof, vermin proof, thermal insulation shall be provided in between two skins of the casing by injection method. The thickness of insulation shall be adequate to arrest condensation of moisture on the outside surface of the units. The insulation shall be securely fixed so that the same does not fall out during operation of the units. f) The drain pan shall be extended to catch any free moisture carried over from the coils. The drain connection shall be readily accessible for cleaning and shall be generously sized.

Accessories (valves, pressure gauges, water flow switches, controls and instruments etc shall be provided with pump as per customer approved PID

Drain piping from the AHUs up to nearest drain point.

Serrated rubber pads for vibration isolation

4.5 High efficiency filter

The filters shall have efficiency of 99% down to 5 microns. The filters shall be of cleanable type construction of reinforced glass fiber or cotton fabric or fabric-like material sandwiched in between two galvanized wire netting arrangement in a uniformly corrugated form to increase the surface area. The filters shall have G.I. frames of adequate thickness suitable for long use in an industrial plant. The filters may be in panels of size about 600 x 600 for easy handling them.

High efficiency filter mounted in supply air duct shall be provided for air conditioning of all areas excepting areas served by FCUs. The filter panels shall be mounted on the ladder type angle iron holding frames. The frames shall be designed strong enough to take the load of double the pressure drop in dirty condition of the filters. Face velocity of air across the filters shall not exceed 1.5 m/sec and the maximum air pressure drop across the filter shall be limited to 12mm WG.

4.6 COOLING TOWER

Cooling tower shall be of cross flow induced draft two cell type with FRP casing and sump with air entry on all four sides and air discharge on top. The fan motor shall be easily accessible from outside and out of moist air steam.


Cooling tower shall be of sufficient capacity to cool the rated amount of water through the specified range at the design W.B. temperature.

The structural frame-work of the tower including all members and connections shall be designed for operating loads and prevailing wind pressure. Steel members shall be galvanized steel and be of sufficient size to safely withstand all imposed loads including maximum wind speed.

FRP casing sheets shall be clamped on close centers to the structural steel members. Rubber neoprene gaskets must be used on all bolted joints as a seal against water leakage.

The fan deck shall be of ample strength to support all loads normally encountered in operation and maintenance. Stiffeners shall be provided on the under side.

Galvanized Steel / Aluminium ladder with safety cage and hand railing shall be provided in such a number and locations as necessary to give safe and complete access to all parts to tower

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 13 of 28	

requiring occasional inspection or adjustment. An access door shall be provided in the fan deck and in the cell for ready access to the interior parts of the tower.

Honeycomb type fixed louvers shall be an integral part of PVC film type fill which also incorporates integral drift eliminators.

Formed PVC fill sheets shall have a suitable shape to minimize resistance to airflow. The entire fill assembly shall be sufficiently durable construction in operating conditions and shall be supported by hot dip galvanized steel structural tubes/members. Fill sheets shall be suitable to withstand hot water temperature of 55°C.

PVC eliminators integral to the fill shall have adequate efficiency to reduce drift loss to 0.05% of the water circulated.

The water distribution system shall be open basin type with gravity feed nozzles. The system shall be self draining and non-clogging and designed for flexible operation and ready accessibility. Suitable measuring orifices shall be provided. All main piping connections shall be brought out and end in flanges, to flexible connection.

The cold water basin shall be of FRP construction. The basin shall be complete with float valve for make up water control quick fill connection with valve, drain connection with valve and overflow connection. The make-up water supply pipe shall be positioned at least twice in diameter of pipe above maximum water level in the basin. The water basin shall be constructed such as to provide a coarse strainer of Brass wire mesh easily accessible from outside.

Fan shall be of the propeller type, cast aluminium and multibladed aerofoil construction with adjustable pitch. The entire fan assembly shall be statically balanced. Outlet velocity of air shall be not less than 610 meters per minutes and the fan tip speed shall not exceed 75 meter per second.

Each fan shall be either belt driven or gear driven. Where reduction gears are used, housing shall be of heavy cast iron construction with large oil reservoir and complete with supply of oil.

Fan motors shall be of the totally enclosed fan cooled type and of the required capacities. Motor shall be located outside the moist air stream.

Fan drive shaft using reduction gearing shall be dynamically balanced and connected through flexible couplings.

The mechanical equipment assembly shall be adequately supported on the fan deck.

Fan discharge batch shall be covered with galvanized wire mesh to prevent birds nesting during idle periods.

All nuts, bolts and fasteners used in the cooling tower shall be not dip galvanized.

- a) Design wet bulb: 28° C.
- b) Approach: 5° C.

4.7 AIR-COOLED PACKAGED AIR CONDITIONER (PRECISION TYPE)

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 14 of 28	

Compressor

The compressor shall be hermetically sealed scroll type medium speed, single acting type designed for R-407C/410/134a duty. The compressor shall be complete with crank case heater (to be energised when compressor is on off cycle). The compressor shall have proper lubrication system.

Safety devices viz. high-pressure switch, low pressure switch, low oil pressure (if applicable) shall be provided and such devices shall be electronically operated. Manual reset on safety cut out shall be provided. The horsepower for the compressor motor shall be adequately sized or 110% of the rated power required for the unit including drive loss. Capacity control shall be devised by providing at least two compressors.

Condenser

Condensers shall be of air cooled type with condenser fans tube and fin arrangement duly housed in a sturdy casing for outdoor installation.

Evaporator Cooling Coil


The cooling coil shall be direct expansion type with multi-row deoxidised copper tubes with aluminium fins. Air velocity across the coil shall be limited to 2.5 m/sec. The coils shall be pressure tested and thoroughly dehydrated before assembling. The coil shall be placed to make the system draw through type. Refrigerant feed control shall be by electronic expansion valve. Temperature control shall be through microprocessor based control panel. The cooling coil shall be to produce the capacity required under specified coil condition and air quantity. Heat load calculation to check the system selection shall be carried out and submitted by the tenderer.

Evaporator Fan

The fan shall be heavy duty DIDW centrifugal type statically and dynamically balanced with forward curve blade, indirect drive designed for high efficiency and quiet operation with automatic belt tension adjustment mechanism. Fan wheels and casing shall be constructed of steel and mounted on steel shaft. The bearings shall be ball bearing type mounted on vibration absorbing rubber mounts. The fan motor shall be mounted within the cabinet. Motor base shall be adjustable for alignment. Motor horsepower shall be sized for 120% of the rated power required including the drive loss. The supply fan shall be sized to deliver the required air quantity against the total external static pressure required for the system application, after taking care of all internal static pressure requirements of the units.

High Efficiency Filter

A set of High efficiency filters shall be located inside the PAC unit cabinet. The filters shall be high efficiency of 99% down to 5 microns. The filters shall be of cleanable type construction of reinforced glass fiber or cotton fabric or fabric-like material sandwiched in between two galvanized wire netting arrangement in an uniformly corrugated form to increase the surface area. The filters shall have G.I. frames of adequate thickness suitable for long use in an industrial plant. The filters may be in panels of size about 600 x 600 for easy handling them. The filter panels shall be mounted on the ladder type angle iron holding frames. The frames shall be designed strong enough to take the load of double the pressure drop in dirty condition of the filters. Face velocity of air across the filters shall not exceed 1.5 m/sec.

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 15 of 28	

Humidifier

The humidifier shall be of Electrode type and shall be placed inside the PAC unit cabinet. The humidifier shall be electronically controlled through the built-in microprocessor based control panel of the unit. A provision of make-up water connection with the humidifier shall be kept with the Unit cabinet.

Electric Strip Heater

The PAC unit shall be provided with built-in electric strip heater electronically controlled through the built-in microprocessor based control panel of the unit. Such control includes both operating and safety controls with the sense of air temperature at the RA path and at the downstream side of the heater respectively.

Casing and Cabinet

All components shall be housed in a welded sheet metal cabinet of double skin of not less than 22 G thick MS powder coated sheets. The gap between two skins is filled up with at least 25mmthick PUF/ EPS insulation. Different sections shall be constructed with framework and connected with each other in an air tight manner through gaskets, thermal barriers and sealant. Removable panels shall be constructed of framed 1.6 mm sheet steel with angle iron framing. Units shall be provided with 316 L.S.S. fasteners for easy removal and access for servicing. Air handling section of evaporator shall be provided with an acoustic lining of 25 mm thick fiberglass covered with fiber glass cloth and perforated aluminium sheet on the inside surface of the unit casing. Insulated condensate drain pan of SS construction shall be provided within the unit. The unit shall be factory assembled, wired, with inter connecting refrigerant piping and built-in microprocessor based control console and tested as per the relevant code. The return air opening shall be on the front face with a matching grille of same colour finish

4.8 Fan Coil Units

The fan coil units shall be cabinet type floor mounted on self standing pedestal or ceiling suspended type as applicable. The units shall be complete with chilled water coil, one or more centrifugal fans and motor, cleanable filters of non-woven or HDPE media, double wall insulated condensate drain pan with at least 15 mm thick expanded polystyrene (self extinguishing quality) insulation sandwiched between top and bottom sheets of drain pan and 18 gauge sheet steel drip pans within the unit. Cabinet shall be constructed of 18-gauge die-formed cold-rolled steel, with primer and coated with hammer tone/baked enamel finish. Corners shall be rounded without break lines.

The cabinets shall be of sufficient size to enclose all piping and control valve and shall have access doors to piping and controls. Piping and control valves shall be so accommodated within the unit, that drippings (if any) fall on the drip pan and then into drain pan.

All pipes, valves within the unit shall be insulated with insulation tubes and tapings. External piping shall be insulated as per insulation specification of pipes. Access panels shall have positive locking fasteners for easy removal.

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	Page 16 of 28		DATE: APRIL 2015

The filters shall be mounted at the bottom section of the cabinet with filter box. All cooling coils shall be standard three row staggered seamless copper tube with aluminium plate fins mechanically bonded to copper tubes. Tubes shall be minimum 10 mm. O.D. and wall thickness shall be minimum 0.5 mm.

All bends and joints shall be enclosed within the insulated end sections of the base unit for protection against sweating. Each coil shall be provided with an air vent and drain plug. All coils shall be factory tested at 16 Kg. per Sq.cm. air pressure while submerged in water. Fin spacing shall not be less than 4 fins per Cm. Tubes shall be mechanically/hydraulically expanded for thermal contact with fans.

Fans shall be centrifugal, forward-curve, direct driven by shaded- pole multi speed motor. All fan coil units shall be equipped with copper piping connection and manual air vent at the cooling coil. Other accessories shall be unit thermostat for individual unit, containing three speeds and on/off control for fan speed, motorized three-way diverting valve for individual unit, strainer, ball valve and globe valve, adjustable discharge air grills. The fan coil unit shall be selected for the lowest operating noise level. It should offer capacity at the lower speed.

4.9 Fresh air unit

Fresh air unit consisting of a tube axial flow/centrifugal fan with drive motor, inlet louver with bird screen, dry panel HDPE filters, high efficiency filters volume control damper, supports, supporting structures etc. for each AHU room/ Precision PU room. 1 x100% capacity Fresh air unit shall be provided in each AHU room/ Precision PU room. For normal package unit rooms fresh air arrangement comprising of louver filter and dampers shall be provided.

4.10 Expansion Tank

The expansion tank shall be made of G.I or FRP and shall be of adequate thickness & suitably reinforced. It shall be complete with make-up connection with float valve, quick fill connection, overflow connection and drain connection with valve. The tank shall be provided with level gauge glass and shall be completely insulated with 6 mm thick Nitrile Rubber foam/XLPE or equivalent with black UV protection coating.

4.11 Make-up water Tank

The Make-up water tank shall be made of G.I or FRP and shall be of adequate thickness & suitably reinforced. It shall be complete with make-up connection with float valve, quick fill connection, overflow connection and drain connection with valve. The tank shall be provided with level gauge glass. This tank shall supply make-up water to Cooling towers, Expansion tank and humidifiers.

4.12 Humidification System

Humidifying unit shall be pan type as per manufacturer's standard. The unit shall be complete with humidistat for ON-OFF operation of the section. Humidifiers with the Precision Air Conditioners shall be of electrode type. Whenever the humidity of the conditioned space reaches the minimum allowable limit, the humidifier shall be energized to restore the relative humidity. The humidifier shall be such controlled that it shall not exceed the maximum

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 17 of 28

allowable limit of relative humidity in the conditioned space. The humidifier shall be sized and designed accordingly.

The pan humidifier shall have three immersion type electric heaters each of adequate capacity. The water tank shall be hot dip galvanized with float-operated valve for maintaining sufficient water level. The humidifier tank shall be fitted with low-level switch for putting off the electric heaters in case of low level of water. Visual alarm shall also be provided for low level of water. The tank shall be provided with a drain connection, overflow connection. 3-Phase supply for the immersion heaters should be energized from the signal generated from the space humidistat. Necessary wiring arrangement is to be provided by the tenderer.

4.13 Heating System

Heating equipment wherever required shall be electrical type. All frame members, control box cover and associated sheet metal parts are to be heavy gauge steel with corrosion resistance treatment. Heating equipment may be required for winter heating as well as for reheating. Reheating heaters may be used for winter heating also. Electric heaters shall be of fin-tube type of required KW rating, with fins permanently brazed to metal sheath. The metal sheath and fins shall be of G.I. sheet material. Wherever electric heaters are installed in the ductwork, size of ducts should be suitably increased to effect the additional resistance created by the heaters. All heaters shall be mounted on such insulators that there shall be no leakage current under all weather conditions including high humidity operation. The mounting frame shall be suitably grounded by earth wires/earth leads at two points.

An air stat is to be installed such that in case there is no circulation of air around the heater coils the heaters shall be de-energized. Wherever the heaters are installed in the duct work the terminal block shall be such positioned in a junction box that it shall be outside the duct work in an accessible position. The junction box shall be vermin proof, rat proof and provided with a hinged cover. A caution plate as per I.E.E. rules shall also be provided. Access door shall be provided in the duct near the heating coil for easy inspection and removal/replacement/fixing of individual strip heaters. The capacity of heaters shall be distributed over three phases. In case of re-heaters the controller shall be humidistat and in case of winter heaters the controller shall be thermostat.

4.14 Water Piping

All condenser cooling water piping of diameter 150 mm NB or below shall conform to IS-1239, Part-I, heavy grade and IS-3589 for sizes above 150 mm NB with minimum pipe thickness of 6 mm.

The piping shall be so designed that the water velocity through the piping shall not exceed 3 m/Sec. and also the piping friction drop shall be limited to 4 m per hundred meter of pipe length.

The pipes shall be of plain end in case of M.S. Pipes (i.e. suitable for welded connections) as far as possible.

Counter-flanges for connecting to flanges on valves or equipment shall be made of IS-2062 or superior and shall preferably be slip on type, suitable for welding on the piping in case of All

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	Page 18 of 28		DATE: APRIL 2015

bolts and nuts for flange connection shall be of hexagonal carbon steel type as per IS-1363 and with the material and other requirements as per IS-1367.

For piping of size above 100 mm bends and fittings, fabricated at site from straight length of piping, would be acceptable. If instead, the Bidder uses the regular type fittings/bends that shall be as per IS-1239, Part-II. Welding of joints of fabricated fittings should be such that they do not obstruct in air the flow or increase the fluid resistance appreciably.

The flange joints for waterline shall use canvas impregnated rubber gasket. The gasket material thickness shall be minimum 3 mm. The material shall have adequate strength in compression without damage. Pipe lines should be such installed that any equipment or valves can be removed by disconnecting flange bolts and nuts/union joints. If necessary, a short piece joint is to be installed for easy removal. All threads for screwed joints should be properly made. The threads shall be covered to make a leak proof joint. Pipes passing through any building structure shall pass through a pipe sleeve. The thickness of pipe sleeve shall be not less than the thickness of the passing pipe itself. Pipes entering any equipment shall be protected by a rubber grommet or such other material. All drainpipes shall use "Tee" fitting instead of elbows or bends. "Tee" fitting should be such installed that the plug can be removed, and any section of pipe can be cleaned. Drain valves shall be located at lowest point of pipelines. If necessary, more than one drain valve shall be installed to facilitate complete drainage from pipe. Water filling valve and air vent shall be installed on the highest point of pipe line. If necessary, more than one valve is to be installed for satisfactory operation or maintenance of the plant. In case of insulated pipes the connections for pressure gauge, thermometer, drain valve, purge valve, filling valve and any such other accessories, the connection should be long enough such that the requisite pipe insulation can be carried out on the main pipe. The connecting pipes or fittings shall be insulated separately if necessary.

Spacing and location of pipe supports shall conform to preferred engineering practice. Hangers and supports shall be made up of structural steel sections. The design of hangers and supports shall be provided for suitable protection to insulation on the pipes, wherever required.

4.15 SHEET METAL WORK

Velocity of air in any section of supply air duct shall not exceed 8 m/sec. for air conditioning system. Equal Friction method shall be employed for duct sizing.

All duct work for supply of air inclusive of accessories such as damper, vanes, access doors etc. shall be fabricated from G.I. sheet or aluminium sheet. The ductwork shall be properly reinforced to prevent sagging, buckling or vibration. Interior of all ducts shall be smooth and free from obstruction. All duct sections shall be cross-broken. All longitudinal joints for the ducts shall be Pittsburgh Lock seam type.

Transverse joints of the low-pressure ducting shall be continuous around the four sides, the corner closures, we required.

The type of transverse joints shall be follows:

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 19 of 28	

Large side mm Type of transverse joints

Up to 600 : 25 mm wide pocket, drive or S-slip

600 - 1000 : 85 mm wide, bar s-slip or pocket slip

1001-225 : 40 mm x 40 mm x 6 mm M.S. Angle Connection

The low-pressure ducting work shall be provided with intermediate transverse bracings continuous around the four sides between the joints according to the following sizes:

Large side mm Bracing

0 - 450 : None

451 - 1500 : 40 mm x 40 mm x 6 mm angle 1200 mm from joints.

1501 and above : 40 mm x 40 mm x 6 mm angle 600 mm from joints.

All flat surfaces between bracing or joints having 900 mm or more crosswise dimension of the duct, shall be reinforced by a longitudinal internal standing seam located in the center third of the duct width. All flat surfaces over 1500 mm wide shall be reinforced by the longitudinal internal standing seams located approximately on the third points or the width.

All ducting work includes:

G. I. Duct having zinc deposition of at least 180 gm/m².

Volume control dampers inside duct with control arrangement at each branch off and wherever necessary.

All supply & return air grilles and diffusers made of extruded aluminum powder coated and complete with volume control dampers (for SA grilles/diffusers only) and supporting frames.

Flexible connections of rubberized canvas.

Hangers and supports.

Sealing compound and jointing gasket for ducts

Motorized fire dampers (spring return type) shall be provided in the supply & return air duct which shall close and stop the air flow in the event of fire. These dampers shall be operated with the help of a signal from smoke detectors/thermal sensors. The dampers shall operate on "De-energized to close" mode. In the event of fire, the dampers shall close automatically & AHU / FCU fan shall also stop. Necessary interlocks shall be provided for this purpose in PLC control system. Fire damper shall be of rating 90 minute (min.).

4.16 INSULATION WORK

- Duct Insulation**

13 mm thick Aluminium foil faced Nitrile Rubber foam / XLPE thermal insulation for the entire air conditioning ducting.

- Acoustic insulation**

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 20 of 28

Acoustic lining of 25 mm thick fiberglass covered with fiberglass cloth and perforated aluminium sheet with 30% perforation shall be provided in the ducting up to a length of 5 M from the air handling unit outlet.

- Pipe Insulation**

The insulation shall be at least 39 mm thick Nitrile Rubber foam/XLPE with 24G aluminium sheet cladding. For Chilled water drain pipes the insulation thickness shall be at least 6 mm.

S.No	Surface	Insulation Material	Insulation Form	Thickness (mm)	Finish
i)	AC Duct	Al foil faced Nitrile rubber / Eqvt	Roll / Slab	13	Al Foil Facing
ii)	Acoustic insulation of first 5M of ducting after AHUs but limited to plenum	Fibreglass (48 Kg density)	Roll / Slab	25	Perforated Al sheet
iii)	Refrigerant Piping	Al foil faced Nitrile rubber / Eqvt	Roll / Slab	39	Al cladding
iv)	AHU drain pipe	-do-	Roll / Slab	26	Al cladding
v)	Chilled water piping, valves & specialties	-do-	Roll / Slab	39	Al cladding
v)	Chilled water piping, valves (Exposed to atmosphere)	EPS (TF Quality 16 Kg Density)	Pipe section	50	Sand cement plaster and Al cladding
vi)	Chilled Water Pumps	-do-	Roll / Slab	39	Al cladding
vii)	Expansion tank with pipe	Al foil faced Nitrile rubber / Eqvt	Roll / Slab	06	Al cladding

4.17 ONLINE NON CHEMICAL WATER TREATMENT EQUIPMENT

The water treatment equipment shall consist of Metal Cell and Core and shall be installed on line after the pumps and before the heat exchange zone. The distance of the heat

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 21 of 28	

exchange zone should not be more than 30 M and there should not be any static area between the water treatment equipment and heat exchange area.

5.0 CONTROL PHILOSOPHY

A common PLC based control system shall be provided for AC & Ventilation system. The PLC based control system shall cover the followings.

- AC system for main power house.
 - AC system for ESP building.
 - Air washer & UAF unit.
- a) The operation of the AC plant shall be done by microprocessor-based panel mounted on the chiller package with overall control from PLC based control panel located in the AC PLANT-1 Room. The AC Plant compressor can be started only when its associated condenser fan, chilled water pumps are in operation.
 - b) Chiller Package / VAM shall be provided with skid mounted microprocessor based control panel.
 - c) All fire dampers shall be closed on getting signal from the respective fire panels. Necessary cabling required for the purpose shall be covered under bidder's scope. Further the respective AHU motor / Precision Unit motor shall stop on closure of fire damper.
 - d) There shall be a common PLC for AC and ventilation system. The same shall be under AC vendor scope. Ventilation equipment required to be covered under the common PLC shall be Air washers and UAF.

5.1 SAFETY CONTROLS

All necessary measuring – control instruments & control system shall be provided. With following compressor & evaporator interlock in the control panel of the Chiller Package.

Following safety controls shall be incorporated with the Screw chiller Unit, as applicable:

- High pressure cut out (condensing pressure)
- Low pressure cut out (evaporating pressure)
- Low oil pressure cut out (if applicable)
- Low condenser water flow cut out
- Low chilled water flow cut out
- Low chilled water temperature cut out
- Overload trip of compressor motor
- Overload trip of Condenser Cooling Water and chilled water pump motors
- Overload trip of cooling tower fan motor

5.2 Interlocks

- The chiller compressor shall not start, if:

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 22 of 28	

- The cooling tower fan is not running
- The respective condenser water pump is not running
- The respective chilled water pump is not running
- At least one AHU is not running.

The chilled water plant shall therefore be started in the following sequence:

- Cooling tower fan
- Condenser water pumps
- Chilled water pumps
- Air handling units
- Compressors

All the standby equipment shall be put into operation manually after getting alarm of failure of normally running unit. All the units shall be manually restarted after any trip off due to malfunctioning. Stand-by selection of drives shall be done through selector switch to be located at control panel.

5.3 OPERATING CONTROL

All operating control as necessary shall be provided. However following minimum control shall be provided. Central chilled water system shall have the following controls:

- Automatic capacity control system.
- Automatic unloaded starting device
- Operating Thermostat
- Unloading solenoid valves (if applicable)
- 3 way flow control valve at the AHU's

Operation / Sequence Interlock of the Air conditioning system shall be as under:

- Condenser fan / cooling tower fan is started.
- The Air Handling Unit is started.
- Chiller Pump is started
- Chilling unit is started

5.4 INTERFACE WITH DCS

Following hardwired signals shall be provided in the DCS for monitoring purpose

- Temperature & Humidity.
- AC Plant On / Off Status.

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 23 of 28	


- c) Pump Run / Trip.
- d) AHU Run / Trip.
- e) General AC Plant Warning.

6.0 SPECIFIC REQUIREMENT

Efficiency of centrifugal fan and pump shall not be less than 70%.


Electrical feeder suitable for following motor rating shall be provided for following equipment. Vendor to ensure that motor rating is not more than the rating mentioned below.

Sr. no.	Items	Motor rating (Kw)
1.	Screw Chiller (250 TR)	250
2.	VAM (250 TR)	15
3.	Chilled Water Pump (180 CMH / 35M head) (min.)	30
4.	Condenser Water Pump (250 CMH / 30M head) (min.)	37
5.	AHU for Power House at 21.0Mtr.	30
6.	Cooling Tower	12.5
7.	Fresh Air Fan	1.5
8.	Precision AC	32.5
9.	Air Cooled PAC 15TR	21
10.	Air Cooled PAC 10TR	16


	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 24 of 28	

7.0 GENERAL

- 1) Basis of design all calculations including heat load calculations for summer seasons, equipment selection criterion, layout drawings/ schemes/G.A. dwg and documents like data sheet/ technical particulars etc are subject to Customer approval during detail engineering stage.
- 2) Vendor to furnish characteristic curves for all major equipment offered indicating duty point during detailed engineering.
- 3) All drawings and documents shall be computer based.
- 4) All commissioning spares & consumables for trouble free operation shall be provided Vendor to include level gauge & level switch for each tank for alarm & trip of the pumps. Also include one no. Pressure switch for each pump
- 5) Quality Requirements in the Technical Specification are indicating minimum requirements for inspection and testing. Vendor shall note that quality plan is subject to Customer & BHEL-approval during detail engineering stage. Standard QP format is enclosed in the technical specification.
- 6) Indicative list of makes is enclosed as per Annexure-I however these equipments / items shall be subject to Customer & BHEL approval during detail engineering Stage.
- 7) Inserts or any support arrangement for fixing ducting, fans, piping etc. shall not be provided by BHEL. Necessary supports may be taken from nearest structure / walls / roofs / floors etc. by Vendor.
- 8) Fixing frame works for diffusers and grilles in the scope of Vendor.
- 9) Anchor fastener shall be used by vendor for fixing duct pipes etc. wherever applicable.
- 10) Necessary supports and structures / frames etc. as required for supporting the duct / piping / equipments etc. as lump-sum basis is in the scope of Vendor and no unit rates shall be applicable for these items.
- 11) Drain piping within room up to the drain point to be provided by the Vendor.
- 12) Vendor to furnish schedule of power and control cables. Vendor to furnish cable termination details interconnection drawings etc. during detail engineering stage.
- 13) The tools and machine required for erection of equipment shall be arranged by Vendor.
- 14) Tools & tackles as required for regular maintenance shall be supplied by Vendor.
- 15) Instruments required for performance testing of various equipment / system of the package shall be arranged by Vendor at site.
- 16) Instrument for testing shall be calibrated by Air-conditioning plant supplier before taking up testing.
- 17) Temperature gauges shall be provided with thermo wells and fixing arrangement.
- 18) Pressure gauges shall have provision for air venting. Three way valves shall be used which shall have air venting provision.

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 25 of 28	

- 19) Matching sockets / stubs (weld type) for flow switches and other instruments shall be supplied.
- 20) Bidders shall guarantee to maintain specified inside design conditions during summer, monsoon and winter and also even if the internal equipment load varies from 100% to 25%.
- 21) Besides the system performance as above, bidder shall guarantee major technical parameters of various equipments as per design basis / details furnished.
- 22) The guarantee tests shall cover but not limited to the following rated parameters for smooth operation of ventilation system.
 - Design dry bulb temperature and relative humidity of conditioned air, Auxiliary power consumption, Vibration and noise level etc.
 - Performance test of the Ventilation system shall be carried out at site after proper installation. The site test shall include performance testing of equipment for 72 continuous hours in summer or monsoon and 24 continuous hours in winter. Bidder, as may be required to carry out site tests shall arrange all instruments, tools etc.
 - All calibrated instruments to be used for the tests at manufacturer's works/site shall be arranged by the bidder. Any Electrical/C&I items and accessories like junction box, glands etc. shall be included by vendor in his scope. Only those items shall be provide free of cost which are categorically listed in the Electrical scope sheet of technical specification.
- 23) For motorized fire damper / 3 Way valve actuators / motorised valves, power supply shall be derived by vendor from respective control panels. BHEL shall not provide any feeder for them. Suitable transformer shall be provided by bidder (if required) to derive the power input. Further distribution through junction box / distribution board shall be in vendor scope and shall have provision for isolation of individual fire damper/ valves.
- 24) Tender drawings enclosed form the part of specification and the bidder shall check the space requirements for installing the equipment as per the specification and layout requirements given in the specifications.
- 25) Bidder should suitably group the signals coming from various instruments etc. & the same shall terminate in local JB, from Local JB common cable to PLC / panel / MCC shall be selected. Any Electrical / C&I items and accessories like junction box, glands etc. shall be included by vendor in his scope. Only

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 26 of 28	

those items shall be provided free of cost which are categorically listed in the Electrical scope sheet of technical specification.

- 26) In the event of any conflict between the requirements of two clauses of this specification documents or requirements of different codes and standards specified, the more stringent requirement as per the interpretation of the owner shall apply.
- 27) Bidder to note that BHEL reserve the right for drg/doc submission through web based Document Management System. Bidder would be provided access to the DMS for drg/doc approval and adequate training for the same. Bidder to ensure proper net connectivity at their end.
- 28) Quality requirements in the Technical specification are minimum requirements for inspection and testing. Vendor to note that quality plans are subject to Customer approval during detail engineering stage. Standard QP format is enclosed in the technical specification.
- 29) The drawings/ documents submitted by vendor shall be complete in all respects with revised drawing submitted incorporating all comments. Any incomplete drawing submitted shall be treated as non-submission with delays attributable to vendor's account. For any clarification/discussion required to complete the drawings, the bidder shall himself depute his personal to BHEL / Customer's place any number of time as per the requirement for across the table discussions/ finalizations/ submissions of drawings.
- 30) Sealing of duct opening, grouting of foundation / foundation bolts etc. including special type of grouting like GPX2 etc. are in the scope of Air-conditioning system vendor.
- 31) Flat, platform type RCC / PCC foundation shall be provided for installing Chiller/ PUMP, AHU and FAN etc. Vendor shall fix the equipment using anchor fasteners to secure the equipment obtain parameters related to vibration and noise.
- 32) Bidder to note that the P&ID shows only the bare minimum requirement of valves and instruments. Any instrumentation & valves as required for the completion of the system in line with technical

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT		SPECIFICATION No: PE-TS-411-553-A001
			VOLUME II B
			SECTION C-1
			REV : 00
	DATE: APRIL 2015		Page 27 of 28

specification shall be provided by bidder during detailed engineering without any commercial implication.

- 33) RCC foundation of cooling tower shall be provided by BHEL. However, steel beam / joist etc as required shall be supplied by air-conditioning plant supplier.
- 34) Air-conditioning plant supplier to furnish drawings/ documents as per the dwg. / documents distribution as per project requirement.
- 35) Each motor terminal box shall be provided with cable gland and lugs for the size and type of power and control cable of respective motor.
- 36) All electrical equipment shall be suitable for the power supply fault levels and other climatic conditions indicated in project information / synopsis / specifications enclosed.
- 37) The bidder's proposal shall be for equipment in accordance with the tech. Specification.
- 38) The bidder shall furnish complete tech. Particulars in data sheet and schedules as specified elsewhere in the specification.
- 39) Necessary duct mounted Booster fan (if required) to maintain the static pressure for Precision AC shall be provided without any implication.

8.0 EXCLUSIONS

Items of works listed below are excluded from scope of the air-conditioning plant supplier.

- a) Construction of AC plant room, air handling unit room, foundations for AC equipments.
- b) False ceiling, drop ceiling.
- c) Slab cut out for running ducts, pipes, cables, grilles/dampers. Underground masonry trenches and masonry risers. However minor civil work like making opening to suit / finishing of opening, sealing of duct opening, grouting of foundation bolts including special type of grouting like GPX2 etc. are in the scope of AC system vendor.
- d) Provision of drain traps / points,
- e) For Electrical scope, refer Electrical scope matrix sheet.

9.0 Codes and Standards

Design, manufacture, inspection and testing of the equipment covered by the specification shall unless otherwise specified conform to the latest edition of the standards and codes including all addenda mentioned below:

IS-659 : Safety code for air-conditioning

IS-660 : Safety code for mechanical refrigeration

ASHRAE-23 : Standard method of testing and rating [67 Standards] air conditioner.

ARI-450-6 : Standards for water cooled refrigerant Condenser.

ASME Sec. VII : Unfired pressure vessels

	4X270 MW BHADRADRI TPS AIR-CONDITIONING SYSTEM SPECIFIC TECHNICAL REQUIREMENT	SPECIFICATION No: PE-TS-411-553-A001	
		VOLUME II B	
		SECTION C-1	
		REV : 00	DATE: APRIL 2015
		Page 28 of 28	

IS-4503 : Shell and tube type heat exchanger.

ASHRAE 22-72 : Method of testing for rating water cooled refrigerant condenser.

ASHRAE-15-2007 : Safe Standard for Refrigeration System

ASHRAE-30-1995 : Method of testing liquid chilling packages

ANSI-8-31.5 : Refrigeration piping.

ANSI-8-9.1 : Safety code for mechanical refrigeration.

AR1-410 : Standard for air cooling and air heating coils.

AR1-210 : Standard for unitary air conditioning equipment.

IS-3588 : Specification for electrical axial flow fans.

AMCA-210 : Methods of performance test for fans.

BS-2831 : Methods of test for air filters used in AC and general ventilation.

IS-4671 : Expanded polystyrene for thermal insulation purpose.

IS-1239 : Heavy class Pipes for sizes up to 150 mm dia.

IS-3589 : Heavy class Pipes for sizes above 150 mm dia

IS-8188 : For Water conditioning

IS-325 : 3 phase induction motors

IS-4029 : Guide line for testing 3 phase induction motor

IS-210 : Specification grey iron casting

IS-2062 : Structural steel

AMCA - Bulletin : Standard code of testing centrifugal and axial No. 210 flow fans

IS-2825 : Code of practice for welding mild steel

IS-2676 : Dimensions for wrought aluminum and aluminum alloy sheets and strips.

ASHRAE Code : For various filter

ASHRAE-62-2004 : Ventilation rates

IS-655 : Specification for metal air ducts

Pump design and testing should correspond to the procedure mentioned in IS-1520



**TECHNICAL SPECIFICATION
4X270 MW BHADRADRI TPS
TECHNICAL SPECIFICATIONS
VENTILATION SYSTEM**

SPECIFICATION No: PE-TS-411-554-A001

VOLUME II B

SECTION C1-B


REV. 00

DATE: MARCH 2015

**SECTION: C1-B
GENERAL REQUIREMENT**


Arvind


S A Khan



Praveen Kishore

CONTENT

CLAUSE NO.	DESCRIPTION
1.00.00	CODES AND STANDARDS
2.00.00	RESPONSIBILITY FOR DESIGN
3.00.00	NAME PLATES (RATING PLATES)
4.00.00	SAFETY AND SECURITY
5.00.00	GUARDS
6.00.00	LOCATION AND LAYOUT REQUIREMENTS
7.00.00	OPERATION, MAINTENANCE AND AVAILABILITY CONSIDERATIONS
8.00.00	MATERIALS
9.00.00	LUBRICATION
10.00.00	LUBRICANTS & CONTROL FLUIDS
11.00.00	OPERATION AND MAINTENANCE
12.00.00	PLANT LIFE AND MODE OF OPERATION
13.00.00	PACKAGING & MARKING
14.00.00	PROTECTION
15.00.00	ENVIRONMENT PROTECTION AND NOISE LEVEL REQUIREMENT
16.00.00	INSPECTION AND TESTING
17.00.00	TRAINING OF OWNER'S PERSONNEL
18.00.00	DEVIATIONS
	ATTACHMENTS
ANNEXURE-I	LIST OF STANDARDS FOR REFERENCE
ANNEXURE-II	CRITERIA FOR LAYOUT


Arvind


S A Khan


Praveen Kishore

GENERAL TECHNICAL REQUIREMENTS

1.00.00 CODES AND STANDARDS

1.01.00 Except where otherwise specified, the Plant shall comply with the appropriate Indian Standard or an agreed internationally accepted Standard Specification as listed in the annexure to this Section and mentioned in detailed specifications, each incorporating the latest revisions at the time of tendering. Where no internationally accepted standard is applicable, the Bidder shall give all particulars and details as necessary; to enable the Owner to identify all of the Plant in the same detail as would be possible had there been a Standard Specification.

1.02.00 Where the Bidder proposes alternative codes or standards he shall include in his tender one copy (in English) of each Standard Specification to which materials offered shall comply. In such case, the adopted alternative standard shall be equivalent or superior to the standards mentioned in the specification.

1.03.00 The plant will be designed in compliance with applicable National and International Codes and Standards such as ASME, ASTM, DIN, BS, IEC, IEEE, IS, etc. Wherever specified or required the Plant shall conform to various statutory regulations such as Indian Boiler Regulations, Indian Explosives Act, Indian Factories Act, Indian Electricity Act, Environmental Regulations, etc. Wherever required, approval for the plant supplied under the specification from statutory authorities shall be the responsibility of the Contractor.

1.04.00 In the event of any conflict between the codes and standards referred above, and the requirements of this specification, the requirements, which are more stringent, shall govern.

1.05.00 In case of any change of code, standards and regulations between the date of purchase order and the date the Contractor proceeds with manufacturing the Owner shall have the option to incorporate the changed requirements. It shall be the responsibility of the Contractor to advise Owner of the resulting effect.

1.06.00 Successful Bidder to furnish two (2) sets of latest of national/inter-national codes and standards to owner.

2.00.00 RESPONSIBILITY FOR DESIGN

2.01.00 The Contractor shall assume full responsibility for the design of the whole and every portion of the Plant, whether or not the design work was undertaken specifically in relation to the Contract and whether or not the Contractor was directly involved in the design work.

-
- 2.02.00 Notwithstanding the Owner's wish to receive the benefits of new, advanced and improved technologies, a prime requirement is that all the systems and components proposed shall have been already adequately developed and shall have demonstrated good reliability under similar, or more arduous conditions elsewhere, at least for continuous 2 years in two different power station.
- 2.03.00 The successful bidder shall have to carry out surge analysis, BFP transient analysis and other transient condition studies as may be necessary and as required by the Owner as per proven engineering practice.
- 2.04.00 The Bid shall include a detailed discussion on the development status of, and the reasons for any changes made in proposed systems or components for the Plant, as compared with similar items previously supplied in other installations cited by the bidder as reference plants.
- 2.05.00 The Bidder may also make alternate offers, provided such offers are superior in his opinion in which case adequate technical information, operating feed back, etc. are to be enclosed with the offer, to enable the Owner to assess the superiority and reliability of the alternatives offered. In case of each alternative offer, its implications on the performance, guaranteed efficiency, auxiliary power consumptions, etc. shall be clearly brought out to the Owner to make an overall assessment. In any case, the base offer shall necessarily be in line with the specifications i.e. Base offer shall be as per the technical specifications and the same will be considered for techno-commercial evaluation.

3.00.00 **NAME PLATES (RATING PLATES)**

- 3.01.00 Instruction plates, name plates or labels shall be permanently attached to each main and auxiliary item of plant in a conspicuous position. These plates shall be engraved with the identifying name, type and manufacturers serial number, together with the loading conditions under which the item of plant has been designed to operate.
- 3.02.00 Items such as valves, etc. which are subject to hand operation, shall be provided with nameplates so constructed as to remain clearly legible throughout the life of the plant giving due consideration to the difficult climatic conditions to be encountered. Nameplates shall be securely mounted where they will not be obscured in service by insulation, cladding, actuators or other equipment. Direction of flow is also to be engraved.
- 3.03.00 All trade nameplates and labels shall be in English language. All measurements shall be in M.K.S. Units.
- 3.04.00 The size and location of nameplates shall be subject to Approval of the Engineer.

4.00.00 **SAFETY AND SECURITY**

- 4.01.00 The design shall incorporate every reasonable precaution and provision for the safety of all personnel and for the safety and security of all persons and

property. The design shall comply with all appropriate statutory regulations relating to safety. All structures and equipment shall be designed and constructed to withstand every foreseeable static and dynamic loading condition, including loading under earthquake conditions, with an adequate margin of safety.

4.02.00 Ready and safe access with clear head room shall be provided to all parts of the plant for operation, inspection, cleaning and maintenance.

4.03.00 Escape routes and clear ways shall be provided to allow speedy evacuation of the plant in the event of fire or explosion, and the plant layout shall allow for ease of access to all parts of the Works by rescue and fire fighting teams. The plant layout shall be designed to localise and minimise the effects of any fire or explosion. The recommendations of NFPA, OSHA, and TAC etc. as necessary shall be followed in all respects.

4.04.00 The use of corrosive, explosive, toxic or otherwise hazardous materials shall be kept to a minimum during construction and the design of the plant shall minimise the requirement for such materials during operation and maintenance. Where such materials must be used, all necessary precautions shall be taken in the design, manufacture and layout of equipment to minimise the resulting hazard, and all equipment necessary for the protection and first-aid treatment of personnel in the event of accidents shall be provided. Particular attention is drawn to avoid the use of materials containing asbestos in any form.

5.00.00 **GUARDS**

5.01.00 Effective guards and fences must be provided to prevent injury to operators through accident or malpractice.

5.02.00 Mesh guards which allow visual inspection of equipment with the guard in place are generally preferable. The guards shall be constructed of mesh attached to a rigid framework of mild steel rod, tube, or angle and the whole galvanised to prevent loss of strength by rusting or corrosion. The guards shall be designed to facilitate removal and replacement during maintenance.

5.03.00 All drive belts, couplings, gears, sharp metallic edges and chains must be safely guarded. Any lubricating nipple requiring attention during normal running must be positioned where they can be reached without moving the guards.

5.04.00 Guards for couplings and rotating shafts shall be in accordance with BS 5304-1975 or similar approved standard. All rotating shafts and parts of shafts must be covered.

5.05.00 Suitable fencing shall be provided to enclose all openings or doorways used for the hoisting and lowering of machinery etc. This fencing must be securely fixed but quickly detachable when required. A secure hand hold must be provided on each side of the opening or doorway.

LOCATION AND LAYOUT REQUIREMENTS

The majority of plant and equipment (excluding steam generator and some other auxiliaries) shall all be of indoor installation. A broad list of buildings housing such equipment is given elsewhere in this specification. Layout should facilitate access for operation-maintenance and inspection of any one or more equipment/components at a time without disturbing the operation or installation of rest of the plant. Further, Bidder should comply with the criteria given under the various equipment and system specifications as well as those stipulated in Annexure-II attached to this section.

Enclosed General Layout and other tender layout drawings show the location of major installations and auxiliary buildings. The Bidder shall try to retain these locations as far as practicable. The layout of equipment within the power house as shown in the tender drawings is indicative. The Bidder may, subject to Owner's approval alter the same to suit the space requirement of the equipment offered.

Bidder may give as an alternative his own preferred layout clearly indicating the advantages and other implications, if any. Such alternative will not be considered for evaluating the bid, but may be considered with the successful Bidder if Owner/Engineer finds the proposal more attractive in terms of techno-economic consideration.

While developing the layout of buildings the following criteria shall be given effect :

- a) The minimum width of clear access corridors around equipment shall be 1.2 meter.
- b) Each building shall have an identified vacant space for equipment unloading and maintenance and preferably a separate bay altogether in buildings housing heavy equipment. Provision for handling equipment by monorail hoist and/or overhead crane shall be made as specified.
- c) The minimum clear height available between two consecutive floor slabs shall not be less than five (5) meters. A clear head room of 2.5m shall be maintained between the floor and any overhead piping/ cables or other obstruction. Adequate provision for natural ventilation and illumination shall be made as per good engineering practices.
- d) There shall be at least two (2) nos. main access doors, one on either side of each building, of which one shall be minimum 3 meters wide with rolling shutters for equipment entry. For multistoried buildings, at least two (2) nos. regular staircases diagonally opposite to each other shall be provided connecting all the floors and roof. These minimum requirements shall be augmented as required depending on the floor area, statutory requirements and TAC recommendations.
- e) All buildings shall have provision for toilet and associated effluent discharge system together with facility for drinking water. The criteria for ventilation, fire protection and illumination of building spaces specified

elsewhere in this specification shall be complied with.

- f) All rail/road crossings for pipe/cable racks shall be done with minimum 8 meters headroom from top of rail/road to bottom of rack. Similarly top cover over underground pipes/cables shall be minimum one (1) meter. For other detail refer to Annexure-II.
- g) Cubicle for operating personnel shall be located at safe place near the equipment.
- h) Interplant cable routing will be on overhead cable trays on pipe cum cable trestle or on cable trestle except where approved by purchaser/consultant. In exceptional case, small stretch of outdoor run of interplant cable routing may be taken through cable trench only with the Employer's prior approval.
- i) Concept of various mechanical and electrical equipment location and building dimensions (including column-row spacing) as shown in Plot Plan/Floor Plan drawing are to be adhered to. Any departure from this suggestive layout is primarily not recommended.

7.00.00 OPERATION, MAINTENANCE & AVAILABILITY CONSIDERATIONS

7.01.00 Equipment/works offered shall be designed for high availability, high reliability, low maintenance and ease of operation & maintenance. The Bidder shall specifically state the design features incorporated to achieve high degree of reliability, availability, operability and ease of maintenance. He shall also furnish details of availability records in plants stated in his experience list.

7.02.00 Ample space for ease of operation and maintenance including equipment removal, tube bundle/cartridge/rotor pulling etc. shall be provided. All valves, gates, dampers and other devices shall be located and oriented in such a way that they are accessible from operating floor levels. Where this cannot be adhered to, platforms and walkways with access ladders shall be provided to facilitate operation and maintenance.

7.03.0 Motorised lifting devices, i.e. hoists, chain pulleys, jacks, etc. shall be provided for handling and carrying out maintenance of any equipment and/or part having weight in excess of 2000 Kg. Suitable beams, hooks etc. for this purpose shall be provided in the buildings.

No lifting arrangement is necessary for part having weight less than 500 Kg. Hoist shall be well protected by environment. Suitable painting and coating covering hoist at outdoor shall be provided.

Lifting devices like lifting tackles, slings, etc. to be connected to hook of the hoist/crane shall be provided by the Bidder for lifting the equipment, accessories covered under this specification.

7.04.00 All similar parts of the equipment shall be made to gauge and shall be interchangeable with and shall be made of same material and workmanship as the corresponding parts of the equipment. Where feasible common

components shall be employed in different pieces of equipment in order to optimize the spares inventory and utilization.

8.00.00 **MATERIALS**

8.01.00 In selecting materials of construction of equipment, the Contractor shall pay particular attention to the atmospheric conditions existing at the Site and the nature of material/fluid handled. Wherever deviations are taken in respect of materials specified, the reasons shall be spelt out clearly in the proposal.

All materials shall be new, and shall be of the quality most suited to the proposed application.

8.02.00 In as far as is possible; materials shall be in accordance with Indian or international standard specifications and shall be used in accordance with Indian or international codes of practice. Where such standards or codes of practice are not available sufficient information shall be provided to allow the Owner to assess the suitability of the material for the particular application.

All materials used shall have performed lengthy satisfactory service in similar or more arduous conditions to those proposed by the Contractor.

8.03.00 All parts which could deteriorate or corrode under the influence of the atmospheric, meteorological or soil conditions at the Site, or under the influence of the working conditions shall be suitably and effectively protected so that such deterioration or corrosion is a minimum over the life of the plant.

9.00.00 **LUBRICATION**

9.01.00 Provision shall be made for suitable efficient lubrication where necessary to ensure smooth operation free from undue wear.

9.02.00 Non ferrous capillary tubing shall be used throughout.

9.03.00 Gear boxes and oil baths shall be provided with filling and drain plugs, both of adequate size. An approved means of oil indication including level switches and temperature indication shall be provided.

9.04.00 All high speed gears shall be oil bath lubricated. Low speed gears shall be lubricated by means of soft grease. Removable and accessible drip pans shall be provided to collect lubricant which may drop from operating parts.

9.05.00 All lubrication points shall be conveniently situated for maintenance purposes. It must be possible to carry out lubrication from a gangway or landing and without the removal of guarding or having to insert the hand into it. Where accessibility to a bearing for oiling purposes would be difficult a method of remote lubrication shall be fitted.

9.06.00 The Contractor shall supply grease gun equipment suitable to service each type of nipple fitted.

10.00.00 **LUBRICANTS AND CONTROL FLUIDS**

10.01.00 The Contractor shall provide a detailed and comprehensive specification for all lubricating oils, greases and control fluids required for the entire plant. A sufficient supply of these shall be provided by the Contractor for initial commissioning, first fill and till COD of the unit.

10.02.00 The Contractor shall supply a detailed schedule giving the lubricant testing, cleaning and replacement procedures. All equipment and facilities necessary for the testing, cleaning and changing of lubricants and control fluids shall be provided. The Contractor shall endeavor to reduce the varieties and grades of required lubricants and control fluids to a minimum, matching them where possible to those already in use in the generating station in order to simplify procurement and minimise storage requirements. All lubricants and control fluids shall be of internationally recognised standards and shall be easily obtainable from a large number of Indian suppliers. Bidder shall also indicate the equivalent Indian Standard for the above for easy procurement in future.

10.03.00 No lubricant or control fluid shall have toxic or other harmful effects on personnel or on the environment.

11.00.00 **OPERATION AND MAINTENANCE**

11.01.00 The plant shall be designed and constructed so that operation and maintenance manpower requirements are minimised.

The design and layout shall facilitate inspection, cleaning, maintenance and repair. The importance of continuity of operation is second only to that of safety.

11.02.00 Spare parts for equipment shall be interchangeable with the original components and, so far as possible, be of common design and manufacture.

11.03.00 All similar standard components/parts of similar standard equipment provided shall be interchangeable with one another. Further identical equipments shall be provided for similar duties so that the same are interchangeable with one another in totality and component wise.

11.04.00 All heavy parts (500 Kg and above) must be provided with a convenient arrangement for slinging and handling during erection and overhaul. Any item of plant normally stripped or lifted during periods of maintenance and weighing one tonne or above, shall be clearly marked with its weight.

11.05.00 On completion of commissioning, a complete set of tools for the maintenance of the entire plant shall be provided by the Contractor. This shall include all necessary spanners, special wrenches, extraction equipment and any special tools reasonably required by the Engineer. Tools used during erection and commissioning shall not be accepted except with the specific approval of the Engineer.

11.06.00 All equipment and major valves should be provided with adequate maintenance approach and facility.

12.00.00

PLANT LIFE AND MODE OF OPERATION

The complete plant including all the equipment and systems individually and collectively shall be designed for continuous operation for an economic service life of thirty (30) years under the prevailing site conditions and for the type of duty intended.

The critical components of the Steam Generator, Turbine-Generator and Auxiliary equipment, the life of which is limited by time and temperature dependent mechanisms such as thermal stress, creep and low cycle fatigue, are to be designed considering expected (hot, warm and cold) start-up, shut-down and cyclic load variations.

The allowable stresses shall be reduced so that life expectancy to minimum 2,00,000 hours of operation can be achieved. The Bidder shall discuss this aspect in his technical proposal.

The unit would be operated on base load with cyclic load variation. The load variation is expected to be as per schedule depending on power demand.

The expected start-ups should be considered as minimum
(Based on HPT metal temperature)

Cold start-up (>72 hrs. shutdown)	:	6 per year
Warm start-up (between 10 to 72 hrs. of shutdown)	:	40 per year
Hot start-up (less than 10 hrs. shutdown)	:	160 per year

13.00.00

PACKAGING & MARKING

All the equipment shall be suitably protected, coated, covered or boxed and crated to prevent damage or deterioration during transit, handling and storage at site till the time of erection. While packing all the materials, the limitations from the point of view of availability of railway wagon sizes in India should be taken account of. The details of various wagons normally available with Indian Railways for transportation of heavy equipment shall be considered by the Bidder. The Contractor shall be responsible for all loss or damage during transportation, handling and storage due to improper packing.

As per the information available, the dimensions of OD consignment for transportation of the equipment by rail (if any equipment to be handled through rail transportation) are as below :

- | | | | |
|----|---|---|-------------|
| a) | Width of the Package
(from centre-line of rails
- 1.6 metres on both sides) | : | 3.2 Meters |
| b) | Height of the package from rail top | : | 4.47 Meters |

The above indicates the dimensions which can be normally transported on the

wagons without infringement of the "moving gauge". This is however not indicative of the consignment which can be carried out with infringement of "moving gauge" duly authorised and approved by the Indian Railways. There may be difference between the "moving gauge" and the "fixed structure gauge" and consignments infringing the "moving gauge" can be moved after investigation regarding possible infringement with the fixed structures. As the critical fixed structures in each route are different, consignments infringing moving dimensions have to be individually investigated to select a route and also determine the restrictions under which such movement is to be carried out. Such routes selected or other mode of transport envisaged is to be clearly brought out in the proposal wherever transport of over dimensional equipment is involved.

Bidder to consider unloading of material delivered through rail transportation, at near by railway station/ site unloading siding. The subsequent transportation up to project work place shall be considered by road only. All unloading and handling equipment both at railway station siding and at project site shall be arranged by the Bidder. Necessary arrangement to be organized with the railway authority for such purpose shall also be under the scope of services of the Bidder. Bidder may consider entire material delivered up to site through rail transportation only.

The identification marking indicating the name and address of the consignee shall be clearly marked in indelible ink on two opposite sides and top of each of the packages. In addition the Contractor shall include in the marking gross and net weight, outer dimension and cubic measurement. Each package shall be accompanied by a packing note (in weather proof paper) quoting specifically the name of the Contractor, the number and date of contract and names of the office placing the contract, nomenclature of contents and Bill of Material.

For imported equipment and material, suitable port facilities may be used in which case material may be transported from the port by tractor-trailer. Bidder may consider this aspect.

14.00.00

PROTECTION

Equipment having antifriction or sleeve bearings shall be protected by weather-tight enclosures. Coated surfaces shall be protected against impact, abrasion, discoloration and other damages. Surfaces that are damaged shall be repainted.

Electrical equipment, controls and insulations shall be protected against moisture and water damages. All external gasket surfaces and flange faces, couplings, rotating equipment shafts, bearings and like items shall be thoroughly cleaned and coated with rust preventive compound as specified above and protected with suitable wood, metal or other substantial type covering to ensure their full protection. All exposed threaded parts shall be greased and protected with metallic or other substantial type protectors.

All piping, tubing and conduit connections on equipment and other equipment openings shall be closed with rough usage covers or plugs. Female threaded openings shall be closed with rough usage covers or forged steel plugs. The closures shall be taped to seal the interior of the equipment. Open ends of

pipings, tubing and conduit shall be sealed and taped.

Returnable containers and special shipping devices shall be returned by the manufacturer's field representative at the Contractor's expense.

15.00.00 **ENVIRONMENT PROTECTION AND NOISE LEVEL REQUIREMENT**

15.01.00 **Environment Protection**

The plant shall be designed for installation and operation in harmony with the surrounding environment and all measures of pollution control shall be ensured by the Bidder to restrict pollution from the liquid effluent and stack emission within the limits as given below with due consideration of Environment (Protection) Rules 1986 as amended till date.

In case the Ministry of Environment & Forest stipulate any other conditions not specified hereunder while clearing the project shall be complied with the plant by the contractor.

15.01.01 For Liquid Effluent

- a) Provision laid down in schedule-I for Thermal Power Plants and also in Schedule-VI. General Standards for discharge of Environmental pollutants Part-A : Effects of Environmental (protection) Rules 1986, as amended till date.
- b) Any specific requirement of State Pollution Authorities over and above the above stipulation.

15.01.02 For Air Emission

- a) Suspended Particulate Matter i.e. dust burden at chimney outlet - Maximum 50 mg/Nm³ (with worst coal and one field out at TMCR).
- b) NO_x - 365 ppm Max. or 750 mg/Nm³ (Equivalent NO₂).
- c) SO₂ - Concentration based standard 2000 mg/Nm³. Load based standard 0.2 metric tonne /MWe/day (for first 500 MW and 0.1 metric tonne/MWe/day for rest of the capacity above 500 MW)

In absence of Indian Standard for emission from power plants as on date, for certain gaseous effluents, the internationally accepted World Bank Standard is to be followed. Indian Standard for emission of power plants are under formulation. Should this standard is published before finalisation of the contract, the bidder has to comply the more stringent of the above norm or the new Indian Standard.

The bidder shall include in his scope all necessary equipment and measuring instruments to comply with above requirements. Location and accessibility of the instruments shall be properly coordinated.

15.02.00 **Noise Level Requirement**

The plant will be designed, constructed and provided with suitable acoustic measures to ensure the noise level criteria as per the following stipulations.

- a) Maximum noise level shall not exceed 85 dB (A) when measured at 1.0M away from the noise emission source.
- b) Maximum noise level from its source within the premises shall not exceed 70 dB (A) as per Environment (Protection) Rules 1986, Schedule-III, 'Ambient Air Quality Standards' in respect of noise.
- c) Any statutory changes in stipulations regarding noise limitation that may occur in future according to State Pollution Control Board or Central pollution Control Board or Ministry of Environment & Forest regulation during tenure of the contract, the contractor shall comply with the requirement.

An exception will be made for the plant at startup operations and other big pressure reducing devices operating during emergency periods and for the safety valves.

16.00.00 **INSPECTION AND TESTING**

16.01.00 **Inspection and Tests during Manufacture**

- 16.01.01 The method and techniques to be used by the Contractor for the control of quality during manufacture of all plant and equipment shall be agreed with the Owner prior to the Award of Contract.
- 16.01.02 The Owner's general requirements with respect to quality control and the required shop tests are set out elsewhere in this specification.
- 16.01.03 Before any item of plant or equipment leaves its place of manufacture the Owner shall be given the option of witnessing inspections and tests for compliance with the specification and related standards.
- 16.01.04 Advance notice shall be given to the Owner as agreed in the Contract, prior to the stage of manufacture being reached, and the piece of plant must be held at this stage until the Owner has inspected the piece, or has advised in writing that inspection is waived. If having consulted the Owner and given reasonable notice in writing of the date on which the piece of plant will be available for inspection, the Owner does not attend the Contractor may proceed with manufacture having forwarded to the Owner duly certified copies of his own inspection and test results.

The Contractor shall forthwith forward to the engineer duly certified copies of the Test Certificates in six copies (one to the Purchaser and five to the Consulting Engineer) for approval. Distribution of six (6) copies of Test Certificates for approval will be two(2) copies to owner and four(4) copies to consultant. These four(4) copies will be further distributed by consultant after approval to owner, site and bidder. One copy will be retained with the

consultant for record purpose.

Further, nine (9) copies of Shop Test Certificates shall be bound with Instruction Manuals referred to elsewhere. Distribution of nine (9) copies of Shop Test Certificates for approval will be Two (2) copies to owner, Three (3) copies to site, Two (2) copies to consultant, Two (2) copies to owner's library / record.

16.01.05 Under no circumstances any repair or welding of castings be carried out without the consent of the Owner's Engineer. Proof of the effectiveness of each repair by radiographic and/or other non-destructive testing technique, shall be provided to the Engineer along with Defect Map.

16.01.06 All the individual and assembled rotating parts shall be statically and dynamically balanced in the works.

Where accurate alignment is necessary for component parts of machinery normally assembled on site, the Contractor shall allow for trial assembly prior to despatch from place of manufacture.

16.01.07 All materials used for the manufacture of equipment covered under this specification shall be of tested quality. Relevant test certificates shall be made available to the Purchaser. The certificates shall include tests for mechanical properties and chemical analysis of representative material or any other test as required by approved QAP/ Material specification.

16.01.08 All pressure parts connected to pumping main shall be subjected to hydraulic testing at a pressure of 150% of shut-off head for a period not less than one hour. Other parts shall be tested for one and half times the maximum operating pressure or as required by design code of that part, for a period not less than one hour.

16.01.09 All necessary non-destructive examinations shall be performed to meet the applicable code requirements.

16.01.10 All welding procedures adopted for performing welding work shall be qualified in accordance with the requirements of Section-IX of ASME code or IBR as applicable. All welded joints for pressure parts shall be tested by liquid penetrant examination according to the method outlined in ASME Boiler and Pressure Vessel code. Radiography, magnetic particle examination magnafux and ultrasonic testing shall be employed wherever necessary/recommended by the applicable code. At least 10% of all major butt welding joints shall be radiographed.

16.01.11 Statutory payments in respect of IBR approvals including inspection for design and manufacturer of equipment shall be made by the Bidder. All payment for erection and testing at site (i.e. under IBR jurisdiction) shall also be made by the Bidder. In such case Contractor's scope shall also be extended to preparation of all necessary documents, co-ordination and follow-up with IBR authorities for above approval.

16.02.00 **Performance Tests at Site**

- 16.02.01 The full requirements for testing the system shall be agreed between the Owner and the Bidder prior to Award of Contract. The completely erected System shall be tested by the Contractor on site under normal operating conditions. The Contractor shall also ensure the correct performance of the System under abnormal conditions, i.e. the correct working of the various emergency and safety devices, interlocks, etc.
- 16.02.02 The Bidder shall provide complete details of his normal procedures for testing, for the quality of erection and for the performance of the erected plant. These tests shall include site pressure test on all erected pipe work to demonstrate the quality of the piping and the adequacy of joints made at site.
- 16.02.03 The Contractor shall furnish the quality procedures to be adopted for assuring quality from the receipt of material at site, during storage, erection, pre-commissioning to tests on completion and commissioning of the complete system/equipment.
- 16.03.00 For details of specific tests required on individual equipment refer to respective section of this specification.

17.00.00 **TRAINING OF OWNER'S PERSONNEL**

The Contractor shall extend all possible assistance and co-operation to the Purchaser regarding the transfer of technology and developing expertise in the area of engineering operation and maintenance of the Plant.

Number of man-days of training as mentioned below shall be included in his Tender.

17.01.00 **Training at Contractor's Premises**

The Contractor shall conduct training of sixty (60) engineers of the Owner on engineering, operation and maintenance of the Plant at the Contractor's or Associates or Sub-contractor's premises where adequate training facilities are available during the design and manufacturing stage of the Contractor.

The total man-months for training of engineers shall be maximum sixty (60), having following indicative break-up :

Discipline	No. of Engineers	No. of Man-month
Operation	20 heads	20
Maintenance Boiler, Turbine, Mechanical	20 heads	20
Electrical Maintenance	8 heads	4
Control & Instrumentation	8 heads	4
Maintenance Planning	4 heads	2
	-----	-----

However, the details of the training programme will be discussed and finalised with the successful Bidder.

The training may also be arranged by the Contractor in any Plant where the equipment manufactured by the Contractor or his Associates is under installation, operation or testing to enable the trainees to become familiar with the equipment being furnished by the Contractor. All expenses inherently related to the training shall be borne by the Contractor and shall include but not limited to travel expenses (international and inland fares), lodging and per diem charges as well as medical insurance, instructors fee, programme and miscellaneous cost to be incurred during the training.

The training programme shall be adequate for the trainees to acquire the necessary expertise and competence in the area of engineering, operation and maintenance and as trainers for in-house technology transfer programme of the Purchaser.

The Contractor shall be responsible for the development of the Training Module and Programme Schedule which shall be submitted to the Purchaser for approval.

The components of the training modules shall include but not be limited to the training procedures/methodology, instructional materials such as audio visual materials, CDs and slides and manuals for each trainee.

Three (3) sets of the materials included in the training modules shall be handed over to the Purchaser upon completion of the training. An evaluation shall be jointly undertaken by the Contractor and the Purchaser's representative on the adequacy, appropriateness and relevance of the training and the programme effectiveness after the training. The training material shall be in English language only.

The content of the training programme shall include but not be limited to:

1. Coal fired thermal plant principles in management and practice for operators, technicians and maintenance personnel.
2. Plant operation and systems training for operators including simulator training as applicable.
3. Maintenance training programme covering electrical, mechanical and instrumentation and control.

Said training programme shall be submitted to the Purchaser for approval.

The timing of the training should be such that the participants will be conversant with sufficient know-how to participate in the pre-commissioning and commissioning tests of the Plant.

The Contractor shall provide qualified English speaking instructors and training

coordinator(s) during the tenure of the training programme.

17.02.00 Operation and Maintenance Training at Site

The Contractor shall provide a comprehensive training programme related to design application, plant management, operation and maintenance, including trouble shooting, of the Contractor's supplied system and equipment at the Site starting from Start of Commissioning and thereafter up to the Final Acceptance of the first Unit.

The following instructors shall be at the Site continuously during the training :

- a) One (1) for Steam Generator and Auxiliaries ;
- b) One (1) for Turbine Generator and Auxiliaries ;
- c) One (1) for Electrical Works ;
- d) One (1) for Instrumentation and Control (Boiler and Auxiliaries) ;
- e) One (1) for Instrumentation and Control (Turbine and Auxiliaries).

17.03.00 On-the-Job Training

During the period of pre-commissioning, commissioning and trial operation, the Purchaser shall provide operation and maintenance personnel to assist the Contractor in the operation and maintenance of his supply and work under the direction of the Contractor for the purpose of on-the-job training.

The Purchaser shall have the right to send to the Site his employees later intended to operate and maintain the equipment supplied under this Contract. The Contractor shall, without additional cost, use his site staff to instruct these employees on the operation and maintenance of the equipment. All instructions shall be in the English language.

17.04.00 For detail C&I training refer to Volume-VI, Section-9.

18.00.00 DEVIATIONS

The Bidder is required to submit with his proposal in the relevant schedules a detail list of any and all deviations taken by him clearly without any ambiguity. In the absence of such a list it will be understood and agreed that the Bidder's proposal is based on strict conformance to this specification and no post-contract negotiations would be allowed in this regard.

Unless otherwise specifically indicated in the deviation list, it will be construed and agreed that details indicated in documents & drawings furnished by the Bidder along with the offer is in-line with the specification requirement.

ANNEXURE-I

LIST OF STANDARDS FOR REFERENCE

- a) International Standards Organisation (ISO).
- b) International Electro-technical Commission (IEC).
- c) American Society of Mechanical Engineers (ASME).
- d) American National Standards Institute (ANSI).
- e) American Society for Testing and Materials (ASTM).
- f) American Institute of Steel Construction (AISC).
- g) American Welding Society (AWS).
- h) Architecture Institute of Japan (AIJ).
- i) National Fire Protection Association (NFPA).
- j) National Electrical Manufacturer's Association (NEMA).
- k) Japanese Electro-technical Committee (JEC).
- l) Institute of Electrical and Electronics Engineers (IEEE).
- m) Federal Occupational Safety and Health Regulations (OSHA).
- n) Instrument Society of America (ISA).
- o) National Electric Code (NEC).
- p) Heat Exchanger Institute (HEI).
- q) Tubular Exchanger Manufacturer's Association (TEMA).
- r) Hydraulic Institute (HIS).
- s) International Electro-Technical Commission (IEC) Publications.
- t) Power Test Code for Steam Turbines (PTC).
- u) Applicable German Standards (DIN).
- v) Applicable British Standards (BS).
- w) Applicable Japanese Standards (JIS).

- x) Electric Power Research Institute (EPRI).
- y) Standards of Manufacturer's Standardization Society (MSS).
- z) Bureau of Indian Standards Institution (BIS).
- aa) Indian Electricity Rules.
- bb) Indian Boiler Regulations (IBR).
- cc) Indian Explosives Act.
- dd) Indian Factories Act.
- ee) Tariff Advisory Committee (TAC) rules.
- ff) Emission regulation of Central Pollution Control Board (CPCB).
- gg) Pollution Control regulations of Dept. of Environment, Govt. of India
- hh) Central Board of Irrigation and Power (CBIP) Publications.
- ii) The Air Prevention and Control of Pollution Act.
- jj) The Environmental Protection Act
- kk) The Public Liability Insurance Act.
- ll) The Forest Conservation Act
- mm) The Wildlife protection Act.
- nn) The EIA Notification, 1994.
- oo) IS: 14665-Specification for Electric Traction Lift
- pp) Any other statutory Codes/Standards/Regulations

ANNEXURE-II

CRITERIA FOR LAYOUT

PLOT PLAN LAYOUT REQUIREMENTS

ITEM	SPECIFICATION REQUIREMENT
A. Site conditions to be considered	
1. Prevalent wind direction	See wind-rose in plot plan. Also refer Metrological Data.
B. Layout Requirements	
1. Maximum permissible slope in	
a) Rail track	1 in 400
b) Road	1 in 30
c) Sides of unpaved embankment	1 in 2
2. Required road width	
a) Main roads	As per Civil DBR
b) Auxiliary interconnections	
c) Road to the power house unloading bay :	
• Only for entry to the unloading bay	Yes
• To pass through the unloading bay	No
3. Required minimum horizontal distance between the nearest points of	
a) Plant boundary and the boundary of residential area	(Local municipality/factory rule)
b) Electrical transformer and any other building/facility	As per the Tariff Advisory Committee/ LPA Rules
c) Fire water supply installation and any building/facility subject to fire risk.	As per the Tariff Advisory Committee/ LPA Rules
d) Inflammable liquid (fuel oil, etc.) storage & handling installation and their fencing and other buildings/facilities.	Rules of the Indian Explosive (Indian Explosives Act) and Indian Petroleum Code

ITEM	SPECIFICATION REQUIREMENT
4. Required minimum vertical clearance	
a) Under pipes/cable racks at road crossings	8.0 Metres
b) Soil coverage over underground pipes	1.0 Metre (minimum)
5. Railway Wagon clearance	Rules of the Indian Railways
6. Minimum Clearance between any road edge and building/structure/ any fixed installation.	3 Metres
7. Required level, above the local developed grade level, of	
a) top of all roads	150 mm above FGL
b) all outdoor paved areas	100 mm above FGL
c) Temporary storage areas, workshops, offices, residence etc. required at the time of erection work.	Yes
d) Green belt around power plant area	As per environmental guidelines of MOEF, Govt. of India.

BUILDING/ EQUIPMENT LAYOUT REQUIREMENTS

- A. Minimum clear space required at all working and walking areas for operating & maintenance personnel
1. Horizontal, in all directions
 - a) Adjacent to any electrical equipment, electrical cables, running (rotating/reciprocating) equipment, safety valve or vent/drain pipe outlet, pipe/ equipment of surface temperature exceeding 60°C. 1200 mm
 - b) Adjacent to any other plant facilities (including walls/structures) 1000 mm
 2. Vertical (head-room clearance)
 - a) Under any pipe/equipment surface of temperature exceeding 60°C and any electrical cables or other electrical items. 2.5 Metre
 - b) Under any other plant facilities (including structures, pipes etc.) 2.5 Metre


ITEM	SPECIFICATION REQUIREMENT
3. For all areas where any equipment (including trucks, trolleys and other material handling equipment) will move or maneuver.	Minimum 500 mm clear in all direction from the outer edges of the equipment
4. Minimum clear hand space required for	
a) The application of thermal insulation	100 mm
b) Welding work	150 mm
c) Bolt tightening	150 mm
B. Floors, platforms, staircase, ladders, walls, doors & windows	
1. Statutory Requirement	As per the regulations of Tariff Advisory Committee, Indian National Building Code, Indian Factories Act, Local Municipal Rules, etc.
2. Operation & Maintenance Requirement	
a) Adequate floor space shall be kept to permit dismantling, temporary storing and in-situ maintenance of plant & equipment parts, satisfying the clear space requirements stated above. A separate unloading bay for such purpose is required.	Yes
b) Floors or fixed/portable platforms with stairs/ ladders shall be provided for easy approach to any plant item, including valves, instruments, etc. to be operated, observed and/or to be frequently (more than once a month) maintained.	Yes
3. Plinth level of all buildings, above the finished grade level	500 mm
4. Minimum access opening required (with rolling shutter) for transportation, wherever entry of truck for material handling is envisaged	3.5M wide x 4M high or, more depending upon the equipment size to be handled.

ITEM	SPECIFICATION REQUIREMENT
C. Other Maintenance Requirement	
1. Generator stator handling In case the Generator stator cannot be handled by the turbine house crane, all provisions for its overhauling, including the arrangement to slide the stator on the turbine house floor, the foundation work for stator jacking /lowering assembly, dismantling of building end walls/structures etc. shall be kept.	Yes
2. Maintenance of the internals/impellers of all important equipment, like boiler feed pumps, feed water heaters, Surface Condenser, fans of the boiler draft plant, Intake and circulating water pumps, cooling water pumps, coal mills, compressors, blowers, heat exchangers, fuel oil pumps, filters etc.	Shall be possible without disconnecting or dismantling any piping/ducting.
3. Overhauling and handling of the casings for the above items	Shall be possible without disturbing/dismantling any piping/ducting not directly connected to them.
4. Crane Approach Wherever required the unobstructed approach of the crane hook/other hoisting equipment hook to various plant & equipment shall be possible.	Yes
D. Central Control Room All electronic equipment other than those directly associated with control, operation or presentation of displays shall be mounted external to the control room in air conditioned control equipment room.	Yes
The bidder shall describe in his bid the proposed layout philosophy of the Central Control Room and Control Equipment Room and the arrangement of equipment best suited for the system offered by him and as per good ergonomically consideration.	
However, as a guide line, following features are given :	
a) False ceiling and false flooring shall be provided.	
b) Uniform height, colouring schemes for cabinets etc. shall be available.	

ITEM	SPECIFICATION REQUIREMENT
c)	The total area of floor space covered by Control Consoles/Panels in the Control Room shall not exceed 15% of floor area.
d)	No opening shall be provided from Boiler side.
e)	Two double leaf doors, suitably located for entering the Control room shall be provided with opening towards the turbine floor.
f)	Cable entry for the panels/consoles shall be from bottom and suitable openings shall be provided.
g)	The Control Room lighting shall be designed to provide a glare free uniform illumination. The level of illumination shall be minimum 400 LUX.
h)	Necessary Air Conditioning shall be provided for Central Control room, Control Equipment Room and SWAS room etc.
i)	Basic amenities like toilet, Tiffin rooms, wash basins, rest rooms etc. shall be provided near the Control Room.
E.	Toilet and drinking water facility
	Required in all buildings and on all floors wherever operating personnel are to be deployed.


Arvind


S A Khan


Praveen Kishore


PROJECT MANAGEMENT AND SITE SERVICES



Arvind



S A Khan



Praveen Kishore

CONTENT


CLAUSE NO.	DESCRIPTION
1.00.00	PROJECT MANAGEMENT SERVICES
2.00.00	SITE SERVICES
3.00.00	PROJECT INFORMATION AND MANAGEMENT SYSTEM, INCLUDING DCOUMENT MANAGMENT SERVER (DMS)



Arvind



S A Khan



Praveen Kishore

PROJECT MANAGEMENT AND SITE SERVICES

1.00.00 PROJECT MANAGEMENT SERVICES

1.01.00 Responsibility

The Bidder shall identify a separate and independent project management team headed by a Project Manager for the execution of this project. Responsibilities of this project Management team shall cover the areas listed below :

- a) Planning and Monitoring
- b) Engineering Management
- c) Contracts Management
- d) Project Safety Management
- e) Quality Assurance, Inspection & Expediting
- f) Construction Management
- g) Spares Management
- h) Erection & Commissioning Management

Detailed responsibilities in the above areas are discussed below :

1.02.00 Organisation

1.02.01 Headquarters

The headquarters of the project management team shall be headed by a senior level executive designated as the Project Manager who shall be responsible to Owner for the execution of the project. He should have adequate financial power and authority to give decision.

Separately, designated leaders shall be identified for each of the areas mentioned under 1.01.00, who, in turn, will report to the Project Manager for all matters relative to this contract.

1.02.02 Central Co-ordination Cell

The central coordination cell shall have sufficient technical personnel to coordinate technical matters and to quickly resolve day to day queries or

references made by Owner and his Consultants without having the need to refer to his headquarters each time.

1.02.03 Site Organisation

The site should have a competent construction manager for all site operations with adequate financial power and sufficient level of authority to take site decisions. The organisation chart for site should indicate the various levels of experts to be posted for supervision in the various fields in civil construction, erection, commissioning etc.

1.02.04 Organisation Chart

The Bidder shall furnish a detailed organisation chart for the project management team, clearly identifying the key personnel in each of the areas mentioned at 1.01.00 above. The expected number of executives at different levels shall also be indicated, separately for headquarters, central coordination cell and site organisation.

1.03.00 **Implementation Schedule**

The schedule for the completion of the Project would be as follows :

As per project specific special condition of contract.

To achieve these targets, the Contractor shall furnish to the Owner, various schedules as defined below:

1.03.01 Engineering Schedules

These schedules shall cover various design submissions indicating different engineering activities to be performed. Such schedules shall be furnished by the Bidder for each and every plant/systems/ equipment item covered in the scope of this specification.

1.03.02 Manufacturing Schedule

The Contractor shall submit to the Engineer his manufacturing and delivery schedules for all equipment within thirty (30) days from the date of issue of the Letter of Intent (LOI). Such schedules shall be in line with the detailed network for all phases of the work of the Contractor. Such schedules shall be reviewed, updated and submitted to the Engineer, once in every two months thereafter, by the Contractor. Schedules shall also include the materials and equipment purchased from outside suppliers.

1.03.03 Erection Schedules

In order to achieve the overall completion schedule, the Contractor shall provide the Owner all the information covering erection sequence, testing and commissioning activities. These schedules may be based on the recommended erection procedures and will be subject to discussions/agreements with the Owner subsequent to the award of contract.

1.03.04 The successful Bidder shall have to provide all the above schedules (i.e. 1.03.01, 1.03.02 & 1.03.03) in a tabular form in addition to that in the form of L2 & L3 networks and these shall necessarily include information not limited to the earliest and latest dates for various activities/submissions and also any related constraints. However, the Bidder shall include in his proposal a Level-1 (L-1) network showing the major activities and various milestones to achieve the above mentioned completion schedule.

1.03.05 The Contractor shall provide the Owner the original disc/software for all such schedules alongwith requisite no. of copies (as required by the Owner) within an agreed time schedule. This time schedule will be agreed between Owner/Bidder at the time of award of contract. The Contractor's project management software shall be compatible with that of the Owner and the input data shall be furnished to the Owner in a manner compatible with Owner's project management software, SAP.

1.04.00 Detailed Responsibilities

1.04.01 Planning & Monitoring

a) Planning

The Bidder shall prepare a Master Network Schedule in the form of PERT network.

The network shall be prepared on a Work Breakdown Structure for the project which sub-divides the project into a set of manageable systems/sub-systems. The master network will identify milestones of key events for each system/package in the areas of engineering, procurement, manufacture and despatch and erection and commissioning. The master network shall represent the Level-I plan and will form the basis for development of detailed second and third tier execution plans. The master network shall conform to the overall schedule prescribed by Owner.

The master network should be submitted along with the bid which would be mutually discussed and finalised before the Award of Contract. This master network would clearly indicate the responsibility of the Bidder and project management team. This master network would form a part of the contract. The master network shall also identify a complete list of inputs to be furnished by the Owner which may be required for proper interfacing and tie-up. Scheduled dates for providing such inputs shall also be indicated, which will be mutually discussed and finalised.

b) Monitoring & Progress Reporting

The progress reports would be emanated every month, one from the head office of the Contractor and another from the site office. The progress report emanating from the head office should necessarily include the following sections:

- i) Report on key milestones.
- ii) Management summary indicating critical areas with details of actions initiated and effect of any on the project.
- iii) Action needing attention of the Owner/Consultant.
- iv) Detailed packagewise status of engineering submissions, quality plan submissions and approval, procurement manufacture and despatch.

The monthly report generated from the site office should necessarily include:

- i) Report on key milestones.
- ii) Management summary indicating critical areas with details of actions initiated and effect if any on the project.
- iii) Action needing attention of the Owner/Consultant.
- iv) This report would also cover the areas pertaining to the receipt of the equipment at the port, port clearance, transport, receipt at site, erection and commissioning.

In addition to the above, as the project execution progresses, the Contractor shall also be responsible for generating more frequent reports in the form of fax/e-mail information on progress in critical areas so that actions can be expedited. The exact format of the progress report shall be finalised after award of Contract.

1.04.02 Engineering Management

Based on the master network for the project (L-1) the Contractor will prepare an exhaustive list of engineering activities for the equipment/systems covered in his scope and a detailed programme of accomplishing the same within the time frame specified in the master network. This schedule will form the Level-2 (L-2) network for engineering activities.

Based on (L-2) network, the Contractor shall further develop the Level-3 (L-3) network for engineering activities which will indicate schedule for data availability, drawing release date and document submission dates.

Detailed (L-2) and (L-3) networks would be submitted sequentially by the Contractor within two months from the date of issue of Letter of Intent and finalised within one (1) month thereafter.

All such networks shall be provided in MS PROJECT software as well as in other format / software suitable to Owner.

The engineering management team should also co-ordinate all interface engineering activity between the Contractor and the equipment sub-vendors so as to ensure the correctness and completeness of related engineering documentation before the same is submitted to the Owner.

TSGENCO is implementing SAP ERP. Hence the bidder apart from submission of the hard copies shall upload all the documents, drawings etc. in soft format in the relevant C- folder environment (web based) and comply with the additional requirements, if any.

1.04.03 Contracts Management

Based on the master network, the Contractor shall submit L-2 programmes of manufacture and despatch. In addition, the master network shall also include periods considered for site activities viz. erection, commissioning etc. These L-2 programmes would be submitted in 2 months time from the date of award of contract and finalised within one (1) month thereafter. The Contractor will also submit site mobilisation plan. This programme would be submitted at the time of finalisation of award of contract and agreed immediately thereafter so that immediate development of the various activities at site could take place.

The Contractor should also submit L-3 programmes for the manufacturing, despatch of the various items. These networks shall also show the customer hold points (CHP) which have to be cleared by Owner or their authorised representative(s) before further manufacture can take place. These L-3 programmes for the manufacture and despatch would clearly identify responsibilities of the Contractor, sub-Contractor and Owner. These networks shall be submitted within one (1) month of the date of finalisation of the various sub-contracts by the Contractor.

In case all the manufacture is being done by the Contractor then the L-2 programmes would be themselves amplified to cover details of the manufacture, inspection, clearance by Owner and despatch.

The Contractor shall also submit the programme for procurement of boughtout items, detailed shipping schedule and cash flow statement for Owner's approval.

1.04.04 Quality Assurance, Inspection and Expediting

The Contractor shall submit the list of manufacturers/sub-vendors from whom the equipment are expected to be procured and the quality assurance plans thereof for the manufacture shall be approved by the QA group of Owner before the manufacture is commenced. The list of major suppliers would be submitted along with the bid and this shall be mutually discussed and approval will be given by the Owner during contract negotiation meeting prior

to placement of Letter of Intent. This approved list will be binding to the bidder. In the said list, Owner reserves the right to include reputed/reliable vendors of his own choice. Regarding the various other sub-vendors, the list would be submitted within six (6) months of the award of the contract that shall be scrutinized by the Owner to accord approval. In such list Owner reserves the right to include vendors of his own choice. No further vendor approval will be given after twelve (12) months. On the quality plans, the customer hold points will also be identified based on which Owner would give clearance for the manufacture to proceed further.

Quality assurance/Inspection group of Owner or its representative would issue a material despatch clearance certificate (MDCC) after the inspection clearance which will enable the Contractor to despatch the equipment and claim the payment. In the despatch programme, the Contractor shall indicate a schedule of estimated programme, tonnages specifically identifying various oversize dimensioned consignments (ODC). Further the Contractor will also be required to ensure at all stages of shipment that packing of all shipments despatched are suitable for ocean freight to India, handling at the port of entry, inland transportation and preservation at site upto erection. All despatch details & item lists shall be made available to both Owner & site immediately after shipping.

The Contractor shall also expedite all despatches from their own works/works of their sub-vendors, so as to match with the various activities mentioned at 1.04.03 above.

1.04.05 Construction Management

Based on the L-1 Master Network Programme, within two (2) months of the issue of Letter of Intent, the Contractor shall submit a programme of construction/ erection/ commissioning, either in continuation with the manufacture and despatch or separately for the implementation. These programmes would be amplified showing when the civil drawings shall be released by him and construction of civil works shall be completed by him to facilitate start of erection and subsequent activities and shall form the basis for site execution and detailed monitoring. The three monthly rolling programme with the first month's programme being tentative based on the site conditions would be prepared based on these L-3 programmes. The Contractor shall also be involved along with the Owner to tie up detailed resource mobilisation plan over the period of time of the contract matching with the performance targets.

The L-3 programme would be jointly finalised by the site in charge of the Contractor with the Owner's project coordinator as well as the site planning representative. The erection programme will also identify the sequential erectable tonnages that are required for various equipment which should be taken care of in the despatch programmes.

Erection and commissioning of the equipment shall also be done under the supervision of experts from the respective equipment/ system supplier.

1.04.06 Spares Management

Alongwith the proposal for the plant and equipment, the Contractor shall also submit proposals/schedule for the following:

- a) Mandatory spares
- b) Recommended spares

While the award for mandatory spares will be finalised at the time of the award of contract, recommended spares will be finalised thereafter.

1.05.00 **Project Progress Review Meetings**

Keeping in mind the overall responsibility of the Contractor it is intended that periodic progress reviews on the entire activities of execution of the project will be held initially at least once in two (2) months at Hyderabad/site/ at the discretion of the Owner.. During peak period it may be held once in a month. These meetings will be attended by reasonably higher officials of the Contractor and their leading sub- contractors and will be used as a forum for discussing all areas where progress needs to be speeded up. Actions will be placed on the concerned agencies and decisions will be taken to expedite/speed up the progress. Minutes of such meetings will be issued reflecting the major discussions and decisions taken and circulated to all concerned for reference and action. The Contractor shall be further responsible for ensuring that suitable steps are taken to meet various targets decided upon such meetings.

In addition to the above, and to streamline the construction and erection at site, a suitable frequency and forum of periodic meetings between the Contractor and the Owner will be decided upon as part of erection coordination procedure. Site co-ordination meeting may be held on weekly basis.

1.06.00 **Owner's Consultant**

The Owner would appoint a consultant to assist him in some of the areas mentioned at 1.01.00 above. The details of interaction and procedures for coordination between Owner / Owner's Consultant and Contractor/ Contractor's project management team shall be finalised during contract negotiations.

1.07.00 **Commissioning Management**

1.07.01 For commissioning of the various equipment/system covered under the scope of contract, Owner will form an organisation structure which may consist of the following committees. The Contractor shall nominate his representative on one or more of the committee as decided by the Owner:

- a) Steering Committee
- b) Commissioning Panel.
- c) Working Parties
- d) Testing Teams.

1.07.02 Commissioning documents shall be prepared by the Contractor in the

following manner and submitted for Owner's approval :

a) Field Quality Plan

This document shall be prepared for the various equipment/ systems under commissioning and shall have the following objectives to fulfill and shall be submitted for Owner's approval at least six (6) months before their actual commissioning :

- i) Establish design data against which Plant Performance will be compared.
- ii) Set-out the testing objectives and proposals.
- iii) Define the documentation required.

b) Testing/Commissioning Schedule

These shall be prepared for the various equipment/systems under consideration and shall contain sections like detailed testing method, programme, safety, individual responsibility and results.

c) Standard Check Lists

Standard check lists are intended for use at the completion of erection to ensure correct erection, testing and to a limited extent operation for repetitive items.

1.07.03 Test Reports

After the completion of commissioning activity of equipment/ systems, the Contractor shall prepare the test reports which shall include all the relevant information related to various commissioning checks, tests carried out, any deviations/commissions noticed with respect to the intended design requirements, sequence of various commissioning activities as actually adopted vis-a-vis as recommended in the procedures, programme schedules achieved and any other such information as required. These test reports shall be submitted in requisite number of copies to the Owner and this should be duly signed jointly by the Owner/Consultant and the Contractor/Equipment supplier, who are involved during the commissioning activities.

2.00.00 **SITE SERVICES**

These services shall be rendered by the Bidder as part of the overall project management service. The services shall broadly include but not be limited to the following :

2.01.00 Arranging material despatch from the shop by rail/road and/or sea as applicable.

2.02.00 Monitoring movement of materials & follow-up as necessary with Railways, road transport, port clearance etc. from the time of despatch F.O.R. works/ F.O.B. port of shipment by Contractor till receipt of the same at site.

- 2.03.00 Unloading of materials at Railway Station/Railway Siding inside project area/ Road Transportation, transportation to site store, assessment of lost/damaged items in transit and arranging insurance claims and replacement of lost/damaged items. The Contractor shall submit to the Engineer a report detailing all the receipts during the week as well as storing, preservation of material at site.
- 2.04.00 Issuing materials from site store/open yard from time to time for erection as per the construction programme. The Contractor shall be the custodian of all the materials issued till the plant is officially taken over by the Owner after complete erection and successful trial run & commissioning.
- 2.05.00 Transportation of materials to their respective places of erection and erection of the complete plant & equipment as supplied under this specification.
- 2.06.00 Trial run and commissioning of individual equipment/sub-systems and the plant as a whole to the satisfaction of the Owner, including supply of temporary equipment & services for chemical cleaning, steam blowing as well as performance guarantee tests.

Apart from Boiler, proper chemical cleaning shall be carried out in following pipe lines/equipment before commissioning

- a) Deaerator
- b) Boiler feed suction, recirculation leak-off lines
- c) Boiler Feed discharge line by passing heaters
- d) Attenuation lines
- e) Condensate suction & discharge piping upto deaerator by passing the feed water heaters.
- f) Fuel oil lines.

Provision for preservation of individual equipment after trial run and commissioning e.g. Nitrogen blanketing etc. as necessary shall also be in the scope of the Bidder.

Safe disposal of effluent after chemical cleaning shall be done by the contractor.

- 2.07.00 Supply and application of the final paints and first fill lubricants on all the equipment to be erected under this specification. Supply of chemicals, lub oils and other consumables upto COD.
- 2.08.00 For the purpose of erection and commissioning the Contractor's scope of work shall include but not be limited to the following :
- 2.08.01 Deployment of all skilled and unskilled manpower required for erection, supervision of erection, watch & ward, commissioning and other services to

-
- be rendered under this specification.
- 2.08.02 Deployment of all erection tools & tackle, construction machinery, transportation vehicles and all other implements in adequate number and size, appropriate for the erection work to be handled under the scope of this specification.
- 2.08.03 Supply of all consumables, e.g. welding electrodes, cleaning agents, diesel oil, grease, lubricant etc. as well as materials required for temporary supports, scaffolding etc. as necessary for such erection work except those listed under exclusion elsewhere in this specification.
- 2.08.04 Construction of all civil/structural/architectural works, including construction of foundation for all equipment supplied as required, grouting of equipment on foundation after alignment, and all other incidental civil activities as detailed elsewhere.
- 2.08.05 All structural steel fabrication and erection work as detailed elsewhere in the specification.
- 2.08.06 Providing support services for the Contractor's erection staff e.g. construction of site offices, temporary stores, residential accommodation and transport to work site for erection personnel, insurance cover, watch & ward for security and safety of the materials under the Contractor's custody etc. as required.
- 2.08.07 Maintaining proper documentation of all the site activities undertaken by the Contractor as per the proforma mutually agreed with the Owner; submitting monthly progress reports as also any such document as and when desired by the Owner; taking approval of all statutory authorities e.g. Boiler Inspector, Factory Inspector, Inspector of Explosives, Electrical Inspector etc. for respective portions of work under the jurisdiction of such statutes or laws.
- 2.08.08 The Contractor shall provide 'Industrial Relations' unit and 'Medical' unit to take care of his erection staff and the Owner shall have no obligation in the regard.
- 2.08.09 The successful Bidder shall arrange for Tower cranes of adequate capacity for speedy erection activities.
- 2.09.00 **Site Organisation**
- The Contractor shall maintain a site organisation of adequate strength in respect of manpower, construction machinery and other implements at all times for smooth execution of the contract. This organisation shall be reinforced from time to time, as required, to make up for slippages from the schedule without any commercial implication to the Owner. The site organisation shall be headed by a competent construction manager having sufficient authority to take decisions at site.

On award of contract, the Contractor shall submit to the Owner a site organisation chart indicating the various levels of experts to be deployed on the job. The Owner reserves the right to reject or approve the list of personnel

proposed by the Contractor. The persons, whose bio-data have been approved by the Owner, will have to be posted at site and deviations in this regard will not generally be permitted.

The Contractor shall also submit to the Owner for approval a list of construction equipment, erection tools, tackle etc. prior to commencement of site activities. These tools & tackle shall not be removed from site without written permission of the Owner.

2.10.00 General Guidelines for Field Activities

2.10.01 The Contractor shall execute the works in a professional manner so as to achieve the target schedule without any sacrifice on quality and maintaining highest standards of safety and cleanliness.

2.10.02 The Contractor shall co-operate with the Owner and other Contractors working in site and arrange to perform his work in a manner so as to minimise interference with other Contractors' works. The Owner's engineer shall be notified promptly of any defect in other Contractor's works that could affect the Contractor's work. If rescheduling of Contractor's work is requested by the Owner's engineer in the interest of overall site activities, the same shall be complied with by the Contractor. In all cases of controversy, the decision of the Owner shall be final and binding on the Contractor without any commercial implication.

2.10.03 The Engineer shall hold weekly meetings of all the Contractors working at Site at a time and a place to be designated by the Engineer. The Contractor shall attend such meetings and take notes of discussions during the meeting and the decisions of the Engineer and shall strictly adhere to those decisions in performing his Work. In addition to the above weekly meeting, Engineer may call for other meetings either with individual contractors or with selected number of contractors and in such a case the Contractor, if called will also attend such meetings.

2.10.04 Time is the essence of the Contract and the Contractor shall be responsible for performance of his Work in accordance with the specified construction schedule. If at any time the Contractor is falling behind the schedule, he shall take necessary action to make good of such delays by increasing his work force or by working overtime or otherwise accelerate the progress of the work to comply with the schedule and shall communicate such action in writing to the Engineer, satisfying that his action will compensate for the delay. The Contractor shall not be allowed any extra compensation for such action.

2.10.05 The Engineer shall however not be responsible for provision of additional labour and or materials or supply or any other services to the Contractor except for the co-ordination work between various Contractors as set out earlier.

2.10.06 The works under execution shall be open to inspection & supervision by the Owner's engineer at all times. The Contractor shall give reasonable notice to the Owner before covering up or otherwise placing beyond the reach of inspection any work in order that same may be verified, if so desired by the Owner.

- 2.10.07 Every effort shall be made to maintain the highest quality of workmanship by stringent supervision and inspection at every stage of execution. Manufacturer's instruction manual and guidelines on sequence of erection and precautions shall be strictly followed. Should any error or ambiguity be discovered in such documents, the same shall be brought to the notice of the Owner's engineer. Manufacturer's interpretation in such cases shall be binding on the Contractor.
- 2.10.08 The Contractor shall comply with all the rules and regulations of the local authorities, all statutory laws including Minimum Wages, Workmen Compensation etc. All registration and statutory inspection fees, if any, in respect of the work executed by the Contractor shall be to his account.
- 2.10.09 All the works such as cleaning, checking, leveling, blue matching, aligning, assembling, temporary erection for alignment, opening, dismantling of certain equipments for checking and cleaning, surface preparation, edge preparation, fabrication of tubes and pipes as per general engineering practice at site, cutting grinding, straightening, chamfering, filling, chipping, drilling, reaming, scrapping, shaping, fitting-up bolting/welding, etc., as may be applicable in such erection and are necessary to complete the work satisfactorily, are to be treated as incidental and the same shall be carried out by the Contractor as part of the work.
- 2.10.10 In case of any class of work for which there is no such specification as laid down in the contract such as, blue matching, welding of stainless steel parts, etc., the work shall be carried out in accordance with the instructions and requirements of the Engineer and as per the Standards.
- 2.10.11 It may sometimes be necessary to remove some of the erected structural members to facilitate erection of bigger/pre-assembled equipment. In such cases, the removal and re-erection of such members, which are essential, and if so agreed by the Engineer, will have to be done by the Contractor.
- 2.10.12 Attachment welding of necessary instrumentation tapping points, thermocouple pads, root valves, condensing vessels, flow nozzles and control valves etc., both for regular measurement and performance testing to be provided on equipment, its auxiliaries or pipelines covered within the scope of this tender, will also be the responsibility of the Contractor and the same will be done as per the instructions of Engineer. The erection and welding of all above items will be the Contractor's responsibility, even if :
- a) Product groups under which these items are re-leased are not covered in the scope of this tender.
 - b) Items are supplied by an agency other than the Contractor.
- 2.10.13 Preservation of all materials/equipment under custody of the Contractor during storage, pre-assembly & erection, commissioning etc., shall be the responsibility of the Contractor. All necessary preservatives and consumables like paints, etc., shall be arranged by the Contractor. Necessary touch up painting, periodic application of preservatives/paints on pressure parts/other equipment even after erection until completion of work shall be carried out by

the Contractor. The Contractor shall fabricate piping, install lub oil systems and carry out the acid cleaning of fabricated piping. The Contractor shall also service the lub. oil system, carryout the hydraulic test of oil coolers, etc.

- 2.10.14 It is responsibility of the Contractor to do the alignment etc. if necessary, repeatedly to satisfy Engineer, with all the necessary tools & tackle, manpower, etc. The alignment will be complete only when jointly certified so, by the Contractor's Engineer & Owner. Also the Contractor should ensure that the alignment is not disturbed afterwards.
- 2.10.15 Additional platforms for approaching different equipment as per site requirement, which may not be indicated in drawings, shall be fabricated and erected by the Contractor. The materials required for these works shall be supplied by the Contractor and he will have to fabricate them to suit the requirement.
- 2.10.16 Equipment and material which are wrongly installed shall be removed and reinstalled to comply with the design requirement at the Contractor's expense, to the satisfaction of the Owner/ Consultant.
- 2.10.17 Before erection of any equipment on a foundation, the Contractor shall check and undertake if necessary rectification of foundation bolts, reaming of holes, drilling of dowels, matching of bolts and nuts, making new dowel pin, etc.
- 2.10.18 Assistance for calibrating/testing the power cylinders, valves, gauges, instruments, etc., and setting of actuators coming under various groups shall be provided by Contractor.
- 2.10.19 It shall be the responsibility of the Contractor to provide ladders on columns for initial works till such time stairways are completed. For this, the ladder should not be welded on the column and should be prefabricated clamping type. No temporary welding on any structural member is permitted except under special circumstances with the approval of Owner.
- 2.10.20 Structural materials required for the supporting/operating platforms required for the valves at various levels for the same operation of valves will be arranged by the Contractor.

2.11.00 **Safety**

Safety and overall cleanliness of work site shall be given top priority.

- 2.11.01 The Contractor shall ensure the safety of all workmen, materials and equipment either belonging to him or to others working at site. He shall observe safety rules & codes applied by the Owner at site without exception.
- 2.11.02 The Contractor shall notify the Owner of his intention to bring to site any equipment or material which may create hazard. The Owner shall have the right to prescribe the conditions under which such equipment or material may be

handled and the Contractor shall adhere to such instructions. The Owner may prohibit the use of any construction machinery, which according to him is unsafe. No claim for compensation due to such prohibition will be entertained by the Owner.

- 2.11.03 Storage of petroleum products & explosives for construction work shall be as per rules and regulation laid down in Petroleum Act, Explosive Act and Petroleum and Carbide of Calcium Manual. Approvals as necessary from Chief Inspector of Explosives or other statutory authorities shall be the responsibility of the Contractor.
- 2.11.04 The Contractor shall be responsible for safe storage of his and his sub-contractor's radioactive sources.
- 2.11.05 All requisite tests & inspection of handling equipment, lifting tools & tackle shall be done by the Contractor and certified copies shall be supplied to the Owner. Defective equipment shall be removed from service. Any equipment shall not be loaded in excess of its recommended safe working load.
- 2.11.06 All combustible waste and rubbish shall be collected and removed from the worksite at least once each day. Use of undercoated canvas paper, corrugated paper, fabricated carton, plastic or other flammable materials shall be restricted to the minimum and promptly removed.
- 2.11.07 The Contractor shall provide adequate number of fire protection equipment of the required types for his stores, office, temporary structures, labour colony etc. Personnel trained for fire-fighting shall be made available by the Contractor at site during the entire period of the Contract.
- 2.11.08 All electrical appliances used in the work shall be in good working condition and shall be properly earthed. No maintenance work shall be carried out on live equipment. The Contractor shall maintain adequate number of qualified electricians to maintain his temporary electrical installation.
- 2.11.09 All workmen of the Contractor working in construction site shall wear safety helmets, safety boots and safety belts. The Contractor shall take appropriate insurance cover against accidents for his workmen as well as third party.
- 2.11.10 All the worksites shall be provided with adequate lighting facilities e.g. flood lighting, hand lamps, area lighting etc. by the Contractor for proper working environment during night times.
- 2.11.11 All safety precautions shall be taken for welding and cutting operations as per IS-818.
- 2.11.12 All safety precautions shall be taken for foundation and other excavation marks as per IS-3764.
- 2.12.00 **Taking Delivery & Storage**
- 2.12.01 The Contractor shall arrange issue of all equipment and materials to be erected under the contract from the stores/open yard at site by signing on standard indent forms. After completion of work, detailed auditing of the

materials so issued shall be submitted to the Owner.

- 2.12.02 The Contractor shall arrange for proper and safe storage of materials till the same are taken over by the Owner as per terms of the contract. Manufacturer's instructions for preservation shall be strictly followed.
- 2.12.03 All empty containers, packing materials, gunny bags, transport frames and also surplus and unused materials reconciliation prior to completion of contract shall be the property of the Owner and returned to the Owner by the Contractor.
- 2.13.00 **Site Welding & Heat Treatment**
- 2.13.01 Welding shall be done in accordance with IS-813, IS-816, IS-9595 & other relevant IS/International standards and as per instructions of Contractor. Only those welders, who are qualified as per IS-817 for ordinary welds and as per IBR/ASME Section-IX for high pressure welds, shall be employed in the job.
- 2.13.02 All welders shall be tested and approved by Engineer before they are actually engaged on the work even though they may possess the requisite certificates. The Owner reserves the right to reject any welder without assigning any reason. The welder identification code as approved by the Engineer shall be stamped by the welder on each joint done by them. The Contractor will be responsible for the periodic renewal, re-testing of the welders as demanded by Owner.
- 2.13.03 The Engineer is entitled to stop Contractor's any welder from his work if his work is unsatisfactory for any technical reason or there is a high percentage of the rejection of joints welded by him, which in the opinion of Engineer will adversely affect the quality of welding even though the welder has earlier passed the tests. The welders having passed the tests do not relieve the Contractor from his contractual obligations, to check the performance of the welders.
- 2.13.04 All charges for testing of welders including destructive and non- destructive tests if conducted by Owner or by the inspection authority at site shall have to be borne by the Contractor. The necessary test materials and consumables will have to be arranged by the Contractor and all testing facility made available, as required.
- 2.13.05 All welded joints shall be subject to acceptance by Engineer. Inspection of welds shall be in accordance with IS-822 or equivalent code.
- 2.13.06 Preheating/post heating and stress relieving after welding are part of fabrication and erection work and shall be performed by the Contractor in accordance with the instruction of Engineer. Contractor shall arrange to supply heating equipment with automatic recording devices. Also the Contractor shall have to arrange for the labour, heating elements, thermocouples, compensating cables, insulation materials like mineral wools, asbestos cloth, ceramic beads, asbestos rope, etc. required for the heat-treatment and stress relieving works. During pre- heat/stress relieving operations, the temperature shall be measured at one or more points as required by attaching thermocouples and recorded on a continuous printing

type recorder. All the record graphs for the heat treatment works carried out shall be got signed by the Engineer prior to the commencement of each cycle and handed over to Engineer on completion. The graphs will be the property of Owner. The Contractor has to provide thermo-chalks temperature recorders, thermocouple attachments, units, graph sheets, etc. required for the job and maintain them in good condition.

- 2.13.07 All electrodes shall be baked and dried in the electric/electrode drying oven to the required temperature and for the period specified by the Engineer before they are used in erection work. The electrodes used shall be as per IS-814, IS-815, IS-1442, IS-7280 and other codes as applicable, and shall be of approved reputed manufacture. The electrodes shall meet the requirement of the pipe material. No electrode manufactured more than 12 months ago and the type covered under certificate issued after conducting tests more than 6 months ago shall be used. All electrodes shall be preserved at works and at site as per manufacturer's recommendations.
- 2.13.08 Oxy-acetylene flame or Exothermic chemical heating for stress relieving is not permitted. Heating shall be by means, of electric induction coil or electric resistance coil.
- 2.13.09 It may become necessary to adopt inter layer radiography/MPT/UT depending upon the site/technical requirement necessitating interruptions in continuation of the work and making necessary arrangement for carrying out the above work.
- 2.13.10 Gas tungsten arc welding process (TIG) shall be adopted for all root pass welds except for structural works until 4.75 mm thickness is deposited. Subsequent welding after root pass can be carried out by manual metal arc welding with coated electrodes. For pipes of thickness less than 6 mm the entire welding has to be carried out by TIG welding.
- Fillet weld shall be made by shielded metal arc process as per applicable codes.
- However, the Engineer will have the option of changing the method of welding as per site requirement. The method adopted for manual arc welding shall be weaving technique and the width of weaving shall not exceed 1.5 times of the dia. of the electrode.
- In case of deviation from welding process and electrodes, the Contractor shall take approval of the Owner prior to adoption of same.
- 2.13.11 The root pass for butt joints shall be such as to achieve full penetration with complete fusion of root edges.
- 2.13.12 Each pass shall be cleared and freed of slag before the next pass is deposited.
- 2.13.13 On completion of each run, craters, weld irregularities, slag etc. shall be removed by grinding or chipping.
- 2.13.14 Each layer of welding shall have an even and smooth appearance.

- 2.13.15 Welding sequence shall be adjusted in such a way that distortion due to welding shrinkage is minimised. Further any movement, shock or vibration during welding shall be avoided to prevent weld cracks.
- 2.13.16 Proper protection of welders and the work shall be taken during periods of rain. No welding shall be carried out when surface to be welded are wet from any cause.
- 2.13.17 Following will be stages of inspection during welding :
- a) Two pieces to be joined shall be individually checked for the weld edge preparation and profile dimensionally and to the template. Dye penetrant check shall be carried out on edge prepared surfaces at random. The percentage will depend upon on criticality as specified by Engineer.
 - b) Joint fit up will be a stage of inspection. Misalignment after fit up may vary from 0.3 mm to 1.6 mm depending on outside diameter and thickness.
 - c) All joints shall be offered for visual inspection after root run. Subsequent welding should be made only after the approval of root run.
- 2.13.18 All welded joints shall be painted with anti-corrosive paint immediately on completion of radiography and stress-relieving.

3.00.00 **PROJECT INFORMATION AND MANAGEMENT SYSTEM, INCLUDING DCOUMENT MANAGMENT SERVER (DMS)**

3.01.00 Contractor shall submit as part of its Work Scope detailed documentation as outlined in this section and / or required by the Technical Requirements. The content and format of the documentation to be submitted are subject to Owner's approval.

3.02.00 Contractor shall utilise a computer based system for control and management of project documentation. The system must be capable of producing customized reports and information on demand. This control system should have been successfully applied to similar projects and be familiar to the project control personnel selected. Contractor's detailed project documentation plan shall identify all documentation requirements for the project, the party responsible for production of the document, the basic content of the document and the required timing for issue. This plan shall include, but not be limited to the details of all Drawings to be produced, plant specification / definition documentation, equipment orders and manuals. The documentation identified shall be entered into the computer based control system The database thus created shall be capable of being sorted and

ordered on a variety of selected parameters such as document type, subject description, responsible party, start date and finish date, to enable review and update to be conducted only on those documents which are relevant.

3.03.00 Regular documentation control progress reports shall be prepared by the Contractor to record the status of documentation. In the event either Party or Engineer expresses concern with the content of such progress reports, the accuracy of progress reports, status of documentation production and other such matters, the concern will be identified to the Project Manager. Within five days of notification of this concern, the Project Manager will attend a meeting with relevant Owner Representatives and provide details of specific actions to be initiated to satisfactorily overcome the difficulties identified. It will be the Project Manager's responsibility to initiate whatever action is necessary to ensure that the production of documentation is completely in accordance with Project Information Management System (PIMS).

3.04.00 Within 90 days after Effective Date of Contract, the Contractor shall establish an integrated PIMS which will support the needs of Project and management, detail design and engineering, procurement, construction and operation, and maintenance.

PIMS shall utilise software which links various software and database programs to form a composite system. The typical scope of PIMS shall include, but not be limited to, the following:

- (a) Power plant systems and equipment data, from which Project specific flow diagrams, data sheets and other integrated data are derived. The Power plant systems and equipment data, from which Project specific flow diagrams, data sheets and other integrated data are derived. This data shall include, but not be limited to, the following:
 - (i) System descriptions and design requirements and design criteria
 - (ii) Equipment and material technical specifications for all engineering disciplines
- (b) Detail engineering data to create flow diagrams, plant arrangements, piping configurations, equipment layout and design, electrical and instrumentation systems, structures, and other systems. The software tool used shall be capable of manipulation and storage of plant layout and design information. The 3D model of the plant shall also contain details of the various components like pipe, structural steel work, etc., and relevant information shall be available on-line from relevant data base. Software shall be multi-user, multi-access nature allowing the designers of Contractor and major Sub-Contractors, if required, to work in interactive real time environment and software shall be capable of interference checking. The software shall allow access to different types of information held in the database. It shall estimate the type and quantity of materials required to build the plant and it shall be possible for such data to be taken off the system at any time.

-
- (c) Construction data to monitor and manage site activities, including material control, scheduling and progress, quality control, start-up and testing, operation, maintenance, training, and all other site functions.
 - (d) Plant design and construction records to provide data for safe and efficient maintenance and operation. Records to include may be maintenance schedule, man power tracking, tools, spare parts, and test equipment inventory, equipment list, drawing, control, technical specifications, and equipment instruction manuals.

3.05.00 The PIMS shall be installed in a distributed processing array system and operated through personal computer work stations at the Contractor's site office. A complete integrated system shall be implemented. This system shall be utilised by Contractor during the Project execution.


ENGINEERING SERVICES



Arvind



S A Khan



Praveen Kishore

CONTENT

CLAUSE NO.	DESCRIPTION
1.00.00	GENERAL
2.00.00	DESIGN COORDINATION MEETING
3.00.00	CO-OPERATION WITH OTHER CONTRACTORS AND CONSULTING ENGINEERS
4.00.00	GUIDELINES FOR ENGINEERING SERVICES
5.00.00	OPERATING MANUALS AND MAINTENANCE INSTRUCTIONS
6.00.00	PLANT HANDBOOK
7.00.00	CONTRACT STAGE DOCUMENT SUBMISSION AND APPROVAL PROCEDURE
8.00.00	TENDER STAGE DOCUMENT SUBMISSION

ATTACHMENTS

ANNEXURE-1	DISTRIBUTION SCHEDULE
------------	-----------------------

ENGINEERING SERVICES

1.00.00 GENERAL

1.01.00 As part of the overall project management activity, the Contractor shall be responsible for proper engineering and co-ordination of activities during various phases of execution of the contract. The Contractor shall identify a person, designated as Project Manager, with whom the Owner, the Consulting Engineer or the Review Consultant shall interact on matters related to engineering as well as execution of the contract. The Project Manager shall be the single-point contact person on behalf of the Contractor and shall be responsible for all engineering co-ordination. The Owner/Consultant/Review Consultant shall interact with the Project Manager only on all matters of co-ordination between the Owner and the Contractor or on matters involving the Contractor, his manufacturing units and sub-vendors. For the purpose of expediting the Owner or his representative may sometimes interact with the manufacturing units or sub-vendors of the contractors. However such interaction will not, under any circumstance, dilute the responsibility of the Contractor to provide a fully engineered and co-ordinated package under this contract.

1.02.00 On finalization of the contract, a procedure for exchange of engineering information will be mutually agreed and finalized between the Owner and the Contractor.

2.00.00 DESIGN COORDINATION MEETING

The Contractor and his sub-vendors will be called upon to attend design co-ordination meetings with the Engineer, other Contractors and the Consultants of the Owner during the period of execution of contract. The Contractor including his sub-vendors shall attend such meetings at their own cost at Owner's or Consultant's office in Kolkata or at mutually agreed venue as and when required and fully cooperate with such persons and agencies involved during those discussions.

3.00.00 CO-OPERATION WITH OTHER CONTRACTORS AND CONSULTING ENGINEERS

The Contractor shall agree to cooperate with the Owner's other Contractors and Consulting Engineers and freely exchange with them such technical information as is necessary to obtain the most efficient and economical design and to avoid unnecessary duplication of efforts. The Engineer shall be provided with copies of all correspondences addressed by the Contractor to other Sub- contractors and Consulting Engineers in respect of such exchange of technical information.

- 4.00.00 **GUIDELINES FOR ENGINEERING SERVICES**
- 4.01.00 Prior to commencement of the engineering work as part of design submissions, all aspects of design viz., criteria for selection and sizing of all equipment and systems, design margins etc. including that for structural steel and civil work shall be outlined and these shall form the basis for the detailed engineering work.
- 4.02.00 Engineering work shall be performed on modern and proven concepts and internationally accepted good engineering practices but fully compatible with the Indian environments. Owner shall have the right to review and approve the engineering work by themselves and/or through consultant and ask for any clarifications and changes/modifications to the work performed by Contractor.
- 4.03.00 At any stage during the performance of assignment, the Contractor may be required to make certain changes/modification/improvements in design/drawing/other documents which are applicable to 800 MW Unit, which in the opinion of the Owner could result in better improved design, layout, operability, plant availability, maintainability, reliability or economy of the plant and its systems/sub-systems in view of revised and more accurate information/data available at a later date(s) or feedback(s) received during execution / operation of similar units. Such changes / modifications/ improvements required could be identified by Owner and/or consultant and mutually discussed. Owner requires the Bidder to incorporate such action in the subject assignment appropriately without any additional cost liability and time implication to the Owner and same shall be within the responsibilities and scope of the Contractor.
- 4.04.00 During the course of review of detailed engineering stages, it may be essential in the opinion of Owner to obtain certain classified data for review purposes only. In case Owner so desires, the Bidder shall submit such data to Owner.
- 4.05.00 During the course of review of detailed engineering, it may be essential in Owner's opinion to obtain data and information on similar equipment and plants engineered by the Bidder. In case Owner so desires the Bidder shall submit such data and information to the Owner.
- 4.06.00 It is not the intent to give details of every single task covered in the total engineering work to be carried out by Contractor, however, all engineering work required for the satisfactory completion of the plant/systems as specified shall be carried out by the Contractor. Broadly, the following are the minimum requirements in respect of scope of major items of work:
- 4.06.01 Preparation, updating and finalisation of scheme drawings, control and interlock diagrams, detailed and fully dimensioned layout drawings (plant layout and equipment layout detailed plan, elevation and cross-sectional drawings at different elevations / floor levels) covering all mechanical, electrical, C&I, civil and structural items, equipment, systems and facilities. Drawings and Schedules prepared by the Contractor from time to time, as detailed designs are developed, shall be submitted for Owner's / Consultant's

approval before the work is taken up. Revisions, corrections, additions to drawings and schedules shall not be considered to change the scope of work.

- 4.06.02 Preparation of detailed technical specifications including data sheets, tender drawings and bill of material for all bought out items, as also finalisation of corresponding sub-contractors.
- 4.06.03 Review of sub-contractor's data, drawings, design calculations, schedules, bill of materials, instruction manuals etc. for all equipment, before forwarding them to Owner/Consultant for approval.
- 4.06.04 Preparation of civil construction drawings for all equipment showing foundation details and full details regarding equipment loads, floor openings, details of embedments etc. required for preparation of civil construction drawings and also as referred at relevant sections of Scope, Terminal Points & Exclusions. These documents shall be preceded by appropriate design calculations, static and dynamic analysis as necessary.
- 4.06.05 Preparation and finalisation of process piping and instrumentation diagrams and schematics, complete in all respects for all systems/packages of the power plant.
- 4.06.06 Preparation of consolidated schedules and bills of materials, including line numbers, tag numbers, source of supply, service conditions, specifications, materials, types and connections details, quantities for items of the plant including dampers, steam traps, strainers, instrumentations, ducting.
- 4.06.07 Sizing of all piping and equipment as per the stipulated design criteria; carrying out of flexibility analysis/dynamic analysis as necessary; hangers & support engineering.
- 4.06.08 Final revision of all documents including preparation and compilation of Instruction Manuals for installation, commissioning, operation and maintenance for all equipment and systems. Refer clause 5.00.00 for the specific requirement in this regard.
- 4.06.09 Certification and submission of final as-built drawings for all areas.
- 4.06.10 Preparation and compilation of all drawings, schedules and instructions which may be required at site, whether separately mentioned or not.
- 4.06.11 All erection and assembly drawings which may be required at site.
- 4.06.12 For all bought out item packages, the Contractor shall provide complete material / component list along with detail specification, drawings, component part no. etc. during detail engineering stage prior to final approval. Such approved drawing/document shall be made available at site in adequate number prior to commencement of work. Moreover, such document/drawing shall be provided in soft form (CD)
- 4.06.13 Preparation of necessary documentation, design calculations etc. required for submission to statutory authorities like IBR, Chief Electric Inspector, Factory Inspector etc.

5.00.00 **OPERATING MANUALS AND MAINTENANCE INSTRUCTIONS**

5.01.00 The Contractor shall provide at least six (6) months before the time of commissioning and before taking over of the plant and equipment, all necessary maintenance manuals and operating instructions. The instruction manual shall be submitted in the form of one (1) soft copy in CD and 15 hard copies as per distribution schedule (Annexure-1).

5.02.00 The information provided, which shall be contained in loose leaf stiff backed covers, shall include :

- a) A complete inventory of all main items of plant, with identification details.
- b) Service manuals for all plant and equipment giving full descriptions of the main items and auxiliary items such as power packs, hydraulic equipment, actuators, lubricating pumps, etc.
- c) A separate electrical manual covering items such as switchgear, cabling, instrumentation, controls, cabling layouts and wiring diagrams.
- d) A schedule of recommendations for routine maintenance of all electrical and mechanical equipment, recommended inspection point, information on detection, cause and rectifications of troubles & faults.
- e) A lubrication schedule with all necessary drawings diagrams to identify the lubrication points.
- f) Manufacturer's literature.

5.03.00 The instruction manual shall be subject to the approval of Owner.

6.00.00 **PLANT HANDBOOK**

The Contractor shall submit to the Engineer, a preliminary plant handbook preferably in A-4 size sheets which shall contain the design and performance data of various plant, equipment and systems covering the complete project including single line flow diagrams, within twenty four (24) months from the date of his acceptance of the Letter of Intent. The final plant handbook complete in all respects shall be submitted by the Contractor six (6) months before start-up and commissioning activities. The plant handbook shall be submitted as per distribution schedule.

7.00.00 **CONTRACT STAGE DOCUMENT SUBMISSION AND APPROVAL PROCEDURE**

7.01.00 Within fifteen (15) days to one month of issue of Letter of Intent (LOI) by the Owner, the Contractor shall furnish a schedule of drawings and design

document to be submitted by him to the Owner/Engineer indicating dates against each document.

The documents shall be divided into two categories : a) for approval and b) for information/further engineering and co-ordination by the Owner.

In preparing this schedule, the Contractor shall allow two (2) weeks from date of receipt for review and comments by the Owner/Engineer for each submission of a document.

This document submission schedule shall require approval by the Owner/Engineer.

7.02.00 All contract documents shall be marked, without fail, with the name of the Owner, the Project, the specification title and number and the unit designation.

All dimensions shall be in metric units.

All notes, markings etc. shall be in English.

7.03.00 Documents/Drawings, submitted during tender stage, shall be revalidated or revised as required and submitted as certified contract document for approval / information of the Owner/Engineer.

7.04.00 Unless specified otherwise, the following categories of documents/drawings would require approval of the Owner/Engineer:

- a) List of sub-vendors (from Owner only)
- b) System scheme and instrumentation diagrams
- c) Design basis justifying selection of equipment & process parameters where not specified in the Contract
- d) Equipment data sheets and general arrangement drawings
- e) Materials of construction
- f) Layout drawings.
- g) Operation logic diagrams.
- h) Typical control circuit.
- i) Drawings of Instrumentation and control.

7.05.00 Unless specified otherwise, the following categories of documents/ drawings would be treated for information/further engineering by the Owner/Engineer. The Contractor shall, however, incorporate all additional information and clarifications in these documents / drawings as and when desired by the Owner/Engineer.

- a) Equipment foundation drawings.
- b) Equipment cross-section drawings, product literature etc. which are of proprietary nature.
- c) Predicted performance curves of equipment.
- d) Various bills of quantity, schedules etc.
- e) Piping fabrication drawings, isometrics etc.
- f) Panel wiring diagrams.
- g) Instruction/Operation manuals.
- h) Service manuals and trouble shooting guide for C & I system including field instruments.
- i) Cable schedule and interconnection chart.
- j) Drive/feederwise control scheme showing all external interfaces.

In essence, the Contractor is solely responsible for corrections and adequacy of design & engineering for documents under this category.

7.06.00

Upon review, the Owner/Engineer shall put his remarks and one of the following action stamps on the drawing/document:

- a) A - Drawing submitted as approved, proceed with fabrication
- b) B - Drawing approved subject to comments noted, proceed with fabrication, considering our comments. Correct as necessary and resubmit for record.
- c) C - See attached memo.
- d) D - Correct your original drawing incorporating our comments and resubmit for approval.
- e) E - Information furnished is noted.
- f) F - Prints not enclosed

For action stamps in category (c) & (d), documents must be resubmitted for review by the Owner/Engineer. For action stamp in category (b), further review by Owner/Engineer would not be necessary provided the Contractor agrees & incorporates the comments made on the document.

Except for action stamp under category (c) & (d), the Contractor can proceed with manufacturing and other sequential activities for those areas of a drawing/document which do not have any review comment by the Owner/Engineer.

The Owner/Engineer may accord approval in category (c) or (d) in more than one submission of a document till he is satisfied that the intent of the specification has been fully complied with. The Contractor shall be responsible for delay in such cases and no extension of time shall ordinarily be allowed on such grounds. Approval of contract documents by the Owner/Engineer shall not relieve the Contractor of his responsibility for any errors and fulfillment of contract requirements.

The Contractor's work shall be in strict accordance with the finally approved drawings and no deviation shall be permitted without written approval of the Owner/Engineer.

- 7.07.00 Except key plan/general yard plan, any layout drawing requiring scrutiny shall not be drawn to a scale less than 1:50.
- 7.08.00 For review by the Consulting Engineer, the Contractor shall furnish soft copies of drawings & documents and three (3) prints of each drawing/document. Two (2) prints of such submission shall also be sent to the Owner. After review, comment/approval will be sent to the Contractor. Upon action under category (a) or (e), the Contractor shall directly distribute the documents to the various offices of the Owner and other agencies in number of copies as specified in the contract document. Such distribution copies shall be marked with the reference and date of the letter by which the Owner/Engineer has accorded his final approval. Penal action shall be taken against the Contractor for any unauthorised revision in the drawings so distributed from the drawings approved by the Owner/Engineer. The contractor shall furnish three (3) CDs of all as built/final drawings for Owner/Consultant site.
- 7.09.00 In case of contradiction between the stipulations above and those stated elsewhere in the specification, the stipulations herein shall prevail.

ANNEXURE-1

DISTRIBUTION SCHEDULE

S. No	Description	TSGENCO										Consultant			Equipment Vendor	Remarks
		Director Projects	Director Technical	CE/Civil Thermal Projects Hyd.	CE/ TPC-I, Hyd	CE/ O&M/	SE/ Civil	SE/E&M /	DE Constr.			HYD	BTPS			
A	Letter Of Intent or Contract Documents	1	1	1	S	1	2	2	1	1	1	1	1	2		
B	Vendor Drawings															
1.	Preliminary	1	1	1	2	1	1	2	2	12	1	1	-	S		
2.	Return preliminary with comments	-	-	1	2	1	1	1	1	S	1	1	-	1		
3.	Final and any revision thereof															
	a. Civil	1	1	6+1T	1	1	6+1T	1	-	2+1T	1	1	1	S		
	b. E&M	1	1	1	6+1T	1	1	6+1T	1	2+1T	1	1	1	S		
C.	Design Drawings															
1.	Preliminary															
	a. Civil	1	1	2	1	1	2	1	1	4	1	1	1	S		
	b. E&M	1	1	1	2	1	1	2	1	4	1	1	1	S		
2.	Released for construction															
	a. Civil	1	1	2	1	1	6	1	1	1	1	1	2	S		
	b. E&M	1	1	1	1	2	1	6	1	1	1	1	2	S		
3.	Return marked 'As built'															
	a. Civil	-	-	1	-	-	1	-	-	1	1	1	S	1		
	b. E&M	-	-	-	1	-	-	1	1	1	1	1	S	1		
4.	As built drawings															
	a. Civil	-	-	1+1T	-	2+1T	5+1T	-	1	1+1T	-	-	1	S		
	b. E&M	-	-	1	2+1T	2+1T	-	5+1T	1+1T	1+1T	-	-	1	S		

Arvind

S A Khan

Praveen Kishore

S. No	Description	TSGENCO										Consultant		Equipment Vendor	Remarks
		Director Projects	Director Technical	CE/Civil Thermal Projects Hyd.	CE/ TPC-I, Hyd	CE/ O&M/	SE/ Civil	SE/E&M /	DE Constr.			HYD	BTPS		
D	Progress Report Monthly														
1.	Equipment vendor	1	1	1	2	1	1	2	1	1	1	1	1	S	
2.	Consultant	1	1	2	2	1	1	2	1	S	1	1	1	Nil	
E	Test & Inspection Reports														
1.	Equipment manufacturer														
	a. Civil	1	1	1	2	1	1	1	-	11	1	1	1	S	
s	b. E&M	1	1	-	2	1	-	1	1	11	1	1	1	S	
2.	Consultant	1	1	-	2	1	-	1	1	S	-	1	1	-	
F	Instruction Manuals/Data Books														
1.	Equipment manufacturer														
	a. Civil	1	1	1+1T	1	1	6+1T	1	1	2+1T	1	1	1	S	
	b. E&M	1	1	-	3+1T	1	-	6+1T	2	3+1T	1	1	1	S	
2.	Consultant	1	1	-	10+1T	1	-	15+1T	-	S	1	1	1	Nil	
G	Consultant	1	1	1	8+1T	1	1	2	1	1	1	1	1	S	
H	Design Calculations	1	1	1	8+1T	1	1	2	1	1	1	1	1	S	
I	Final consulting Engineering Report	1	1	1	10	1	1	2	1	S	1	1	1	Nil	

S – Source, T – Transparency & Soft Copy on CD,

TSGENCO : Telangana State Power Generation Corporation Limited
Director, Projects, Hyd : Director/ Projects, TSGENCO, Vidyut Soudha, Hyderabad – 500 082


QUALITY ASSURANCE REQUIREMENTS



Arvind



S A Khan



Praveen Kishore

CONTENT


CLAUSE NO.	DESCRIPTION
1.00.00	QUALITY ASSURANCE PROGRAMME
2.00.00	GENERAL REQUIREMENTS QUALITY ASSURANCE
3.00.00	QUALITY ASSURANCE DOCUMENTS
4.00.00	INSPECTION, TESTING & INSPECTION CERTIFICATES

ATTACHMENTS

ANNEXURE-I	FORMAT OF QUALITY ASSURANCE PROGRAMME
ANNEXURE-II	FIELD WELDING SCHEDULE


Arvind


S A Khan


Praveen Kishore

QUALITY ASSURANCE REQUIREMENTS

1.00.00 QUALITY ASSURANCE PROGRAMME

1.01.00 To ensure that the equipment and services under the scope of Contract whether manufactured or performed within the Contractor's works or at his Sub-contractor's premises or at the Owner's site or at any other place or work are in accordance with the specifications, the Contractor shall adopt suitable quality assurance programme to control such activities at all points, as necessary. Such programmes shall be outlined by the Contractor and shall be finally accepted by the Owner/Authorised representative after discussions before the award of contract. A quality assurance programme of the Contractor shall generally cover the following :

- a) His organisation structure for the management and implementation of the proposed quality assurance programme.
- b) Documentation control system.
- c) Qualification data for Bidder's key personnel.
- d) The procedure for purchase of materials, parts, components and selection of Sub-contractor's services including vendor analysis, source inspection, incoming raw-material inspection, verification of materials purchased etc.
- e) System for shop manufacturing and site erection control including process controls and fabrication and assembly controls.
- f) Control of non-conforming items and system for corrective actions.
- g) Inspection and test procedure both for manufacture and all site related works.
- h) Control of calibration and testing of measuring and testing equipments.
- i) System for quality audit.
- j) System for indication and appraisal of inspection status.
- k) System for authorising release of manufactured product to the Owner.
- l) System for handling storage and delivery.
- m) System for maintenance of records.

- n) Furnishing of quality plans for manufacturing and field activities detailing out the specific quality control procedure adopted for controlling the quality characteristics relevant to each item of equipment/component as per format enclosed at Annexure-I to this section for Owners approval
- o) Internal standards, if referred in the quality plans shall generally be compatible with National / International standards and shall be mentioned in the quality plans. Alternatively bidder shall furnish extracts of the internal standards detailing out acceptance norm for the product / material.

2.00.00 GENERAL REQUIREMENTS - QUALITY ASSURANCE

2.01.00 All materials, components and equipment covered under this specification shall be procured, manufactured, erected, commissioned and tested at all the stages, as per a comprehensive Quality Assurance Programme. An indicative programme of inspection/tests to be carried out by the Contractor for some of the major items is given in the respective technical specification. This is however, not intended to form a comprehensive programme as it is the Contractor's responsibility to draw up and implement such programme duly approved by the Owner/Consultant. The detailed Quality Plans for manufacturing and field activities should be drawn up by the Bidder, separately in the format attached at Annexure-I and will be submitted to Owner/Authorised representative for approval. Schedule of finalisation of such quality plans will be finalised before award.

Contractor shall furnish list of Manufacturing Quality Plans of major equipments indicating proposed inspection categorisation indicating items that will be offered for Owner's inspection etc and the Field Quality Plans

2.02.00 Manufacturing Quality Plan for all the major equipment will detail out their respective important components, their in-process various tests/inspection & final inspection / tests, to be carried out as per the requirements of this specification and standards mentioned therein and quality practices and procedures followed by Contractor's Quality Control organization. The relevant reference documents and standards, acceptance norms, inspection documents raised etc., during all stages of materials procurement, manufacture, assembly and final testing/performance testing are to be comprehensively documented by Contractor.

Manufacturing Quality Plan for all major equipments/ items will be approved by owner. In these approved quality plans, Owner / Authorised representative shall identify customer hold points (CHP), test / checks which shall be carried out in presence of the Owners Engineer or his authorised representative and beyond which the work shall not proceed without consent of Owner / Authorised representative in writing. Inspection/ Test reports are to be submitted to owner as specified in final approved Manufacturing Quality Plans.

2.03.00 Field Quality Plans / Procedures for all field activities shall be submitted to

owner for review / approval. These Quality Plans / procedures will detail out, for all equipment, the quality practices and procedures etc. to be followed by the Contractor's site Quality Control organisation, during various stages of site activities from receipt of materials/ equipment at site.

- 2.04.00 The Bidder shall also furnish copies of the reference documents/plant standards/acceptance norms/tests and inspection procedure etc., as referred in Quality Plans along with Quality Plans. These Quality plans and reference documents/standards etc. will be subject to Owner's approval without which manufacture shall not proceed. These approved documents shall form a part of the contract. In these approved quality plans, Owner/Authorised representative shall identify customer hold points (CHP), test/checks which shall be carried out in presence of the Owners Engineer or his authorised representative and beyond which the work will not proceed without consent of Owner/Authorised representative in writing. All deviations to this specification, approved quality plans and applicable standards must be documented and major deviations in the form of Non Conformity Report shall be referred to Owner/Authorised representative for approval and dispositioning.
- 2.05.00 No material shall be despatched from the manufacturer's works before the same is accepted subsequent to pre-despatch final inspection including verification of records of all previous tests/inspections by Owner's Engineer/ Authorised representative for "CHP" and "W" points marked in quality plans , and duly authorised for despatch by issuance of Material Despatch Clearance Certificate (MDCC). For items which is not under owner's inspection the contractor shall apply for despatch clearance (MDCC) from owner by submitting their internal inspection reports and quality records
- 2.06.00 All materials used or supplied shall be accompanied by valid and approved materials certificates and tests and inspection report. These certificates and reports shall indicate the sheet serial numbers or other such acceptable identification numbers of the material. The material certified shall also have the identification details stamped on it.
- 2.07.00 Castings and forgings used for construction shall be of tested quality. Details of results of chemical analysis, heat treatment record, mechanical property test results shall be furnished.
- 2.08.00 All welding and brazing shall be carried out as per procedure drawn and qualified in accordance with requirements of ASME Section - IX (latest edition) or other International equivalent standard acceptable to the Owner.

All brazers, welders etc. employed on any part of the contract at Contractor's/ Sub-Contractor's works or at site shall be qualified as per ASME Section-IX (latest edition) or equivalent international standard approved by the Owner. Such qualification tests shall be conducted in presence of Owner / his authorised representative or owner approved Third Party Inspection Agency(TPIA). Previously qualified WPS & PQR shall be acceptable if witnessed by owner's approved TPIA.

For welding of pressure parts and high pressure piping coming under IBR purview, the requirements of IBR shall also be complied with.

-
- 2.09.00 All non-destructive examination (NDT) shall be carried out in accordance with LIST OF STANDARDS FOR REFERENCE as given below in this section.
- The NDT operator shall be qualified as per SNT-TC-IA (of American Society of non- destructive examination). Results of NDT for the list major equipments / items identified for owner's inspection shall be properly recorded and submitted for review and approval. Other items not covered under owner's inspection, contractor shall review and approve the NDT results and such reports shall be submitted to owner in the final documentation of the items / equipments
- 2.10.00 All the sub-vendors proposed by the Contractor for procurement of major bought out items including castings, forgings, semi-finished and finished components/equipment list of which shall be drawn up by the Contractor and finalised with the Owner shall be subject to Owner's approval. Quality Plans of the successful vendors shall be discussed, finalised and approved by the Owner/Authorised representative and form part of the Purchase Order between the Contractor and the Vendor.
- 2.11.00 All the purchase specifications for the major bought-out items, list of which shall be drawn up by the Contractor and finalised with the Owner shall be furnished to the Owner for comments and subsequent approval before orders are placed.
- Owner reserves the right to carry out quality audit and quality surveillance of the systems and procedures of the Contractor's or their sub-vendor's quality management and control activities. The Contractor shall provide all necessary assistance to enable the Owner carry out such audit and surveillance.
- Quality audit/approval of the results of tests and inspection will not prejudice the right of the Owner to reject equipment not giving the desired performance after erection and shall not in no way limit the liabilities and responsibilities of the Contractor in earning satisfactory performance of equipment as per specification.
- 2.12.00 Quality requirements for main equipment shall equally apply for spares and replacement items.
- 2.13.00 Repair/rectification procedures to be adopted to make any job acceptable shall be subject to the approval of the Owner.
- 2.14.00 For quality assurance of all civil works refer to the specifications for civil works.
- 3.00.00 **QUALITY ASSURANCE DOCUMENTS**
- 3.01.00 The Contractor shall be required to submit two (2) copies and two (2) sets of microfilms / CDs of the following Quality Assurance documents within three (3) weeks after despatch of the equipment:
- a) Material mill test reports on components as specified by the specification.

- b) The inspection plan with verification, inspection plan check points, verification sketches, if used and methods used to verify that the inspection and testing points in the inspection plan were performed satisfactorily.
- c) Non-destructive examination results /reports including radiography interpretation reports.
- d) Factory tests results for testing required as per applicable codes and standards referred in the specification.
- e) Welder identification list listing welder's and welding operator's qualification procedure and welding identification symbols.
- f) Sketches and drawings used for indicating the method of traceability of the radiographs to the location on the equipment.
- g) Stress relief time temperature charts.
- h) Inspection reports duly signed by QA personnel of the Owner and Contractor for the agreed inspection hold points. During the course of inspection, the following will also be recorded :
 - i) When some important repair work is involved to make the job acceptable.
 - ii) The repair work remains part of the accepted product quality.
- i) Letter of conformity certifying that the requirement is in compliance with finalised specification requirements.

4.00.00 **INSPECTION, TESTING AND INSPECTION CERTIFICATES**

4.01.00 The Owner's Engineer, or his duly authorised representative and/or an outside inspection agency acting on behalf of the Owner shall have access inside the workshops, test labs, establishments at all reasonable times to inspect and examine the materials and workmanship of the works during its manufacture or erection and if part of the works is being manufactured or assembled on other premises or works, the Contractor shall obtain for the Owner's Engineer and for his duly authorised representative permission to inspect as if the works were manufactured or assembled on the Contractor's own premises or works.

4.02.00 The Contractor shall give the Owner's Engineer/ Authorized Inspector twenty one (21) days written notice for "CHP" / "W" points of any material being ready for testing by owner' engineer / Authorized inspector. Such tests shall be to the Contractor's account except for the expenses of the Inspector. The Engineer/ Inspector, unless the witnessing of the tests is virtually waived, will attend such tests within fifteen (15) days of the date on which the equipment is notified as being ready for test/inspection. If owner's Engineer / Authorised Inspector fail to attend the inspection, next mutually convenient date for test shall be agreed with Contractor. Contractor shall, in

no case proceed with the test without owner or his authorized inspectors, unless the witnessing is officially waived and advised Contactor to proceed with the test. Contractor shall forthwith forward duly certified completed test report and a product quality certificate in six (6) copies to owner upon completion of such test.

- 4.03.00 The Engineer or Inspector shall within fifteen (15) days from the date of Inspection as defined herein give notice in writing to the Contractor, or any objection to any drawings and all or any equipment and workmanship which is in his opinion not in accordance with the contract / QAP or other approved quality documents. The Contractor shall give due consideration to such objections and shall either make modifications that may be necessary to meet the said objections or shall confirm in writing to the Engineer/Inspector giving reasons therein, that no modifications are necessary to comply with the contract / QAP or other approved quality documents.
- 4.04.00 When the factory tests have been completed at the Contractor's or sub-contractor's works, the Engineer/Inspector shall issue a certificate to this effect fifteen (15) days after completion of tests excluding the test completion date subject to submission of all certified documents related to the test, If the tests are not witnessed by the Engineer/Inspectors, the certificate shall be issued within fifteen (15) days of the receipt of the Contractor's test certificate by the Engineer/Inspector. Failure of the owner's Engineer/Inspector to issue such a certificate shall not prevent the Contractor from proceeding with the works. The completion of these tests, or the issue of the certificates shall not bind the Owner to accept the equipment should it, on further tests after erection be found not to comply with the contract / QAP or other approved quality documents.
- 4.05.00 In all cases where the contract provides for tests whether at the premises or works of the Contractor or any sub-contractor, the Contractor, except where otherwise specified shall provide free of charge such items as labour, materials, electricity, fuel, water, stores, apparatus and instruments as may be reasonably demanded by the owner's Engineer/Inspector or his authorised representatives to carry out effectively such tests on the equipment in accordance with the Contract / QAP or other approved quality documents. Contractor and shall give facilities to the owner's Engineer/ Inspector or to his authorised representative to accomplish testing.
- 4.06.00 To facilitate advance planning of inspection in addition to giving inspection notice as per Clause 4.02.00, the Contractor shall furnish quarterly inspection programme indicating proposed schedule dates of inspection at customer hold point and final inspection stages. Updated quarterly inspection plans will be made for each three consecutive months and shall be furnished before beginning of each calendar month.


LIST OF STANDARDS FOR REFERENCE

- a) International Standards Organisation (ISO).
- b) International Electro-technical Commission (IEC).
- c) American Society of Mechanical Engineers(ASME)
- d) American National Standards Institute (ANSI).
- e) American Society for Testing and Materials (ASTM).
- f) American Institute of Steel Construction (AISC).
- g) American Welding Society (AWS).
- h) Architecture Institute of Japan (AIJ).
- i) National Fire Protection Association (NFPA).
- j) National Electrical Manufacturer's Association (NEMA).
- k) Japanese Electro-technical Committee (JEC).
- l) Institute of Electrical and Electronics Engineers (IEEE).
- m) Federal Occupational Safety and Health Regulations (OSHA).
- n) Instrument Society of America (ISA).
- o) National Electric Code (NEC).
- p) Heat Exchanger Institute (HEI).
- q) Tubular Exchanger Manufacturer's Association (TEMA).
- r) Hydraulic Institute (HIS).
- s) International Electro-Technical Commission Publications.
- t) Power Test Code for Steam Turbines (PTC).
- u) Applicable German Standards (DIN).
- v) Applicable British Standards (BS).
- w) Applicable Japanese Standards (JIS).
- x) Electric Power Research Institute (EPRI).
- y) Standards of Manufacturer's Standardization Society (MSS)

-
- z) Bureau of Indian Standards Institution (BIS).
 - aa) Indian Electricity Rules.
 - bb) Indian Boiler Regulations (IBR).
 - cc) Indian Explosives Act.
 - dd) Indian Factories Act.
 - ee) Tariff Advisory Committee (TAC) rules.
 - ff) Emission regulation of Central Pollution Control Board (CPCB).
 - gg) Pollution Control regulations of Dept. of Environment, Govt. of India
 - hh) Central Board of Irrigation and Power (CBIP) Publications


Arvind


S A Khan


Praveen Kishore

ANNEXURE-I
FORMAT OF QUALITY ASSURANCE PROGRAMME

VENDOR'S LOGO , NAME & ADDRESS		MANUFACTURING QUALITY ASSURANCE PLAN				DOC NO: XXXXX-CAL-QAP-M-0001	
ITEM :		-				REV NO : 0 1 2 3 4	
CLIENT :		LOCATION :		DATE :			
PROJECT :		REFERENCE PURCHASE ORDER NO. & DT :					
VENDOR :		REFERENCE APPROVED DATA SHEET :					
SUB VENDOR :		REFERENCE APPROVED DRAWING. NO. :					
ABBREVIATIONS :		GENERAL REMARKS					
QAP - QUALITY ASSURANCE PLAN, CR - CRITICAL, MA - MAJOR, MI - MINOR SPEC - SPECIFICATION, TC - TEST CERTIFICATES P - PERFORM W - WITNESS V - VERIFY CHP - CUSTOMER HOLD POINT		AGENCY : 1 - PROJECT AUTHORITY 2 - SUPPLIER 3 - SUB-SUPPLIER 4 - MANUFACTURER 5 - THIRD PARTY INSPECTION AGENCY MATL - MATERIAL, APP - APPROVED, DWG - DRAWING, SUPL - SUPPLIER, PROC - PROCEDURE					
NOTES:		1 THE ITEMS WHICH ARE FALLING UNDER ANY STATUTORY AUTHORITY'S (LIKE I.B.R. ETC.) SCOPE SHALL BE SUBJECTED TO THAT STATUTORY AUTHORITY'S INSPECTION CLEARANCE.					
1. EXACT MATERIAL / PROCESS / INSPECTION / TESTS FOLLOWED BY THE MANUFACTURER SHALL BE SPECIFIED 2. EXACT REFERENCE DOCUMENT/ACCEPTANCE STANDARD SHALL BE SPECIFIED 3. IN CASE SPECIFIED ACCEPTANCE STANDARD / NORMS IS OTHER THAN NATIONAL / INTERNATIONAL STANDARDS . STANDARD / COPY OF THE ACCEPTANCE NORMS FOLLOWED BY THE MANUFACTURER SHALL BE SUBMITTED FOR REVIEW RECORD 4 FINAL INSPECTION DOSSIER SHALL BE PREPARED BY MANUFACTURER & SHALL BE ENDORSED BY INSPECTION AGENCY		Checked by R0 R1 R2 R0 R1 R2					
Prepared by		Approved By					
Revision DATE		R0 R1 R2 R0 R1 R2					

ANNEXURE-II

FIELD WELDING SCHEDULE

PROJECT : FWS NO :
 CONTRACTOR : REV NO. :
 PACKAGE : FIELD WELDING CODE :
 SYSTEM : PAGE NO. :


Sl No.	Drawing No. for Weld Locations & Identification mark	Description of parts to be welded	Material specification	Dimensions	Process of Welding	Type of Weld	Electrode Filler Specification	WPS No.	Minimum Pre-heat Temperature	Heat Treatment Temperature [Holding Time in secs]	NDT Method	NDT Specification Number	Acceptance Norm Ref.	Remarks
--------	--	-----------------------------------	------------------------	------------	--------------------	--------------	--------------------------------	---------	------------------------------	---	------------	--------------------------	----------------------	---------

The Field Welding Schedule should be submitted for :

0 Pressure Parts
 0 Tanks/Vessels
 0 Piping
 0 Heavy/Important Structural Steel
 0 Heat Exchangers
 0 Bus Ducts


Anind



S A Khan


Praveen Kishore

REQUIREMENTS OF SPARES, TOOLS & TACKLE, LUBRICANTS/OIL/CONSUMABLES


Arvind


S A Khan



Praveen Kishore

CONTENT

CLAUSE NO.	DESCRIPTION
1.00.00	TOOLS AND TACKLE
2.00.00	SPARES
	ATTACHMENT
ANNEXURE-I	MANDATORY SPARE LIST


Arvind


S A Khan


Praveen Kishore

REQUIREMENTS OF SPARES, TOOLS & TACKLE, LUBRICANTS/OIL/CONSUMABLES

1.00.00 TOOLS & TACKLE

The Contractor shall supply with the equipment one complete set of special tools and tackle as required for the erection, assembly, dismantling & maintenance of the equipment. These special tools will also include special material handling equipment, jigs & fixtures for maintenance and calibration/readjustment, checking & measurement aids etc. A list of such tools & tackle shall be submitted by the Bidder along with the offer. Detailed description of each tools/tackle, its function along with the equipment/part for which it is meant for and the price of each tools/tackle shall also be indicated in the offer. These tools & tackle shall be separately packed and sent to site before the first unit commissioning. The Bidder shall also ensure that these tools are not used for erection purpose.

2.00.00 SPARES

2.01.00 General

The Bidder shall indicate and include in his scope of supply all the necessary start-up, commissioning and recommended spares in addition to mandatory spares as specified elsewhere in the specification. The Owner reserves the right to buy any or all mandatory and recommended spares. The Contractor shall also state for each item of spares both mandatory and recommended, the normal expected service life.

2.01.01 All spares supplied under this contract shall be strictly interchangeable with the parts for which they are intended to replace. The spares shall be treated and packed for long storage under the climatic conditions prevailing at the site, e.g. small items shall be packed in sealed transparent plastic bags with dessicator packs as necessary.

2.01.02 Each spare part shall be clearly marked or labelled on the outside of the packing with the description. When more than one spare part is packed in a single case, a general description of the contents shall be shown on the outside and a detailed list enclosed. All cases, containers and other packages must be suitably marked and numbered for the purposes of identification.

2.01.03 All cases, containers or other packages are liable to be opened for examination as may be considered necessary by the Engineer.

2.01.04 All mandatory spares shall be delivered to site within one to three months prior to the scheduled date of the trial operation of the plant. However, they shall not be despatched before the despatch of the associated main equipment.

2.01.05 The Bidder shall also guarantee supply of spare parts, which will be made, based on manufacturer's drawings on special order from the Purchaser for 30 years after commissioning of the plant.

2.02.00 **Recommended Spares**

2.02.01 The Contractor shall provide a list of recommended spares giving unit prices and total prices for 2 years of normal operation of the plant for spares of indigenous origin, and for 5 years of normal operation for spares of non-indigenous origin. This list shall take into consideration the mandatory spares specified elsewhere in the specification and should be a separate list.

2.02.02 The price of recommended spares will not be used for the evaluation of bids. The price of these spares shall remain valid for a period as specified elsewhere in the specification from the date of Award of the Contract. Where the recommended spares are the same as mandatory spares, the prices shall be the same. The prices of any recommended spares, which are not common with mandatory spares, shall be subject to review by the Owner, and shall be finalised after mutual discussion.

2.03.00 **Start-up Commissioning Spares**

2.03.01 Start-up commissioning spares are those spares which may be required during the start-up and commissioning of the equipment/system. All spares used until the plant is handed over to the Owner shall come under this category. Said spares, properly marked, shall be supplied together with the main equipment and shall be used by the Contractor, if needed, during erection & commissioning stage. All such spares which remain unused till issuance of Taking Over Certificate by the Owner, along with an equipment-wise quantitative consumption report shall be returned to the Owner during time of handover. The list of commissioning spares to be brought by the Contractor to ensure smooth commissioning of the plant shall be subject to the Engineer's approval.

2.03.02 The Contractor shall submit a complete BBU list inclusive of recommended, mandatory, initial start-up and commissioning spares. Costs of the above spares, which are consumed before the handing-over of the plant, shall be deemed to have been included in the lump sum proposal price of the package, and the Contractor shall have no claim on this account to the Owner.

2.04.00 **Mandatory Spare Parts**

2.04.01 The Owner considers some of the spares are essential for running the equipment irrespective of whether they are included in the list of recommended spares by the Bidder as mentioned above.

Since the components involved can not be foreseen at the bidding stage, only

broad requirements of the Owner in this respect are outlined hereinafter. The bidder shall include his proposal, on the basis of this guideline, an item-wise list of all components and the quantity, unit prices & total price thereof, offered as mandatory spares for each and every equipment. This list shall be separate from the list of recommended spares and shall be used for bid evaluation purposes. Any clarification in this respect may be obtained by the Bidder at the pre-bidding stage.


- 2.04.02 The mandatory spares should be supplied to the Owner at least one month before the trial run. The despatch programme is subject to approval of the Owner/Consultant after award of contract.



Arvind



S A Khan



Praveen Kishore