

Rev. 00 Dt. : 15-02-2003

REV	DATE	ALT Ckd & Appd	REV-	DATE	ALT Ckd & Appd	REV 00	NAME	SIGN	DATE
						PREP	R.K.SINGH		15-02-03
						Ckd & Appd.	T.K.GANGULI		15-02-03
DWI/TCB/TRE/016									

PRODUCT PURCHASING SPECIFICATION
TRANSFORMER ENGINEERING DEPARTMENT
BHEL BHOPAL

Specification No. **TRE 162**

Page 2 of 2 Pages

Rev. 00 Dt. : 15-02-2003

- 2.10 The offered equipment shall include all the items i.e. detector, sufficient sensors (suitable for large size 400 KV Power Transformer), couplets, battery charger (suitable for 240 volts, 1-ph., 50 Hz. AC supply) etc. to complete the equipment in all respect for the purpose described in this specification.
- 2.11 3 sets of descriptive leaflets, describing complete operation and function of equipment shall be sent alongwith offer.

3. TESTING & DESPATCH

- 3.1 All applicable type tests report as per IEC60270 and other relevant standard shall be submitted.
- 3.2 All applicable routine tests as per IEC60270 and other relevant standard shall be conducted.
- 3.3 Three sets of inspection, routine and calibration test reports and erection, commissioning, operation and maintenance manual shall be sent alongwith dispatch document. One set shall be kept inside the carrying case.
- 3.4 The supplier shall furnish a list of all fittings and components in the dispatch details giving description and quantity of each item (Quantity of each item shall be mentioned). All items shall be properly packed in wooden boxes so as to avoid scratches/damage in transit.

4. TRAINING

The supplier shall provide training/ demonstration to our customer at site on intimation by BHEL for using and maintaining the equipment for 1 man day. Supplier should quote the charges for the same, if any, in the offer separately.