

**1 x 800 MW APGENCO, Dr. NTTPS, VIJAYWADA
(STAGE - V, UNIT - 8)**

&

**1 x 800 MW APPDCL, KRISHNAPATNAM
(STAGE - II)**

TECHNICAL SPECIFICATION
FOR
**AUXILIARY STEAM PRESSURE REDUCING
AND DESUPERHEATING STATION
ALONGWITH ACCESSORIES**

SPECIFICATION No: PE-TS -419/420-142-N101



BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEL, NOIDA, INDIA

	TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION	SPEC. NO.: PE-TS-419/420-142-N101	
		SECTION	CONTENTS (I & II)
		REV. NO.	00 DATE 17.11.16
		SHEET	0 OF 17

CONTENTS

	<u>TITLE</u>	<u>PAGE NO.</u>
	<u>SECTION-I</u>	1-14
A	Scope of enquiry	1-2
B	Project Information	3-5
C	Specific Technical Requirements	6-17
1.0	Brief System Description	
2.0	Sizing Data sheets (A-1)	
3.0	Data Sheets (A) for APRDS	
4.0	Tender Drawing	
5.0	Customer Specification	
	<u>SECTION-II</u>	1-24
	Specification for APRDS	1-10
1.0	Scope	
2.0	Codes And Standards	
3.0	Technical requirements	
4.0	Testing And Inspection	
5.0	Spares And Consumables	
6.0	Drawings And Documents	
7.0	Marking And Packing	
8.0	Hook-up Diagrams	
	Quality Plan for Control Valve	14-19
	Compliance Certificate	20
	Data Sheet-C for Control Valves	21-23
	Schedule of Technical Deviation/ Clarification	24



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101			
SECTION	I		
REV. NO.	00	DATE	17.11.16
SHEET	1	OF	17

SCOPE OF ENQUIRY

This specification is applicable for both the projects i.e

- 1) Project-1 : 1x800 MW Dr. Narla Tata Rao Thermal Power Station (VTPS), Stage-V, Unit-8
- 2) Project-2 : 1x800 MW Sri Damodaram Sanjeevaiah Thermal Power Station (SDSTPS), Stage-II, Unit-3

Entire scope of supply i.e main package, mandatory spares, commissioning spares etc, as mentioned anywhere in the specification are to be supplied for each of the two projects.



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 2 OF 17

- 1.1 This enquiry covers the Design, Manufacture, Assembly, Inspection and Testing at Vendor's and/or his sub-vendors works, painting and delivery to site of Auxiliary Steam Pressure Reducing & Desuperheating Stations, as mentioned in different sections of this specification .
- 1.2 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship and shall be capable of performing the required duties in a manner acceptable to the Engineer/Owner who will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material, which in his judgment is not in full accordance herewith.
- 1.3 The bidder may quote for his standard, proven design of equipment and shall submit stamped compliance certificate (enclosed in Section II) conforming all the specification requirements.
- 1.4 The bids shall be in English language and MKS Units.
- 1.5 The omission of specific reference to any component / accessory necessary for the proper performance of the equipments shall not relieve the supplier of the responsibility of providing such facilities to complete the supply within the quoted prices.
- 1.6 BHEL's / CUSTOMER'S representatives shall be given access to the shop in which the equipments are being manufactured or tested and all test records shall be made available to him.
- 1.7 The Equipment covered under this specification shall not be dispatched unless the same have been finally inspected, accepted and Material Dispatch Clearance Certificate (MDCC) is issued by BHEL / CUSTOMER.



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 3 OF 17

PROJECT



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 4 OF 17

PROJECT-1: INFORMATION

- 1 JOB NO. 419
- 2 Project 1x800 MW Dr. Narla Tata Rao Thermal Power Station (VTPS), Stage-V, Unit-8
- 3 Customer Andhra Pradesh Power Generation Corporation Limited.
- 4 Consultant DCPL,Kolkata
- 5 Location The proposed 1x800 MW Dr. Narla Tata Rao Thermal Power Station (VTPS), Stage-V, Unit-8 would be set up by Andhra Pradesh Power Generation Corporation Ltd. (APGENCO) at Ibrahimpatnam, Krishna District, Andhra Pradesh near Vijaywada. The proposed Power Plant will be installed adjacent to the existing 1x500 MW Unit-7 of Dr. Narla Tata Rao Thermal Power Station. Site is located in the existing premises of Dr. Narla Tata Rao Thermal Power Station which is on the left side of river Krishna at a distance of 2 km between Ibrahimpatnam and Kondapalli village in Krishna district. It is 16 km on the north side of Vijaywada city and 285 km from Hyderabad.
- Nearest railway station : Kondapalli(3 Kms)
- Nearest Airport: Vijaywada(16kms) Hyderabad(285kms)
- 6 LAND 85 acres of land is available within the plant boundary for Main plant and auxiliaries and green belt.
230 acres of land required for Ash Dyke will be acquired near the existing ash pond. Land is available for staff colony.
- 7 SALIENT DESIGN DATA Meteorological data of site is given below:-
Elevation above MSL : 21.5 m
Annual average temperature :
Max :47.6 ° c
Min :13 ° C
Rainfall
Avg: 1488.9mm
Max : 206mm/hr for 90 min.
Mean Wind Speed :16.5 kmph
Relative Humidity
Max: 82%
Min :45%



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 5 OF 17

PROJECT-2: INFORMATION

<u>1</u>	JOB NO.	420
<u>2</u>	Project	1x800 MW Sri Damodaram Sanjeevaiah Thermal Power Station (SDSTPS), Stage-II, Unit-3
<u>3</u>	Customer	Andhra Pradesh Power Development Company Limited.
<u>4</u>	Consultant	DCPL,Kolkata
<u>5</u>	Location	The proposed site is located at Krishnapatnam near Nellore Town. Nellore town is situated on National Highway NH-5 connecting Kolkata and Chennai. The nearest broad gauge railway station Venkatachalam is located about 23 Km from plant site. Venkatachalam railway station is located on Vijayawada-Chennai main road broad gauge line of Southern Railway. Nearest railway station : Venkatachalam Railway Station (23 Kms from plant site) Nearest Airport: Chennai (170 KM from site)
<u>6</u>	LAND	51 acres of land is available within the existing plant boundary for Main plant and auxiliaries and Balance of Plant(BOP). Existing Coal Storage and handling facilities for Stage-I will also be used for 1x800 MW, Stage-II extension project. Land acquired for Staff Colony for Stage-I to be used for staff colony for Stage-II.
<u>7</u>	SALIENT DESIGN DATA	Meteorological data of site is given below:- Elevation above MSL : 2.1 to 3.0 m Finished Grade level of Plant : 3.5 m Annual mean ambient temperature : Max : 42.2 ° c Min : 18.3 ° C Highest Temperature in a day : 33 ° C Lowest Temperature in a day : 24.4 ° C Relative Humidity Max : 84% Min :46% Rainfall Average : 1032 mm Max : 100 mm/hr. Basic Wind Speed :50 m/ sec



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 6 OF 17

SPECIFIC TECHNICAL REQUIREMENTS



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 6 OF 17

BRIEF SYSTEM DESCRIPTION

- 1.1 Auxiliary steam system is designed to provide steam for the turbine auxiliaries, boiler auxiliaries and fuel oil heating system during start-up, low loads and normal running of unit.
- 1.2 The system comprises of One "High capacity PRDS" with tapping from Main steam line to meet auxiliary steam requirements during unit start-up, low loads and the other "Low Capacity PRV" with tapping off steam from CRH line to meet auxiliary steam requirements during normal running. Spray water required for desuperheating will be tapped off from CEP discharge.
- 1.3 The HCPRDS will reduce the pressure and temperature of the steam tapped off from main steam line to 16 kg/cm² (abs) & 290°C. The LCPRV shall reduce the pressure of steam tapped from CRH line to 16 kg/cm² (abs) and temperature in the range of 285°C to 350°C, depending upon the CRH parameters at corresponding load.

- 1.4 APRDS system Comprises of:

S No	Description	Quantity (Per unit)
1	Combined Type High Capacity Pressure Reducing & De-superheating Valve (On MS line)	1
2	Low Capacity PRV (on CRH Line)	1
3	Spray Control Valve for HC-PRDS	1

- 1.5 Spares, consumable and specified tools & tackles:

- i) Start-up, Commissioning spares and consumables shall be part of main package supply; however bidder to indicate prices separately. All such items shall be strictly interchangeable with the parts for which they are intended for replacements.
- ii) The bidder shall supply one complete set of special tools & tackles (if any) required for the erection, assembly, disassembly & maintenance of the equipment. A list of such tools & tackles to be supplied shall be submitted along with the bid.
- iii) Bidder to indicate the service life expectancy period for the spare parts under normal working conditions. The spares shall be treated and packed for long storage under climatic conditions prevailing at site. Small items shall be packed in sealed transparent plastic bags with desiccators' packs as necessary.



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 7 OF 17

iv) **Mandatory Spares List:**

Auxiliary Steam Pressure Reducing & Desuperheating System		
High Capacity PRDS System (ASV-22)		
a)	Pilot Relay	1 set for each valve
b)	Actuator Diaphragm	1 no. for each valve
c)	Feedback Linkage	1 no. for each valve
d)	Smart Positioner	10% of total quantity of each model/type
e)	I/P Converter	10% of total quantity.
f)	Complete Consumables for Valve Viz. O-ring, Gland Packing, Packing Ring, Bonnet Seal etc	2 Sets each size, rating, type
g)	Valve Disc	2 Sets each size, rating, type
h)	Valve Spindle	2 Sets each size, rating, type
i)	Valve Seat	2 Sets each size, rating, type
j)	Bush	2 Sets each size, rating, type
k)	Guide	2 Sets each size, rating, type
l)	Guide Bush	2 Sets each size, rating, type
m)	Coupling Nut	2 Sets each size, rating, type
n)	Actuator Piston with Rod & Seal	2 Sets each size, rating, type
o)	Control valve stem packing and spare operator moulded rubber diaphragms	1 set for each size, rating, type
p)	Valve trim (including cage, plug, stem, seat rings, guide bushings etc.) for each of the control valves as offered.	1 set for each size, rating, type
q)	Solenoid valves, position transmitters, limit switches, I/P convertors, positioners etc of each type	10% of total quantity spare with minimum 1 no. for each size, rating, type

Low Capacity PRV (ASV-26)		
a)	Pilot Relay	1 set for each valve
b)	Actuator Diaphragm	1 no. for each valve
c)	Feedback Linkage	1 no. for each valve
d)	Smart Positioner	10% of total quantity of each model/type
e)	I/P Converter	10% of total quantity.
f)	Complete Consumables for Valve Viz. O-ring, Gland Packing, Packing Ring, Bonnet Seal etc	2 Sets each size, rating, type
g)	Valve Disc	2 Sets each size, rating, type
h)	Valve Spindle	2 Sets each size, rating, type
i)	Valve Seat	2 Sets each size, rating, type
j)	Bush	2 Sets each size, rating, type
k)	Guide	2 Sets each size, rating, type



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 8 OF 17

l)	Guide Bush	2 Sets each size, rating, type
m)	Coupling Nut	2 Sets each size, rating, type
n)	Actuator Piston with Rod & Seal	2 Sets each size, rating, type
o)	Control valve stem packing and spare operator moulded rubber diaphragms	1 set for each size, rating, type
p)	Valve trim (including cage, plug, stem, seat rings, guide bushings etc.) for each of the control valves as offered.	1 set for each size, rating, type
q)	Solenoid valves, position transmitters, limit switches, I/P convertors, positioners etc of each type	10% of total quantity spare with minimum 1 no. for each size, rating, type

Spray Control Valve for High Capacity PRDS System (CDV-138)

a)	Pilot Relay	1 set for each valve
b)	Actuator Diaphragm	1 no. for each valve
c)	Feedback Linkage	1 no. for each valve
d)	Smart Positioner	10% of total quantity of each model/type
e)	I/P Converter	10% of total quantity.
f)	Complete Consumables for Valve Viz. O-ring, Gland Packing, Packing Ring, Bonnet Seal etc	2 Sets each size, rating, type
g)	Valve Disc	2 Sets each size, rating, type
h)	Valve Spindle	2 Sets each size, rating, type
i)	Valve Seat	2 Sets each size, rating, type
j)	Bush	2 Sets each size, rating, type
k)	Guide	2 Sets each size, rating, type
l)	Guide Bush	2 Sets each size, rating, type
m)	Coupling Nut	2 Sets each size, rating, type
n)	Actuator Piston with Rod & Seal	2 Sets each size, rating, type
o)	Control valve stem packing and spare operator moulded rubber diaphragms	1 set for each size, rating, type
p)	Valve trim (including cage, plug, stem, seat rings, guide bushings etc.) for each of the control valves as offered.	1 set for each size, rating, type
q)	Solenoid valves, position transmitters, limit switches, I/P convertors, positioners etc of each type	10% of total quantity spare with minimum 1 no. for each size, rating, type



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 9 OF 17

- v) Commissioning Spares: As applicable for the project
(For Minimum requirement refer section II)

Stat-up & Commissioning spares:

- i) Start-up and Commissioning spares are those spares, which may be required during the start-up and commissioning of the Control Valves. All start-up spares, which are supplied under this contract, shall be strictly interchangeable with the parts for which they are intended for replacements.
- ii) The Start-up and commissioning spares indicated by the bidder shall be a part of the main Control valves supply. However bidder to indicate prices separately. The list of these spares required to be supplied shall be submitted along with the bid.



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 10 OF 17

SIZING DATA SHEET- A-1

COMBINED AUXILIARY STEAM PRDS & SPRAY CONTROL VALVE (ASV-22)

S.No.	Parameters	Cond.-1	Cond.-2	Cond.-3	Cond.-4	Cond.-5	Mech. Design
1.0	Inlet of Combined APRDS						
1.1	Pressure (kg/cm ² (a))	64	89	247	84	94	272
1.2	Temp. (°C)	365	475	565	375	435	573
1.3	Flow (T/Hr)	Bidder To Calculate					
2.0	Outlet of combined APRDS						
2.1	Pressure (kg/cm ² (a))	16	16	16	16	16	21
2.2	Temp. (°C)	290	290	290	290	290	350
2.3	Flow (T/Hr)	132.7	80.7	68.2	160.2	101.2	-
3.0	Inlet of Spray Control Valve						
3.1	Pressure (kg/cm ² (a))	40.5	40	38	40.5	40	46
3.2	Temp. (°C)	40	40	44	40	40	60
3.3	Flow (T/Hr)	BIDDER TO CALCULATE					



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 11 OF 17

SIZING DATA SHEET- A-2

AUXILIARY STEAM PRV (ASV-26)

S.No.	Parameters	Cond.-1	Cond.-2	Cond.-3	Mech. Design
1.0	Inlet of PRV				
1.1	Pressure (kg/cm ² (a))	24.04	60.61	60.61	74.5
1.2	Temp. (°C)	350.4	344.7	344.7	365
1.3	Flow (T/Hr)	11.2	11.2	15	-
2.0	Outlet of PRV				
2.1	Pressure (kg/cm ² (a))	16	16	16	21
2.2	Temp. (°C)	Bidder To Calculate			
2.3	Flow (T/Hr)	11.2	11.2	15.0	-



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO. 00

DATE 17.11.16

SHEET 12 OF 17

DATA SHEETS- A

AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION



TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO.

00

DATE	17.11.16
------	----------

SHEET

13

OF

17

Tag No.: ASV-22		DATA SHEET – A	Qty.: ONE
GENERAL	PROJECT SERVICE LOCATION DUTY PIPE SIZE (inlet / outlet) PIPE MATERIAL (inlet / outlet)	APGENCO/PROJECT-1 & PROJECT-2 COMBINED TYPE MAIN STEAM TO AUX. STEAM PRDS (HC PRDS) ☐ INDOOR ☐ OUTDOOR ☐ ON/OFF ☐ MODULATING Ø 219.1x 34 Ø 457 x 9.53 SA 335 P91 SA 335 P22	
BODY#	MODEL NO. TYPE OF BODY: GUIDING : NO. OF PORTS BODY SIZE: PORT SIZE: DESIGN CV END CONNECTION & RATING (ANSI) BODY MATERIAL PACKING: MATERIAL SINGLE / DOUBLE BONNET TYPE TRIM FORM TRIM MATERIAL: SEAT PLUG : CAGE GUIDE BUSH FLOW OUTLET VELOCITY REQUIRED LEAKAGE CLASS NOISE LEVEL VACUUM SERVICE ANTI CAVITATION TRIM	BIDDER TO SPECIFY ☐ GLOBE ☐ ANGLE ☐ TOP ☐ CAGE ONE BIDDER TO SELECT ☐ BWE ☐ SWE ☐ FLANGED ☐ A216 WCB ☐ A217 WC6 ☐ SA182 F91 ☐ SS ☐ A351 CF8M ☐ PTFE ☐ GRAFOIL ☐ DOUBLE ☐ SINGLE ☐ STD ☐ EXTENDED ☐ FINNED ☐ LINEAR ☐ EQ. PERCENTAGE ☐ QUICK OPEN (ON/OFF) SS316 (ST) SS316 (ST) SS316 (ST) SS316 (ST) ☐ BELOW SEAT ☐ ABOVE SEAT ☐ < 7 M/SEC (WATER) ☐ <150M/SEC (STEAM) ☐ II ☐ III ☐ IV ☐ V ☐ VI LESS THAN 85 dBA (AT ONE METER DESTANCE) ☐ YES ☐ NO ☐ YES ☐ NO	
PNEUMATIC ACTUATOR	MODEL NO. & SIZE CLOSE AT : OPEN AT (KG/CM2g) *TRAVEL TIME FOR OPEN TO CLOSE AND CLOSE TO OPEN *VALVE POSN. ON SIGNAL AIR FAILURE *VALVE POSN. ON SUPPLY AIR FAILURE	AS PER SPECIFICATION REQ. 0.2 1.0 LESS THAN 10 SECS. ☐ TO OPEN ☐ STAYPUT ☐ TO CLOSE ☐ STAYPUT	
ACCESSORIES*	POSITIONER (SMART) AIR FILTER REGULATOR AIR LOCK RELAY POSITION LIMIT SWITCH POSITION TRANSMITTER SOLENOID VALVE E/P CONVERTOR JUNCTION BOX HAND WHEEL (SIDE MOUNTED) LOCAL POSITION INDICATOR (*refer pneumatic actuator datasheet for details)	☐ REQUIRED ☐ NOT REQUIRED ☐ REQUIRED ☐ NOT REQUIRED ☐ REQUIRED ☐ NOT REQUIRED ☐ REQUIRED ☐ NOT REQUIRED PART OF SMART POSITIONER ☐ REQUIRED ☐ NOT REQUIRED PART OF SMART POSITIONER ☐ REQUIRED ☐ NOT REQUIRED ☐ REQUIRED ☐ REQUIRED	
PROCESS CONTROL	LINEARITY HYSTERISIS SENSITIVITY ACCURACY (OVERALL)	+ 1% - 1% + 0.5% ± 2%	
DESIGN	#MAX SHUT OFF PRESS (KG/CM2(G) # BODY DESIGN : PRESS (KG/CM2(G) TEMP (DEG C) IBR FORM III-C #VALVE TYPE	272 272 573 ☐ REQUIRED ☐ NOT REQUIRED ☐ CAVITATION ☐ FLASHING ☐ HIGH DP	



TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO.	00
----------	----

DATE	17.11.16
------	----------

SHEET 14 OF 17

Tag No.: ASV-26		DATA SHEET – A	Qty.: ONE
GENERAL	PROJECT SERVICE LOCATION DUTY PIPE SIZE (inlet / outlet) PIPE MATERIAL (inlet / outlet)	APGENCO/PROJECT-1 & PROJECT-2 COLD REHEAT STEAM TO AUXILIARY STEAM PR. REDUCING VALVE (LC PRV) ☐ INDOOR ☐ OUTDOOR ☐ ON/OFF ☐ MODULATING Ø 114.3x6.02 Ø 219.1 x 12.7 SA 106 Gr C SA 106 Gr C	
BODY#	MODEL NO. TYPE OF BODY: GUIDING: NO. OF PORTS BODY SIZE: PORT SIZE: DESIGN CV END CONNECTION & RATING (ANSI) BODY MATERIAL PACKING: MATERIAL SINGLE / DOUBLE BONNET TYPE TRIM FORM TRIM MATERIAL: SEAT PLUG : CAGE GUIDE BUSH FLOW OUTLET VELOCITY REQUIRED LEAKAGE CLASS NOISE LEVEL VACUUM SERVICE ANTI CAVITATION TRIM	BIDDER TO SPECIFY ☐ GLOBE ☐ ANGLE ☐ TOP ☐ CAGE ONE BIDDER TO SELECT ☐ BWE ☐ SWE ☐ FLANGED ☐ A216 WCC ☐ A217 WC9 ☐ SS ☐ A351 CF8M ☐ A351 CF8M ☐ PTFE ☐ GRAFOIL ☐ DOUBLE ☐ SINGLE ☐ STD ☐ EXTENDED ☐ FINNED ☐ LINEAR ☐ EQ. PERCENTAGE ☐ QUICK OPEN (ON/OFF) SS316 (ST) SS316 (ST) SS316 (ST) SS316 (ST) ☐ BELOW SEAT ☐ ABOVE SEAT ☐ < 7 M/SEC (WATER) ☐ <150M/SEC (STEAM) ☐ II ☐ III ☐ IV ☐ V ☐ VI LESS THAN 85 Dba (AT ONE METER DESTANCE) ☐ YES ☐ NO ☐ YES ☐ NO	
PNEUMATIC ACTUATOR	MODEL NO. & SIZE CLOSE AT : OPEN AT (KG/CM2g) *TRAVEL TIME FOR OPEN TO CLOSE AND CLOSE TO OPEN *VALVE POSN. ON SIGNAL AIR FAILURE *VALVE POSN. ON SUPPLY AIR FAILURE	AS PER SPECIFICATION REQ. 1.0 0.2 LESS THAN 10 SECS. ☐ TO OPEN ☐ STAYPUT ☐ TO CLOSE ☐ STAYPUT	
ACCESSORIES*	POSITIONER (SMART) AIR FILTER REGULATOR AIR LOCK RELAY POSITION LIMIT SWITCH POSITION TRANSMITTER SOLENOID VALVE E/P CONVERTOR JUNCTION BOX HAND WHEEL (SIDE MOUNTED) LOCAL POSITION INDICATOR (*refer pneumatic actuator datasheet for details)	☐ REQUIRED ☐ NOT REQUIRED ☐ REQUIRED ☐ NOT REQUIRED ☐ REQUIRED ☐ NOT REQUIRED ☐ REQUIRED ☐ NOT REQUIRED PART OF SMART POSITIONER ☐ REQUIRED ☐ NOT REQUIRED PART OF SMART POSITIONER ☐ REQUIRED ☐ NOT REQUIRED ☐ REQUIRED ☐ REQUIRED	
PROCESS CONTROL	LINEARITY HYSTERISIS SENSITIVITY ACCURACY (OVERALL)	± 1% ± 1% ± 0.5% ± 2%	
DESIGN	# MAX SHUT OFF PRESS (KG/CM2(G) # BODY DESIGN : PRESS (KG/CM2(G) TEMP (DEG C) IBR FORM III-C #VALVE TYPE	74.5 74.5 365 ☐ REQUIRED ☐ NOT REQUIRED ☐ CAVITATION ☐ FLASHING ☐ HIGH DP	



TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION

SPEC. NO.: PE-TS-419/420-142-N101

SECTION I

REV. NO.

00

DATE	17.11.16
------	----------

SHEET

15

OF

17

Tag No.: **CDV-138**

DATA SHEET – A

Qty.: **ONE**

GENERAL	PROJECT SERVICE LOCATION DUTY PIPE SIZE (inlet / outlet) PIPE MATERIAL (inlet / outlet)	APGENCO/PROJECT-1 & PROJECT-2 SPRAY TO COMBINED PRDS CONTROL VALVE ☐ INDOOR ☐ OUTDOOR ☐ ON/OFF ☒ MODULATING Ø 88.9 x 5.49 Ø 88.9 x 5.49 SA 106 Gr B SA 106 Gr B
BODY#	MODEL NO. TYPE OF BODY: GUIDING : NO. OF PORTS BODY SIZE: PORT SIZE: DESIGN CV END CONNECTION & RATING (ANSI) BODY MATERIAL PACKING: MATERIAL SINGLE / DOUBLE BONNET TYPE TRIM FORM TRIM MATERIAL: SEAT PLUG : CAGE GUIDE BUSH FLOW OUTLET VELOCITY REQUIRED LEAKAGE CLASS NOISE LEVEL VACUUM SERVICE ANTI CAVITATION TRIM	BIDDER TO SPECIFY ☒ GLOBE ☐ ANGLE ☐ TOP ☒ CAGE ONE BIDDER TO SELECT ☐ BWE ☒ SWE ☐ FLANGED ☒ A216 WCB ☐ A217 WC6 ☐ A217 WC9 ☐ SS ☐ A351 CF8M ☐ PTFE ☒ GRAFOIL ☐ DOUBLE ☒ SINGLE ☐ STD ☐ EXTENDED ☒ FINNED ☐ LINEAR ☒ EQ. PERCENTAGE ☐ QUICK OPEN (ON/OFF) SS316 (ST) SS316 (ST) SS316 (ST) SS316 (ST) ☐ BELOW SEAT ☐ ABOVE SEAT ☒ < 7 M/SEC (WATER) ☐ <150M/SEC (STEAM) ☐ II ☐ III ☐ IV ☒ V ☐ VI LESS THAN 85 dBA (AT ONE METER DESTANCE) ☐ YES ☒ NO ☐ YES ☒ NO
PNEUMATIC ACTUATOR	MODEL NO. & SIZE CLOSE AT : OPEN AT (KG/CM2g) *TRAVEL TIME FOR OPEN TO CLOSE AND CLOSE TO OPEN *VALVE POSN. ON SIGNAL AIR FAILURE *VALVE POSN. ON SUPPLY AIR FAILURE	AS PER SPECIFICATION REQ. 0.2 1.0 LESS THAN 10 SECS. ☐ TO OPEN ☐ STAYPUT ☒ TO CLOSE ☒ STAYPUT
ACCESSORIES*	POSITIONER (SMART) AIR FILTER REGULATOR AIR LOCK RELAY POSITION LIMIT SWITCH POSITION TRANSMITTER SOLENOID VALVE E/P CONVERTOR JUNCTION BOX HAND WHEEL (SIDE MOUNTED) LOCAL POSITION INDICATOR (*refer pneumatic actuator datasheet for details)	☒ REQUIRED ☐ NOT REQUIRED ☒ REQUIRED ☐ NOT REQUIRED ☒ REQUIRED ☐ NOT REQUIRED ☒ REQUIRED ☐ NOT REQUIRED PART OF SMART POSITIONER ☒ REQUIRED ☐ NOT REQUIRED PART OF SMART POSITIONER ☒ REQUIRED ☐ NOT REQUIRED ☒ REQUIRED ☒ REQUIRED
PROCESS CONTROL	LINEARITY HYSTERISIS SENSITIVITY ACCURACY (OVERALL)	± 1% ± 1% ± 0.5% ± 2%
DESIGN	#MAX SHUT OFF PRESS (KG/CM2(G) #BODY DESIGN : PRESS (KG/CM2(G) TEMP (DEG C) IBR FORM III-C #VALVE TYPE	48 48 60 ☐ REQUIRED ☒ NOT REQUIRED ☐ CAVITATION ☐ FLASHING ☐ HIGH DP



DATA SHEET FOR CONTROL VALVES (WITH PNEUMATIC ACTUATOR)

DOCUMENT NO. PE-TS-419/420-145-N101

VOLUME

SECTION

REV. NO. 00

DATE: 17.11.16

SHEET 16

OF

17

DATA SHEET – A & B for ACCESSORIES

DATA SHEET – A FOR CONTROL VALVE (WITH PNEUMATIC ACTUATOR) (TO BE FILLED BY PURCHASER)

DATA SHEET – B (TO BE FILLED-UP BY BIDDER)

POSITIONER (SMART)	MFR. & MODEL NUMBER			TO BE INDICATED IN VENDOR'S DOCUMENT		
	BYPASS	GAUGES	ENCL. CLASS	☐ YES ☐ NO	☐ THREE ☐ TWO	☐ IP-65
	INPUT SIGNAL (ELECTRICAL)			4-20 mA DC		
	OUTPUT SIGNAL (PNEUMATIC)(Kg / Cm ²)			TO SUIT ACTUATOR		
AIR FILTER REGULATOR	MFR. & MODEL NUMBER			TO BE INDICATED IN VENDOR'S DOCUMENT		
	AIR SUPPLY PRESS (Kg / Cm ² g)			☒ 5.0 - 8.0		
	FILTER SIZE			5 MICRONS		
	OUTPUT PRESS (Kg / Cm ² g)			TO SUIT SMART POSITIONER		
AIR LOCK	MFR. & MODEL NUMBER			TO BE INDICATED IN VENDOR'S DOCUMENT		
	SET PRESS (Kg / Cm ²)			TO BE INDICATED IN VENDOR'S DOCUMENT		
	SUPPLY PRESS (Kg / Cm ²)			☒ 5.0 - 8.0		
	RESET TYPE			AUTO		
	VENT PLUG			REQUIRED		
LIMIT SWITCH (Applicable only for tag nos. CDV-67 & DRV-73)	MFR. & MODEL NUMBER			TO BE INDICATED IN VENDOR'S DOCUMENT		
	OPEN posn	INT posn	CLOSE posn	1 NO.	---	1 NO.
	CONTACT TYPE			SPDT 2 NO + 2 NC		
	RATING (AC / DC)			5A 240V AC AND 0.5A 220V DC		
	ENCLOSURE CLASS			☒ IP 65		
POSITION TRANSMITTER (IN BUILT IN SMART POSITIONER)	MFR. & MODEL NUMBER			NOT APPLICABLE		
	TYPE			☒ Electronic (2-Wire Type), Non-Contact Type ☐ OTHER		
	SUPPLY			☒ 24V DC ☐ 220V DC ☐ 110V AC ☐ 240V AC		
	OUTPUT RATING			☒ 4-20mA ☐ 0-100 ohms		
	ACCURACY			± 1% FS		
	ENCLOSURE CLASS			☒ IP 65		
SOLENOID VALVE	MFR. & MODEL NUMBER			TO BE INDICATED IN VENDOR'S DOCUMENT		
	RATING			☒ 24V DC ☐ 220V DC ☐ 240V AC ☐		
	OPERATION	QUANTITY		☐ Stayput ☒ Interlock	AS PER DATASHEET & HOOK UP	
	COIL INSULATION CLASS			CLASS - H		
	ENCLOSURE CLASS			☒ IP 65		
HANDWHEEL	ORIENTATION			☐ TOP MOUNTED ☒ SIDE MOUNTED		
JUNCTION BOX	NO. OF WAYS			☒ 24-WAYS ☐ 36-Ways ☐ AS REQUIRED		
	SIZE			AS REQUIRED		
	CABLE GLANDS (Size / Quantity)			AS REQUIRED (Double Compression Type).		
	ENCLOSURE CLASS			☒ IP 65		
I/P CONVERTER	MFR. & MODEL NUMBER			IN BUILT IN SMART POSITIONER		
	INPUT SIGNAL	POWER SUPPLY				
	SPLIT RANGE					
	ENCLOSURE CLASS					
SS Tubing & SS Fittings / per CV	This is in addition to SS Tubing and SS fittings which are integral part of CV			12 Meters of ¼ " SS Tubing, with 1 set of SS Fittings for each CV for connection to IA Header on one end and accessories on another end of CV.		
						COMPANY SEAL
						NAME
						SIGNATURE
						DATE



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPECIFICATION NO.: PE-TS-419-142-N101

SECTION I

REV. NO. 00

DATE : 17.11.16

CUSTOMER SPECIFICATION

CONTROL VALVES

1.00.00	GENERAL
1.01.00	Control valves for regulating service shall normally be globe body, preferably cage guided, metal-to-metal seated, pneumatically operated and shall be provided with characterized plugs
1.02.00	Where high stroking speed , high actuation forces and accurate positioning is critical for the operation of the plant, as in case of HP or LP bypass valves, Separator Drain Valves , hydraulic actuators with electro-hydraulic interface shall be offered.
2.00.00	GENERAL TECHNICAL REQUIREMENTS
2.01.00	VOID
2.02.00	VOID
2.03.00	VOID
2.04.00	VOID
2.05.00	Wherever, steam conditioning calls for , Pressure reducing & desuperheating, combined PRDS type valves shall be offered.
2.06.00	Control Valve shall be furnished with IBR certification wherever required .
2.07.00	Valve Body / End Connections
2.07.01	Valve end to end dimension and connection shall be according to ANSI standard, straight through pattern. However, Bidder may offer angle body valve for high pressure drop applications. For high pressure drop applications, construction of the valve shall be such that the gland is not exposed to inlet pressure.
2.07.02	Control valves of 40 mm. size and above with line pressure up to 50 Kg / Sq. cm may have flanged or welded end connections.

- 2.07.03 Control valves, used in high pressure services shall have butt welded end connections for size 65mm and above and socket weld end connection for size 50 mm or below.
- 2.07.04 Control valve body shall be selected as per the ISA GUIDeline. Generally control valve body shall be cast and machined for pressure rating up to 1500 lbs. Above 1500 lbs, valve body shall be of Cast Steel . For Demineralized Water application, valve body shall be Stainless Steel.
- 2.07.05 Bonnet joints for all control valves shall be of flanged and bolted type.
- 2.07.06 VOID
- 2.07.07 The direction of flow shall be clearly engraved on the body . Valve tag no, , description or purpose, stroke time shall be painted on all control valve body with black letters on white background in Bold letters.
- 2.07.08 VOID

- 2.07.09 Bidder may supply valves with body and trim materials with superior quality than specified material and in such cases Bidder shall furnish the comparison of offered material properties ,such as cavitation resistance , , hardness , tensile strength , strain energy , corrosion and erosion resistance etc. , with specified material for Owner's approval.

2.08.00 Valve Size

The control valve sizing (Cv / Kv) shall be based on following guidelines :

- a) The valves shall pass normal flow (MCR condition) with 60 to 70 percent opening for linear characterised valves and between 70 to 80 percent opening for equal percentage characterised valves.

- b) The valves shall have adequate rangeability to pass the minimum and maximum flows at 10% and 85% of the valve opening respectively. Valve stem travel range from minimum to maximum flow condition shall not be less than 50% of the total valve stem travel.
- c) Valve Cv shall be selected in such a way that the valve shall be capable of handling at least 120% of required maximum flow.
- d) The valve selection shall be based on the highest size dictated by the above considerations unless noise, flashing or other factors dictate the final selection.
- e) VOID

2.09.00 Valve Top work

2.09.01 Top work shall be sized so that the valve shall operate properly when upstream pressure is 10 percent above maximum inlet pressure and downstream pressure is atmospheric.

2.09.02 Extended bonnet/ bonnet when maximum temperature fluid is greater than 280⁰ C shall be provided and high temperature packing shall also be used for high temperature application.

2.09.03 VOID

2.10.00 Valve Trim

2.10.01 Valve trim for applications up to leakage class-V shall be stainless steel 316 SS for pressure drop up to 7 Kg/ Sq. cm. For pressure drops above 7 Kg/Sq. cm hard trim (stellite or equivalent) shall be used. Other alloys or treatment such as nitride shall be used if severe erosion is expected.

2.10.02 Balanced trim valves shall be offered for high shut-off pressure or high pressure drop condition to reduce the size of the actuators.

2.10.03 VOID

2.10.04 VOID

2.10.05 Quick replacement type trim shall be considered for easy maintenance.

2.10.06 Plug shall be one-piece construction cast , forged or machined from solid bar stock .Plug shall be screwed or pinned to valve stems or shall be integral with the valve stems.

- 2.11.00 Noise Level
- The equivalent sound level measured at 1.5M above nearest floor level in elevation and 1 M horizontally from the control valve expressed in decibels to a reference of 0.0002 microbar shall not exceed 85 dBA. The noise abatement shall be achieved by valve body & trim design and not by use of silencers. Valve Actuators
- 2.12.00 Actuator
- 2.12.01 Spring-diaphragm type actuators shall generally be used. Piston type actuators shall be offered in case of high shut-off pressure & quick response requirement. Hydraulic actuation system shall be provided for Critical valves as described elsewhere in the specification.
- 2.12.02 The actuator shall be designed for 150% thrust required for the valve (at shut-off pressure) at an air line supply pressure of 5.5 Kg/Sq. cm.
- 2.12.03 Diaphragms shall be designed for 200% maximum operating pressure.
- 2.12.04 Nylon reinforced neoprene is preferred as diaphragm material.
- 2.12.05 Valve actuators shall be capable of operating at 80⁰ C ambient, continuously.
- 2.12.06 Entire actuator assembly shall be painted with corrosion inhibiting paint.
- 2.12.07 Air connection size shall be 1/4" NPT (F) unless otherwise dictated by process response time. Integral tubing shall be stainless steel.
- 2.12.08 Bidder shall indicate the stroking time of the valve assemblies with positioned and ensure that the stroke time shall meet the process and equipment dynamics and shall be better than 10 seconds.
- 2.12.09 All actuators shall be of fail safe design signifying that the spring direction will tend to move the valve (open or close) in a direction safe for the process. "Failure to Open" or "Failure to Close" shall be marked on the actuator.
- 2.12.10 Hydraulic actuation system
- The system shall consist of , but not limited to , Hydraulic cylinder , proportional valve with blocking unit , SMART positioner with position transmitter , SOVs , safety bypass unit , safety control unit , Hydraulic supply unit and local controller cubicle with controller unit
- 2.13.00 Valve Positioners
- 2.13.01 All regulating service valves shall be offered with HART protocol based Smart Electro Pneumatic Positioners to ensure accuracy and repeatability of response.
- 2.13.02 Positioners shall have integral non contact type position transmitter, input and output gauges, local keypad & display and 4-20 mA DC output to DDCMIS in CCR.
- 2.13.03 Positioners shall be capable of functioning under hot, humid and vibrating conditions.
- 2.13.04 Positioner casings shall be dust tight, corrosion resistant and weatherproof to IP 65 .and explosion proof in hazardous areas.

- 2.13.05 In general, positioner shall operate at signal range 4 – 20 mA DC for the full travel of the valve. Split range operation in few cases may be required.
- 2.13.06 Remote calibration from control room shall be possible through HART management station.
- 2.14.00 Performance
- 2.14.01 Performance of the complete assembly of the control valves shall be better than +/- 1% of FS for linearity , +/- 0.5 % of FS for hysteresis , 1% for accuracy.
- 2.15.00 Valve Accessories
- 2.15.01 Accessories shall include side mounted hand wheels, open & close , intermediate (as applicable) limit switches for both regulating and On off valves , junction boxes with 20 % spare terminals , Air filter regulators , airlock relays , volume chambers etc. Solenoid valve (SOV) wherever required shall be furnished. Each limit switch shall have not less than 2 NO & 2 NC contacts with contact rating 5A , 240 V AC / 0.5 A , 220 V DC . SOV shall have SS bar stock body , SS316 Trim , SS coil enclosure , Class H insulation Air filter regulator shall have sintered bronze filter element with maximum 5 microns filter size & 2 inch dial size pressure gauges. .Protection class of all Limit switches , junction boxes , SOV etc. shall have protection class IP 65 and explosion proof for hazardous areas.
- 2.15.02 Air distribution line to all final control elements like control valves, pneumatic dampers (both regulating / on-off type) , SOV operated valves shall be through SS manifolds and SS isolating valves only. These valves shall be properly tagged also with KKS tag no. and description of final control element / instrument for which they are intended.
- 2.16.00 Test and Examination
- All valves shall be tested in accordance with the Quality Assurance programme agreed between the Owner and Bidder , which shall meet the requirements of IBR and other applicable codes mentioned elsewhere in the specification . The test shall include but not be limited to Non destructive test , Hydrostatic shell test prior to seat leakage test , Seat leakage test , Valve closure test , Functional test of fully assembled valves including actuators and accessories. CV test etc. For all control valves Cv test shall be witnessed by Owner.



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION II

REV. NO. 00

DATE 17.11.16

SHEET 1 OF 24

SPECIFICATION FOR APRDS

	TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION		SPEC. NO.: PE-TS-419/420-142-N101
			SECTION II
			REV. NO. 00 DATE 17.11.16
			SHEET 2 OF 24

1.0 SCOPE

- 1.1 This specification covers the Design, Manufacture, Inspection and Testing at the manufacturer's works, proper packing for transportation and delivery to site of AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION (with Pneumatic Actuator) for use in Utility/Captive Power Station.
- 1.2 Expander/Reducer between valve body & pipe shall be in BHEL's scope of supply. However, any other expander/reducer required shall be in bidder's scope of supply.

2.0 CODES AND STANDARDS

- 2.1 As a minimum requirement, the latest revision/version of the following or equivalent standards shall be complied as a minimum requirement :-

Indian Boiler Regulation	:	IBR
ASME	:	B31.1/BPVC
Allowable Seat leakage	:	FCI-70.2
Pressure & Temperature ratings	:	ANSI-B16.34
Enclosure class	:	IEC-144 / NEMA / IS-13947
Control Valves Sizing	:	ISA S-75

3.0 TECHNICAL REQUIREMENTS

The Control valve, Actuator and the accessories shall be suitable for continuous operation under an ambient temperature of 0-60°C and Relative Humidity of 0-95% unless specified otherwise in volume IIB Section-B or Section-C.

3.1 Control Valve

The control valve shall be suitably designed for the process operating conditions and system characteristics as specified in the Data Sheet-A.

- 3.1.1 The control valve shall be of globe/angle body design, as per datasheet, with single port. Valve trim shall be cage guided balanced type for valve sizes $\geq 3"$ and above. The valve trim shall be suitable for quick replacement without any cutting or welding. Anti-cavitation trims shall be provided for valves with cavitation service and hardened trims for flashing services.
- 3.1.2 Bidder to note that High Capacity PRDS is a combined type steam conditioning valve with single valve body design. Bidder to offer body and trim materials as per the datasheet-A. Wherever there is a deviation from the datasheets, bidder to furnish the documentary proof for confirming superior trim material/body material selection along with their offer. BHEL/Customer reserves the right to accept/reject any variation in the specification.
- 3.1.3 Asbestos shall not be used for the packing or any other component.
- 3.1.4 The valve bonnet and packing shall be suitable for the service conditions as in Data Sheet-A. Gland sealed type bonnets are not acceptable. Bonnets having Teflon packing shall have valve stem finished to

	TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION	SPEC. NO.: PE-TS-419/420-142-N101		
		SECTION II		
		REV. NO.	00	DATE 17.11.16
		SHEET 3 OF 24		

2-4 micro inches RMS. Packing material requiring lubrication will not be acceptable.

Type of bonnet shall be according to the service condition. Extension bonnets shall be provided when the maximum temperature of the flowing fluid is greater than 280 or unless otherwise specified.

- 3.1.5 The valve end connection as specified in Data Sheet-A shall conform to ANSI B16.25 for Butt Weld connection and ANSI B16.11 for socket weld connection. Tolerances on end to end, center to center, center to face shall be in accordance with ASME B16.10. The end connections shall be Socket Welded for sizes below 50NB and Butt Welded for sizes 50NB and above.
- 3.1.6 The valve seat leakage shall be as per FCI-70.2. The leakage class shall be as per Data Sheet-A.
- 3.1.7 The valve body shall have the direction of flow embossed on all valves.
- 3.1.8 The sizing shall conform to the requirements of ISA S75.01. Valve shall be capable of handling 120% of required maximum flow with meeting below mentioned requirements:
- | | | | | |
|--|---|---|---|--------------------|
| Valve with Linear characteristic. | - | Normal Flow (Design Point) | : | 70-75% valve lift. |
| | - | Max. Flow | : | 90% valve lift. |
| | - | Min. Flow | : | >10% valve lift. |
| Valve with Equipercentage Characteristic | - | Normal Flow (Design Point) | : | 75-85% valve lift. |
| | - | Max. Flow | : | 90% valve lift. |
| | - | Min. Flow | : | >10% valve lift. |
| ON/OFF Quick open Characteristic | - | 1.2 times the CV calculated on the basis of maximum flow condition. | | |
- 3.1.9 Calculation for valve sizing, velocity and noise shall be subject to purchaser's approval during contract stage. However responsibility of proper selection and design for the duties specified lies with the vendor. Any modifications required to be done on the valves or actuators & accessories to achieve satisfactory performance of the control system shall be done without any commercial & delivery implication.
- 3.1.10 The valve outlet velocities shall be limited to the following values, unless otherwise specified in the Data sheet-A.
- | | | | |
|-----|----------------|----|-----------------|
| i) | Liquid service | <= | 8 Meters/Sec. |
| ii) | Steam service | <= | 150 Meters/Sec. |
- 3.1.11 For cavitation service, the trim design shall be of multistage pressure drop type, so as to avoid cavitation altogether, instead of keeping cavitation away from valve parts
- 3.1.12 The equivalent weighted sound level measured at 1.5 metre above floor level in elevation and 1 metre horizontally from the control valve expressed in decibels to a reference of 0.0002 microbar shall not

	TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION	SPEC. NO.: PE-TS-419/420-142-N101			
		SECTION	II		
		REV. NO.	00	DATE	17.11.16
		SHEET	4	OF	24

exceed 85 dBA (without pipe insulation). The offer shall include noise prediction calculations for each valve.

3.1.13 In case of predicted noise level above 85 dBA, same shall be brought down to acceptable noise level i.e. below 85dBA through Source treatment (proper valve trim & valve body selection). Path treatment (LNP/ Diffuser/ Cartridge/ Silencer etc.), if any shall be subject to Customer’s/Owner’s approval.

3.1.14 In case of wrong selection/mal operation of valve and for associated actuator during guarantee period, the vendor shall replace the valve suitably with a modified/new valve of design as approved by purchaser and all the expenses for replacement, rectification/modification including transportation both ways will be at vendor’s expenses.

3.2 **ACTUATORS-** The control valves shall be operated with pneumatic actuator

3.2.1 **Pneumatic Actuator**

The actuator shall be designed for a thrust of 120% of valve’s shut-off pressure at an air line supply pressure of 5-8 Kg/Sq. cm.
The pneumatic actuators shall be employed for modulating or open/close duty, as specified in Data Sheet-A. The bidder shall be responsible for proper selection and sizing of valve actuators in accordance with the pressure drops, shut off pressure and valve travel.
The pneumatic spring opposed diaphragm actuator or piston actuator as the case may be for modulating duty shall be capable of positioning the associated valve at desired opening for all the operating conditions specified.

3.2.2 The pneumatic actuator for open/close duty shall be suitable for fast opening/closing of the associated valve.

3.2.3 The actuator design shall allow valve assembly to be mounted at 45° inclination on either side in the vertical plane.

3.2.4 The actuators shall be suitably sized to ensure that the associated valve travel time from full open to full closed position and vice versa is less than 10 seconds or as specified in the datasheet under the most stringent service conditions.

3.3 **Accessories for Control valve with Pneumatic Actuator**

The bidder shall offer all the accessories as specified in the Data Sheet - A for the Pneumatic Actuators under modulating or OPEN/CLOSE duty. The accessories specified shall be supplied duly mounted on the valve actuator and piped with PVC covered copper/ SS tube and flare less brass/ SS fittings etc. as per the hook up diagram (Refer drawing no. PES-145-06B).

3.3.1 **Handwheel**

Handwheel shall have OPEN & CLOSE direction marking and clockwise rotation as viewed from front shall close the valve. The handwheel shall have a circular stainless steel plate with Tag number and service.



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION II

REV. NO. 00

DATE 17.11.16

SHEET 5

OF 24

3.3.2 Local Position Indicator

Each actuator shall be provided with a mechanical pointer attached to stem, moving over a graduated scale with markings, for OPEN, 25%, 50%, 75%, CLOSE positions.

3.3.3 Position Transmitter

The position transmitter shall be integral part of the smart positioner.

3.3.4 Air Filter Regulator

Instrument quality air at suitable pressure of 5 Kg/Cm²(g) to 8 Kg/Cm²(g) shall be supplied to each valve through air filter regulator. The filter regulator shall include an inbuilt blow-down valve (auto drain feature), 5 micron size filter. The bowl material for the AFR shall be sintered bronze. The Air filter regulator shall be selected to meet the requirements of positioner/actuator, E/P convertor and air-lock. The flow capacity of the Air filter regulator shall be variable with a knob. Output gauge shall be provided wherever pneumatic positioner is not specified for the valve.

3.3.5 Air Lock Relay

Air lock relay shall retain the valve position stayput, in case of air supply failure and shall reset automatically on resumption of air supply. Air lock shall have a threaded plug for evacuating diaphragm air if required for local manual operation.

3.3.6 Solenoid Valves

Solenoid valves are meant for interlock & protection purposes overriding the controller signal, and/or to result stayput action on controller signal failure. The Solenoid valve shall be 3-way Universal type and the valve internals and valve body shall be of stainless steel. The coil shall have class-H insulation and rated for continuous AC/DC duty as specified in Data sheet-A. The enclosure shall be to IP-65. Cable gland shall be provided for cable entry. The solenoid shall in general conform to IS-8935. The solenoid shall be provided with manual overriding facility. The solenoid shall be suitable for 24V DC supply, unless specified otherwise in Data Sheet-A.

3.3.7 Limit Switch Assembly

Limit switch assembly are required as specified in the data sheet-A. Each limit switch shall have 2NO+2NC contacts with contact rating of 5A at 240V AC/0.2A at 220V DC unless otherwise specified. The switch enclosure shall conform to IP-65. Each limit switch shall be supplied with cable glands.

3.3.8 I/P Converter

I/P Converter shall be integral part of the smart positioner.



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION II

REV. NO. 00

DATE 17.11.16

SHEET 6

OF 24

3.3.9 Smart positioner

Microprocessor based Electronic (Smart)Positioner

1	Electrical	a) Input Demand Signal	4-20 mA
		b) Power Supply	Loop Powered from the output card of Control System (12-30 V DC)
		c) HART Protocol	Compatibility for Remote Calibration & Diagnostics (Superimposed HART signal on input Signal (4-20 mA)
		d. Valve position sensing	Position sensing, 4-20 mA output signal to be provided for control system.
2	Environment	a) Operating temp.	(-)30 To 80 Deg. C
		b) Humidity	0-95 %
		c) Protection class	IP-65 Minimum
3	Software for Configuration and Diagnostics	Software	Windows based software. Software shall meet the requirements for Configuration, Diagnostics, Calibration and Testing of the actuator. It shall be easily upgradable with some hardware and compatible with any HART management system/AMS. Valve positioning timing, actuator leakage, and valve wear and tear, fault alarm to be offered as a minimum.
		Diagnostic/Test features	Advanced diagnostic features like Stroke counter or Travel counter, Leakage in actuators, Valve Signature analysis, Step Response test, Valve friction /Jamming detection etc. to be provided.
4	Test reports/ Certificates	Factory Valve Signature Tests Reports (Pressure versus Valve travel and Travel versus I/P signal) are to be provided.	
		Test certificates as per manufacture standard/Relevant standard are to be submitted.	
5	Configuration/ Calibration	Remote & Local Calibration, Auto & Manual Calibration shall be possible.	
6	Operating Range	Full range/ Split range.	
7	Modes	Valve Action	Direct / Reverse Valve Action
		Flow Characterization	Possible to fit Valve Characteristic Curves- Linear , Equal percentage etc.
8	Fail Safe/Fail Freeze	Fail Safe/Fail Freeze feature is to be provided as per datasheet. (In case the fail freeze feature is not intrinsic to the positioner, Bidder shall achieve the	

	TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION		SPEC. NO.: PE-TS-419/420-142-N101
			SECTION II
			REV. NO. 00 DATE 17.11.16
			SHEET 7 OF 24

		same externally through solenoid valve Connected in the pneumatic circuit).	
9	Pneumatic	Air capacity	Sufficient to handle the valves & actuators selected/ Boosters to be supplied, if required.
		Air pressure	To suit the air supply pressure/quality available.
		Process connection	¼" NPT
10	Performance	characteristic deviation	≤0.5 % of span. (<0.75%)
		ambient temp effect	≤0.01 %/ deg c or better.
		dead band	adjustable to 0.1to 10%
		scan time	10ms
		resolution	≤0.05%
		sensitivity/linearity	0.3-0.4% of FS
		repeatability	0.32% of FS
		auto tune	yes
11	EMC & CE compliance	Required to International Standard like EN/IEC.	EN50081-2 & EN50082 or equivalent.
12	Accessories	In-built Operator Panel	Display with push buttons for configuration and display on the positioner itself (Password protected/Hardware lock).
		Pressure Gauge Block & Position Indicators.	For supply & output pressures, Air Filter Regulator, integral type position transmitter, in built mechanical position indicator and other accessories shall be provided on as required basis for making system complete.
		Electrical Cable Entry	1/2" NPT, side or bottom entry to avoid water ingress.
		Valves Mounting Assembly	For Sliding Stem/Rotary/Single acting/Double acting actuators on as required basis.

3.3.10 Junction Box

Integral junction box with all electrical accessories conduited up to JB shall be supplied. The junction box shall have two (2) cable glands for outgoing cables. Junction box shall have enclosure class of IP-65.

3.4 **Painting** of the control valve assembly shall be as per the Painting Specification attached elsewhere in this technical specification. In the absence of specification for painting, vendor to submit their standard painting procedure for painting for BHEL's approval. Epoxy based paint (corrosion-resistant) to be provided for control valves for coastal environment.

3.5 **Sub-vendors** shall be subject to BHEL/ Customer/Customer's Consultant approval in the event of order.

	TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION	SPEC. NO.: PE-TS-419/420-142-N101		
		SECTION II		
		REV. NO.	00	DATE 17.11.16
		SHEET 8 OF 24		

4.0 TESTING AND INSPECTION

- 4.1 The testing and inspection of the equipment/items shall be in line with the approved QAP
- 4.2 The cost of all tests as per the approved QAP will be deemed to have been included in the bid.
- 4.3 In case, the bidder is supplying the valve from outside India, the third party inspection shall be arranged and considered by the bidder in their offer.

5.0 SPARES AND CONSUMABLES

5.1 Start-up/Commissioning Spares

The bidder shall supply all the start-up/commissioning spares as per the BOQ given in the technical specification.

S.No.	ITEM DESCRIPTION	QUANTITY REQUIRED (per unit)
1	Gaskets	One (1) set with each control valve Tag
2	Gland Packings	One (1) set with each control valve Tag
3	SS Tubing (as applicable)	12 Meters of ¼ “ SS Tubing, with 1 set of Fittings for each CV

5.2 Mandatory Spares

The bidder shall supply all the mandatory spares as per the BOQ given in the technical specification.

6.0 DRAWINGS AND DOCUMENTS

6.1 The bidder shall furnish the following documents (4sets) along with the bid

- Compliance certificate as enclosed in Section II.
- Schedule of deviations if any.
- Sizing Calculations.
- General Assembly (GA) drawings indicating all important details for layout.
- Quality Plan duly signed & stamped.
- Relevant Catalogs with detailed technical information.
- Un-price schedule of prices & unit prices as per NIT.

6.2 The successful bidder shall furnish the following documents to BHEL during the contract stage viz. after the award of contract:



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION II

REV. NO. 00

DATE 17.11.16

SHEET 9

OF 24

6.2.1 2 sets of the following CONTROL VALVE DOCUMENTS for approval + 1 sets of CD/soft copy:

- All Sizing Calculations (CV, Noise Level, Valve Outlet Velocity, Actuator sizing etc.)
- General Assembly (GA) drawings indicating all important details (edge preparation details, dimensions, weight etc) for layout.
- Data sheet-B completely filled-up.
- Hook-up diagram of Control Valve with Actuator & Accessories.
- Quality Plan duly signed & stamped.
- Relevant Catalogs with detailed technical information.

6.3 Final documentation:

Final Documents / drawings to be furnished by the successful bidder shall be as follows:
12 sets with 5 CD-ROMS/Soft Copy of:-

- Category I & IV approved CONTROL VALVE DOCUMENTS
- Test certificates
- Operation & maintenance manuals for Control Valve, Actuator and all accessories

7.0 MARKING AND PACKING

7.1 Marking

A stainless steel metal nameplate should be permanently fixed on each equipment giving its tag number and technical specifications. The Following Details are to be marked on the Packing Cases

- ✓ Address of consignee
- ✓ Purchase order no.
- ✓ Description of items or title of packing list
- ✓ Weight
- ✓ Dimension of the Box
- ✓ Marking showing upright position
- ✓ Marking showing sling position
- ✓ Marking showing umbrella (i.e. for machines/components to be stored under covered storage)





**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION II

REV. NO. 00

DATE 17.11.16

SHEET 10

OF 24


7.2

Packing

All equipment / materials shall be suitably packed and protected for the entire period of dispatch, storage and erection against impact, abrasion, corrosion, incidental damage due to vermin, sunlight, high temperature, rain, moisture, humidity, dust, sea water spray (where applicable) as well as rough handling and delays in transit and storage in open. Guidelines for packing are as follows:

- ✓ After inspection of control valves assembly, smart Positioner along with Pressure Gauge shall be disassembled & packed separately.
- ✓ Threaded connection of Smart Positioner & Pressure Gauge shall be shipped with the end caps fitted to avoid any damage.
- ✓ Instructions with sketch for mounting the Smart Positioner & Pressure Gauge shall be sent along with the aforesaid accessories.
- ✓ Packing of the control valves and Smart Positioner along with Pressure Gauge shall be done in separate wooden boxes/cases in order to avoid damage during transit and also during storage at site in tropical climatic conditions for a period of 18-24 months.
- ✓ All valves & smart positioner along with pressure gauges shall be packed properly with quality wooden planks with proper wooden frame support. Moreover the valves are internally covered with polythene sheets to protect from the water and moisture entry.
- ✓ Stronger shock absorbing cover material like expanded Polyurethane which can take any direct impact on it shall be used for packing.
- ✓ Proper reaper support to be provided in the packing and Valve assembly to be aligned properly to avoid the damage of accessories during transit due to vibration effect.
- ✓ Marking for Fragile & Condensing environment shall be done on the packing box.

STANDARD CONTROL VALVE HOOK-UP DIAGRAM (WITH SMART POSITIONER)



NOTES :-

1. POSITION OF EACH VALVE ON SUPPLY AIR FAILURE / ELECTRICAL SIGNAL FAILURE SHALL BE AS PER SPECIFICATION / DATA SHEET.
2. SOLENOID VALVE & LIMIT SWITCHES WILL BE PROVIDED ONLY FOR CONTROL VALVES IF INDICATED IN RESPECTIVE DATA SHEETS.
3. SOLENOID VALVES PORTS CONDITION:
PORT 1 AND 2 SHALL BE CONNECTED UNDER DE-ENERGISED CONDITION.
PORT 2 AND 3 SHALL BE CONNECTED UNDER ENERGISED CONDITION.
4. PRESSURE GAUGES REQUIRED FOR AIR SUPPLY & OUTPUT(S).
5. MOUNTING ACCESSORIES AS REQUIRED.
6. POSITION FEEDBACK SIGNAL SHALL BE 2 WIRE 4-20mA ISOLATED SIGNAL.
7. JB TERMINALS SHALL BE CAGE CLAMP TYPE SUITABLE FOR 2.5 SQ. MM COPPER WIRE. EXTERNAL CONNECTION, OF PLUG IN TYPE OR THROUGH CABLE GLAND, SHALL BE AS PER DATA SHEET
8. ALL APPLICABLE ACCESSORIES SHALL BE PROVIDED AS INDICATED IN THE INDIVIDUAL CONTROL VALVE DATA SHEET / ACCESSORIES DATA SHEET.
9. 12 METERS 1/4" SS TUBING (AS PER ACCESSORIES DATA SHEET) & 1 SET OF FITTINGS TO BE SUPPLIED FOR EACH CONTROL VALVE FOR CONNECTION TO ISO VLV AT INST AIR HEADER ON ONE END AND TO AIR LOCK RELAY/AIR FILTER REGULATOR ON THE OTHER END. ALL THE SS FITTINGS SHALL BE DOUBLE COMPRESSION TYPE.
10. VOLUME BOOSTER (ALONG WITH TEE-T2 AND RELATED TUBING & CONNECTORS) SHALL BE PROVIDED IF REQUIRED. AIR CONNECTION TO VOLUME BOOSTER FROM TEE-T2 SHALL BE PROVIDED.



STANDARD

DRG.
No.

PES-145-06B

TITLE:-

CONTROL VALVE HOOK-UP DIAGRAM

REV.
No.

0


DATE

17.11.16

SHEET

11 of 24

STANDARD CONTROL VALVE HOOK-UP DIAGRAM (DOUBLE ACTING PISTON ACTUATOR WITH SMART POSITIONER)



NOTES :-

1. POSITION OF EACH VALVE ON SUPPLY AIR FAILURE / ELECTRICAL SIGNAL FAILURE SHALL BE AS PER SPECIFICATION / DATA SHEET. AIR LOCK SHALL BE PROVIDED ACCORDINGLY.
2. SOLENOID VALVE & LIMIT SWITCHES WILL BE PROVIDED ONLY FOR CONTROL VALVES IF INDICATED IN RESPECTIVE DATA SHEETS.
3. SOLENOID VALVES PORTS CONDITION:
PORT 1 AND 2 SHALL BE CONNECTED UNDER DE-ENERGISED CONDITION.
PORT 2 AND 3 SHALL BE CONNECTED UNDER ENERGISED CONDITION.
4. PRESSURE GAUGES REQUIRED FOR AIR SUPPLY & OUTPUT(S).
5. MOUNTING ACCESSORIES AS REQUIRED.
6. POSITION FEEDBACK SIGNAL SHALL BE 2 WIRE 4-20mA ISOLATED SIGNAL.
7. JB TERMINALS SHALL BE CAGE CLAMP TYPE SUITABLE FOR 2.5 SQ. MM COPPER WIRE. EXTERNAL CONNECTION, OF PLUG IN TYPE OR THROUGH CABLE GLAND, SHALL BE AS PER DATA SHEET
8. ALL APPLICABLE ACCESSORIES SHALL BE PROVIDED AS INDICATED IN THE INDIVIDUAL CONTROL VALVE DATA SHEET / ACCESSORIES DATA SHEET.
9. 12 METERS 1/4" SS TUBING (AS PER ACCESSORIES DATA SHEET) & 1 SET OF FITTINGS TO BE SUPPLIED FOR EACH CONTROL VALVE FOR CONNECTION TO ISO VLV AT INST AIR HEADER ON ONE END AND TO AIR LOCK RELAY/AIR FILTER REGULATOR ON THE OTHER END. ALL THE SS FITTINGS SHALL BE DOUBLE COMPRESSION TYPE.
10. VOLUME BOOSTER (ALONG WITH TEE-T2 AND RELATED TUBING & CONNECTORS) SHALL BE PROVIDED IF REQUIRED. AIR CONNECTION TO VOLUME BOOSTER FROM TEE-T2 & TEE-T3 SHALL BE PROVIDED.



STANDARD

**DRG.
No.**

PES-145-06B

TITLE:-

CONTROL VALVE HOOK-UP DIAGRAM

**REV.
No.**

0

DATE

17.11.16

SHEET

12

OF

24

		STANDARD QUALITY PLAN FOR CONTROL VALVE (PNEUMATIC)						QUALITY PLAN NO.: PE-QP-999-145-I 006				
								SECTION II				
								ISSUE NO. 1		REV. NO. 00		DATE: 11.11.2016
				SHEET 14		OF 24						
Sl. No.	Component / operation	Characteristics Checked	* Cate gory	Type/Method of Check	Extent of Check	Reference documents	Acceptance Norms	Format of Records	Agency \$			Remarks
									P	W	V	
1.0	INCOMING MATERIAL											
1.1	Body & Bonnet casting / forgings, plug, valve stem, seat ring/cage.	1. Physical, Chemical properties	MA	Physical, Chemical tests	One/ Heat(HT Batch)	Approved drg. / data sheet /	Approved drg. / data sheet /	Test Certificate	3	---	2,1	TC for body/bonnet from foundry only
		2. Heat Treatment	MA	Review of H.T. Chart	Each H.T.	Approved drg. / data sheet /	Approved drg. / data sheet /	Test Certificate	3/2	2	1	1.IBR Certification (if applicable) to be verified by BHEL. 2.Applicable for body /bonnet only
		3. Internal quality of castings	MA	RT for Body & UT for Bonnet	100%	ASME B 16.34	ASME B 16.34	Test Report / FILM	3/2	2	1	Applicable for body and bonnet for rating ANSI 900 and above.
		4. Surface Quality	MA	1. Visual	100%	MSS-SP-55	MSS-SP-55	Test Certificate	3/2	---	2	
				2. MT/PT	100%	ASME B 16.34	ASME B 16.34	Test Certificate	3	2	1	After Machining on machined surface only
		5. Pressure test for shell	MA	Hyd. Test	100%	ISA-S-75.19/ ASME B 16.34	ISA-S-75.19/ ASME B 16.34	Test Certificate	2	2	1	For Body & Bonnet after machining.
1.2	Diaphragm	1. Surface Quality	MA	Visual	100%	Mfr. standard	Mfr. standard	Test Certificate	3/2	---	2	

LEGEND: * CR - Critical characteristics
MA - Major characteristics
MI - Minor characteristics

RT- Radiographic Test
UT – Ultrasonic Test

PT – Dye penetrant Test
MT- Magnetic Test

\$ P - Agency Performing the Test.
W - Agency Witnessing the Test.
V - Agency Verifying the Test.

1 - BHEL
2 - Vendor
3 - Sub-vendor

		STANDARD QUALITY PLAN FOR CONTROL VALVE (PNEUMATIC)						QUALITY PLAN NO.: PE-QP-999-145-I 006					
								SECTION II					
								ISSUE NO. 1		REV. NO. 00		DATE: 11.11.2016	
								SHEET 15		OF 24			
Sl. No.	Component / operation	Characteristics Checked	* Category	Type/Method of Check	Extent of Check	Reference documents	Acceptance Norms	Format of Records	Agency \$			Remarks	
									P	W	V		
		2. Hardness	MA	Measurement	100%	Mfr. standard	Mfr. standard	Test Certificate	3/2	---	2		
		3. Endurance / Life cycle	MA	Cyclic test 10,000 cycles	One / Type	10,000 cycles/ Mfr. standard.	No damage	Test Certificate	3/2	---	2,1		
1.3	Spring	1. Composition	MA	Chemical-Analysis	One sample/ Heat	Material spec. / Mfr. standard	Material spec. / Mfr. standard	Test Certificate	3	---	2		
		2. Mech. Properties	MA	Mech. Test	One sample/ Heat	Material spec. / Mfr. standard	Material spec. / Mfr. standard	Test Certificate	3	---	2		
		3. Performance	MA	1. Stiffness ratio	100%	Material spec. / Mfr. standard	Material spec. / Mfr. standard	Test Certificate	3	---	2		
				2. Scragging	100%	Material spec. / Mfr. standard	Material spec. / Mfr. standard	Test Certificate	3	---	2		
				3. Cyclic test (Endurance)	One / type	10,000 cycles	Material spec. / Mfr. standard	Test Certificate	3	---	2,1		
				4. Dimension (Measurement)	One sample/ Lot	Mfr. standard	Mfr. standard	Record	3	---	2		
1.4	Electrical items [Limit switches, Solenoids, Position Transmitter(if provided externally)]	1. Routine Test	MA	HV, IR, Continuity function	100%	Relevant Standards	Relevant Standards	Test Certificate	3	---	2		
		2. Degree of protection	MA	IP/NEMA Tests	One sample / type	Approved Data sheet	Approved Data sheet	Test Certificate	3	---	2,1		

LEGEND: * CR - Critical characteristics
MA - Major characteristics
MI - Minor characteristics

RT- Radiographic Test
UT – Ultrasonic Test

PT – Dye penetrant Test
MT- Magnetic Test

\$ P - Agency Performing the Test.
W - Agency Witnessing the Test.
V - Agency Verifying the Test.

1 - BHEL
2 - Vendor
3 - Sub-vendor



STANDARD QUALITY PLAN FOR CONTROL VALVE (PNEUMATIC)

QUALITY PLAN NO.: PE-OP-999-145-I 006

SECTION II

ISSUE NO. 1 REV. NO. 00 DATE: 11.11.2016

SHEET	16	OF	24
-------	----	----	----

Sl. No.	Component / operation	Characteristics Checked	* Category	Type/Method of Check	Extent of Check	Reference documents	Acceptance Norms	Format of Records	Agency ^s			Remarks
									P	W	V	
1.5	Pressure Gauges	1. Performance	MA	Review of calibration certificates	100%	Mfr. Standard	Mfr. Standard	Test Certificate	3	---	2	
		2. Marking	MA	Visual	100%	Mfr. standard	Mfr. standard	Records	3	---	2	
2.0	IN PROCESS INSPECTION											
2.1	After machining, i, Body ii Bonnet iii Plug iv Valve Stem v seat ring/cage	1. Surface flaws	MA	Visual & MT/PT	100% (on accessible surfaces)	ASME B 16.34	ASME B 16.34	Test Records	2	---	1	Butt weld ends shall be included.
		2. Dimensional checks	MA	Measurement	100%	Mfr. Standard	Mfr. Standard	Records	2	---	1	
		3. Hard facing (wherever applicable)	MA	Hardness Measurement	One sample/Lot	Mfr. Standard	Mfr. Standard	Records	2	---	1	
3.0	TESTS ON COMPLETED VALVE											
3.1	Actuator Chamber	Leakage & Strength	MA	Pneumatic test	100%	Mfr. Standard	No Leakage	Test Certificate	2	1	1	Refer Note-4
3.2	Body	Leakage and Pressure test (Body Mount Leakage)	MA	Hydro test	100%	ISA - S-75.19/ ASME B16.34	No Leakage	Test Certificate	2	1	1	Refer Note-4
3.3	Seat leakage test for completed valve	Seat Leakage	MA	Pneumatic Test	100%	FCI-70.2	FCI-70.2	Test Certificate	2	1	1	Refer Note-4
4.0	OPERATION TEST ON COMPLETED VALVE (Final inspection)	1. Valve Travel	MA	Measurement	100%	Mfr. Procedure	Approved drg. / data sheet	Test Report	2	1	1	Refer Note-4
		2. Opening/Closing time	MA	Measurement	100%	Mfr. Procedure	Approved drg. / data sheet	Test Report	2	1	1	Refer Note-4
		3. Linearity/cam characteristic	MA	Measurement	100%	Mfr. Procedure	Approved drg. / data sheet	Test Report	2	1	1	Refer Note-4

LEGEND: * CR - Critical characteristics
MA - Major characteristics
MI - Minor characteristics

RT- Radiographic Test
UT – Ultrasonic Test

PT – Dye penetrant Test
MT- Magnetic Test

\$ P - Agency Performing the Test.
W - Agency Witnessing the Test.
V - Agency Verifying the Test.

1 - BHEL
2 - Vendor
3 - Sub-vendor



STANDARD QUALITY PLAN FOR CONTROL VALVE (PNEUMATIC)

QUALITY PLAN NO.: PE-QP-999-145-I 006

SECTION	II
---------	----

ISSUE NO. 1	REV. NO. 00	DATE: 11.11.2016
-------------	-------------	------------------

SHEET	17	OF	24
-------	----	----	----

Sl. No.	Component / operation	Characteristics Checked	* Category	Type/Method of Check	Extent of Check	Reference documents	Acceptance Norms	Format of Records	Agency \$			Remarks
									P	W	V	
		4. Repeatability	MA	Measurement	100%	Mfr. Procedure	Approved drg. / data sheet	Test Report	2	1	1	Refer Note-4
		5. Hysteresis	MA	Measurement	100%	Mfr. Procedure	Approved drg. / data sheet	Test Report	2	1	1	Refer Note-4
		6. Sensitivity	MA	Measurement	100%	Mfr. Procedure	Approved drg. / data sheet	Test Report	2	1	1	Refer Note-4
		7. Accuracy (Overall)	MA	Measurement	100%	Mfr. Procedure	Approved drg. / data sheet	Test Report	2	1	1	Refer Note-4
		8. Control Valve characteristics / CV Test	MA	♦ Measurement (Press. vs. discharge and discharge vs. opening 0-100% in steps of 10%)	One per type	Mfr. Procedure	Approved drg. / data sheet	Test Certificate	2	--	1	♦ Size = Body & port size Or Body size & CV for non std port. Refer Note 1.
		9. Operation of limit switch & solenoids and other accessories	MA	Function	100%	Mfr. Procedure	Approved drg./ data sheet	Test Report	2	1	1	On assembled valve Refer Note-4
		10. Overall dimensions	MI	Visual and dimensional	100%	Approved drg. / data sheet	Approved drg./ data sheet	Records	2	1	1	Refer Note-4
		11. Pre defined valve position in case of air failure	MA	Visual	100%	Approved drg. / data sheet	Approved drg. / data sheet	Test Certificate	2	1	1	
		12. Cleanliness, painting, stamping (for direction of flow), Tag No.	MA	Visual and dimensional, paint thickness	100%	Mfr. Procedure	Approved drg./ data sheet	Test Certificate	2	1	1	
		13. Surface Quality	MA	Visual	100%	MSS-SP-55	MSS-SP-55	Test Certificate	3/2	---	2,1	

LEGEND: * CR - Critical characteristics
MA - Major characteristics
MI - Minor characteristics

RT- Radiographic Test	PT – Dye penetrant Test
UT – Ultrasonic Test	MT- Magnetic Test

\$ P - Agency Performing the Test.
W - Agency Witnessing the Test.
V - Agency Verifying the Test.

1 - BHEL
2 - Vendor
3 - Sub-vendor

		STANDARD QUALITY PLAN FOR CONTROL VALVE (PNEUMATIC)						QUALITY PLAN NO.: PE-QP-999-145-I 006				
								SECTION II				
								ISSUE NO. 1		REV. NO. 00		DATE: 11.11.2016
								SHEET 18		OF 24		
Sl. No.	Component / operation	Characteristics Checked	* Category	Type/Method of Check	Extent of Check	Reference documents	Acceptance Norms	Format of Records	Agency \$			Remarks
									P	W	V	
5.0	AUXILIARY ITEMS (Performance test of auxiliary items shall be performed on the completely assembled valve)											
5.1	Positioner	Overall leakage after assembly including Nozzles leakage	MA	Leak Test (in the steady state input signal)	100 %	Mfr. Standard	No leakage	Test Certificate	3/2	---	---	Certificate of Conformance (C.O.C)
5.2	Air filter regulator	1. Normal air consumption	MA	Measurement	Each type	Mfr. Standard	No leakage	Test Certificate	3/2	---	---	(C.O.C)
		2. Overall leakage	MA	Visual (soap solution)	100 %	Mfr. Standard	No leakage	Test Certificate	3/2	---	---	(C.O.C)
5.3	Air lock relay	Performance Test	MA	Leakage test	100%	Mfr. Standard	No leakage	Test Certificate	3/2	---	---	(C.O.C)
5.4	Electronic position transmitter(not applicable if provided integral to smart positioner)	1. Accuracy	MA	Operation	100%	Approved data sheet /	Approved data sheet /	Test Certificate	2	1	---	(C.O.C)
5.5	Current to Pneumatic converter(not applicable for smart positioner)	1. Physical Verification Make/Model	MA	Visual	100%	Approved drg. / data sheet	Approved drg. / data sheet	Test Certificate	2	---	---	(C.O.C)
		2. Degree of Protection	MA	IP/NEMA test	Each type	Relevant Standard	Relevant Standard	Test Certificate	3	---	---	(C.O.C)
		3. Linearity	CR	Measurement	100%	Approved drg. / data sheet /	Approved drg. / data sheet /	Inspection Report	2	---	---	(C.O.C)
		4. Hysteresis	CR	Measurement	100%	Approved drg. / data sheet /	Approved drg. / data sheet /	Inspection Report	2	---	---	(C.O.C)
5.6	Smart Positioner	1. Physical Verification Make/Model	MA	Visual	100%	Approved drg. / data sheet	Approved drg. / data sheet	Test Certificate	2	---	---	(C.O.C)

LEGEND: * CR - Critical characteristics
MA - Major characteristics
MI - Minor characteristics

RT- Radiographic Test
UT – Ultrasonic Test

PT – Dye penetrant Test
MT- Magnetic Test

\$ P - Agency Performing the Test.
W - Agency Witnessing the Test.
V - Agency Verifying the Test.

1 - BHEL
2 - Vendor
3 - Sub-vendor

		STANDARD QUALITY PLAN FOR CONTROL VALVE (PNEUMATIC)						QUALITY PLAN NO.: PE-QP-999-145-I 006				
								SECTION II				
								ISSUE NO. 1		REV. NO. 00		DATE: 11.11.2016
								SHEET 19		OF 24		
Sl. No.	Component / operation	Characteristics Checked	* Cate gory	Type/Method of Check	Extent of Check	Reference documents	Acceptance Norms	Format of Records	Agency \$			Remarks
									P	W	V	
	(As Applicable)	2. Degree of Protection	MA	IP/NEMA test	Each type	Relevant Standard	Relevant Standard	Test Certificate	3	---	---	(C.O.C)
		3. Linearity	CR	Measurement	100%	Approved drg. / data sheet /	Approved drg. / data sheet /	Inspection Report	2	---	---	(C.O.C)
		4. Hysterisis	CR	Measurement	100%	Approved drg. / data sheet /	Approved drg. / data sheet /	Inspection Report	2	---	---	(C.O.C)
		5. Calibration with Hand Held Communicator	MA	Measurement	Each type	Mfr. Standard	Mfr. Standard	Test Certificate	2	---	---	(C.O.C)
6.0	PAINTING	Soundness of Painting	MA	Visual and Measurement	100%	Mfr. Standard	Mfr. Standard	Inspection Report	2	---	---	Refer Note-2
7.0	PACKING	Soundness of Packing against transit damage	MA	Visual	100%	Mfr. Standard	Mfr. Standard	Inspection Report	2	---	---	Refer Note-3

NOTES:

1. In case valid CV test certificate for a similar control valve(same size, same CV, same trim characteristics) is not submitted to BHEL by the vendor, CV test shall be conducted at FCRI/Any govt. approved laboratory/ BHEL approved Laboratory.
2. In the absence of BHEL spec. for painting, vendor to obtain BHEL's approval on their painting specification / procedure.
3. Sea worthy packing shall be provided, if called for in the Data sheets.
4. The quantum of check shall be 100% for manufacturer and 10% for BHEL/BHEL nominated inspection agency.
5. IBR certificates in Form III-C shall be submitted if called for in the specification/datasheet.
6. Copies of all TC's(Test Certificates) for materials duly correlated with Heat Nos., TC's for electrical items and mechanical tests(Leak/Operation), C.O.C's(Certificates of Conformance) shall be submitted to BHEL for verification and acceptance.

LEGEND: * CR - Critical characteristics
MA - Major characteristics
MI - Minor characteristics

RT- Radiographic Test
UT – Ultrasonic Test

PT – Dye penetrant Test
MT- Magnetic Test

\$ P - Agency Performing the Test.
W - Agency Witnessing the Test.
V - Agency Verifying the Test.

1 - BHEL
2 - Vendor
3 - Sub-vendor



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION II

REV. NO. 00

DATE 11.11.16

SHEET 20 OF 24

COMPLIANCE CERTIFICATE

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate and furnish same with the offer.

- a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions with regard to same.
- b) There is no other deviations w.r.t. specification other than those furnished in the 'Schedule of Technical Deviation/ Clarification'. Any other deviation, stated or implied, taken elsewhere in the offer stands withdrawn. The acceptance of the deviations is not binding on BHEL/ Customer.
- c) Bidder shall submit stamped QP on compliance basis in the event of order based on the guidelines given in the specification. In case, the bidder is supplying the item from outside India, the third party inspection shall be arranged and considered by the bidder in their offer.
- d) Any drawing/ document/ data-sheet/ calculation/ Quality plan/ Instrumentation etc. submitted along with the offer shall be considered for reference only, same shall be subject to BHEL/ Customer/Customer's Consultant approval in the event of order.
- e) The offered materials shall be either equivalent or superior to those specified in the specification. For components where materials are not specified, same shall be suitable for intended duty, all materials shall be subject to approval in the event of order.
- f) Bidder to confirm that any calculation/format required during the contract (in the event of order) to ascertain any calculated/selected value shall be furnished.
- g) Selection of valves and actuators are bidder's responsibility. Any change in selection of type of valve / sizing / percentage opening, calculations, QP, etc., if desired by BHEL / customer during approval of the documents after award of contract, without major changes in process parameters as per tender specification, shall be carried out by bidder without any commercial implication and time delay.
- h) All sub - vendors shall be subject to BHEL/ Customer/Customer's Consultant approval in the event of order.



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION II

REV. NO.

00

DATE 11.11.16

SHEET

21

OF

24

Tag No..... Quantity.....

Data Sheet No. PES-145-06-DS2-1

DATA SHEET-B

**DATA SHEET – C FOR CONTROL VALVE (WITH PNEUMATIC ACTUATOR)
(TO BE FILLED BY THE BIDDER AFTER THE AWARD OF CONTRACT)**

GENERAL*	PROJECT	
	SERVICE	
	LOCATION	
	DUTY	
	PIPE SIZE (inlet / outlet)	
	PIPE MATERIAL (inlet / outlet)	
BODY	MODEL NUMBER	
	TYPE OF BODY : GUIDING : NO. OF PORTS	
	BODY SIZE : PORT SIZE : DESIGN CV	
	END CONNECTION & RATING (ANSI)	
	BODY MATERIAL	
	PACKING MATERIAL SINGLE / DOUBLE	
	BONNET TYPE	
	TRIM FORM	
	TRIM MATERIAL : SEAT PLUG	
	TRIM MATERIAL : CAGE GUIDE	
	FLOW	
	OUTLET VELOCITY	
	REQUIRED LEAKAGE CLASS	
	NOISE LEVEL (dBA)	
	VACUUM SERVICE	
	ANTI CAVITATION TRIM	
PNEUMATIC ACTUATOR	MODEL NO. & SIZE	
	CLOSE AT : OPEN AT (Kg / Cm ² g)	
	*TRAVEL TIME FOR OPEN TO CLOSE, CLOSE TO OPEN	
	*VALVE POSN. ON SIGNAL AIR FAILURE	
	*VALVE POSN. ON SUPPLY AIR FAILURE	
ACCESSORIES	POSITIONER	
	AIR FILTER REGULATOR	
	AIR LOCK RELAY	
	POSITION LIMIT SWITCH	
	POSITION TRANSMITTER	
	SOLENOID VALVE	
	E / P CONVERTER	
	JUNCTION BOX	
	HAND WHEEL (SIDE MOUNTED)	
	LOCAL POSITION INDICATOR	
	ELECTRO PNEUMATIC POSITIONER	

	TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION				SPEC. NO.: PE-TS-419/420-142-N101				
					SECTION II				
					REV. NO. 00			DATE 11.11.16	
					SHEET 22 OF 24				
Tag No..... Quantity..... Data Sheet No. PES-145-06-DS2-1									
DATA SHEET-B									
DATA SHEET – C FOR CONTROL VALVE (WITH PNEUMATIC ACTUATOR) (TO BE FILLED BY THE BIDDER AFTER THE AWARD OF CONTRACT)									
PERFORMANCE OF VALVE	HYTERSIS								
	LINEARITY								
	SENSITIVITY								
	ACCURACY (Overall)								
SERVICE CONDITION*	SL.+ NO.	LOAD	FLOW (T/HR)	INLET PR. (KG/CM ² (A)	OUTLET PR. (KG/CM ² (A)	TEMP DEG. C	CALCULA TED CV	% VALVE LIFT	VALVE O/L VELOCITY
		VALVE TYPE							
		* MAX SHUT OFF PRESS ((KG/CM ² g)							
		* BODY DESIGN : PRESS ((KG/CM ² g) TEMP (DEG. C)							
		* IBR FORM III-C							
TOTAL WEIGHT (VALVE + ACTUATOR + ACCESSORIES) KG.									
SEA WORTHY PACKING									

	TECHNICAL SPECIFICATION FOR AUXILIARY STEAM PRESSURE REDUCING & DESUPERHEATING STATION		SPEC. NO.: PE-TS-419/420-142-N101	
			SECTION	II
			REV. NO.	00
			DATE	11.11.16
			SHEET	23 OF 24

Tag No.....		Quantity.....		Data Sheet No. PES-145-06-DS2-1	
DATA SHEET-B					
DATA SHEET – C FOR CONTROL VALVE (WITH PNEUMATIC ACTUATOR) (TO BE FILLED BY THE BIDDER AFTER THE AWARD OF CONTRACT)					
POSITIONER	MFR. & MODEL NUMBER				
	BYPASS	GAUGES	ENCL. CLASS		
	INPUT SIGNAL (Kg / Cm ²)				
	OUTPUT SIGNAL (Kg / Cm ²)				
AIR FILTER REGULATOR	MFR. & MODEL NUMBER				
	AIR SUPPLY PRESS (Kg / Cm ² g)				
	OUTPUT PRESS (Kg / Cm ² g)				
	OUTPUT GAUGE				
	FILTER SIZE				
AIR LOCK	MFR. & MODEL NUMBER				
	SET PRESS (Kg / Cm ²)				
	SUPPLY PRESS (Kg / Cm ²)				
	RESET TYPE				
	VENT PLUG				
LIMIT SWITCH	MFR. & MODEL NUMBER				
	OPEN posn	INT posn	CLOSE posn		
	CONTACT TYPE				
	RATING (AC / DC)				
	ENCLOSURE CLASS				
POSITION TRANSMITTER	MFR. & MODEL NUMBER				
	TYPE				
	SUPPLY				
	OUTPUT RATING				
	ACCURACY				
SOLENOID VALVE	MFR. & MODEL NUMBER				
	RATING				
	OPERATION	QUANTITY			
	COIL INSULATION CLASS				
	ENCLOSURE CLASS				
HANDWHEEL	ORIENTATION				
JUNCTION BOX	NO. OF WAYS				
	SIZE				
	CABLE GLANDS (Size / Quantity)				
	ENCLOSURE CLASS				
	BODY MATERIAL				
I/P CONVERTER	INPUT SIGNAL	POWER SUPPLY			
	SPLIT RANGE				
	ENCLOSURE CLASS				
	LINEARITY				
	HYSTERESIS				
Cu. Tubing & Fittings / per CV	25 Meters of ¼" PVC coated Cu. Tubing, with 1 set of Fittings for connection to IA Header on one end and accessories on another end of CV				
PAINTING	COLOUR/SHADE				
	THICKNESS (DFT)				
	TYPE				
				COMPANY SEAL	
				NAME	
				SIGNATURE	
				DATE	



**TECHNICAL SPECIFICATION FOR
AUXILIARY STEAM PRESSURE REDUCING &
DESUPERHEATING STATION**

SPEC. NO.: PE-TS-419/420-142-N101

SECTION II

REV. NO. 00

DATE 11.11.16

SHEET 24 OF 24

SCHEDULE OF TECHNICAL DEVIATION/ CLARIFICATION

S. No.	Document Ref/ Title / Section	Page No.	Clause No.	Description	Deviation/ Clarification