

	PROJECT: 3X27.5 MW KUTTIYADI HEP-RMU PRE-QUALIFICATION REQUIREMENT- HVAC SYSTEM.	PE-PQ-471-571-11000-A001	
		DATE	23.12.2021
		REV NO	00

1.0	Bidder should have designed, supplied, erected and commissioned at least one (1) no. Ventilation system in industrial / commercial installations, consisting of Centrifugal/ Axial fans of total capacity 50,000 Cu. Mtr. / Hr. at least, along with associated ducting work etc., which are in successful operation for a period of not less than one (1) year as on date of techno commercial bid opening.
2.0	Bidder has to submit following supporting documents meeting above mentioned pre-qualifying requirement Copy of performance certificate (in English) from end user along with copy of related Purchase Order (PO) or Letter of intent (LOI) or Letter of Award (LOA) or Work Order (WO) in support of PQR clause at S.No.1.0 above.
3.0	Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
4.0	Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
5.0	Notwithstanding anything stated above, BHEL / KSEBL reserves the right to assess the capabilities and capacity of the bidder / sub vendors to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL / KSEBL.
6.0	Consideration of offer shall be subject to customer's approval of bidders, if applicable.
7.0	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.
8.0	The bidder shall meet PQR based on its own credentials. Bid from joint venture (JV) company / Consortium bid is not acceptable.

Prepared By

Reviewed By

Approved By