



ANNEXURE – A to TENDER 2760713E/OT-05
Specification for 3.0 Ton Cassette AC

Sl no	Description	QTY
01	Supply, Installation and Commissioning of Cassette AC, 3.0 Ton Capacity, with..... Remote controller, TIMERS AND Auto restart, 440V, Three Phase, 50 HZ, AC. Make: Voltas/ LG/ Hitachi/ Bluestar/ Carrier/ O'General / Daikin	03 nos
02	Required Length of (for Suction) Copper Tube with Insulationfor 03 no of AC	50 M
03	Required Length of (For Delivery)Copper Tube with Insulationfor 03 no of AC	50 M
04	Required Thread rod 10 Feet Length X 05 nos....to hang Cassettefor 03 no of AC	150 feet
05	Required Channel ...10 Feet Length X 5 nos ...to lay Copper tubesfor 03 no of AC	150 feet
06	Required One inch Dia PVC Pipe.. Length...For Water drainagefor 03 no of AC	50 M
07	One inch Dia PVC Bends..... For Water drainagefor 03 no of AC	26 nos
08	Suitable Electrical cable ... lengthfor 03 no of AC	50 M

Signature and Office Seal of Vendor