



**Power Sector – PEM Noida
Technical Pre - Qualification
Requirements
(For Open/Global Tender)**

**Project: 3X800 MW PATRATU STPP,
EPC
Package: DOUBLE GIRDER EOT CRANE
ABOVE 100T
DEPARTMENT: Mechanical Auxiliary
Engineering**

Sheet 1 of 1

REV 00

**Pre-Qualification Requirement:-Double girder EOT crane having capacity of 100T or more
with span of 28M or more.**

- 1) The Bidder should have designed, manufactured, erected and commissioned EOT cranes of capacity 100T or more with minimum crane span of 28 meters, which is in successful operation in at least one (1) station for a minimum period of one (1) year as on 08/09/2018.

For this the supplier has to submit performance certificate in English from end user along with copy of Purchase Order, meeting above mentioned pre-qualifying requirement.

- 2) Notwithstanding anything stated above, the BHEL/NTPC reserves the right to assess the capabilities and capacity of the Bidder/ its subcontractors to perform the contract, should the circumstances warrant such assessment in the overall interest of the BHEL/NTPC.
- 3) Bidder shall provide all necessary data such as type, design, make, capacity, duty conditions, date of commissioning/ operation etc.