



**Power Sector – PEM Noida
Technical Pre - Qualification
Requirements
(For Open/Global Tender)**

**Project: 3X800 MW PATRATU STPP,
EPC
Package: MILL REJECT HANDLING SYSTEM
DEPARTMENT: Mechanical Auxiliary
Engineering**

Sheet 1 of 1

REV 00

1. Mill reject handling system offered by the bidder who has previous experience of manufacturing and supplying metallic belt conveyor type or chain flight conveyor type coal mill rejects handling systems of capacity 1.5 MTPH or higher for a pulverized coal-fired boiler unit which are in successful operation in at least one (1) plant for a period not less than one (1) year as on the date of Techno-commercial bid opening or 08/09/2018, whichever is earlier.

The reference mill reject handling systems should be of the same type i.e. metallic belt conveyor system or chain flight conveyor system as is being offered by the Bidder.

For this the supplier has to submit performance certificate in English from end user along with copy of Purchase Order, meeting above mentioned pre-qualifying requirement.
2. Notwithstanding anything stated above, the BHEL/NTPC reserves the right to assess the capabilities and capacity of the Bidder/ its subcontractors to perform the contract, should the circumstances warrant such assessment in the overall interest of the BHEL/NTPC.
3. Bidder shall provide all necessary data such as type, design, make, capacity, duty conditions, date of commissioning/ operation etc.