

	POWER SECTOR-PEM NOIDA TECHNICAL PRE-QUALIFICATION REQUIREMENTS (FOR OPEN/GLOBAL TENDERS) To be read in conjunction with PEM general PQR	Project: 1x660 MW Panki TPS PACKAGE: FUEL OIL UNLOADING & STORAGE SYSTEM DEPARTMENT : MECHANICAL AUXILIARY	
	Sheet no 1 of 1	Rev 00	

The bidder is required to meet the provenness criteria and / or qualification requirement for fuel oil unloading & storage system as per criteria stipulated below:

- 1) The Bidder should have designed, supplied, erected and commissioned at least one (1) no. of fuel oil handling installation consisting of:

- a) Unloading facilities
- b) One (1) number of Storage tank of capacity not less than 500 cu m.

The above system should have been in successful operation as on 02.11.2015.

Bidder to submit Performance certificate in English from the end user along with copy of related purchase (PO) orders or Letter of Intents (LOI) or letter of Awards (LOA) or Work Orders in support of PQR clause at S. No. 1) above.

- 2) Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
- 3) Minimum one (1) no. Purchase order shall be submitted which should not be more than seven (7) years old as on date of bid submission, for establishing continuity in business. This is over and above the requirement of PO mentioned at PQR clause at S. No. 1) above.
- 4) In case documents submitted for meeting PQR are in language other than English, notarized English translation shall also be submitted.
- 5) BHEL/Customer reserves the right to visit the works/office of the prospective bidder in order to ascertain its credentials at any time without any advance notice.