

	PROJECT: 3x800 MW PATRATU TPS		DOC NO.: PE-PQ-434-571-A001	
	PRE-QUALIFICATION REQUIREMENT (PQR)		DATE	07.01.2020
	GYPSUM DEWATERING SYSTEM		REV NO.	00

1.0	The bidder shall submit its credentials having previously designed and manufactured for at least one (1) number Vacuum Belt Filter for dewatering process in a Wet Limestone based FGD application in Coal fired power plant, of minimum capacity of 108.8 Tons per hour (wet cake), which is in successful operation for a period of not less than one (1) year as on 08.09.2018.
2.0	In case the Bidder does not have above credential, but is a manufacturer, previously designed and manufactured, at least one (1) number Vacuum Belt Filter for dewatering process in a Wet Limestone based FGD application in Coal fired power plant or in any other process application, of capacity of 65-108.8 Tons per hour (wet cake), which is in successful operation for a period of not less than one (1) year as on 08.09.2018.
3.0	In case bidder is not meeting either of the above clauses, it shall fulfil the requirement <i>placed at the Anenxure-1</i> pertaining to the Provenness criteria for vacuum belt filter and associated equipments for the Flue Gas Desulphurisation System.
4.0	The supplier has to submit following supporting documents meeting above mentioned pre-qualifying requirement: Copy of minimum one (1) performance certificate (in English) from end user along with copy of related Purchase Order (PO) or Letter of intent (LOI) or Letter of Award (LOA) or Work Order (WO) in support of PQR above.
5.0	Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
6.0	Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a translation of its pertinent passages in English language in which case, for purposes of interpretation of the bid, the translation shall govern. The English Translation of the documents shall be carried out by professional translators and the translator shall certify that he is proficient in both languages in order to translate the document and that the translation is complete and accurate. Further, translation shall be authenticated by the Indian Consulate located in the Country where the documents have been issued or the Embassy of that Country in India.
7.0	Notwithstanding anything stated above, BHEL/PVUNL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL/PVUNL.
8.0	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

Notes:

1. Please note, PQR indicated at Clause no 1 is requirement of BHEL's end customer (M/s PVUNL) with respect to capacity and FGD application in coal fired power plant and to be considered by M/s PVUNL while approving the bidder.
2. **BHEL has taken up with M/s PVUNL for relaxation with respect to capacity and alternate process application which are indicated at clause no 2 and under consideration.**

	PROJECT: 3x800 MW PATRATU TPS		DOC NO.: PE-PQ-434-571-A001	
	PRE-QUALIFICATION REQUIREMENT (PQR)		DATE	07.01.2020
	GYPSUM DEWATERING SYSTEM		REV NO.	00

3. Bidders are advised to furnish the PQR documents in line with Clause no 1 which is specific requirement of BHEL's end customer. However, in case the bidder feels that they are not meeting the requirement of clause no 1, but can meet the requirement of clause no 2, then they are advised to submit the bids along with PQR documents meeting the clause no 2. **The bids meeting the requirement of clause no 2 shall be technically recommended by BHEL and shall be forwarded to end customer for acceptance of any relaxation with respect to clause no 2 and shall be subject to approval of bidder(s) by M/s PVUNL.**

4. In case BHEL's end customer (M/s PVUNL) does not consider any relaxation with respect to clause no 2, the bids and bidder's approval shall be governed with respect to clause no 1 of PQR and bidder will not have any claim with respect to clause no 2.

Annexure-1 to Doc No. PE-PQ-434-571-A001

1. Bidder shall offer and supply only the type of the specified equipment(s) for which he himself or the manufacturer proposed by the bidder for the above equipment(s) is qualified.
2. A JV / Subsidiary Company formed for manufacturing and supply of equipment(s) as listed at clause no. 1.0 of document no. PE-PQ-434-571-A001, in India can also manufacture such equipments, provided that it has a valid collaboration or licensing agreement for design, engineering, manufacturing of such equipment(s) in India with a qualified equipment manufacturer who meets the requirements stipulated at the said clause (or the technology provider of the qualified equipment manufacturer) for the respective equipment(s). However, in this case, the proposed JV / Subsidiary Company before resorting to design, engineering, manufacturing of such proven equipment(s) listed at said clause by himself should have sourced / shall source such proven equipment(s) for at least the first 800 MW unit completely from such qualified manufacturer. For subsequent units before taking up the manufacturing of such equipment(s), the bidder/ his sub-vendor(s) must create /have created manufacturing facilities at his works as per collaborator's/licenser's design, manufacturing and quality control system for such equipment(s).
3. Further, in such a case, such qualified equipment manufacturers should have, directly or indirectly through its holding company/ subsidiary company, at least 26% equity participation in the Indian Joint Venture Company/ Subsidiary Company, which shall be maintained for a lock-in period of seven (7) years from the date of incorporation of such Joint Venture/ Subsidiary or up to the end of defect liability period of the contract, whichever is later. In addition, the Bidder along with the Indian Joint Venture Company/ Subsidiary Company, qualified equipment manufacturers and its holding/ subsidiary Company, as applicable, shall furnish DJU in which executant of the DJU shall be jointly and severally liable for the successful performance of the equipment as per the format enclosed in the bidding document. The DJU shall be submitted prior to the placement of order on the approved sub-vendor for a particular system/equipment. In case of award, each executant of the DJU shall be required to furnish an on demand bank guarantee for INR 1.5 Million (Indian Rupees One and Half Million only) for each equipment.
4. Before taking up the manufacturing of such equipment(s) as per clause 2 above, the Bidder must create (or should have created) manufacturing and testing facilities at its works as per Collaborator / licensor's design, manufacturing and quality control system for such equipments duly certified by the Collaborator / licensor. Further, the Collaborator / Licensor shall provide (or should have provided) all design, design calculation, manufacturing drawings and must provide (or should have provided) technical and quality surveillance assistance and supervision during manufacturing, erection, testing, commissioning of equipments.
5. Bidder shall offer and supply only the type of the above equipment(s) for which it, itself or the manufacturer / Collaborator(s) / Licensor(s) proposed by the Bidder for the above equipment(s) is qualified.
6. BHEL/PVUNL reserves the right to fully satisfy himself regarding capability and capacity of Bidder / its sub-vendor(s) and the proposed arrangement and may prescribe additional requirement before allowing manufacture of the equipment listed above for this contract.