



**PRE-QUALIFICATION REQUIREMENTS FOR
DC LEAD ACID BATTERIES**

PE-PQ-999-508-E003

REVISION NO. 01 DATE 30/03/2019

SHEET NO. 1 OF 1

ITEMS: 220V/110V DC Lead acid (Plante) battery of rating 1200AH & above

SCOPE: Supply : YES; Erection & Commissioning : NO; Supervision of Erection & Commissioning : YES;

1	Vendor should be designer & manufacturer of the applicable type of Battery.
2	Vendor to furnish published technical catalogue for the applicable type of batteries.
3	Availability of type test certificates conducted at independent Lab or witnessed by third party as per IS/International standards for the applicable type of batteries.
4	In-house capability to carry out all routine and acceptance tests as per IS/International standards for the applicable type of batteries.
5	Option-1: Performance certificates for min. 2 years of trouble free operation at two (2) different installations/sites for the applicable type of batteries. Performance certificate should be from end user only. OR Option-2: Repeat order received from 2 different purchasers / end users for the applicable type of batteries during last 5 years provided the gap between award of two PO's is minimum 2 years. OR Option-3: 1 no. performance certificate (as per Option-1) and 1 no. repeat order (as per Option-2). OR Option-4 : Successful execution of a major order for BHEL-PEM for the applicable type of batteries.
6	Minimum two (2) nos. purchase orders for the applicable type of batteries shall be submitted which should not be more than five(5) years old from the date of application for registration or date of techno- commercial bid opening (as applicable) for establishing continuity in business.

Notes (General points):

1. Consideration of offer shall be subject to customer's approval of bidders, if applicable.
2. Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
3. Any other project specific requirement shall be as per Annexure-I and bidder shall submit relevant supporting documents. Bidder to meet criteria as stated above and as per Annexure- I.
4. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
5. After satisfactory fulfillment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

PREPARED BY

NAME: KANHAIYA KUMAR
DESIGNATION: MANAGER(E)

REVIEWED BY

NAME: MANISH SHUKLA
DESIGNATION: DGM(E)

APPROVED BY

NAME: DEBASIS PATHY
DESIGNATION: AGM & DH(E)