

BHEL-PEM-MAUX
PRE-QUALIFICATION CRITERIA

	PROJECT: 2 X 660 MW BIFPCL MAITREE STPP TECHNICAL PRE-QUALIFICATION REQUIREMENTS FOR WORKSHOP EQUIPMENT (HVAC WORKSHOP FOR POWER STATION)		PE-PQ-421-568-A004	
			DATE	05/05/2020
			REV NO	00

1.0	Supplier should have supplied at least one of the following Machines with specified minimum parameters. 1. Freon Charging bench with vacuum pump 2. Compressor overhauling Desk (Minimum 100 TR Compressor) 3. Electrical test bench (Minimum 90 KW compressor motor testing) 4. Reclamation set (Minimum 30kg cylinders) 5. Vacuum pumps - Double Stage
2.0	Supplier has to submit following supporting documents meeting pre-qualifying requirements mentioned at S. no. 1.0 above: a. Copy of minimum one (1) Purchase Order (PO) or letter of intent (LOI) or letter of award (LOA) or work order (WO), which shall include at least one machine / equipment as defined at S. No. 1. b. Copy of inspection report / handing over protocol / copy of invoice / copy of Material Receipt certificate / any other documents as an evidence of supply of same equipment as mentioned in Purchase Order (PO) / letter of intent (LOI) /letter of award (LOA) /work order (WO).
3.0	Minimum one (1) no. Purchase order, shall be submitted which should not be more than ten (10) years old as on date of bid submission, for establishing continuity in business. This is over and above the requirement of PO mentioned of PQR clause at S. no. 2.0 above.
4.0	Stockist/ trader/ distributor/ dealer/ authorized agent/ channel partner/ sales office or subsidiary of principal who are authorised by OEM/principal are also acceptable provided OEM/principal meets the minimum pre-qualification criteria stipulated above at sl. no 1.0, 2.0 & 3.0.

Note: -

- A) Above PQR is for technical pre-qualification of bidders only. However, bidder has to supply Workshop Equipment as per standards indicated in clause no. B0.6.2 of BIFPCL specification enclosed in technical specification PE-TS-421-568-A007 only. Supplier has to give undertaking along with the bid confirming the same. Supplier not giving the same shall not be qualified.
- B) In case equipment details (type, description, minimum capacities etc.) as mentioned in S. no. 1.0 above are not established from document mentioned at S. no. 2 (a) & (b), bidder will have to submit GA drawing/ Catalogue of Equipment / technical data sheet/ any other document of respective equipment to establish the same.
- C) All the documents submitted by supplier against Sl. no. 2 (a) & (b) above should pertain to the equipment as defined at Sl. N. 1 above.
- D) Acceptance of the supplier is subject to customer (BIFPCL) approval before ordering.