

Annexure_TQR

Technical Qualifying Requirements:

Selection of Sub-Vendor

The Bidder shall have designed, manufactured, type tested at least the minimum specified quantity of all equipment as below covered under the scope of this contract of at least the rating as specified herein under or higher:

Minimum rating required for the 400 KV GIS & 400 KV SF6 CGI Bus Ducts

420 kV Class GIS & 420 kV CGI Bus Ducts and auxiliary equipment of 400 kV (minimum) 50 Hz, 50% of rated current of 2500A (i.e. **1250 A**), 40 kA/1sec (min.) short circuit rating, SF6 gas insulated switchgear for indoor/outdoor installation for minimum of **6 nos of bays**.

These equipments should have been supplied in last 20 years & should be in successful operation for at least 2 years in last 7 years as on the **date of Bid opening (09.02.2018)** in Power Plant or Sub-stations or Industrial Complex etc.


VPM / TREM



