

	PRE - QUALIFYING REQUIREMENTS (TECHNICAL)- NDCT DESIGN CONSULTANCY	DOCUMENT NO: PE-TS-426-165-N001 (PQR)
		REVISION NO: 00 DATE: 04/06/2018
		SHEET: 1 of 2

FORM NO. PEM 6100-0	ENQUIRY NO.:
	PROJECT: 1 x 660 MW PANKI TPS
	PACKAGE: NATURAL DRAFT COOLING TOWER (NDCT) DESIGN & ENGINEERING CONSULTANCY
	1. The bidder should have designed the natural draft cooling towers (NDCT) with counter flow with Splash/Film type fill in RCC construction with minimum flow of 70000 Cum/hr, which have been successfully in use for at least 1 year as on 18.04.2016 in thermal power plant or similar industry/ application of only one customer and bidder is in business of design of NDCT on continuous basis.
	2. The Bidders shall furnish following support documents for assessment of Bidder w.r.t. PQR as indicated at Sl. No. 1 above: A. Bidder's Experience list of NDCT for last 10 years for assessment of bidder for designing the NDCT on regular basis in enclosed format- Annexure-1. Bidder shall furnish the PO copy of minimum one executed contract along with the experience list. B. In support of successful performance of NDCT for one year, Bidder shall furnish Satisfactory Performance feedback certificate from End Customer (Owner) (in English) for at least one successfully executed contract which has been in use for at least one year as on 18.04.2016, indicating salient features like year of commissioning of NDCT, rating of project, flow of NDCT, project name etc., date of issue of certificate and name/ designation of the certificate issuer for power plant/similar application industry. Refer note (a) below also. The date of satisfactory performance feedback certificate should not be later than the date of subject enquiry/NIT. <u>Notes:-</u> a. Purchase order copy, approved drgs/technical data sheets etc. are to be submitted along with the bid for which the bidder intends to furnish the performance feedbacks for reference purpose only. b. The Performance feedback certificate issued to main contractor of Cooling tower from end user shall also be acceptable for meeting the above PQR provided the bidder furnishes the PO copy from main contractor for NDCT design / Engineering works in bidder's name for the subject performance feedback certificate. <u>Any additional document required in support of above documents to establish the co-relation between the above documents and the supplied item shall be provided by the bidder.</u>
3. Bidder to submit all supporting documents in English, If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.	

PREPARED BY:	REVIEWED BY:	APPROVED BY:
NAME: DHARMENDRA KR. SINGH	NAME: VISHAL KR. YADAV	NAME: ASHWANI KHANNA
DESIGNATION / DEPT.:	DESIGNATION / DEPT.:	DESIGNATION / DEPT.:

	PRE - QUALIFYING REQUIREMENTS (TECHNICAL)- NDCT DESIGN CONSULTANCY	DOCUMENT NO: PE-TS-426-165-N001 (PQR)
		REVISION NO: 00 DATE: 04/06/2018
		SHEET: 2 of 2

	4. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
	5. After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

PREPARED BY:	REVIEWED BY:	APPROVED BY:
NAME: DHARMENDRA KR. SINGH DESIGNATION / DEPT.:	NAME: VISHAL KR. YADAV DESIGNATION / DEPT.:	NAME: ASHWANI KHANNA DESIGNATION / DEPT.:

ANNEXURE I

EXPERIENCE LIST - NDCTS

[illegible]