

BHEL-PEM-MAUX
PRE-QUALIFICATION CRITERIA

	PROJECT: 3X800mw PATRATU STPP		PE-PQ-434-673-01000-A001
			DATE 10/05/2019
	PRE-QUALIFICATION REQUIREMENT PACKAGE: SEWAGE TREATMENT PLANT		REV NO 00

1.0	The Bidder is required to meet the provenness criteria and /or qualification requirement for Sewage Treatment Plant as per criteria stipulated below: 1) Bidder should have engineered/got engineered, supplied, erected, tested and commissioned at least one (1) number Sewage Treatment Plant of minimum capacity of 60 cum/day based on “Moving bed Bio Film Reactor” (MBBR). The above system/Sewage Treatment Plant should have been in successful operation for minimum one (1) year as on 08.9.2018.
2.0	The supplier has to submit following supporting documents meeting the above mentioned pre-qualifying requirements. Copy of minimum one performance certificate in English from end user along with copy of related Purchase Order (PO)/ Letter of Intent(LOI)/ Letter of award(LOA) or Work order(WO) specifying that the product is running successfully for one (1) year from date of commissioning, in support of PQR clause mentioned at S. No. 1 above.
3.0	Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/ purchase order.
4.0	Bidder to submit supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
5.0	Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, should the circumstances warrant such assessment in overall interest of BHEL.
6.0	Consideration of offer shall be subject to customer’s approval of bidder, if applicable.
7.0	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all other terms of the tender.