

Annexure A

Insulation tester (Megger) 5KV

1. Test voltages: 5 KV DC either continuously variable or variable in steps of 500/1000 volts.
2. Voltage stability: $\pm 3\%$ of rated output
3. Scale length: More than 100mm.
4. Mega ohm range: 0.1 to 100000 M ohms either on multiple scales or provided with suitable range multiplier.
5. Accuracy: $\pm 2\%$ of full scale or better.

Insulation tester (Megger) 2.5KV

1. Test voltages: 2.5KV DC either continuously variable or variable in steps of 500/1000 volts.
2. Voltage stability: $\pm 3\%$ of rated output
3. Scale length: More than 100mm.
4. Mega ohm range: 0.1 to 50000 M ohms either on multiple scales or provided with suitable range multiplier.
5. Accuracy: $\pm 2\%$ of full scale or better.