

2X800 MW NTPC KARIMNAGAR SG PKG PHASE_I

VOLUME – II

**TECHNICAL SPECIFICATION
FOR MS ROD
FOR BELOW GROUND EARTHING**

**SPECIFICATION NO. : PE-TS-424-509-E002
REVISION: 00**



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA-201301
INDIA**



TECHNICAL SPECIFICATION FOR
MS ROD FOR BELOW GROUND EARTHING

SPECIFICATION NO.

PE-TS-424-509-E002

VOLUME NO. : II

SECTION -

REV NO. : 00 DATE : 24.12.2016

SHEET : 1 OF 3

STANDARD TECHNICAL REQUIREMENTS



TECHNICAL SPECIFICATION FOR MS ROD FOR BELOW GROUND EARTHING

SPECIFICATION NO.
PE-TS-424-509-E002
VOLUME NO. : II
SECTION -
REV NO. : 00 DATE : 24.12.2016
SHEET : 2 OF 3

1.0 INTENT OF THE SPECIFICATION

1.1 This specification covers the design, manufacture, inspection & testing, packing at manufacturer's works and delivery to site of **MS ROD FOR BELOW GROUND EARTHING**.

1.2 The intent of specification is not to specify all details of design & construction of material. The material shall, however, conform in all aspects to high standard of design, engineering and workmanship and be capable of performing in continuous operation upto & after bidder's guarantee period in manner acceptable to purchaser who will interpret the drawings & specification and shall have power to reject any work or material which in his judgement is not in full accordance with this specification.

2.0 CODES & STANDARDS

2.1 The material shall comply with all currently applicable safety codes and statutory regulations of India as well as of the locality where the material is to be installed.

2.2 Applicable Standards:-

- a) **IS 2062, Grade E250 Sub-quality A**
- b) **ASTM A 510M-08* Grade SAE 1010/1018/1020**

3.0 TECHNICAL REQUIREMENTS

- 3.1 Straight lengths of MS rods of standard diameter of **40 mm in minimum length of 6 m** shall be supplied.
- 3.2 All finished MS rods for Below Ground Earthing shall be free from sharp edges, corners, burs & unevenness.

4.0 QUALITY / INSPECTION

4.1 The supplier shall perform all tests necessary to ensure that the material and workmanship conform to the relevant standards and comply with the requirements of this specification.

4.2 The tests shall be in accordance with relevant Indian/American standards. The extent of the tests to be performed by the supplier shall include but not be limited to the following: -

a) Routine Tests:

- (i) Tests for Chemical Composition
- (ii) Test for Mechanical Properties.

Necessary Test Certificates shall be submitted to BHEL for review before actual dispatch of material.

5.0 PACKING

The material shall be packed to ensure protection against damage during transit, storage for prolonged periods and handling.



TECHNICAL SPECIFICATION FOR
MS ROD FOR BELOW GROUND EARTHING

SPECIFICATION NO.

PE-TS-424-509-E002

VOLUME NO. : II

SECTION -

REV NO. : 00 DATE : 24.12.2016

SHEET : 3 OF 3

BOQ FOR BELOW GROUND EARTHING (MS ROD)

S.NO.	ITEM DESCRIPTION	UNIT	ORDER QUANTITY
1)	40 mm Dia MS ROD	MT	332