

| Designation | Category           | Interface / Terminal Points                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
|-------------|--------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| TP20        | Construction Power | <p>per section B7.1.1. Cables and raceways are out of Bidder's/Contractor's scope of supply, however, sufficient free space to be considered by the Bidder/Contractor for later installation of associated cables and raceways towards township area.</p> <p>2 terminals at 33 KV line at the border of the Power Plant Site</p> <p>Construction Power (Please refer to Section V.TS/B9/B9.4.2.1)</p> <p>Power supply for construction purposes will be provided at 33 KV voltage (2 no. of lines). The same will be extended to the Contractor for him to develop 33/11 KV sub-stations and construction power supply comprising of</p> <ul style="list-style-type: none"> <li>• Two (2) 5 MVA, 33/11 KV step down transformers.</li> <li>• Two (2) 11 KV switchgears</li> <li>• 11 KV main ring, design according to plant layout, construction requirement and schedule.</li> <li>• 11 KV/4.15 KV step down transformers (number and sizes as required according to plant layout, construction requirement).</li> <li>• Two (2) 11 KV feeders (minimum 630 A) for usage of the Employer.</li> </ul> <p>For improved reliability these feeders shall be connected to separate 11 KV bus systems at 33/11 KV sub-stations.</p> <p>The electricity prices/power tariffs for the case of 33 KV voltage level are defined in the Annex C.</p> <p>Further preliminary details regarding provided construction power system are shown in Annex C.</p> |

#### Construction Water:

As described under Section B9 the supply of construction water is in the scope of Bidder/Contractor. It is not allowed to use ground water. For construction water shall be used only river water suitably treated for his purposes.

#### B0.4.2 Interfaces to electricity dispatcher

Communication, control, monitoring and voice channels will be provided between the Facility and BPDB's National/ Regional Control Center by BPDB. The Contractor shall provide interconnection within the Facility for all such communication circuits/ channels.





#### B0.4.2.1 Interface between the Power Plant and the NLDC

In order to link the Plant to the 400 kV PGCB National Load Dispatch Center (NLDC) the Contractor shall make available all analogue and digital signals in accordance with the requirements of the Bangladeshi Grid Code and as requested by PGCB and the Employer. These will include command signals from the NLDC to the Plant's automatic load control systems (AGC, see **Part B8**).

The Contractor shall liaise with NLDC to facilitate necessary interfacing with the SCADA System in NLDC. All necessary firmware and software with suitable communication link through serial interface (to match the protocol of the existing system) shall be provided by the Contractor. Necessary reconfiguration is to be done by the Contractor to establish logical link with the existing SCADA system in NLDC. Further, reconfiguration of the database and various display builder functions of the SCADA system in NLDC to accommodate additional signals are under the scope of work of the Contractor.

The following reserve requirements shall be taken into account:

- Min. 10% of the equipment installed shall be a reserve to enable handling of an additional 10% of signals without the need for equipment extensions.
- Min. 15% of the equipment installed shall be a reserve to enable handling of an additional 15% of signals by extending the equipment but without the need to modify the existing structure of any of the interface marshalling cubicles installed.


#### B0.4.2.2 Signal interface to NLDC for automatic generation control

The power plant shall be equipped with terminals to receive command from the BPDB load dispatch center to allow control from NLDC.

The NLDC shall be able to link to the Automatic Generation Control (AGC) via telecontrol facilities so as to act on the turbine load control, adjusting the latter by decrease/increase load commands. All measurement data to indicate if the target load has been matched shall be transmitted by the telecontrol system to NLDC. Type and initial number of signals are defined in **Section B8**.

#### B0.4.2.3 Interfaces between the 400/230kV substation and the NLDC

The Contractor (in consultation with BPDB) shall provide suitable interface unit for communication links to the PGCB's SCADA system for communication, control, monitoring and voice channels to accommodate the PGCB and the National/ Regional Control Center requirements.



000098

000097



The communication interface unit shall be adequate to fulfil the PGCB/NLDC information requirement. Communication to the National Load Dispatch Center shall be provided by data communication, utilizing both, the IEC 60870-5-104 and the IEC 60870-5-101 protocols. Settings shall ensure interoperability with the remote National Load Dispatch Center.

For possible future extensions, it shall be possible to interface with two remote control centers simultaneously by using dual port capability.

From the National Load Dispatch Center, all related high voltage apparatus of the substations shall be remote controlled and monitored. Necessary interface shall be provided within the substation automation system for receiving the signals from PGCB grid control.

All signals of the substation required for the control and monitoring from the remote National Load Dispatch Center shall be made available for data transmission via the gateway.

The scope of supply includes all required equipment and installations to enable the substation for the proper connection of the required control and monitoring signals. Communication, telemetry, fiber optical terminal and tele-protection equipment (PLCC) will be supplied and installed by PGCB at Company substation end matching with PGCB's remote substation end requirements. However, line trap and capacitive voltage transformer of required rating along with 48 VDC/AC auxiliary supply at Company substation end shall be provided by the Contractor. The Contractor shall supply and install the necessary cabling and cubicles. Cabling between these cubicles and the telecommunication equipment provided by PGCB shall be provided and installed by the Contractor.

The cabling between Contractor's cubicles and the telecommunication equipment provided by PGCB in the Control Building of the 400/230 kV GIS shall be in the scope of the Bidder/Contractor.

#### B0.4.2.4

#### Interfaces between the 400/230kV substation and the Power Plant

The Contractor is responsible for the construction of the interconnections between the substation and the Power Plant. Provision and installation of all control and signal cables between the substation and the Power Plant is within the responsibility of the Contractor.

The Power Plant shall be able to supervise and control the substation via an OPC client workstation installed in the Power Plant's CCR. The Contractor shall provide and install the OPC Server/Client architecture as well as all necessary equipment required for the proper translation of the native data (either acquired directly from the IEDs or from connectivity with the station bus) in OPC-format and the data provision at the OPC-client in the Power Plant control room via a TCP/IP communication link.





In addition the SCMS may communicate with the DCS either by serial communication link or by hardwired connection. In the former, dual redundant links and communication apparatus must be provided. However, the watchdog signalling logic must be hardwired so that this will continue to operate effectively even during SCMS failure.


#### B0.4.2.5 Interface to power transmission system (PGCB - Power Grid Company of Bangladesh)

The interface between the power transmission system of PGCB and Maitree-STPP will be the following points of the 400/230 kV GIS:

- 400 kV and 230 kV Interconnection:
  - 400 kV and 230 kV OHL conductors on the gantries for connection of the GIS bushings. The gantries shall be provided under the Maitree-STPP project.
- 400 kV and 230 kV OHL Protection, Control and Synchronization:
  - None.

**Remark:** *The 400 kV and 230 kV OHL protection on the Power Plant end (not on the remote end) shall be included in the scope of supply of the Maitree-STPP Project.*

- Telecommunication:
  - Terminals on the line traps for connection of the telecommunication equipment provided by PGCB on the related gantries
  - Terminals in the telecommunication panels provided by PGCB and located in the control building of the 400/230 kV GIS for connection of the cables for the signal exchange with the LDC and for the teleprotection.
  - Terminals in the telecommunication panels provided by PGCB and located in the control building of the 400/230 kV GIS for connection of the cables for auxiliary/control power supply (240V AC, 220 VDC and 48VDC).
- Earthing:
  - Terminals on the gantries for connection of the OPGW.
  - Earthing bars in the control building of the 400/230 kV GIS for connection the protection and telecommunication panels.



#### B0.4.3 Metering

Sufficient metering devices shall be provided to enable an energetic balancing of the power unit, all fuel consumers and additionally the Plant comprising gross and net electric power, coal flow, fuel oil flow, calorific value of fuels, fuels heat energy, electric power, specific heat consumption, etc. for tariff metering and internal balancing purposes.



Metering devices of electrical signals such as frequency, voltage, active power, reactive power, and energy shall be provided:

- i for the power unit for tariff metering at the switchyard
- ii for the power unit and additional the Plant for internal balancing purposes at all switchgears and all generators.

The final number and type of metering device, their accuracy and signal interface requirements shall be according to the Employer's requirements (see **Part B10** and **Annex E**) and the requirements of the relevant grid code.

## B0.5 Technical Schedules

|       |                                               |
|-------|-----------------------------------------------|
| B0/TS | Design Conditions                             |
|       | Design Data                                   |
|       | List of Major Equipment and Service Suppliers |
|       | Guarantees                                    |

## B0.6 General Technical Requirements

### B0.6.1 General requirements

The following directions, information and technical requirements for design, engineering, manufacturing, procurement, construction, commissioning, start-up and testing shall be observed as far as they are applicable for the equipment to be delivered. The requirements stated in this Section of General Technical Requirements are valid for all sections of the specification, except only where additional and/or special requirements are specified.

In case of a contradiction between different Sections of this specification or mentioned standards, the more stringent requirements shall be applicable to Contractor.

Any changes on the design of any part of the Plant, which may become necessary after signing of the Contract, have to be submitted by the Contractor in writing to the Employer for approval, being sufficiently substantiated and justified.

The Plant shall be new and clean, and designed, manufactured and arranged so that it will have a functional design and a pleasant appearance. All parts of the Plant shall be arranged in such a manner as to facilitate surveillance by the operator and to ease maintenance, operation and control.

The parts of the Plant shall be designed and arranged so that they can be easily inspected, cleaned, erected and dismantled without necessitating large scale dismantling of other parts of the Plant. They shall be designed,





manufactured and put into operation in accordance with the latest recognized rules of workmanship, modern engineering practice and with good standards of prudence applicable to the international electricity generation industry which would have been expected to accomplish the desired result at the lowest reasonable cost consistent with reliability, safety and expedition.

The regulations, standards and guidelines listed in the Specification as well as all applicable laws and governmental decrees, regulations, orders, etc. shall be observed in the design, calculation, manufacture, erection, installation, testing, commissioning and start-up of all parts of the Plant.

The following shall be considered in the design and engineering of the Plant facilities:

- All parts of the Plant shall be suitable in every respect for continuous operation at maximum output as well as part loads and expected transient operating conditions peculiar to the site and shall be able to safely withstand the stresses arising from the operating conditions without any reduction in its planned life.
- The Contractor shall familiarize himself with the conditions on site.
- Suitable and automatically acting protection and safety measures shall be provided for automatic load reduction or shut down of equipment in case of abnormal operating conditions.
- Switchover to stand-by units shall be automatically, as far as required for continuous Plant operation without interruption of Plant operation.
- In case of equipment and/or system shut down process conditioned drainage of components (such as pipelines, tanks, etc.) shall be performed automatically from the control room.
- Minor equipment which, in case of failure would cause a failure of a power generation unit and/or the Plant is to be provided with a stand-by facility in order to ensure further operation of the power generation unit or the Plant.
- All live, moving and rotating parts shall be provided with appropriate effective protection in order to avoid danger to the operating staff. All metal parts shall be electrically grounded.
- All equipment shall be designed to ensure start-up from any condition, i.e. from long term shut-down, cold, warm or hot condition without necessitating special or preparatory measures.
- The project language shall be English.

#### B0.6.2 Standards and codes

The work must be performed according to the most recent relevant codes, standards, accident prevention regulations and local rules and legal regulations.





All materials and equipment supplied and all work carried out as well as calculation sheets, drawings, quality and class of goods, methods of inspection, specific design features of equipment and parts and acceptances of partial plants shall comply in every respect with the applicable standards, codes and regulations to be chosen from the following:

- |                                                                           |        |
|---------------------------------------------------------------------------|--------|
| • American Association of State Highway and transportation Officials      | AASHTO |
| • American Concrete Institute                                             | ACI    |
| • American Gear Manufacturers Association                                 | AGMA   |
| • American Institute of Steel Construction                                | AISC   |
| • American Iron & Steel Institute                                         | AISI   |
| • American Moving and Conditioning Association                            | AMCA   |
| • American National Standards Institute                                   | ANSI   |
| • American Petroleum Institute                                            | API    |
| • American Public Health Association                                      | APHA   |
| • American Society for Testing and Materials                              | ASTM   |
| • American Society of Civil Engineers                                     | ASCE   |
| • American Society of Heating, Refrigeration & Air Conditioning Engineers | ASHRAE |
| • American Society of Mechanical Engineers                                | ASME   |
| • American Water Works Association                                        | AWWA   |
| • American Welding Society                                                | AWS    |
| • American Wire Gauge                                                     | AWG    |
| • Anti-Friction Bearing Manufactures Association                          | AFBMA  |
| • Architectural Institute of Japan                                        | AJ     |
| • Association Francaise de Normalisation                                  | AFNOR  |
| • British Standards Institute                                             | BS     |
| • Chlorine Institute                                                      | CI     |
| • Crane Manufacturers Association of America                              | CMAA   |
| • Deutsches Institut für Normung                                          | DIN    |
| • Diesel Engine Manufacturers Association                                 | DEMA   |
| • European Norm                                                           | EN     |
| • Expansion Joint Manufacturer Association                                | EJMA   |
| • Fédération Européenne de Manutention                                    | FEM    |
| • Heat Exchanger Institute                                                | HEI    |
| • Hydraulic Institute                                                     | HI     |
| • Illuminated Engineers Society                                           | IES    |
| • Institute of Electrical and Electronics Engineers                       | IEEE   |
| • Instrument Society of America                                           | ISA    |
| • Insulated Power Cable Engineers Association                             | IPCEA  |
| • International Electrotechnical Commission                               | IEC    |
| • International Standards Organization                                    | ISO    |
| • Japanese Architectural Standard Specification                           | JASS   |





|                                                                                 |      |
|---------------------------------------------------------------------------------|------|
| • Japanese Electrical Manufacturers Association                                 | JEMA |
| • Japanese Electrotechnical Institute                                           | JEC  |
| • Japanese Industrial Standards                                                 | JIS  |
| • Manufacturers Standardization Society                                         | MSS  |
| • National Association of Corrosion Engineers                                   | NACE |
| • National Electrical Code (USA)                                                | NEC  |
| • National Electrical Manufacturer's Association (USA)                          | NEMA |
| • National Electrical Safety Code                                               | NESC |
| • National Fire Protection Association                                          | NFPA |
| • National Structural Code for Building                                         | NSCB |
| • Occupation Safety and Health Administration                                   | OSHA |
| • Portland Cement Association                                                   | PCA  |
| • Properties of Water and Steam                                                 | IFC  |
| • Scientific Apparatus Manufacturers Association                                | SAMA |
| • Society of Automotive Engineers                                               | ASE  |
| • Standards of Japanese Electrotechnical Committee                              | JEC  |
| • Steel Structures Painting Council                                             | SSPC |
| • Technische Vereinigung der Grosskraftwerksbetreiber                           | VGB  |
| • Tubular Exchanger Manufacturers Association                                   | TEMA |
| • Underwriters Laboratory                                                       | UL   |
| • Uniform Building Code                                                         | UBC  |
| • Verband Deutscher Elektrotechniker                                            | VDE  |
| • Verein Deutscher Ingenieure                                                   | VDI  |
| • Vereinigung Deutscher Elektrizitätswerke (Association of German Power Plants) | VDEW |
| • Water Pollution Control Federation                                            | WPCF |

Generally, all internationally and nationally recognized standards as above will be applied, except if specific standards called for by:

- Occupational Safety Board of Bangladesh
- Department of Inspection for Factories and Establishments, Bangladesh
- Department of Environment, Bangladesh
- Bangladesh Power Development Board
- Bangladesh Energy Regulatory Commission
- Ministry of Power, Energy and Mineral Resources
- Bangladesh Fire Service and Civil Defence Ministry
- All relevant Bangladesh National Statutory Regulations
- Bangladesh National Building Code
- Bangladesh Standards
- Local Authorities.





All steam boilers and unfired pressure vessels together with associated pipework and fittings shall comply with the Bangladesh Boiler Act, 1923 with amendments.

All pressure parts shall be designed in accordance with applicable ASME codes.

All services, supplies and works shall comply with the requirements of the relevant laws of Bangladesh and the IFC/World Bank Group Standards and Guidelines in their latest edition, including but not limited to:

- Environmental Conservation Rules
- Bangladesh Energy Regulatory Commission Act;
- BERC Licensing Regulation
- BERC Technical Quality Standards;
- Bangladesh National Building Code;
- other applicable laws in Bangladesh;
- IFC Performance Standards on Environmental and Social Sustainability;
- IFC / World Bank Group Environmental, Health and Safety (EHS) General Guidelines ;
- IFC / World Bank Group EHS Guidelines for Thermal Power Plants;
- IFC / World Bank Group EHS Guidelines for Electric Power Transmission and Distribution.

It is the Contractor's responsibility to provide sufficient evidence that any national or other standard the Contractor proposes (other than those mentioned above) will ensure an equivalent or higher standard.


Immediately after effective date of the Contract the Contractor shall supply an indexed list of all standards, codes and associated standards referred to, to which the work is to be performed. A copy of all applied standards shall be forwarded to the Employer. The Contractor shall supply preferably two (2) searchable softcopies, else two (2) hardcopies each.

### B0.6.3 Plant and equipment identification

The Contractor shall apply a plant identification system showing the name and number of each item of Plant and its respective arrangement drawing number and add any additional items necessary to fully identify the Plant.

All design submissions shall include a detailed labelling list indicating the label text, size of the lettering and fixing details for the approval of the Employer or its representative.

The identification and numbering of equipment, systems, items, etc. of supply, as well as of all documents and drawings shall be in accordance with





the VGB guideline RDS-PP (Reference Designation System for Power Plants - KKS system).

There is to be only one approved description for any one item of Plant and this must be used consistently for Plant, electrical and instrumentation designations throughout.

The Contractor shall supply all labels (Plant and Equipment Identification Plates), nameplates, manufacturer's equipment nameplate, instruction and warning plates necessary for the identification and safe operation of the Plant, and all inscriptions shall be in the English language and Bangla language.

All labels, nameplates, instruction and warning plates shall be securely fixed to items of Plant and equipment with stainless steel rivets, plated self-tapping screws or other approved means. The use of adhesives will not be permitted.

Nameplates for Plant and equipment identification and record purposes shall be manufactured from stainless steel or aluminium with a mat or satin finish, and engraved with black lettering of a size which is legible from the working position.


Warning plates shall be manufactured from stainless steel or aluminium, engraved red lettering on a white background and sited in the position where they afford maximum safety of personnel.

All equipment within panels and desks shall be individually identified by satin or mat finish stainless steel or aluminium labels.

Each circuit breaker panel, electrical control panel, relay panel, etc. shall have a circuit designation label on the front as well as on the rear panels engraved with black lettering in accordance with the circuit designation system. Circuit designations must be precise and convey complete information. There should be no doubt whatsoever for the operation as to which area of the Plant a particular feeder is supplying with power. Labels such as interconnector 1 or feeder 2 are not acceptable. Corridor type panels shall in addition have circuit designation labels within the panels.

Pipework systems shall be identified with a colour identification systems in conformity with the colours according to the Employer's specification, with colours at the nameplates and, if necessary by colour bands and with KKS numbering and plain language. The direction of flow shall be shown.

Each valve/instrument shall be fitted with a stainless steel or aluminium nameplate indicating the valve/instrument service and reference number in accordance with the approved equipment coding system.





Where possible valve nameplates shall be circular and shall be fitted under the handwheel captive nut. They have to be of such a diameter that there is no danger for persons operating the valve or that they do not prevent lock-off of this valve; on check valves and small valves the Contractor may provide rectangular nameplates fitted to brackets on the valve or attached to a wall or steelwork in a convenient position adjacent to the valve.

#### B0.6.4 Marking and labelling

Each crate or package is to contain a packing list in a waterproof envelope. All items of material are to be clearly marked for easy identification against the packing list.

All cases, packages, etc. are to be clearly marked on the outside to indicate the total weight, where the weight is bearing and the correct position of the slings and are to bear an identification mark relating them to the appropriate shipping documents.

All stencil marks on the outside of cases are either to be made in waterproof material or protected by shellac or varnish to prevent obliteration in transit.

#### B0.6.5 Corrosion protection, coating and galvanizing

This specification shall be used for the corrosion protection of steel structures, components, pipings and equipment in general which are installed in confined areas (indoors) or outdoors.

Surface preparation, as well as protective coatings and coating systems are based on this specification in order to assure that structural parts of different suppliers will get a corrosion protection of similar and high quality.

Coating material shall only be supplied by manufacturers with international experience and their products can be obtained internationally.

Regarding maintenance work (storage), application and supervision of coating work, choice of coating suppliers should be minimized. At any rate, similar parts of structures/components (such as structural steel, containers, piping, etc.) shall only be coated with products of one individual manufacturer.

The materials and equipment used, the methods of application and the quality of work shall at all times be subject to the inspection and approval of the Employer or his Representative.

To mitigate crevice corrosion, the designs and construction of structures and equipment shall ensure that no collection of water occurs in crevices which could lead to crevice corrosion.





It is the responsibility of the Contractor to ensure that, for all supplied equipment (including that from sub suppliers):

- The protection system is perfectly suitable for the Site conditions and for the specific purpose.
- The shop paints provide a sufficient protection during transport, storage and erection.
- The shop paints are suitable for handling and erection conditions (slinging, Site welding works etc.) and are compatible with the Site finishing coats
- All necessary precautions are taken in order to prevent damage to paints during storage, handling, welding.
- The necessary repairs are carefully executed as soon as possible.
- The colour RAL number of the finishing coat has been approved by the Employer, including identification code for piping.
- Standardised equipment will be painted according to the manufacturer's standard.
- All corrosion protection and coating on site shall be done in a workshop specifically for the purpose of the application of corrosion protection and coating.

#### Codes and standards

Applicable standards are:

- Product data of coating manufacturer
- DIN 2403 Indication of pipe-lines according to flowing material
- DIN 4762 Surface roughness
- ISO 8503 Surface roughness
- DIN 8201 Part 1-9 tight blasting agents
- DIN 50976 Corrosion protection, hot dip batch galvanizing of single parts, requirements and testing
- DIN 55928 Part 1-9 corrosion protection of structural steel work through protective coatings and topcoats
- ISO 8501 Preparation of steel substrates before application of paints and associated products
- ISO 12944 Paints and varnishes – corrosion protection of steel structures by protective paint systems
- RAL Colour card
- ISO 8501-1 Preparation of steel substrates before application of paints and related products
- SSPC Vol. 1 and 2 Steel structure painting council

#### Surface preparation and cleaning of surfaces in the shop

Prior to blasting, areas have to be cleaned from oil, grease, paint residues, splatters, welding splashes and welding slag using a suitable aqueous degreaser, or solvent for more severe grease contamination. The cleaning should be to provide a "water break free surface".



Sharp edges have to be rounded off.

Contaminations caused by salts, acids and alkali solutions shall be eliminated by rinsing with water up to a pH value of 6-8. Soluble salt contamination is to be tested using the Weber Reilly test method (or similar approved) and pH is to be tested using universal indicator paper strips prior to continuation with the blasting.

The preparation of substrates shall be carried out on the basis of the specifications of ISO 12944 part 4 and ISO 8501. The preparation of steel before application of paint and related products shall be in line with ISO 11124 for metallic blast cleaning abrasives and ISO 11126 for non-metallic blast cleaning abrasives. No recycled blast grit may be utilised.

After blasting, an anchor profile of 25 - 50 µm shall be achieved. Blasted surfaces have to be provided with a prime coat of the approved coating system immediately within 4 hours of blasting. All blasting and priming must take place outside of the high humidity periods of the day (i.e. maximum relative humidity of 80%).

#### **Cleaning to be performed on site**

Steel work protected by shop primer after arrival on site must be cleaned of salt, sand, oil, etc. before the first coat of paint is applied on site. Shop primer damaged during transport must be rectified by blast-cleaning and coating before application of the site coats.

Wood surfaces shall be sanded clean. All nail holes shall be puttied and sanded before priming, , unless the specific coating system allows for coating onto damp concrete, in which case only with approval from the Employer.

If a protective coating of concrete is required, concrete shall be allowed to cure before painting.

Transport and erection damages, as well as damages which result out of additional welding have to be repaired as soon as possible. The damaged areas have to be derusted with rotating or steel brushes, abrasive wheels, and abrasive blasting according to DIN ISO 8501-1.

#### **Cleaning of prime and intermediate coats (if required)**

To prevent contamination by mineral oil products, areas with prime and intermediate coat have to be treated with suitable cleaning agent. Cleaning has to be done free of residues, e.g. with alkaline detergents and thorough washing done with fresh water. Rusty spots have to be removed according to required purity. Metallic areas which are provided with temporary corrosion protection have to be cleaned. No oxidation products shall remain on the surface. Further care shall be taken that on hot components, no destructive or reaction products will be released when heating which could injure insulation.



**Application procedure**

When using the provided coating material, strict adherence to all application instructions given in product data of coating manufacturer is necessary. To obtain the maximum performance, technical data as well as application instructions for the individual coating material have to be strictly followed. For a multi-layer coating system each layer has to have a different colour shade in order to clearly identify number of coats applied. The last finish coat has to be applied in the specified colour shade.

All paintings shall be performed according to ISO 12944. The durability of all paintings shall be "high" which corresponds to 15 years.

The interval between applying the different coats has to follow according to supplier's precautions. Each layer has to be cleaned and released from spray dust before the next layer will be applied. Prior to applying a further layer, the last one has to be repaired. All coatings have to be applied without retarding.

Following application procedures are allowed:

- prime coats by airless spray  
areas like disconnections, angles, corners, etc. which are difficult to be reached can be applied by brush or roller
- repair of prime coat by brush
- finish coats
  - at works by airless spray, roller or brush
  - at site by roller or brush or airless spray.



When applying coating systems by roller, rollers have to be of kind and quality which make an appropriate application possible.

Control areas in accordance with the coating supplier's instructions have to be applied. For this procedure, a schedule for control areas has to be prepared by the Contractor and coating supplier which corresponds with the requirements of the warranty agreement.

Number and performance of the control areas have to be done in accordance with ISO 12944 part 7 and have to be documented in writing.

No application shall take place either in the condition of the relative humidity not within the given limit or in case of poor weather conditions such as fog, dust, rain, snow, hail or when it can be assumed that such conditions of poor weather will arise within 2 hours after application.

Temperature of the coated parts has always to be above 5 °C and 3 K above dew point.

All specified dry film thicknesses (DFT) are minimum thicknesses.



Welding seams executed at site have to be taped with an adhesive tape of about 30-50 mm after surface preparation (blasting or manual derusting) and prior to application in the manufacturing plant and to be coated with stripping coat.

Chequered plates, nap plates, etc. have not to be covered with adhesive tape, but have to be coated with stripping coat in a dry film thickness of at least 150  $\mu\text{m}$ .

Edging lines on steel structure have to be taped prior to application and after blasting in sufficient width or have to be protected with varnish before application. Thickness of prime coat may be 50  $\mu\text{m}$  maximum.

During repairing works at site on shop-primed structures, it is important that different coats will have different colour shades. Numbers of layers have to be the same as the original coating system to be used.

Application of temporary primer on structures which have to be insulated has to be in accordance with a sufficient corrosion protection for the period of storage respectively erection time.

#### Galvanizing

Galvanizing work shall conform in all respects to ISO 1461 or equivalent standards and shall be performed by the hot dip process unless otherwise specified.

It is essential that details of steel members and assemblies which are to be hot-dip galvanized should be designed to suit the requirements of the process. They should be in accordance with ISO 12944.

Vent holes and drain holes shall be provided to avoid high internal pressures and air locks during immersion and to ensure that molten zinc is not retained in pockets during withdrawal.

Careful cleaning of welds is necessary before welded assemblies are dipped. All defects of the steel surface including cracks, surface laminations, laps and folds shall be removed in accordance with BS 4360. All drilling, cutting, welding, forming and final fabrication of unit members and assemblies shall be completed, where feasible, before the structures are galvanized.

The minimum coating thickness shall be as specified in Table 1 of BS 729. Structural steel items shall be first grit-blasted to BS 4232, second quality, (Sa 2 1/2) or pickled in a bath, and the minimum average coating weight on steel Sections 5 mm thick and over shall be 900  $\text{g/m}^2$ , on steel Sections 2 - 5 mm thick 600  $\text{g/m}^2$ .



Galvanized contact surfaces to be joined by high-tensile friction-grip bolts shall be roughened before assembly so that the required slip factor is achieved. Care shall be taken to ensure that the roughening is confined to the area of the mating faces.

Protected slings must be used for off-loading and erection. Galvanized work, which is to be stored at the works or on site shall be stacked so as to provide adequate ventilation for all surfaces to avoid wet storage staining (white rust).

Small areas of the galvanized coating damaged in any way shall be restored by:

- cleaning the area of any weld slag and thorough wire brushing to give a clean surface
- The application of two coats of zinc-rich paint, or the application of a low melting point zinc alloy repair rod or powder to the damaged area, which is heated to 300 °C or the treatment with suitable cold galvanizing paint, such as ORAPI n.z.a.b 706. All zinc rich paint used for such repairs must contain a minimum of 81% by mass of zinc in the dry film.

Connections between galvanized surfaces and copper, copper alloy or aluminium surfaces shall be protected by suitable tape wrapping.





| Coating Systems<br>System-No. | Surface location                                             | Temp.<br>°C | Surface<br>preparation | Coating<br>systems               | No of<br>coats | Generic type                                          | Dry film<br>thickness<br>(DFT) per coat<br>µm | Total DFT<br>µm        |
|-------------------------------|--------------------------------------------------------------|-------------|------------------------|----------------------------------|----------------|-------------------------------------------------------|-----------------------------------------------|------------------------|
| 1                             | Structural steel works,<br>piping, vessels, tanks<br>INDOOR  | up to 120   | SA 2.5                 | Primer<br><br>Finish             | 1<br>1         | Zinc-Epoxy<br><br>Epoxy High Solid                    | 80<br>80                                      | 80<br>80<br>160        |
| 2                             | Structural steel works,<br>piping, vessels, tanks<br>OUTDOOR | up to 120   | SA 2.5                 | Primer<br>Intermediate<br>Finish | 1<br>2<br>1    | Zinc-Epoxy<br>Epoxy High Solid<br>2 Comp Polyurethane | 80<br>160<br>50                               | 80<br>160<br>50<br>290 |
| 3                             | Piping, tanks, etc.<br>INDOOR and<br>OUTDOOR Insulated       | up to 120   | SA 2.5                 | Primer                           | 1              | Zinc-Epoxy                                            | 50                                            | 50                     |
| 4                             | Pumps, motors, other<br>equipment<br>OUTDOOR                 | up to 120   | SA 2.5                 | Primer<br>Intermediate<br>Finish | 1<br>1<br>1    | Zinc-Epoxy<br>Epoxy High Solid<br>2 Comp Polyurethane | 80<br>110<br>50                               | 80<br>110<br>50<br>240 |
| 5                             | Pumps, motors, other<br>equipment<br>INDOOR                  | up to 120   | SA 2.5                 | Primer<br>Finish                 | 1<br>2         | Zinc-Epoxy<br>Epoxy High Solid                        | 80<br>50                                      | 80<br>100<br>180       |
| 6                             | Piping, reactors<br>OUTDOOR<br>Insulated                     | > 120       | SA 2.5                 | Primer                           | 1              | Zinc Ethylsilicate                                    | 75                                            | 75                     |
| 7                             | Stacks<br>OUTDOOR                                            | < 120       | SA 2.5                 | Primer<br>Finish                 | 1<br>2         | Zinc Ethylsilicate<br>Silicone Acrylic                | 75<br>50                                      | 75<br>100<br>175       |



FICHTNER

B0-99

8140A01/FICHT-15702705-v5  
BIFPCL/EPC-Main Plan/V1



| Coating Systems |  | Surface location                                                               | Temp. °C                                                                                        | Surface preparation                                                                                                        | Coating systems                                                          | No. of coats | Generic type                             | Dry film thickness (DFT) per coat µm | Total DFT µm    |
|-----------------|--|--------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------|--------------|------------------------------------------|--------------------------------------|-----------------|
| 8               |  | Steel surfaces (uninsulated)                                                   | 200-450                                                                                         | SA 2.5                                                                                                                     | Primer<br>Finish                                                         | 1<br>2       | Zinc/Ethylsilicate<br>Silicone/Aluminium | 75<br>35                             | 75<br>50<br>125 |
| 9               |  | Galvanized surfaces                                                            | up to 120                                                                                       | Mechanical cleaning from contaminants and zinc salts by means of washing or steam jetting or sweep-blasting with fine sand | When Finish Coat is required, such as sea climate with chloride exposure | 1            | Epoxy High Solid*                        | 125                                  | 125             |
| 10              |  | Steel surfaces permanently in contact with water, also river water splash zone | Medium temp. °C up to 50                                                                        | SA 2.5                                                                                                                     | Primer and Finish Coat in One                                            | 1            | Glassflake reinforced High Solid Epoxy   | 500                                  | 500             |
| 11              |  | Plant / Cooling water pipes                                                    | GRP, or steel lined concrete pipes with cathodic protection and coating according to AWWA C 203 |                                                                                                                            |                                                                          |              |                                          |                                      |                 |

\* Additional 1 x Finish Coat 2-Comp. Polyurethane, 50 µm, when exposed to UV or weathering conditions and colour retention is required.

Signature: *[Handwritten Signature]*



FICHTNER

BO-100

8140A01/FICHT-15702705-v5  
BIFPCL/EPC-Main Plant/1/

000114

000113



## B0.6.6 Vibration

### Steam turbine generator

The steam turbine and generator have to be statically and dynamically balanced in the workshop such that the following levels of vibrations can be achieved:

- For the steam turbine and the generator the vibration level, measured on the rotating parts at each main bearing shall not exceed the upper limit of the zone "A" as defined in ISO 7919 at steady conditions.
- For the steam turbine and the generator, the vibration level, measured on the rotating parts at each main bearing shall not exceed the upper limit of zone "B" as defined in ISO 7919 for transient operation at rated speed.
- In no case (except alarm condition), the vibrations measured on the rotating parts shall exceed 0.5 of the minimal clearance of the bearings, for the measurements installed near the bearings. This requirement is valid for all speed ranges and load conditions. If conflicts exist between the different specifications, the more restrictive value shall be applied.

The location of sensor element shall be according established standards and generally recognised codes of practice.


### Other rotating equipment

Unless otherwise stated or agreed by the Employer all rotating equipment must have statically and dynamically balanced in the workshop such that the following levels of vibrations can be achieved:

- For large rotating equipment (boiler feedwater pumps, main cooling water pumps, fans (PAFs, FDFs, IDFs), condensate pumps, etc.) the vibration levels, measured on the non-rotating parts, shall not exceed the upper limit of zone "A" as defined in ISO 10816 at steady conditions. For other areas e.g. min flow or run out flow, zone limit "B" shall be maintained.
- For standard pumps, other rotating equipment and reciprocating pumps, the vibration levels, measured on the non-rotating parts, shall not exceed the zone limit "B" as defined in ISO 10816 at steady conditions. For equipment which is not covered by ISO 10816, the manufacturer standard shall be applied.
- For all rotating equipment at transient conditions, the vibration levels, measured on the non-rotating parts, shall not exceed the zone limit "C" as defined in ISO 10816.

For all motors, the vibration levels, measured on the non-rotating parts, shall not exceed the limit as described in the relevant Sections for MV and LV motors.

The vibrations measured on the rotating parts may not exceed 0.5 of the minimal clearance of the bearings. This requirement is valid for all speed ranges and load conditions. If conflicts exist between the different specifications, the more restrictive value must be applied.





Whenever necessary, equipment shall be put on vibration dampers.

#### **Vibration Monitoring System**

Vibration shall be measured at large rotating or reciprocating machinery for protection and predictive maintenance. This includes the turbine, the generator, large rotating equipment (boiler feedwater pumps, main cooling water pumps, fans (PAFs, FDFs, IDF's), condensate pumps, etc.).

Suitable indications shall be provided in the control room for each measurement point and the measurement shall be suitably alarmed where high vibration levels may cause possible damage or affect the safety of the Plant. All the vibration signals, unprocessed, which are present on the machine as well the result of the VMS shall be available in the PADO as well as in DCS.

The vibration monitoring system (VMS) shall be reliable, accurate, easy to maintain, and suitable for use in such ambient conditions appertaining to the intended plant installation. Vibration monitoring signals for trip commands, protection functions or process interlocks shall be hardwired. The VMS shall comprise all the necessary hardware and software modules and shall be configured according the design and the needs of the specific installation and technology.

Standardization and interchangeability of components shall be implemented where feasible.

The following features and requirements shall be considered for the vibration and displacement monitoring system:

- self-checking and single fault tolerant system
- modular and reliable system
- 2 out of 3 voting, if signals shall be used for trips (shaft vibration measurement shall be as per ISO 7919-2)
- hardwired or redundant serial communication have to be foreseen
- All buffered outputs signals shall be passed through to the analysis system as unprocessed (raw) input signals.

The following criteria shall be used as a guideline for rotating machinery such as steam turbine, generator, blowers and fans, mills and main feed water pumps as well as other main pumps, in order to ascertain the monitoring points, principles of what signal shall be measured, what is displayed, and what mechanical conditions entail alarm and/or trip status:

- non-contacting proximity probes shall be provided unless otherwise specified for measuring rotor shaft vibration and axial position,
- vibration measurements shall be in displacement microns peak to peak,





- in cases which, because of process conditions, accessibility or non-critical service, may entail the use of machine casing mounted vibration transmitters, the transmitters shall be of the "acceleration" type incorporating a filter network, if necessary along with integration in the monitor unit for vibration read-out in velocity mm/sec RMS. For alarm only, one transducer may be used. For alarm and trip conditions 3 transmitters shall be used with a voting system (i.e. one high reading out of three = alarm, two out of three = trip). Contacting type of equipment shall meet the requirements of ISO 2954,
- velocity type transmitters shall be used as an alternative to velocimeters when machine rotational speed and generated vibration frequency conditions dictate,
- individual read-out of all channels shall be provided in HMI as well as in the vibration monitoring module. Display shall be by means of a multi-point indicator and digital selector,
- facilities for trend monitoring using trend functions of the DCS shall be provided on the turbo-generator bearings as an aid for predictive maintenance purposes,
- vibration parameters of the turbine shall also be fed in the turbine control system
- buffered signals at the monitor shall be a requirement to enable external data acquisition, if such is necessary,
- facilities shall be provided for the calibration of the instrumentation system.

Further requirements on the analysis functions of the VMS are given in Section B8.

#### B0.6.7 Standardization of makes

The works shall be designed to facilitate access and facility for inspection; cleaning, maintenance and repair. Continuity of supply is a prime concern. The design shall incorporate every reasonable precaution and provision for the safety of all those concerned in the operation and maintenance of the works. The Plant shall be designed to operate satisfactorily under all variations of load, pressure, and temperature.

Corresponding parts throughout shall be made to gauge and be interchangeable wherever possible.

No prototype will be permitted. Continuity of operation and lowest maintenance requirements are of prime concern. The design shall incorporate every reasonable precaution and provision for the safety of all those concerned in the operation and maintenance of the equipment and plant.

The equipment must be standardized as much as possible.





All equipment performing similar duties shall be of the same type and manufacture in order to limit the stock of spare parts required and maintain uniformity of plant and equipment to be installed. Especially the number of types and manufacturers of actuators, valves and instruments shall be reduced to a minimum.

If a piece of equipment is present several times, then all of these pieces shall be identical. All their constituting parts must be exchangeable between them.

The Employer reserves the right to advise the Contractor of preferred type and manufacture to secure the above-mentioned requirements.

Bidder's/Contractor's sub-suppliers and vendors shall comply with Provennes Criteria as stipulated elsewhere in the bidding document.

Throughout the Power Plant metric units, scales and measures shall be used; this applies especially to all fittings.

#### B0.6.8 Accessibility

The Contractor shall supply and erect sufficiently large safe platforms, galleries, stairways or ladders and access ways necessary for providing safe and easy access to all the plant items for operation and maintenance. The Contractor shall ensure that the whole of the access ways is of uniform design and pattern throughout the works.

The design of all stairways, access ways etc. shall conform to the requirements of the relevant chapters is **Section B0**.

#### B0.6.9 Signs & colour code

##### General

Safety colours, safety symbols and safety signs must comply in construction, geometrical form, colour and meaning with the ISO 3864.

Signs for plant identification during the erection period must be to Employer's approval.

The signs should be of a material which is weather-resistant and of sufficient durability for the conditions prevailing on site.

##### Mounting and installation

The positions for the signs must be chosen so that they are within the field of vision of the persons to whom they apply. The signs should be permanently attached. Temporarily dangerous areas (e.g. construction sites, assembly areas) may also be marked by movable signs. The safety signs





must be mounted or installed in such a manner that there is no possibility of misunderstanding.

#### Information signs

Information signs should supply the necessary information to acquaint personnel with the physical arrangement and structure of site, buildings and equipment, e.g. floor numbers, load-carrying capacities including marking of floor areas, working loads of cranes, lifting gear and lifts, room identification, etc. The routing of underground pipes and cables is to be indicated by substantial marker blocks showing the relevant identification numbers.

In the choice of information signs in situations not covered by ISO Draft Recommendation 507 the possibility of using pictograms should be considered. Pictograms are particularly suitable for the identification of rooms, areas and buildings in the non-technical areas of the Plant, sanitary and amenities buildings, etc.

#### Emergency signs

In the event of accidents, all necessary information should be available immediately to those affected. Thus, a sufficient number of signs of appropriate size should be installed, e.g. escape routes (including marking of floor areas), emergency exits, fire alarms, fire extinguishers, instructions for special fire-extinguishing agents, warnings against fire-extinguishing agents (CO<sub>2</sub>), first aid equipment, first aid points, accident reporting points, telephones, etc.

#### Mandatory signs

Signs indicating obligatory actions must be provided installed wherever certain action is necessary, e.g. do not obstruct the entrance; keep right, etc. Signs should also indicate when the wearing of protective clothing and equipment is necessary and obligatory, e.g., protective goggles, protective clothing, helmets, head guards, breathing equipment, ear muffs, etc.

#### Warning Signs

Warning signs should refer to the existence or possible existence of danger, e.g., flammable substances, explosive substances, corrosive or noxious substances, suspended loads, general danger, width/height restriction, steps, risk of trapping, slipping, falling, etc.

In addition to warning signs, appropriate black-yellow strip markings should also be used where necessary.

#### Equipment and Piping Colour Code

For colour code for all equipment and piping see table below, for any other items Employer's approval shall be obtained. For safety issues relevant standards and regulations shall prevail in case of discrepancy. Final colour selection is to be discussed and approved by Employer.





**Colour Code (based on DIN 2403:2007-05 & DIN 5381)**

| Medium                                                                                                        | Base                                                               | RAL  | Band/<br>Ring | RAL  | Let-<br>tering | RAL  |
|---------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------|------|---------------|------|----------------|------|
| Flammable liquids and solids e.g. high speed diesel, lube oil, seal oil, hydraulic oil, coal                  | Signal Brown                                                       | 8002 | Signal Red    | 3001 | Signal White   | 9003 |
| Flammable gases e.g. hydrogen                                                                                 | Signal Yellow                                                      | 1003 | Signal Red    | 3001 | Signal Black   | 9004 |
| Non-flammable liquids and solids e.g. ash                                                                     | Signal Brown                                                       | 8002 | Signal Black  | 9004 | Signal White   | 9003 |
| Non-flammable gases e.g. nitrogen, carbon dioxide                                                             | Signal Yellow                                                      | 1003 | Signal Black  | 9004 | Signal Black   | 9004 |
| Fire fighting, e.g. fire fighting water                                                                       | Signal Red                                                         | 3001 |               |      | Signal White   | 9003 |
| Water e.g. service, demin., condensate, feed, river, cooling, closed cooling water except fire fighting water | Signal Green                                                       | 6032 |               |      | Signal White   | 9003 |
| Steam e.g. main steam, HRH, CRH, aux. steam                                                                   | Signal Red                                                         | 3001 |               |      | Signal White   | 9003 |
| Acids e.g. HCl, ferrous sulphate                                                                              | Signal Orange                                                      | 2010 |               |      | Signal Black   | 9004 |
| Alkali, e.g. ammonia, caustic                                                                                 | Signal Violet                                                      | 4008 |               |      | Signal White   | 9003 |
| Air e.g. station air, service air, instrument air                                                             | Signal White                                                       | 9003 |               |      | Signal Black   | 9004 |
| Oxygen                                                                                                        | Signal Blue                                                        | 5005 |               |      | Signal White   | 9003 |
| Driven machines (e.g. fans and pumps) including motor, Vents, drains, vacuum                                  | Follow medium color                                                |      |               |      |                |      |
| Structural steel, steel skids for equipment                                                                   | Window Grey RAL 7040                                               |      |               |      |                |      |
| Safety caution, e.g. fall or trip hazards, handrails, head room clearance                                     | Alternating stripes Signal Yellow RAL 1003 / Signal Black RAL 9004 |      |               |      |                |      |
| Panels, cubicles, junction boxes                                                                              | Light Grey RAL 7035                                                |      |               |      |                |      |

8





## B0.6.10 Units of measurement

The Contract shall be conducted in the Systems International d'Units (SI) system of units in accordance with the provisions of ISO 31 and ISO 1000.

In all correspondence, technical schedules, drawings and instrument scales, the following units shall be used:

| Quantity                                 | Name of Unit                                                                                                | Symbol                                                       |
|------------------------------------------|-------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|
| Length                                   | Millimeter                                                                                                  | mm                                                           |
| Mass                                     | Kilogram                                                                                                    | kg                                                           |
| Time                                     | Second                                                                                                      | s                                                            |
| Temperature                              | Degree Celsius                                                                                              | °C                                                           |
| Temperature Difference                   | Kelvin                                                                                                      | K                                                            |
| Electric Current                         | Ampere                                                                                                      | A                                                            |
| Luminous Intensity                       | Candela                                                                                                     | cd                                                           |
| Area                                     | Square meter                                                                                                | m <sup>2</sup>                                               |
| Volume                                   | Cubic meter<br>Liter                                                                                        | m <sup>3</sup><br>l                                          |
| Force                                    | Newton                                                                                                      | N                                                            |
| Pressure                                 | Bar                                                                                                         | bar                                                          |
| Pressure below 1 bar                     | Millibar                                                                                                    | mbar                                                         |
| Stress                                   | Newton per square millimeter                                                                                | N/mm <sup>2</sup>                                            |
| Velocity                                 | Meter per second                                                                                            | m/s                                                          |
| Rotational speed                         | Revolutions per minute                                                                                      | rpm                                                          |
| Flow                                     | Cubic meter per day<br>Cubic meter per hour<br>Kilogram per hour<br>Liter per second<br>metric ton per hour | m <sup>3</sup> /d<br>m <sup>3</sup> /h<br>kg/h<br>l/s<br>t/h |
|                                          | For gaseous substance: standard cubic meter per hour                                                        | Nm <sup>3</sup> /h                                           |
| Density                                  | Kilogram per cubic meter<br>Kilogram per standard cubic meter                                               | kg/m <sup>3</sup><br>kg/Nm <sup>3</sup>                      |
| Torque, moment of force                  | Newton meter                                                                                                | Nm                                                           |
| Moment of inertia (mr <sup>2</sup> )     | Kilogram square meter                                                                                       | kgm <sup>2</sup>                                             |
| Work, energy or heat                     | Joule                                                                                                       | J                                                            |
| Heat capacity, entropy                   | Joule per Kelvin                                                                                            | J/K                                                          |
| Specific heat capacity, specific entropy | Joule per kilogram Kelvin                                                                                   | J/kgK                                                        |
| Calorific value                          | Joule per cubic meter<br>Joule per gram                                                                     | J/m <sup>3</sup><br>J/g                                      |



| Quantity                | Name of Unit                    | Symbol            |
|-------------------------|---------------------------------|-------------------|
| Power, radiant flux     | Watt                            | W                 |
| Heat release rate       | Watt per square meter           | W/m <sup>2</sup>  |
| Thermal conductivity    | Watt per meter Kelvin           | W/mK              |
| Dynamic viscosity       | Newton second per square meter  | Ns/m <sup>2</sup> |
| Kinematic viscosity     | Meter squared per second        | m <sup>2</sup> /s |
| Surface tension         | Newton per meter                | N/m               |
| Concentration           | Parts per million               | ppm               |
| Electrical conductivity | Microsiemens per meter at 25 °C | μS/m              |
| Frequency               | Hertz                           | Hz                |
| Electric charge         | Coulomb                         | C                 |
| Electric potential      | Volt                            | V                 |
| Electric field strength | Volt per meter                  | V/m               |
| Electric capacitance    | Farad                           | F                 |
| Electric resistance     | Ohm                             | Ω                 |
| Conductance             | Siemens                         | S                 |
| Magnetic flux           | Weber                           | Wb                |
| Magnetic flux density   | Tesla                           | T                 |
| Magnetic field strength | Ampere per meter                | A/m               |
| Luminous flux           | Lumen                           | lm                |
| Illuminance             | Lux                             | lx                |
| Thermal resistivity     | Kelvin meter per Watt           | Km/W              |
| Energy                  | Kilowatt hour                   | kWh               |


For the thermodynamic properties of steam and water, "The IAPWS Industrial Formulation 1997 for the Thermodynamic Properties of Water and Steam" or the latest version thereof shall be used.

#### B0.6.11 Ways, stairs, ladders, balustrades

The Contractor shall supply all platforms, galleries and stairways necessary for providing safe and proper access to the Plant for operation and efficient maintenance. The Contractor shall ensure that the type of flooring, stair treads and handrails conform to a uniform pattern throughout the whole Project.

The loads for the design of platforms, galleries etc. shall be in accordance with the Section 'Design Loads' of the special civil part of these specifications.

All platforms, galleries, stairways and hand railing shall be of galvanized steel unless otherwise specified.





All platforms and galleries shall be designed with a minimum headroom clearance of 2200 mm and shall have a minimum width of 1500 mm clear passageway and shall be enclosed by hand-railing on both sides. Ladders are only to be provided as an extra means of escape.

All aspects of platforms, stairways, ladders and other access ways shall comply with the requirements of applicable DIN standards, BNBC or equivalent.

#### B0.6.12 Hazardous areas, fire fighting & prevention systems

##### **Hazardous areas**

The Contractor shall take full account of any special requirements concerning the nature, handling and storage of all fuels, flammable gases and chemicals etc., and provide plant, equipment, buildings and other services accordingly, including all facilities to ensure the safety of the operating and maintenance personnel.

The Contractor shall provide drawings to define all the hazardous zones taking account of all sources of hazards under normal and abnormal operating conditions (regardless of whether or not these areas are specifically listed in the specification). The zoning philosophy shall be subject to the approval of the Employer. All equipment necessary for mounting in these areas shall meet the requirements of BS 5345 or equivalent.

In particular, equipment directly concerned with Plant which may give rise to a hazardous situation shall be designed to IEC 60079 Zone 1 or 2 requirements with electrical connection safety barriers or intrinsically safe equipment equivalent to VDE 0171 Type Exi. Where required by the Employer/Engineer, certification shall be provided to confirm the suitability of the equipment and devices.

The Contractor shall be responsible for ensuring that all electrical equipment installed in any hazardous zone is designed and tested to suit the relevant zone classification and shall be to the approval of the Employer. Cables shall not be laid in trenches etc. with fuel pipe work.

All electrical equipment part of a following system installed in hazardous areas shall be of flame/explosion proof type:

- fuel oil handling systems
- burner operating floors
- turbine lubrication oil tank area
- generator sealing oil tank area
- diesel generator area
- hydrogen bottle house
- others required by the above standards.



000122



All equipment offered for use in the above areas shall have the necessary certification by the appropriate National Certification Bureau and its proposed application shall fully comply with all conditions of the certificate.

At least all electrical equipment part of the systems in hazardous area as stipulated in the specification shall be of flame/explosion proof type. For other systems the approach as described by the Bidder/Contractor can be applicable.

All electrical equipment associated with any part of a system within the following areas shall be of dust explosion proof type:

- station bunker rooms,
- conveyor transfer towers,
- 3 meters radius from coal feeders, pulverizers and the center point of pulverized fuel pipes.

**Fire Fighting & Prevention Systems**  
See Section B12.

**B0.6.13 Maintenance isolation**

All major equipment shall be arranged to facilitate safe isolation from all hazards for maintenance purposes. In addition all valves must be capable of being locked either in the open or closed position by means of a chain and padlock.

Non return valves are not acceptable as a means of isolation.

**B0.6.14 Materials**

**B0.6.14.1 General material requirements**

All materials shall be new and of the best quality for use in the conditions and the variations in river water quality (refer to **Part C Annexes**), the temperature and pressure that will be encountered in service without undue distortion or deterioration or the setting up of undue strains in any part that might affect the efficiency and reliability of the Plant.

All materials shall correspond either to the approved standards and the respective code number or to exact analysis data, and full information concerning properties and applied heat, chemical and mechanical treatment shall be submitted.

Special attention must be paid to eliminating the possibility of corrosion resulting from galvanic effects. Design, selection of materials and all methods of erection shall be such as to keep these effects to a minimum.

St





Materials complying with codes and standards listed below shall be used for the design and construction work.

Unless the materials meet these codes and standards the equivalent ASME/ASTM standard shall be used.

### Materials and standards

|     |    |                                     |                                                                                                       |                                                                                                                       |
|-----|----|-------------------------------------|-------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------|
| (A) | a. | Structural Steel Built-up Members   | DIN EN 10 027-1<br>Formerly DIN 17 100 and EN 10 025                                                  | all steel brands S235 and S355<br>Formerly St. USt & RS137-2, St37-3, St52-3 or Fe360B, BFN, C & D1, and Fe S10       |
|     | b. | Structural Steel Hot Rolled Members | DIN 1024 Series DIN 1025 Series<br>DIN 1026 Series DIN 1027 Series DIN 1028 Series<br>DIN 1029 Series | all steel brands S235 and S355,<br>Formerly St. USt & RS137-2, St37-3 and St52-3, or Fe 360B, BFN, C & D1, and Fe S10 |
|     | c. | Structural Steel Tubes              | DIN EN 10 210-1, 2                                                                                    | S235 and S355                                                                                                         |
|     | d. | Crane rail                          | DIN 4132                                                                                              |                                                                                                                       |
| (B) | a. | Bolts and Anchor Bolts              | DIN ISO 898, DIN 18 800-1                                                                             | 4.6 ( $f_y \geq 240 \text{ N/mm}^2$ ) 5.6 ( $f_y \geq 300 \text{ N/mm}^2$ )                                           |
|     | b. | High Strength Bolts                 | DIN ISO 898, DIN 18 800-1                                                                             | 8.8 ( $f_y \geq 640 \text{ N/mm}^2$ )<br>10.9 ( $f_y \geq 900 \text{ N/mm}^2$ )                                       |
|     | c. | Stud Bolts                          | DIN 32 500, Part 1 & DIN 18 800-1<br>DIN 32 500, Part 3 & DIN 18 800-1                                | 4.8 ( $f_y \geq 320 \text{ N/mm}^2$ )<br>St 37-3 per DIN 17 100, ( $f_y \geq 350 \text{ N/mm}^2$ )                    |
| (C) |    | Electrodes for Arc Welding          | DIN 1913/ DIN EN 499                                                                                  |                                                                                                                       |
| (D) |    | Ordinary Portland Cement            | DIN 1164-1 / 1164-2<br>EN 197-1                                                                       |                                                                                                                       |
| (E) |    | Reinforcing Bars                    | DIN 488-2 / 488-4                                                                                     |                                                                                                                       |

### Material properties and allowable strengths

#### • Concrete steel reinforcement

High yield steel deformed bars, types as per DIN 488-2  
The max. bar length shall be 12 m.



FICHTNER



- **Concrete steel fabric reinforcement**

Reinforcement quality

Wire of grade 500 ( $f_y = 500 \text{ N/mm}^2$ ) as per DIN 488

Welding of reinforcement as per DIN 4099.

- **Fabric types**

Preferred range of designated fabric types: see part 4 of DIN 488.

- **Concrete grade and specified strength**

Concrete for blinding grade C12/15 as per DIN 1045. Min. thickness of blinding = 75 mm.

Concrete for all other structures grade 25/30 as per DIN 1045.

All concrete grade 30/37 or higher as well as special qualities, like waterproofed concrete, have to be mixed in accordance with a special design concept, approved by a third party assessment.

- **Concrete cover to reinforcement bars**

The minimum concrete cover for durability to any reinforcing bar shall be in accordance with ZTV-K, Section 6.

Concrete grade 25/30 as per DIN 1045 are minimum requirements, if not mentioned otherwise.

**Note:**

- a) Cover noted is to the outside bar regardless of whether it is main or secondary reinforcement.
- b) For concrete exposed to brackish water, brine and seawater splashing a special design concept is required.
- c) For water or liquid retaining structures, the cover should be reviewed in conjunction with design, to limit the allowable crack widths. Linings could also need to be applied.

**Structural steel**

DIN 18800 / DIN 18801 / DIN 18807 shall be followed.

For all above mentioned material standards, the equivalent standards as per BS, ASME/ASTM are also accepted.

## B0.6.14.2 Specific requirements for high temp./high pressure part materials

The purpose of this part is to provide the additional requirements for the purchase, manufacturing and fabrication of:

- austenitic stainless steels used for high temperature superheater and reheater tubing,
- ferritic/ martensitic steels used for high temperature pressure parts.





All manufacturers and suppliers of the base metals, from raw materials until finished products, shall be ISO 9001:2000 certified for the duration of the contract or being renewed during the duration of the contract as appropriate.

Only seamless tubes and pipes are acceptable for power piping. For low pressure systems (< 6 bar (g)) welded pipes will be accepted. Welded pipes may be used for sizes above DN500 if the design pressure and design temperature are such that it calls for pressure rating of ASME 300 class or below. The fittings shall correspond to ASTM A234 with Grade corresponding to the pipe material. The welded pipes provided shall be of certified source.

All materials and manufacturing procedures shall be certified by an independent 3<sup>rd</sup> party. The approval shall be part of the quality documentation.

The use of SA213-T24 material for membrane walls is not accepted.

The material SA213-T23 is known for cracking sensitivity. It shall be demonstrated and documented in the final data package that all such materials are free from any cracks and that all hardness values are within the required limits.

For SA213-T23 the Contractor must provide a detailed procedure for the calculation, design, purchase, manufacturing, erection, cleaning and pressure testing of this material. The relevant ASME code cases must be respected.

For SA213 T91 and SA335 P91 the latest stress values and the latest information according to ASME code cases must be used. Also the EPRI „Guidelines and Specifications for High-Reliability Fossil Power Plants Best Practice Guideline for Manufacturing and Construction of Grade 91 Steel Components“ shall be respected.

Bidder/Contractor at his sole discretion may use ASME SA-335, P-92 or approved equivalent material for superheater/reheater headers and interconnecting piping, i.e. for the components which are outside the flue gas path. However, use of T92 material for boiler tubes is not permitted.

In case it is proposed by the Bidder/Contractor to use ASTM-A-335, P-92 or equivalent material, Bidder/Contractor shall furnish a certificate of provenness of the material certifying the usage and satisfactory performance of the proposed material in main steam/hot reheat piping for a reference plant (or applicable unit of reference plant) having rated main steam and/or hot reheat steam temperature at turbine inlet at least equal to or higher than the rated main steam and/or hot reheat steam temperature at turbine inlet envisaged by the Bidder/Contractor. Such reference plant(s) (or unit) should have been executed by the Bidder/Contractor himself or by others and should have been under operation for at least 50,000 hours or 6 years from date of commissioning of the applicable unit (of the reference plant).





Maximum allowable stress values for ASME SA-335: P-92 or approved equivalent material as per code shall be reduced by 10% for calculating the thickness of pressure parts.

For SA335 P92 the Contractor shall provide a detailed procedure for the calculation, design, purchase, manufacturing, erection, cleaning and pressure testing of this material. The relevant ASME code cases must be respected. SA213-T92 may be used for header nipples outside of the flue gas pass, while meeting the above mentioned requirements for quality control.

The details on preheating for welding and PWHT shall be stated in detail. Special consideration shall be given to record the metal temperatures during manufacturing, erection and operation.

In case of any repair of any of such materials at site the 3<sup>rd</sup> party engineer must be involved concerning the proposed repair method.

#### B0.6.15 Pre-service cleaning and protection of plant equipment

This clause covers mechanical and pre-service cleaning and protection of the plant items and equipment at the Manufacturer's workshop and at site that are not subsequently to be painted.

Cleaning of fabricated component items shall be carried out after fabrication and final heat treatment or welding at manufacturers' works or at site, as appropriate.


In the event of the surfaces not being cleaned to the Employer's satisfaction, such parts of the cleaning procedures or agreed alternatives as are deemed necessary to overcome the deficiencies shall be carried out at the Contractor's sole expense.

Mechanical cleaning as opposed to alternative chemical cleaning is the preferred method for workshop cleaning except where this is precluded by design or access considerations.

Machined surfaces shall be protected during the cleaning operations. For recleaning small areas, hand cleaning by wire brushing may be permitted. Wire brushes used on austenitic materials shall have austenitic steel bristles.

Austenitic stainless steels, copper and aluminium alloys, cast iron, bimetallic and metallic/plastic items, and components fabricated by spot welding or riveting shall not be chemically cleaned. All weld areas shall be suitably stress-relieved before chemical cleaning.

At an appropriate time, the Contractor shall submit drawings of temporary pipework necessary to carry out the pre-service cleaning simultaneously with a list of works to be carried out on the pipelines, heaters, feedwater



000127



tanks, vessels etc. to connect the temporary pipework with the parts of equipment to be cleaned.

Further, the Contractor shall submit at the same time the basic draft of the cleaning procedure and of the treatment of wastes.

Not less than six months prior to the commencement of any site cleaning, the Contractor has to submit programs covering all procedures, lists of chemicals, calculations which quote the velocities, temperatures hand-pipework forces and movements imposed during site cleaning.

All necessary equipment, provisions, chemicals etc. are to be provided by the Contractor.

All tests, analyses, etc. as required are to be performed by the Contractor.

Besides this, the Contractor shall take over all responsibility for the treatment and disposal of wastes according to the local law and to the satisfaction of the Employer.

The date at which cleaning of plant equipment will be carried out at site shall be notified to the Employer at least 20 days in advance.

The Contractor shall take all necessary precautions to ensure that the internal surfaces of all plant are kept clean and free from injurious matter during erection.

When all plant has been erected and lagged or at such other time as may be agreed with the Employer for sub-assemblies, the installation shall undergo a procedure for site cleaning proposed by the Contractor and subject to the approval of the Employer.

#### B0.6.16 Welding

All pressure part welding must follow the requirements of ASME and connected standards.

Welding work and related heat treatment as well as inspections and test shall be performed in accordance with the specific and approved welding procedure specifications (WPS) and the respective material specifications.

WPS shall be prepared in accordance with relevant ASME standards, endorsed by 3<sup>rd</sup> party / inspector and submitted to the Employer.

Welding plans have to be prepared by every manufacturer for his scope of work.

No welding shall be undertaken until the applicable WPS and Procedure Qualification Record (PQR) are approved by the Employer.





The PQR shall be qualified in accordance with relevant ASME standard. Welding procedures must be qualified by a qualified independent testing authority engaged by the manufacturer.

Welding procedures shall be qualified in accordance with the requirements of the construction code/specification for the Item of plant concerned and in the case of critical plant items the tests shall be witnessed by an internationally recognized inspection authority.

Welders shall be qualified in accordance with the requirements of the construction code/specification for the Item of plant concerned for all types/positions of welding he may perform.

Welder tests shall be carried out in accordance with the approved standards within Contractor's scope. Test results are available for review in the work-shops.

If at any time in the opinion of the Employer the work of any welder appears questionable, such welder is required to pass additional qualification tests to determine his ability to perform the type of work on which he is engaged. Any welder failing the retest may, at the discretion of the Employer be disqualified from further welding on items under this Contract.

The 2 first production welds of every welder shall be 100% examined by volumetric NDE and only when the results are acceptable, shall the welder be released for production welding.

A system of positively identifying the work of each welder shall be maintained and any welder whose work is the subject of multiple rejections shall be required to undergo a requalification test. Any welder failing the retest may, at the discretion of the Employer's Representative be disqualified from further welding on items under this contract.

Welded fabrications shall be stress relieved when specified by the applicable standard or for dimensional stabilization prior to machining.

Copies of temperature charts referenced with load items shall be included in the test certification supplied for the relevant items.

All welds shall be visually examined and shall be of smooth contour, free from cracks, undercut and other significant defects. Wherever possible the interior of tubes etc. shall be examined using a suitable optical device where necessary. The manufacturer shall make every effort to avoid any contamination of the tube interior during the manufacturing process. To ensure the tubes are free from obstruction and debris the tubes shall be cleared with a sponge being blown through.





Fillet welds shall be checked for size using suitable gauges which shall be available for use on request by the Employer's Representative during an inspection visit.

For single side butt welds, all root passes shall be welded using a TIG welding process.

Preheating shall be in accordance with the applicable WPS and the respective material specification. The preheat temperature shall be in function of welding process, wall thickness, type of welding consumables, ambient temperature and climatic conditions

Welding performed outside a workshop is authorised if an approved wind and rain protection (welding bay) is installed around the working place. Anyway, when ambient temperatures falls below 5°C, preheat is required for all ferritic materials and thicknesses. Gas burners or oxy-fuel torches can be used for pre-heating. Preheat shall be maintained over a distance of not less than 4 times the nominal thickness with a minimum of 75mm on either side of the weld. If the material required pre-heating, the same pre-heating shall be done for oxy-fuel or plasma cutting.

Welding consumables such as TIG-rods, electrodes, wires shall be clearly marked in order to avoid any mix-up of material grades. Positive Material Identification to be carried out on where a doubt for mix-up exists.

Any post welding heat treatment (PWHT) shall be performed in accordance with an approved procedure. The procedure shall describe the method, the heat treatment parameters (e.g. holding temperature and time, heating/cooling rates, heated/insulated band...), the number and location of thermocouples, records and calibration. The procedure shall be available on Site and or in the workshops.


Before welding and/or heat treating valves, valve-manufacturer instructions shall be taken into consideration.

In the case of sensitive materials, grinding of the welds or other grinding work may only be carried out with special grinding wheels so as to avoid overheating or an increase in the hardness of the material.

Welding defects of all kinds must be documented and be available to the Employer on Site or in the workshop.

The Contractor maintains and makes available to the Employer or his representative, both at works and Site, adequately indexed records of all welds, weld inspections, weld controls and repair.

Please refer also to Section B0 for "Manufacturing tests".





Additional welding requirements for welding of civil steel structures are stated under **Section B9**.

## B0.6.17 Mechanical equipment

### B0.6.17.1 Pumps

#### General

All pumps shall be designed for continuous operation unless otherwise specified.

Pumps shall be installed in positions convenient for operation and servicing. Where multiple pump installations are required, each pump and its associated equipment shall be arranged in such a manner as to permit easy access for operation, maintenance and pump removal without interrupting plant operation.

Pumps installed for parallel operation or as stand-by sets are to be of identical design, i.e. interchangeable.

Lifting lugs and eyes and other special tackle shall be provided as necessary to permit easy handling of the pump and its components.

#### General design and construction


All pumps shall be designed to withstand a test pressure of 1.5 times the maximum possible pump shutoff pressure under maximum suction pressure conditions. If a pump can operate at sub-atmospheric suction conditions, the entire pump shall be designed for full vacuum.

All pump shafts shall be of ample size to transmit the maximum possible output from the prime mover. The pump shaft and coupling are to be so dimensioned that the maximum permissible torque of the shaft is higher than the maximum transmissible torque of the coupling. Directly coupled pumps shall be used preferably.

Renewable wear rings shall be provided at points of running clearance and shall be made from appropriate materials.

All pumps and accessories in contact with the pumped fluid shall be constructed of materials specifically designed for the conditions and nature of the pumped fluid, and be resistant to erosion and corrosion.

Product water flushing lines and drains are to be supplied for each pump handling the prevailing river water to avoid corrosion if the pump is out of operation for extended periods.





The pump glands or mechanical seals shall be so arranged that repackaging or fitting of replacement seals can be carried out with the minimum of disruption to plant operation. In case of operating under vacuum conditions liquid sealing is to be provided.

The pump casing shall preferably be split for ease of maintenance and be designed such that the impeller and shaft are capable of being withdrawn from the casing without disturbing any of the main pipework and valves carrying the pumped fluid. In general, all horizontal pumps with draw-out-rotors are to be fitted with a coupling to facilitate disassembly without removing the motor. Pull-out design of the shaft shall be applied to vertical wet pit and dry pit pumps as well.

Each horizontal pump shall be mounted with its drive on a common base plate of rigid construction. Vertical pumps are to be provided with foundation frames. In case of submersible pumps suitable frames shall be provided in the pump sump. It shall however be possible to remove these pumps without entering the sump.


Pumps must be carefully set to ensure that the net positive suction head available under all operating conditions will be adequate for the type of pump employed. The NPSH values are to be referred to the least favourable operating conditions - lowest atmospheric pressure, lowest level of water on the suction side of the pump, and highest temperature of the pumped fluid. An adequate safety margin of normally greater than 1 m to the max NPSH required shall be provided unless and otherwise specified for specific pump. Pumps shall operate smoothly throughout the speed range up to their operating speeds. The first coupled critical speed must be at least 20% higher than the maximum operating speed. The determination of the shaft diameter and the distance between two consecutive bearings must include a sufficiently large safety margin to satisfy this condition.

Where necessary, the pumps are to be fitted with devices to ensure a minimum throughput.

### Bearings

For large pumps the bearings shall be of automatic oil lubricated sleeve type, unless otherwise specified. Bearings on vertical shaft pumps shall be so spaced to prevent shaft whipping or vibration under any mode of operation. Vibration sensors and temperature measurements incl. temperature transmitters for continuous monitoring shall be provided for large pumps.

Bearings housings on horizontal shaft pumps shall be designed to enable the bearings to be replaced without removing the pump or motor from its mounting. Bearing housings on horizontal shaft pumps shall be effectively protected against the ingress of water, pumped fluid and dust by suitable nonferrous deflectors.





All bearing oil wells shall be fitted with visual oil level indicators. Non-pressure-oil lubricated bearings shall be equipped with constant level oilers.

#### **Pumps characteristics**

When several pumps are installed for the same service, they shall be suitable for unrestricted parallel operation.

The pump flow/head characteristics shall be such that within the operation range the head will continuously increase with decreasing flow, maximum head (shut off head) being at least 10% higher than the duty point head.

Unless otherwise specified all pumps shall be capable of operating at 110% of the rated capacity at the rated delivery head. Maximum size impellers for the pump body in question shall not be quoted for. By installation of a new impeller a head increase of 5% minimum shall be possible. The performance of the drive motor is to be determined according to the above mentioned technical requirements and to the requirements as specified in the electrical part.

#### **Fittings**

All pumps shall be installed with isolating valves, a non-return valve and suction and discharge pressure gauges unless otherwise stated. Accessible couplings shall be supplied with removable type guards. Coupling halves shall be machine matched to ensure accurate alignment. Couplings as well as gears must have a rated capacity of at least 120% of the maximum potential power transmission requirement. All pumps other than submersible pumps shall have temporary strainers fitted in the suction pipework during all initial running and commissioning phases. Permanent strainers shall be provided where specified.

Venting valves shall be fitted to all pumps at suitable points on the pump casing unless the pump is self-venting, due to the arrangement of the suction and discharge nozzles. Drainage facilities shall be provided on the pump casing or adjacent pipework to facilitate the dismantling of pumps.


All positive displacement pumps shall be fitted with a discharge relief valve capable of passing the maximum pump delivery flow.

### **B0.6.17.2 Piping and accessories**

#### **Design criteria**

The pipework shall be designed, fabricated, erected, inspected and tested on the basis of the applicable standards and codes, and the additional requirements as set out below.

For the plant water and cooling water system GRP is preferred, Bona-Pipe and coated carbon steel is acceptable. For saline water and the water treatment systems LPP piping will be accepted also. If a carbon steel system is offered, a cathodic protection system shall be employed for inside and





outside. For steel underground piping where cathodic protection is not feasible coal tar epoxy coating shall be applied. For painting and coating see chapter painting specification. A sufficient corrosion allowance shall be considered.


Plant water and cooling water piping system: If these pipes are buried cathodic protection system shall be employed for inside and outside. Further communicating lines (from above ground to underground and vice versa) will have to be provided with respective insulation joints. In any case protection against corrosion must be provided. GRP or other appropriate material is required.

Screening channel in the plant water pumping station as well as other equipment installed in pumping stations: In case all piping of mild steel is used require cathodic protection.

GRP piping shall be laid under the responsibility and supervision of the GRP pipe manufacturer.

The maximum flow velocities for the individual media must not be exceeded at maximum throughput (unless expressly specified in the documents or proven by the Contractor):

| Type of Pipework                                                              | Max. Velocity |
|-------------------------------------------------------------------------------|---------------|
| <b>Steam lines:</b>                                                           |               |
| High-pressure live steam lines ( $PN \geq 63$ )                               | 60 m/s        |
| HP / LP turbine bypass lines                                                  | 100 m/s       |
| Intermediate-pressure steam lines ( $PN 25/40$ )                              | 40 m/s        |
| Low-pressure steam lines above 5 bar                                          | 35 m/s        |
| Low-pressure steam lines < 5 bar                                              | 25 m/s        |
| Vacuum lines                                                                  | 80 m/s        |
| Saturated steam lines                                                         | 20 m/s        |
| BFP drive turbine exhaust                                                     | 80 m/s        |
| <b>Water lines (Feedwater, Plant water / cooling water, condensate etc.):</b> |               |
| Feedwater suction lines                                                       | 0.5-2.5 m/s** |
| Feedwater discharge lines                                                     | 3-5 m/s       |
| Other suction lines                                                           | 1.5 m/s       |
| Other discharge lines                                                         | 3.0 m/s       |
| River water lines                                                             | 3.0 m/s       |
| Fuel lines                                                                    |               |
| Fuel oil / LDO suction lines                                                  |               |



00013000134



| Type of Pipework         | Max. Velocity |
|--------------------------|---------------|
| Fuel oil / LDO discharge | 2.0 m/s       |
| Air Lines:               |               |
| Compressed air lines     | 15.0 m/s      |
| Combustion air lines     | 20 m/s        |
| flue gas lines           | 18 m/s        |

\*\* The design and routing of the feedwater suction lines must be optimized considering the allowable velocity of depressurization caused by load changes.

The maximum velocity for the LP extraction shall not exceed 60 m/s. For those media/systems where no maximum velocity is given in the specification, the maximum velocity shall be proposed by the Contractor and is subject to approval by BIFPCL during the basic/detailed engineering.

In addition pressure drop criteria shall govern the sizing of the key lines.

Nominal diameters (DN), nominal pressure (PN) and wall thicknesses shall be standardized.

Nominal diameters of < DN 25 shall not be used for pipe lines except for instrument lines, chemical dosing and analysis lines.

For the design of safety valves installed downstream of reducing stations, high pressure bypass valves or equivalent control valves, the maximum throughput of the fully open reducing or bypass valve including injection water quantity is to be taken as the basis for calculation. All cross Sections and lines for safety devices that protect against excess pressure (safety valves, rupture discs and similar items) must be designed to ensure the necessary blow-off rate and fault free functioning.

The design pressure is equal to the response pressure of the devices protecting the piping. In the case of pump discharge lines a pressure corresponding to 1.1 times of the shut-off head of the pump at the ambient temperature is to be taken as the minimum design pressure. The plant water and cooling water systems must be designed according to the water hammer calculation.

The design temperature is the highest possible fluid temperature occurring in the length of line concerned. Possible tolerances of the temperature control system and any temperature allowances provided by the requirements of the standards shall be considered.

For live steam lines the design pressure of the boiler shall be taken as the design pressure of these lines up to the inlet of the turbine main stop valves. In addition to the required wall thickness in accordance with calculations, a corrosion allowance of 3 mm shall be added for unprotected carbon steel, 1.5 mm for alloy steel and 0.5 mm by stainless steel.





For the cold reheat piping downstream of the connection to the HP bypass exhaust, the selection of the design temperature shall also consider the case that the HP bypass station is operated for limited period without spray injection. The Contractor shall prove both operating cases: Operation of HP bypass with spray attemperation and without spray attemperation (limited time period). Both cases shall not lead to any damage to the cold reheat piping and downstream pressure part.

For the piping systems with a nominal pressure specified as  $PN > 40$  as in DIN 2401 or equivalent and for vacuum systems, the drainage and ventilation facilities shall be fitted with double valves.

All vents, drains or dump points with more than 10 bar/100 °C operating pressure/temperature shall lead to the flash tanks and into funnels at visible points with covers.

#### **Guidelines for the design and construction of pipework and accessories**

- Design and construction of all parts of the power piping shall be according ASME B31.1 (Power Piping).
- Other piping and accessories should correspond to the present state of the art and shall be based on the latest standards and medium properties.
- The pipework and its accessories shall be designed and arranged so that all parts subject to operation and maintenance can be operated, inspected, maintained and replaced without difficulty and with a minimum of effort. All important parts must be accessible.
- Provisions to allow for isolation and for access must be foreseen on all parts subject to acceptance by the local authorities.
- None of the forces and moments transmitted by the pipes to connected machines, apparatus and other components must exceed the maximum permissible values, given by the manufacturers of these items. Attachments to turbine foundations shall be carried out only as agreed with the turbine manufacturer.
- All steam traps shall be provided with a bypass and lines which open to a funnel.
- As far as expansion joints and other parts of pipework are concerned it shall be borne in mind that differential settlement can occur. The reaction forces and moments of the piping system to be withstood by fixed points, walls, foundations and other civil structures shall be reduced to the utmost minimum by suitable means (e.g. expansion joints shall be provided where required).
- The pipe support structures shall be designed to minimize heat transfer.
- The installed pipework with its supports and other components shall not obstruct gangways (min. 1500 mm wide), maintenance, escape routes etc. Overhead piping shall have a minimum vertical clearance of 2.3 meters, 8 meters above main access roads and 6 meters above any other roadways.
- Pipe spools for HP steam, feedwater piping and all steel pipes  $\geq DN 400$  shall be cleaned internally prior to delivery by shot blasting at the



000136



workshop with iron particles to SA2 1/2 or by acid cleaning, and shall be properly protected against corrosion.

- Pipe ends and branch connections of underground piping shall be sealed temporarily during installation if the connecting pipe is not immediately installed.
- The Contractor shall submit a detailed description of proposed steam blowing and other cleaning procedures for all pipelines, and no part of this work shall be started until these procedures have been approved by the Employer. Temporary silencers shall be provided for this.
- The cleaning of water - steam system shall comply to VGB R513e „Internal Cleaning of Water-Tube Steam Generating Plants and Associated Pipework“
- The Employer reserves the right to require the Contractor to modify any of his cleaning procedures if found necessary to obtain acceptable results. The Contractor shall furnish, install and dismantle all temporary pipes, hangers, anchors, etc. required for cleaning all piping systems.
- To the extent that hot fluids can accumulate in pipe Sections isolated for maintenance purposes (including control valves with injection water), drains with hand-operated shut-off valves are to be provided for the safety of the personnel (block and bleed systems). Furthermore the Contractor shall safeguard the piping systems against over-pressurization caused by thermal expansion of blocked-in fluids by adequate means.

#### Welding

- All welding shall be carried out according to relevant standards. The welding procedures of the Contractor shall be supplied before execution of welding works to the Employer for approval. For quality reasons as many welds as possible are to be carried out in the workshop.
- Welding ends of all piping must be carefully prepared before welding. The type of butt welding ends of valves, control devices, orifices, etc. shall be specified by the Contractor and must be given to the manufacturers of these components in due time prior to their start of work if necessary/postweld heating treatment. If there are differences in the wall thickness and/or different materials of piping and valves with butt-welding ends, the necessary transition pieces must be provided by the manufacturer of the valves.
- Socket welds are not permitted for lines above DN 50, for corrosive media lines or for lubricating oil lines.
- After completion of the weld joint, the welder must mark with indelible crayon his identity number and the last two digits of the year in which the work was completed on the pipes. The Contractor shall keep a record of welders.
- Testing of piping and welding shall be as per ASME standard. Minimum requirements for testing of welds are specified in Section B0.7.2.

#### Welding tests.



000138

B0-124

000137



### Piping

- The Contractor shall provide suitable thimbles and flashing where pipelines pass through floors and walls. Floor thimbles shall be installed to provide 90 mm projection above the finished floor surface.
- A stress analysis shall be performed for all piping systems  $DN \geq 50$  with an operating temperature  $\geq 100^\circ C$ .
- For cross country low pressure piping with a straight length of more than 200 m a stress analysis shall also be conducted.
- The piping stress and flexibility analysis shall be based on the relevant standards. Recalculation must be taken into consideration as built condition, actual weight and dimensions.
- Tubes, pipes, bends and fittings shall be produced and tested in accordance with the applicable international standards (ASME/ASTM, EN, etc.).
- All pipe lengths under this package, including piping where alloy steel is used shall be subjected to 100 % ultrasonic examination as per material specification standard with acceptable notch depth of 5% of the selected wall thickness (1.5mm maximum) except for the following piping system: LP piping not under "ASME B31.1 Power Piping" for not dangerous and not explosive media.

### Noise abatement measures

The Contractor shall take all necessary measures to limit noise in accordance with the requirements. On no account shall the sound level exceed the values as mentioned under the relevant subsection.

If this requirement cannot be met by adequate construction of the pipework and valves concerned, sound absorbing housing or insulation have to be provided. Where pipework and valves are installed outdoors, the above mentioned requirement may be fulfilled, if necessary, by providing silencers at the safety valve outlets and at the blowing out lines.

### Pipe supporting elements

As used herein, the term "hangers and supports" shall include all hanger assemblies, support assemblies, constant support hangers, anchors, guides, sway braces, vibration dampers, trays, brackets, attachments, miscellaneous structural steel and other items required to support the piping in a proper manner.

For supporting points up to 25% variation and 40 mm movement variable spring supports shall be selected.

Constant support type spring assemblies shall be provided at all locations where it is necessary to avoid transfer of stress from that support to another support or to an equipment terminal, and at other support locations where vertical movements of the piping are too large to be properly handled by variable support springs. Constant support spring assemblies shall be of a design that will compensate for the normal variation in the supporting force of the helical coil springs, thus providing constant supporting force through-





out a total travel range which shall be at least 20 mm greater than the actual maximum movement of the piping.

Constant support assemblies shall be equipped with a means of locking the spring(s) against movement during erection, hydrostatic testing etc. The use of counterweights in substitution for support spring assemblies will not be permitted.

Support spring assemblies shall be of the enclosed spring type, and shall have an embossed on factory load indication scale showing the hot (operating) and cold (ambient) positions. Each spring assembly shall incorporate an adjustable hanger rod coupling to permit load adjustment. All support springs shall be designed to permit at least  $\pm 10\%$  field load deviation from the factory calibrated load.

The supporting force provided by variable support type spring assemblies shall not change by more than 20% between the cold and hot positions, and supports of this type shall not be used at any point where such a change in supporting force cannot be safely permitted. Variable support spring assemblies shall incorporate springs with maximum working range length in order to reduce the overall length of the assembly.

All pipe hangers and support stands shall be attached to the piping and structural supports such that they will be vertical when the piping is at hot operating condition. So far as practicable, hangers and supports shall be of the same type and component assembly.

All hangers shall be carefully adjusted. After Plant start-up checks shall confirm that all hangers and supports are in the correct position.

The Contractor shall prepare a complete documentation of all pipe hangers and supporting elements. These documents shall contain the following information:

- loads, forces and moments, and their directions at all supports, hangers at normal operating conditions, etc.
- magnitude and directions of the movements at the loading points
- measurements of the loading points referred to the axes of the buildings
- item No. of the supports, hangers etc. according to the piping group
- material specification for the supporting parts.

#### Trace heating

Trace heating shall be provided for fuel oil pipes and other pipes as required. Electric type trace heating is preferred. The referenced Site Conditions as well as media properties shall be base for the design.

#### Protection of buried pipework systems

All buried pipework of steel or cast iron or other materials prone to corrosion shall be protected from corrosion by cathodic protection.





The design of the cathodic protection system(s) shall be executed by a specialist and authorized company. The designed cathodic protection shall be a completely functioning system in all respects according to the state of the art and shall also include the appropriate equipment for measurements.

For the plant water and cooling water piping system only: If these pipes are buried cathodic protection system shall be employed for inside and outside. Further communicating lines (from above ground to underground and vice versa) will have to be provided with respective insulation joints. In any case protection against corrosion must be provided. GRP or other appropriate material is required.

### B0.6.17.3 Valves, steam traps, condensate drainers, safety valves

The Contractor shall design and supply all valves and their accessories required for the safe, efficient and sound operation and maintenance of the Plant based on the appropriate standards. They shall comply as a minimum with the design criteria of the relevant piping.

For reasons of Plant standardization, the Contractor shall co-ordinate types and makes of all valves in his supply and that of his sub-suppliers.

Design, construction, fabrication and testing of the valves shall be in accordance with the ASME B16.34. The stipulations of this Section will take precedence if these are more stringent than the approved standards.

All valves shall be suitable for the media and for the service conditions and those performing similar duties shall be interchangeable.

Acceptance certificates for valves shall follow EN 10204 or approved equivalent codes.

The following types of valves are recommended:

- globe valves up to and including DN 50
- gate valves DN 65 and above
- butterfly valves DN 400 and above as metal seated type for LP steam and exhaust steam (DN 65 and above as soft seated type for waterlines (cooling water, process water etc., operating temp. max. 180 °C)
- lift check valves up to and including DN 50
- swing check valves DN 65 and above
- Ball valves DN 25 and above (fuel oil, natural gas, compressed air)





DN means 'diameter nominal'.

In vacuum service and wherever otherwise necessary to prevent the entry of air, valves shall be provided with suitable sealing facilities. Where applicable, the valves must be suitable for outdoor installation under consideration of the special climatic and environmental conditions of the site.

Unless otherwise agreed, all valves shall be fitted with the spindle in upright position.

All valves shall be positioned so as to be readily accessible for operation and maintenance from permanent floors, catwalks or platforms. Where required, valve spindles shall be lengthened to have the hand-wheel at a height approximately 1 meter above the operation level. All underground valves shall be installed in concrete culverts.

All valves shall be closed in a clockwise direction when looking at the face of the handwheel. The valves shall have rising spindles and non rising handwheels. Plastic valve handwheels will not be accepted.

HP- and large size gate valves to be opened under differential pressure shall be equipped with pressure equalizing valves (globe valves).

All valves shall be fitted with indicators to determine the valve position. In the case of valves fitted with extended spindles, indicators shall be fitted both to the extended spindle and to the valve spindle.

All globe valves shall be equipped with throttling cones with parabolic characteristic.

In general, LP safety valves, butterfly valves, ball valves and orifices as well as all control valves shall be flanged. All valves including valves as mentioned above for steam, feedwater and condensate, HP safety valves (inlet side) shall have welded ends, corresponding to the connected pipes. Also all valves on heater drains and vents and in vacuum systems shall be welded.

Design of valves and materials used must comply with the relevant standards. They must be chosen in accordance with the requirements to be met and to corresponding pipework.

For limiting handwheel forces, for control and operation purposes it may be necessary to install gears and drives.

The maximum handwheel force of 500 N must not be exceeded.

The Contractor shall furnish and install steam traps at each low point. Each steam trap installation shall include a permanent strainer of 20 x 20 mesh



000141



size, upstream and downstream globe valves and a globe valve as free drain. Steam traps shall be supplied with weld ends. Steam traps shall preferably be of the thermodynamic, thermostatic or bimetallic type with multistage nozzles and selected to suit the service conditions.

Traps which incorporate internal screens or check valves will also be accepted.

Each trap shall be sized to provide ample capacity at the minimum working differential pressure, and to open the orifice at maximum working differential pressure.

Condensate drainers such as used on LP saturated steam or compressed air lines shall be of the ball-float type.

HP gate valves shall be equipped with self sealing lid covers. The self-sealing lid covers shall be equipped with a safety device at the body with shut-off valve and interlocking system. This system must be approved by the authorities.

All valves of the HP/IP piping systems shall be suitable for pickling/acid cleaning (special temporary inserts).

The valves for live steam, HP feedwater and HP injection water shall be made of forged steel. Forged steel or cast steel bodies shall be used for the remaining systems. Valves made of gray cast iron are not acceptable.

Acceptance certificates for piping components and valves shall follow EN 10204.

At the economizer inlet a non-return valve shall be installed, but not shut-off valve.

#### **Technical requirements of Butterfly Valve:**

Applicable standard:

- ASME B16.10 2009 Face-to-Face and End-to-End Dimensions Valves
- ASME B16.34 2009 Valves - Flanged, Threaded, and Welding End
- ASME B31.1 2012 Power Piping
- API 609 2009 Butterfly Valves: Double Flanged, Lug- and Wafer-Type
- API 609 2009 Butterfly Valves: Double Flanged, Lug- and Wafer-Type
- ISO 5752 1982 Metal valves for use in flanged pipe systems - face to face and centre to face dimensions
- ISO 80000-1 2009 Quantities and units
- EN 10204 2004 Materials Testing Certificates

Valves assemblies shall be designed for the pressure and temperature ratings of the class specified in the Piping Material Classes and Valve List.





Hydrostatic testing for valves shall be in accordance with ASME B16.34 and API 598.

Carbon steel having carbon contents of more than 0.25% shall not be used in Welded construction valves.

Lug type valves shall not be used.

Valve stem packing, trim and bonnet gasket material shall be manufacturer's standards, unless otherwise specified.

The maximum force requested at the hand wheel shall not exceed 300N (30kgf).

The manually operated valves in the sizes and pressure classes shall be provided with a gear operator as minimum.

- Class Butterfly
- 150 DN 200 & larger
- 300 DN 150 & larger

Gear operator type: Worm-gear type

All valve actuators shall have local indicators fitted to show whether the valves are in an open or shut position. Where extended spindles are used, indicators shall be fitted to both the extended spindle and to the valve spindle.

Plastic or bakelite valve hand-wheels are not permitted.

The stops limiting the travel of any valve in the "open" or "shut" position shall be arranged externally to the valve body.

All valves shall be closed by turning the hand-wheel in the clockwise direction when looking on top of the hand-wheel.

The face of each hand-wheel shall be clearly marked with the words "open" and "shut" in English, with adjacent arrows to indicate the direction of rotation to which each refers.

Each valve hand-wheel shall be fitted with a name-plate of an approved material, indicating in English the valve reference number and function. The name-plate shall incorporate the colour code corresponding to the particular service of the piping.

*JS*



*JS*

*JS*



#### B0.6.17.4 Thermal insulation

##### General

The thermal insulation shall be designed and installed in accordance with AGI, VDI and DIN or equivalent standards, considering the following minimum requirements:

Insulation shall be provided for personnel protection, heat conservation, noise reduction and for prevention of the formation of condensation on all pipework and equipment whose external surface temperature exceeds 60 °C.

For personnel protection all surfaces with a temperature above 50 °C and which are within the reach of personnel shall be provided with protection insulation and the maximum insulation surface temperature shall be 60 °C.

- All insulation material has to be made from non-asbestos materials.

Following design criteria for insulation shall apply: Design ambient temperature:

- Inside buildings: Ambient temperature of 40°C and wind speed of 0.5 m/s
- Outside buildings: Ambient temperature of 45°C and wind speed of 0.25 m/s

Thickness of the insulation shall be calculated according to ASTM C-680. The Emissivity of the cladding shall be 0.2.

##### Type of insulation materials

The mats shall be stable in shape, chemically inert, free of sulfur and alkali, resistant to water and steam, non-flammable and capable of withstanding continuous exposure to the pipe design temperature. The mats used for insulation of stainless steel equipment shall have a chloride content of less than 0.15%. Under no circumstances may asbestos or asbestos containing materials be used.

The material will have the following physical/chemical properties (± 10% allowance):

- service temperature up to 650 °C
- density 120 kg/m<sup>3</sup>
- water adsorption 0.5% weight
- specific heat capacity 0.84 kJ/kg °C
- compressive strength 20 kPa
- conductivity versus temperature:

Average temperature

Blanket (W/m °C)

|     |       |
|-----|-------|
| 0   | 0.034 |
| 50  | 0.040 |
| 100 | 0.048 |



000144



| Average temperature | Blanket (W/m °C) |
|---------------------|------------------|
| 150                 | 0.058            |
| 200                 | 0.070            |
| 250                 | 0.083            |
| 300                 | 0.100            |

For temperatures above 300°C the conductivity required shall be determined by linearly extrapolation of the values presented in the above table.

- conductivity allowance is limited to + 5%.

For special purposes such as for turbines, boilers, etc. spray type insulation or insulation brickwork (for example calcium silicate) may also be applied. The special insulation materials shall be stated by the Contractor and their design shall match the overall design and guarantee the requirements stated in the specifications.

#### Type of insulation setting materials

The surface cladding shall be made of aluminium sheets, manufactured in sheets with the following minimum thickness:

- Outer insulation diameter up to 150 mm Sheet thickness 0.7 mm
- Outer insulation diameter up to 450 mm Sheet thickness 0.9 mm
- Tanks and other large equipment Sheet thickness 1.2 mm

Tank tops shall be provided with insulation strong enough to support a man's weight.

The sheets shall be secured and connected at the longitudinal seams with at least five stainless steel self-tapping screws per meter run.

Plain sheets for flat surfaces shall not exceed 1 meter square and shall be stiffened by crimping.

At the longitudinal and circumferential joints, the sheets shall overlap by at least 50 mm so as to drain off the liquid and not to trap the liquid in the insulation.

Places at which the metal sheets are penetrated for pipe hangers, thermometer sockets, etc. shall be sealed with funnel-shaped recesses of sheet metal rims.

The seams and penetrations of any sheet metal insulating jacket installed outdoors as well as in the boiler and turbine house in areas with risk of water spray etc., shall be sealed against penetration of water by means of a suitable silicon based sealant.





In the case of pipe insulation thicknesses greater than 60 mm, where insulation blankets are used spacers shall be provided at maximum intervals of 950 mm to ensure a uniform insulating thickness on all sides and a perfectly circular shape of the sheet metal jacket. The sheet metal jacket shall be supported by support webs (for pipe diameters below 100 mm) and enclosed support rings (for pipe diameters 100 mm and above). If the enclosed support rings are not provided with ceramic spacers, the spacers made of steel shall be insulated with one heat insulation strip in the case of operating temperatures of up to 200 °C, and with two heat insulation strips where the operating temperature exceeds 200 °C.

To provide protection against contact corrosion, the external circumference of the support ring shall be fitted with heat insulation tape 1 mm thick with two woven edges.

#### **Insulation of flanges, valves and fittings**

All flanges, valves and fittings shall be provided with two-piece or multi-part caps made of aluminium sheet of the specified thickness. Each piece or part shall be double jacketed and the various parts shall be held together by quick release clamps or lever hooks to facilitate assembly and disassembly:

All caps of the welded-in fittings shall be made longer by approximately twice the insulation thickness so that the welding seams will be exposed after removal of the cap.

All manholes shall be provided with heavy duty hinged covers which are to be protected from overheating and corrosion. Such covers shall be secured with easily accessible clamps. In addition, metallic stand-offs shall be provided for personnel protection.

#### **Insulation of tanks and process equipment**

Tanks and process equipment shall be insulated in the same way as pipes, except that the insulating material shall not be attached by wire but by using strong galvanized steel bands.

Spacers shall be welded to process equipment only if this is essential for satisfactory retention of the insulation. Welding of spacers to process equipment is subject to approval by its manufacturer in writing.

#### **Insulation for personnel protection**

Wherever insulation is necessary only for the protection of personnel, it shall be applied around that portion of the pipeline length or to that surface of the equipment that is located within 2.50 m above the passage way floor, or within 1.20 m horizontally to the side or at the end of any floor, platform, walkway, stair or ladder.

Where necessary, drain lines and valves shall be provided with a contact guard of minimum 30 mm thickness against accidental contact, and this shall be installed in the same way as the other insulation.





Where insulation is provided for heat conservation it shall reduce the heat loss to an economic minimum. The maximum heat loss shall be  $200 \text{ W/m}^2$  at an ambient temperature acceptable at  $30^\circ\text{C}$  and a wind speed of  $2 \text{ m/s}$ . For personnel protection all surfaces with a temperature above  $50^\circ\text{C}$  and which are within the reach of personnel shall be provided with protection insulation. The maximum insulation surface temperature shall be  $60^\circ\text{C}$ .

#### B0.6.17.5 Vessels

All vessels shall be designed in accordance with the applicable standards and regulations.

The Contractor is held responsible for the correct design and dimensioning of the apparatus.

Connections shall be provided for all pipework, together with connection and tapping points for instrumentation. Manholes, vents, drains, safety devices and any platforms necessary for safe operation and easy maintenance have to be included in design and supply.

If under any operation conditions vacuum can occur in the vessels, they shall be designed for max. pressure and full (= 100%) vacuum.

The welding factor for all vessels is fixed to  $v = 1.0$ . The minimum wall thickness should not be less than  $10 \text{ mm}$ , and an appropriate corrosion allowance based upon the particular material, but not less than  $1 \text{ mm}$ .

Instrumentation and control equipment shall be provided according to the safe service requirements. A minimum requirement is to equip each vessel with a local level indicator, a temperature and a pressure indicator.

Manholes shall be provided as follows:

1. manholes (minimum nominal bore  $600 \text{ mm}$ ) for vessels of  $1.0 \text{ meter}$  diameter and above
2. handholes (minimum size  $200 \text{ mm}$ ) for vessels below  $1.0 \text{ meter}$  diameter

All nozzles shall be provided with flanges and shall be so arranged that practical pipe connections are possible. The stub length for all stub pipes shall be at least  $200 \text{ mm}$ , measured from the tank wall to the flange sealing surface. In the case of insulated vessels, the length shall be chosen so that there will be a clear space of at least  $100 \text{ mm}$  between the cover of the insulation and the underside of the flange. Nozzles below  $\text{DN } 25$  are not acceptable.

For insulated vessels, provisions must be made for fixing and supporting the insulation.





All tank internals must be replaceable through the manhole unless by approval of the Employer. Prefabricated vessels must as a minimum have a coat of primer applied before transport. They shall be cleaned and internally dry. All openings must be secured closed before transport.

Tank and vessel capacities given for process relevant documents and for basic design calculations shall be *usable net* volumes and shall be in the relevant documents clearly referred as such.

#### B0.6.17.6 Heat exchangers

Heat exchangers are to be designed, manufactured and erected in accordance with the applicable standards.

Only proven products shall be delivered. No cast iron components are permitted.

It must be possible to install and remove the heat exchangers without undue difficulty. Lifting lugs and eyes and other special tackle shall be provided to permit easy handling.

Tubular heat exchangers or plate and frame type heat exchangers are acceptable where no specific requirements expressed. Where necessary the tubes are to be protected by impact shields. An adequate number of visual inspection ports are to be provided in critical areas to facilitate condition monitoring.

Unless otherwise specified, all heat exchanger tubes and casings must be designed to withstand 1.2 times the zero flow pressure of the relevant pump at cold conditions, or 1.2 times of the maximum positive operating pressure, as applicable. The test pressure must be 1.5 times the design pressure.

The heat exchangers shall be designed for the maximum temperature incurred plus 20 K.

Heat exchangers must be capable of continuous unrestricted operation with up to 10% of plugged tubes, and a corresponding factor of conservatism. At least this amount must be used in the design of the heat transfer areas.

Considerable importance will be attached to the ease of cleaning the heat exchangers.

Where any heat exchanger part in contact with liquid can be isolated, and there is a possibility of being heated from the other side, safety valves are to be provided for pressure relief.

Pipes from drains, vents and safety valves are to be grouped together, and routed to easily observable points equipped with covered funnels or to the flash tanks.





The overall design and conception of the heat exchangers and accessories is to be such that they are suitable for the degree of automation envisaged for the individual system.

#### B0.6.17.7 Instrument and service air

To meet the compressed air requirements of the Plant two different compressed air systems, - instrument air and service air, will be provided.

The service and instrument air system shall produce and deliver compressed air for the following main consumer of the Power Plant and desalination plant:

- Service air for atomization of HSD (High Speed Diesel) and for operation of mechanical air tools, wrenches and other consumers during all operation modes of both units and for maintenance purposes.
- Instrument air for all pneumatically operated plant instrumentation and control devices and other consumers. The instrument air quality shall meet ISO 8573-1 Class 2".

For detail instruction on compressed air see **B12 Part 7**.

#### B0.6.17.8 Cranes, hoists and lifts

#### B0.6.17.9 Cranes

For erection and maintenance works, overhead travelling crane per unit shall be installed in:

- One EOT Crane for each turbine hall (Refer the below note)
- One EOT crane for the compressed air station building.

Note: If Bidder/Contractor intends to provide one EOT crane then turbine generator stator shall be moved by special device (to be handed over with special tools).

For handling of the generator stator the following alternative is also acceptable: Tandem/combined operation of two turbine hall EOT cranes for which the necessary arrangements shall be provided. In such case the combined capacity of two EOT cranes shall not be less than the 105% of weight of generator stator, including the weight of lifting beam with swiveling equipment and slings.

HP heater shall be moved by turbine hall crane.

For erection and maintenance works in the plant water screening and pumping station two (2) travelling bridge cranes shall be installed, one for pump and header bay area and one for screening plant area. The cranes shall





be calculated and designed in accordance with the principles of DIN or equivalent standards.

EOT crane shall only be used in closed pumphouses.

For installation and repair works in the cooling water pumping station one (1) gantry crane shall be installed.

Additional overhead travelling cranes are to be installed in pump houses, central work shop and all other locations and buildings for equipment of this Contract where cranes are needed. Refer also to the individual technical sub-sections of this specification.

The nominal carrying capacity of the cranes must be such that the heaviest object to be lifted including the spreader bar and other necessary auxiliary lifting devices can be transported with safety.

Cranes with a span of more than 8 m and/or a nominal carrying capacity of more than 5 t shall be in the form of double-girder cranes with the crab running on top.

Smaller cranes shall be in the form of single-girder cranes with the crab running on the lower flange or in the form of suspension cranes.

Cranes with a nominal carrying capacity of 30 t and above shall be fitted with an auxiliary hoist.

The overhead travelling cranes shall be fitted with gangways on the crane bridges or with gangways fitted to the sides of the crane.

The end-carriages of all cranes shall generally be of welded box-girder construction. Buffers shall be provided at the faces on the end-carriages. The end-carriages shall also be fitted with wheel-breakage supports designed to prevent derailment as well.

The deflection of the crane bridges at nominal load shall not exceed  $1/1000$  of the span for cranes with capacity of 50 t or more, or  $1/900$  of the span for cranes below 50 t capacities.

The crab assemblies shall be of rigid steel construction. Buffers shall be provided at the faces of the crabs.

The crabs shall as far as possible be covered with smooth sheet-metal and fitted with handrails.

The crane switchgear shall be accommodated in switchgear cabinets to be arranged on the crane bridge.



000150



The crane and crab running wheels shall be made of cast or forged steel and shall have double flanges. The wheels should have rolling bearings lubricated for life.

For cranes used for the removal and installation of pump rotors in vertical pumps (e.g. cooling water pumps), it is important to ensure that there is no lateral drift of the hook during lifting and lowering.

All cranes shall be equipped with pendant control units. The pendant control units shall be suspended on the bridge so that they can travel along it independently of the crab.

All pendant control panels shall be fitted with rocker-type or push-button switches for the crane functions. A key switch and an emergency stop switch shall also be provided on each panel. Additional switches or push buttons shall be provided as required.

The crane and crab drives are to be designed as two-corner drives with electric gear motors. 2 (two) motors are to be provided for the crane drives. The crab drives may consist of one motor and universal joint shaft.

All travelling and traversing drives are to incorporate pole-reversible squirrel-cage gear motors with sliding armature and brake.

The lifting gear may consist of standard electric hoists with sliding armature motor and cone brake or disc brake.

The precision speed control shall be provided for all crane and lifting gears.

Speeds for cranes shall be as below:-

- For TG hall crane-
  - Main hoist - 1.6 m/min (creep speed 0.16 m/min thro VFD)
  - Aux hoist - 7.5 m/min (creep speed 0.75 m/min thro VFD)
  - CT - 15 m/min (creep speed 1.5 m/min thro VFD)
  - LT - 30 m/min (creep speed 3.0 m/min thro VFD)
- For other cranes-
  - Main hoist - 3 m/min
  - CT - 10 m/min
  - LT - 10 m/min.



#### B0.6.17.10 Hoists

Hoists shall be provided throughout the entire installation where machines or other components provided under this contract are to be installed, removed, repaired, serviced or transported and these parts are not in the working area of a crane (refer also to the individual technical subsections of this specification).

000151



The final number of hoists to be supplied will be proposed by the Contractor, according to the requirements of the equipment. The Contractor has to include in his offer the number of hoists for the whole Plant. Any necessary change of hoists must not lead to any price change of the contract price.

The hoists used shall be standard production hoists.

The hoists shall be designed and calculated in accordance to applicable standards.

The nominal carrying capacity of the hoists and of their attachment points shall be such that the heaviest object to be lifted can be transported with safety.

For electric hoist, trolley travel speed and hoist speed shall be 15 m/min and 6 m/min respectively.

Manual hoists shall take the form of chain tackle blocks with load and drive chains. The crabs shall be fitted with a drive also operated by a chain. The runways shall be designed according to approved standards.

Electrically driven hoists and crabs shall be equipped with squirrel-cage motors. An inching control shall be provided on all electrically driven hoists and crabs.

The crab power supplies shall be in the form of sheet-steel-enclosed safety power tracks, which can be easily bent to follow the form of the hoist runways.

Electrical switchgear and control gear shall be mounted directly on the hoists in cabinets.

The electric hoists shall be operated by pendant control units fitted with pushbutton or rocker-type switches, which shall be fixed to the hoists in such a way that safe operation is guaranteed.

The control panels shall be equipped also with a key-operated switch and a mushroom-shaped emergency "off" switch.

Limit switches shall be fitted to all lifting and travel gear.

The electrically operated hoists shall be installed in a permanent location.

Where hoists are not easily accessible by simple means such as ladders or mobile scaffolds, maintenance platforms with means of access shall be provided.



000152



## B0.6.17.11 Lifts

One (1) lift in each steam generator building for goods transport (minimum capacity 3,000 kg) and one (1) no. conventional passenger elevator in each the steam generator building for personnel transport (minimum capacity 16 persons and minimum 1,100 kg) shall be installed, reaching the highest accessible platform. Outdoor hoisting arrangements shall be included at one side of each boiler house for lifting long items of up to 4,000 kg.

Further Elevators shall be provided in the following building, reaching the highest floor of these buildings:

- 2 x elevators TG building
- 1 x elevator for service building
- 1 x elevator for crusher house
- 1 x elevator for highest transfer point before main plant.

For administration building 2 x nos. of 16 person capacity (minimum 1,100kg), panoramic type elevator shall be provided.

Lift for light material store shall be provided as follows:

- Quantity = 1
- Type = Goods lift
- Capacity = 1,000 kg.
- Speed = 0.5 m/s.

The basic requirements for conventional passenger elevators are:

- Capacity: 16 person (minimum 1,100 kg)
- Speed: 1 m/s

The lift installations shall be designed as cable-operated lifts with traction machine. The car shall be provided with automatic telescope sliding doors.

The lifts shall be designed, manufactured, erected and tested according to OSHA (Operational Safety and Health Administration) and applicable standards.

During the construction period, the sides of the cars (without doors) and the floor of the cars shall be provided with protective coverings (hardboard panels or similar). The protective coverings shall be removed by the Contractor after the construction period.

The motors and switchgear must be designed for at least 180 starts/stops per hour. The type of enclosure of the switchboards and motors shall comply with the relevant requirements of Section B0.



000153



## B0.6.18 Electrical equipment and works

### B0.6.18.1 Standards

The design and manufacture of all electrical equipment shall comply with the latest editions of the IEC Recommendations if not specified otherwise elsewhere in the specification. Compliance with ANSI/IEEE/NEMA, BS, EN or VDE standards will only be accepted in case no applicable IEC standards are available and subject to approval by the Employer/Engineer.

The Plant shall comply with:

- the Essential Electrical Requirements of the PPA
- the latest edition of the Electricity Grid Code of the Bangladesh Energy Regulatory Commission; and
- the Great Britain Grid Code.

In case of contradictions the order of precedence shall be as follows:

- Essential Electrical Requirements of the PPA;
- Electricity Grid Code of the Bangladesh Energy Regulatory Commission;
- Great Britain Grid Code.

Any other requirements of BPDB/PGCB shall also be considered (if available).

### B0.6.18.2 Voltage levels

The following voltage levels shall apply:

- 400 kV and 230 kV, 50 Hz connection voltage to the public grid
- 18 to 27 kV, 50 Hz generator voltage, depending on manufacturer's standard
- 11 kV  $\pm$  6%, 50 Hz voltage for motors equal to/bigger than 1500 kW and for power distribution within the Plant
- 3.3 kV  $\pm$  6%, 50 Hz voltage for motors equal to/bigger than 160 kW and for power distribution within the Plant
- 240/415 V (+/-) 10%, 50 Hz standard voltage for power supplies to small electric power consumers and motors below 160 kW lighting and domestic power outlets
- 240/415 V (+/-) 10%, 50 Hz voltage for power supply of essential electric power consumers - the system shall be operated with ungrounded neutral
- 220 V DC  $\pm$  10%/-15% voltage for emergency users of electricity, like turbine emergency oil pumps, circuit breaker control, inverters





- 240/415 V  $\pm$  10%, 50 Hz      uninterrupted voltage supplies to consumers, which require uninterrupted infeed like DDCMIS components, control actuators, burner control panels, VDUs.
- 24 V DC  $\pm$  15%      for power supplies to the DDCMIS system components
- 24 V  $\pm$  10%, 50 Hz      for erection work in enclosed plant items of metal

The general arrangement of the particular voltage level for each part of the Plant within the scope of the Contract and the connections of the power supply systems can be seen from the Key Single Line Diagram (Annex E).

### B0.6.18.3 Insulation levels

- The 400 kV system shall be designed to limit the switching surge overvoltage to 2.3 p.u. and the power frequency over-voltage for the 400 kV system and the 230 kV system to 1.5 p.u. The lightning arrestors associated with the 400 kV reactors shall be of 336 kV.
- Following insulation levels shall be considered:

|    | Description                                          | 400 kV   | 230 kV | Generator * | 11 kV | 3.3 kV |
|----|------------------------------------------------------|----------|--------|-------------|-------|--------|
| 1. | Highest voltage for equipment                        | 420      | 245    | 24 or 36    | 12    | 3.6    |
| 2. | Power frequency withstand voltage                    | 650*/630 | 460    | 50 or 70    | 28    | 10     |
| 3. | Lightning impulse withstand voltage                  | 1425     | 1050   | 145 or 170  | 75    | 40     |
| 4. | Switching impulse withstand voltage (phase to earth) | 1050     | -      | -           | -     | -      |

\* According to manufacturer standard

The creepage distance of the outdoor insulators shall be minimum 31 mm/kV.

- 400 kV level:
  - rated switching impulse withstand voltage 1050 kV
  - (phase-to-earth);
  - rated lightning impulse withstand voltage 1425 kV;
  - \*rated power frequency withstand voltage for GIS 650 kV and for transformers 630 kV.
- 230 kV level:
  - rated short duration power-frequency withstand voltage 460 kV;
  - rated lightning impulse withstand voltage 1050 kV.
- Remark: The insulation coordination study shall be carried out by the Contractor.





#### B0.6.18.4 Installation conditions and protection class for electrical operational equipment and control and monitoring equipment

If not specified otherwise the electrical operational equipment must be designed to meet protection classes stated below.

Switchgear, housings for electrical equipment and electrical equipment itself must be designed according to IEC 60529 at least to:

- Class IP 41 if located indoors in air-conditioned/ventilated areas
- Class IP 42 for ventilated enclosure of DDCMIS equipment if located indoors in air-conditioned/ventilated areas with suitable cannope ontop to prevent ingress of dripping water
- Class IP 22 for non-ventilated enclosure of DDCMIS equipment if located indoors in air-conditioned/ventilated areas with suitable cannope ontop to prevent ingress of dripping water
- Class IP 54 if located indoors
- Class IP 65 for all I&C field devices
- Class IP 55 for motors located outdoors and in indoor areas with high dust and humidity
- Class IP 65 for other outdoor electrical and control system equipment such as cubicles or panels with additional measures) if located outdoors in accordance with IEC 60529 (degrees of protection provided by enclosures (IP Code) or equivalent). The additional measures shall consist of sunshades, protection covers against splashing water, additional sealing, special acid resistive coating etc., depending upon the particular site conditions at the place of installation, subject to the approval of the Employer.
- Class IP 21 if located indoors with open doors.

The lamps for external lightning and internal lighting of not completely closed buildings must have protection class IP 55W. Furthermore for dust prone areas the lamps shall have protection class IP 65.

Electrical operational equipment which must be installed in areas exposed to danger from explosions must have the required explosion-proof design appropriate to the flash-point group classification of the explosive mixture as laid down in IEC 60079. Attention must be paid with respect to the use of electrical operational equipment in workshops and storage premises exposed to the risk of explosions.

In all rooms and areas where the local and operational conditions and surroundings can lead to the accumulation of gases, vapors, mists or dusts which, in combination with air, form explosive mixtures, the operational equipment and installations to be used in these circumstances must be of explosion-proof design. All operational equipment must be designed to comply with the class of protection dictated by the ignitable mixture (e.g. compression-proof casing, external ventilation, inherent safety, etc.).



000156



Electrical operational equipment should be located indoors in adjoining buildings rather than inside buildings or other structures exposed to the risk of explosion. Whenever operational equipment has to be installed within areas liable to the risk of explosion, protection against explosion must, in general, be applied wherever explosive mixtures can arise. In this connection, the ignition of explosive mixtures must be reliably prevented by adopting the correct choice of design and construction of the operational equipment and the incorporation of supplementary safeguards where applicable.

Electrical, chemical, thermal and mechanical influences must on no account impair, in any way, the protection afforded against explosion. In particular the high ambient temperatures and the influence of nearby heat sources at the installation point must be taken fully into account.

#### B0.6.18.5 Protective measures, earthing and lightning protection

In view of the potential dangers of electrical power, the following measures are required for the protection of life, equipment and materials. Basically, all 'live' parts, i.e. all parts of electrical, operational equipment at an electrical potential above or below earth potential when in operation, and with a rated voltage over 24 V, must be insulated or covered so that they cannot be touched accidentally.

In addition, measures must be taken by the Contractor to prevent the occurrence or persistence of excessively high contact potentials on conductive parts of electrical operational equipment (frames etc.) brought about by faults in insulation.

For installations up to 1000 V, voltages over 50 V are considered to be excessive contact voltages. Within enclosed electrical installations, with voltages over 1000 V, the contact potential shall be according to the values given in EN 50522 (VDE 0101-2) Earthing of power installations exceeding 1 kV: enclosure B.

The following rules and regulations are to be observed in carrying out protective measures and in earthing procedure:

- IEC 60079 and 60364 for installations up to 1000 V,
- EN 50522 (VDE 0101-2) Earthing of power installations exceeding 1 kV:

In areas exposed to the hazard of explosion, the protective measures outlined in IEC 60079 and IEC 61241 are to be adhered to in the erection and installation of electrical plant and equipment.





### B0.6.18.5.1 Protective measures for installations up to 1000 V

#### Protection against direct contact

All 'live' parts of electrical operational equipment that can be reached by hand must be protected against direct contact either by means of insulation or through constructional design, position or arrangement, or by means of special devices. If, in the case of enclosed switchgear or control cabinets, access is required in the course of normal operation (e.g. for replacing fuses), protection against direct contact must still be ensured when the switchgear or control cabinet has been opened up.

#### Protective insulation

Protective insulation is to be provided by means of additional insulation over and above the insulation provided for operational purposes. This measure must prevent the occurrence of a dangerous contact potential.

#### Use of low voltages as a safety measure

This safeguard applies to all equipment, which is required to operate in metal enclosures, boilers, tanks etc. The operational voltage of tools and lighting equipment must not exceed 24 V AC.

Isolating transformers shall be provided by the Contractor for the purpose of producing the protective low voltage. A separate 24 V system will not be provided.


#### Connection of the neutral

The LV network shall be of the TN type, i.e. the LV neutrals of the auxiliary transformers are earthed directly.

Neutralization (protective multiple earthing) is intended to prevent the persistence of an excessively high contact potential on conductive parts of the installation which do not form part of the actual operating circuit.

Protective multiple earthing as a protective measure requires the neutral to be earthed close to the transformer. However, wherever possible the neutral shall be earthed at the main LV board. In this case the connection transformer to LV main board shall be carried out as TN-C type, i.e. three phases plus PEN:

The LV system for symmetrically as well as unsymmetrical connected power consumers shall generally be of the TN-S type, i.e. a five wire system. The separation of N and PE shall be carried out at the main LV board. Because of the clear demarcation between the neutral conductor N, carrying operational current, and the protective earthing conductor PE, which - under non-fault conditions - carries no current, NO connection between either N and PEN or N and PE is permissible beyond the point of separation of the PEN conductor into PE and N.



000158



The LV system for supply of essential consumers (emergency diesel supply) shall be of IT type. All required isolating transformers shall be included in the scope of supply.

The neutral conductor is to be insulated in the same manner as the phase conductors. The use of constructional parts of the switchgear as a neutral conductor is not permitted.

All earthing conductors have to be rated depending on the value of earth-fault current (see EN 50522 (VDE 0101-2) enclosure D). Separate installed earth conductors must be at least 16 mm<sup>2</sup> for copper and 100 mm<sup>2</sup> for galvanized flat-iron.

The earth electrode resistance shall ensure that potential contact will not be higher than 50V (see IEC 60364 - 4 -41).

#### B0.6.18.5.2 Protective measures for installations over 1000 V

##### Protection against contact

At least the following measures are to be taken for all parts that are 'live' when in operation:

- Protection outside of closed electrical operating areas:
  - complete protection from all sides against contact, the degree of protection shall be at least IP23D according IEC 62271-202 and IEC 60529
  - protective devices may only be removed by means of tools.
- Protection inside closed electrical operating areas:
  - protection against contact with 'live' parts within reach of personnel,
  - protection against accidental contact outside the reach of personnel.

The above-mentioned measures for protection against contact are also to be applied to 'dead' parts of the Plant where, in the case of a fault, a dangerous contact potential might arise, however, where the parts must not be connected to the protective earthing system for operational reasons.

##### Protection against contact voltages

Protective earthing is to be used as a safeguard against excessively high contact potentials for conductive parts of the installation, which do not form part of the operational circuit. Here, all normally 'dead' parts equipment and apparatus shall be earthed if it is possible for them to come into contact with 'live' parts as a result of faults due to the occurrence of surface leakage paths, arcs or direct connections to a 'live' part of the equipment.

In considering the dimensioning of the protective earthing system, the thermal loading and voltages on the earthing equipment are decisive factors and these should be based on the maximum possible earthing current, which can arise.



000159



**Connection of the neutrals**

- 400 kV system: neutrals of the 400 kV windings of the transformers shall be directly grounded
- 230 kV system: neutrals of the 230 kV windings of the transformers shall be directly grounded
- 11 kV system: neutrals of the 11 kV windings of the transformers shall be grounded by means of 400A resistors
- 3.3 kV system: neutrals of the 3.3 kV windings of the transformers shall be grounded by means of 400A resistors.

**B0.6.18.6 Earthing and lightning protection****B0.6.18.6.1 Earthing and potential equalization system**

The earthing system and potential equalization shall comply with the following standards:

- IEC 60364-4-41: Electrical Installation of Buildings – Protection for Safety: Chapter 41: Protection Against Electric Shock
  - IEC 60364-5-54: Electrical Installation of Buildings – Part 5-54: Selection and Erection of Electrical Equipment - Earthing Arrangements, Protective Conductors and Protective Bonding Conductors
  - EN 50522 (VDE 0101-2): Earthing of power installations exceeding 1 kV
  - VDE 0845, Part 1: Protection of Telecommunication Systems Against Lightning, Electrostatic Discharges and Over-voltages from Electric Power Installations; Provisions Against Over-voltages
  - IEC 61643: Low-voltage Surge Protective Devices
- For earthing, protective earthing, functional earthing, potential equalization and lightning protection-potential equalization, a common system shall be established.

Within all buildings, internal earthing rings shall be installed. These shall be linked by way of connection tags to the foundation ground and outdoor earthing system.

All system and plant components which are to be earthed as well as electrical components, like protection and control cubicles, sub-distribution boards, control systems, motors and transformers, shall be connected to the earthing rings/bars. All steel structures within a welded Section shall be connected to the main earthing system.





At pipelines for flammable liquids or gases, earthing tags shall be provided at each flange. All bolted flanges shall be bridged using a flexible braided copper conductor. Each pipe shall be connected at least once to the main earthing system.

No framework parts or other structural components shall be used for the ground bus.

An earthing cable shall be included in all main cable runs. Protective earthing and potential equalization of electronics cubicles, frameworks, racks etc. shall be executed as follows:

- Earthing rings shall be installed in the I&C rooms as buses, to be connected at several locations – at least two – to the earthing network.
- For each row of cubicles, at least two connections shall be made to the earthing ring. Cubicles in a row shall all be connected by conductors to each other.
- If cubicles are attached to a raised platform flooring of steel structural parts, it shall be ensured that these are electrically connected to each other throughout the area. The raised floor shall be connected to the earthing ring at several locations, and as a minimum at two corners of the room.

#### Foundation earthing

All buildings, including those with a steel skeleton, shall be equipped with foundation earthing. The foundation earthing shall be installed in addition to reinforcement that is likewise connected together with braided conductors.

The foundation earthing shall be used in connection with the other earthing systems like protective, operational, functional and lightning protection earthing.

In the case of pile foundations, earthing rods of the same length as the piles shall be installed along with the foundation piles at intervals of around 10 m and connected at around every 2 m to the pile reinforcement using braided conductors. The earthing rods shall project beyond the top of the piles and then be connected to the earthing system of the ring foundation.

In addition to the closed ring of the foundation earthing system, a net of mesh size around 10 x 20 m shall be embedded in the bottommost concrete layer. The foundation earthing shall be connected to the reinforcement by a braided conductor at intervals of about 2 m.

At intervals not exceeding 20 m, and with at least two in every room, connection tags from the foundation earthing shall be foreseen for connecting the internal earthing ring. Connection tags shall likewise be foreseen for connection to the external earthing system and to the lightning rods. Optionally, lightning rods can be connected to the external ring





earthing, with connections then made from this ring earthing to the foundation ground by way of the internal earthing ring at intervals not exceeding 20 m.

#### Earthing material

- Refer to Part B7.

#### Screening

The measures described in the following serve for screening and potential control within (see EN 50522 (VDE 0101-2) Annexes E and F) and for lessening overvoltages.

- For reinforced concrete buildings, at each corner of the building including the bottom slab, an additional mesh of rebars, of approximate mesh size 10 x 10 m, shall be provided at the topmost reinforcement. The meshes shall be produced by welding. This additional reinforcement, connected so that it is electrically conducting, may be dispensed with if it is ensured that the existing reinforcement is so connected by welding at appropriate points that it is electrically conducting.
- At intervals corresponding to the mesh-width, earthing wires from the reinforcement shall be incorporated into the building pillars, rising from the foundations to the roof, and so welded that they are continuous. These earthing wires shall terminate at the roof parapet. The meshes and earthing wires shall be welded to each other.
- For steel skeleton buildings, equivalent measures shall be taken. Framework Sections shall be welded to make up a defined, electrically conducting connection or shall be bolted together so that they are electrically conducting.
- Metal façades and coverings shall be preferred over non-conducting materials and at their topmost and bottommost points shall be connected at an adequate frequency to the lightning protection system.
- Reinforcement of cable ducts of reinforced concrete shall be connected to parallel running earthing cables. These earthing cables shall be connected to the screen of the building earthing system or to the foundation earthing system.

#### B0.6.18.6.2 Lightning protection

All buildings and structures shall be equipped with a lightning protection system. Lightning protection level I (LPL) according to IEC 62305 shall be considered.

The building lightning protection system is to be executed according to:

- IEC 62305-1
- IEC 62305-3 and
- IEC 62305-4





and alongside protection of human life to prevent damage not only to buildings, but also to electrical and electronic installations.

All buildings and structures are to be protected against lightning strikes by means of lightning collectors and conductors. The collectors are to be arranged in such a way that, as far as possible they collect all lightning strokes without these directly striking the parts to be protected. This condition is considered to have been fulfilled if no point on the roof surface is more than 5 m away from a collector. Collector lines suffice as collectors, e.g. along the ridge and at gables and eaves.

Ridge conductors must be taken right to the end of the ridge. Moreover roof conductors should run as natural continuations of all main conductors. Conductors at the gable extremities or eaves must be laid in the closest possible proximity thereto. In the case of steel-framed structures the ridge conductors must be connected to the roof supporting structure at least every 20 m. Lower level annexes are also to be provided with collectors.

Roof lines and other conductors are to be laid and fixed in such a way that they can withstand the stresses expected from storms, lightning strokes, roof work, etc.

One main conductor between the lightning collectors mounted on the top of the building and the potential grading ring laid in the ground is to be provided every 20 m of the before-mentioned lightning collector. The maximum spacing between conductor fixings may not exceed 1 m for horizontal runs and 1.2 m for vertical runs.

#### **Lightning protection material**

In case of buildings with steel structures and sheet steel cladding, the steel columns and the sheet steel cladding shall be used as lightning conductor. In case of masonry buildings or buildings with concrete structure, external lightning conductors made of copper or stainless steel shall be used. Lightning arrestors (arrestor tips and roof conductors) or Lightning air terminal shall also be made of copper or stainless steel rods. The conductor supports of the lightning protection system must be copper or bronze. Nuts and bolts at isolating or other points which are to remain detachable must be made of copper-nickel-silicon-bronze.

#### **B0.6.18.7 Technical conditions for high voltage motors**

If not specified otherwise all electric motors must be designed to meet IP 54 enclosures.

All motors with rated power (referred to 40° C ambient temp.) of 160 kW and above must be designed as HV motors.





### B0.6.18.7.1 Constructive features

The following constructive features shall apply:

- a. Climatic protection provisions for mounting in the open in a humid and hot climate. Insulation class F. During operation at rated power of the driven machine, the motor insulation must only be stressed in accordance with the requirements of class B insulation.
- b. Motor parts made of iron internally and externally sandblasted and surface-protected.
- c. Paint finish resistant to chemicals and seawater.
- d. Bolts with adequate corrosion protection.
- e. All joint faces and gaps sealed.
- f. Anti-condensation heating to be switched into operation when the motor feed circuit is in the 'off' position. Heater supply power 'on' indicating lamp is to be provided.
- g. Special treatment of windings with resin impregnation plus immersion in varnish.
- h. Varnish-insulated laminations.
- i. Pressboard material protected by varnishing.
- j. For motor ratings the cooling air available at the specific location has to be considered.

All motors shall be either totally enclosed fan cooled (TEFC) or totally enclosed tube ventilated (TETV) or closed air circuit air cooled (CACA) type. However, motors rated 3000 kW or above can be Closed Air Circuit Water cooled (CACW). CW motors can be screen protected drip proof (SPDP) type.

- k. Condensation outlets to be provided at the lowest point in the housing.

Design and construction of the motors shall comply with IEC 60034-1, 60034-5 or VDE 0530 and DIN 40050.

### B0.6.18.7.2 Electric features

The following electric features shall apply:

- a. Motor rating to be at least 110% of the maximum required electric power consumption of the driven machine.
- b. Continuous delivery of rated power at voltages of 90 - 110% of the rated voltage and allowable frequency range within the limits of thermal class F.
- c. Rated power output at ambient temperatures existing at the particular site of installation and under continuous running conditions.
- d. All motors shall be designed as 3-phase squirrel-cage motors suitable for direct on line starting. It must be possible, with 100% residual voltage, to switch them on to a large and stable power supply network without incurring damage or deformation. The motors must still be capable of





faultless running up to speed with a voltage drop to 80% of rated voltage and rated loading.

However, 75 % starting voltage shall be allowed for motors above 4000 kW. Mill motor being high starting torque motor, is specially designed and shall be suitable to operate at 85% rated voltage for 1 minute only, provided that the mill motor is suitable for starting/running with voltage variations for which aux. power supply system is designed.

- e. Motor starting current must not exceed 5.5 times rated current (referred to motor rating at 45 °C ambient temperature) for motors up to 2 MW and must not exceed 4.5 times rated current (referred to motor rating at 45°C ambient temperature) for motor ratings above 2 MW. The voltage drop at direct-on-line starting should be limited to 20% at the motor terminals except rating above 4000 kW. However starting of any motor shall not cause tripping of any other consumer. However, Bidder/Contractor is free to design his system with starting currents up to 600% maximum.
- f. From the cold state four consecutive starts up to full speed must be possible. The second start must be possible immediately after the first start, the third 20 minutes after the second, the fourth 20 minutes after the third.
- g. A minimum frequency of starting cycles of 1000 per year must be guaranteed.
- h. In general, motors must be capable of running without overheating when subjected to three consecutive starts within one hour after having run for an extended period on a voltage of 95% nominal voltage. Thereby the second start must be possible immediately after the first start and the third 30 minutes after the second start. In individual cases where operation depends on signals from pressure switches or other such sources, then a more severe duty with respect to the frequency of starting cycles per hour shall be necessary and the design of the motors must be carried out accordingly.

### B0.6.18.7.3 Protective features

The following protective features shall apply:



- a. High voltage motors must be fitted with measuring points for the determination of slot and bearing temperatures.
- b. Six Pt 100 resistance thermometers (2 per phase) are to be provided for slot temperature measurement, and a double thermocouple or resistance thermometer per bearing must be provided for bearing temperature measurement. Type of temperature elements shall be finalized by the manufacturer.
- c. Each Pt 100 shall be connected, potential free, to a terminal strip. The connections to the thermometer as well as the associated over-voltage cutouts shall be brought into separate terminal boxes.





- d. Where motors have closed-cycle cooling, temperature-measuring points must be fitted in the cold air stream.
- e. The winding temperatures have to be detected with RTD's at high temperature and alarm to be produced, at extra high temperature the motor to be tripped.
- f. All motor gaps and joints between it and other units must be sealed.
- g. Earthing clamps at both sides of the stator have to be provided.
- h. All HV motors bearings shall be equipped with vibration sensors for vibration monitoring.

Considering the rating of CHP HT motors vibration monitoring is not required. For Coal Crushers vibration isolation & monitoring shall be provided.

- i. Temperature transmitter to be provided for all temperature measuring devices.

#### B0.6.18.7.4 Other features

##### Terminal Boxes

The main terminal boxes on the high voltage side shall be provided with a pressure relief joint for the purpose of reducing the danger of an accident as a result of short-circuits, and shall be fitted with a terminal block suitable for any desired type of connection.

Cable connecting boxes must be longitudinally divided to facilitate fitting of cable sleeves and end caps. Protection class shall be IP 55.

Inside the terminal box an earthing clamp for connection of the cable shield must be foreseen.

The opened terminal boxes must have provision for local earthing to be carried out.

All terminal boxes shall be provided with a removable undrilled gland plate. The gland plates shall be of non-magnetic material if single core cables are to be installed.

##### Connections, star-point terminal boxes etc.

All motors must have the star-point connection brought out separately to terminals.

For all motors with a rating of 2000 kW or above a differential relay for winding protection shall be provided and installed in the associated switch-gear. In that case the star-point connection shall be brought out separately to terminals. The differential current transformers are to be designed to class 5 P10 with a rating matched to the protection system. The CT's shall be accommodated in the star-point terminal box.





**Coupling**

The motor shaft halves of the couplings, finish-bored, balanced, and complete with key ways are to be drawn on to the motor shaft and balanced out together with the rotor.

**Cooling**

Air cooling for the motors is the preferred method. Where water-cooling is applied, conditioned and treated, water shall be used.

Motor air exchanger circuits should be suitable for the prevailing atmospheric conditions, i.e. ambient temperature, content of humidity and salt in the air, etc. are to be considered.

**Running quality**

The running quality must be within the classification of "Class C, Zone A" according to the ISO 10816-1 or equivalent, i.e. the vibration velocity must be not greater than 1.8 mm/s (rms).

**Reverse speed**

If reverse running, can occur in the case of equipment driven by a motor (e.g. cooling water pump), the motor must be designed for maximum, possible reverse speed.

A reverse rotation alarm and starting-circuit interlock are to be provided to ensure that the equipment cannot be started while running in reverse.

**Lubrication**

All MV and HV Motors shall preferably be equipped with on-line lube oil purification and auto-grease facility. These systems shall preferably be procured from one single manufacturer.

The above requirements of the specification to be considered only as a preferred solution. However OEM recommendation will be accepted.

**B0.6.18.8 Technical conditions for low voltage motors**

If not specified otherwise all motors must be designed to meet IP 55 enclosure according IEC60034-5.

All motors with rated power (referred to 40 °C ambient temp.) less than 160 kW must be designed as LV motors with premium efficiency class IE3.

The equipments which are only operating for short period shall not be covered under IE3 such as:

- a) Sootblower Motors- operates only during sootblowing sequence
- b) Seal air fan motor for damper sealing operation-operated only during maintenance.





**B0.6.18.8.1 Constructive features**

The same features as for high voltage motors shall apply.

Anti-condensing heating shall be provided for motors of 55 kW and above.

**B0.6.18.8.2 Electric features**

All motors shall be designed as 3-phase squirrel-cage motors suitable for direct on line starting.

The motors must be capable of being switched on to a large and stable network and with phases in opposition.

The electric features a), b) and c) of high voltage motors also apply here.

Motors starting current must not exceed 7.0 times rated current (referred to the motor rating and 45 °C ambient temp).

The Starting current of LV Motor (IE3) shall be inline with IEC 60034-30. Applicable de-rating factor for design temperature of 45 Deg C shall also be applied.

**B0.6.18.8.3 Protective features**

An earthing clamp inside the terminal box has to be provided.

**B0.6.18.8.4 Other features****Cable leads**

All cable connecting boxes are to be designed to meet the requirements of IP 55 or IP 58 protection class respectively.


The cable connecting boxes are to be installed easily accessible on the motor. The connecting boxes must be capable of being turned by 90° or 180° and of being opened up longitudinally. The connection boxes are to be fitted with a terminal block.

**Shafts**

Where not otherwise specified, motors must be fitted with a free shaft end.

**Protection against explosion hazards**

Low-voltage motors, which are to be installed in areas exposed to the risk of explosion, must comply with the rules laid down in VDE 0165/0170/0171 for explosion-proof design in relation to the flash-point group classification for the particular explosive mixture.





**B0.6.18.9 DC motors**

The use of DC motors is to be avoided and must be agreed by the Employer. The maximum starting current must not exceed 1.8 of the rated motor current (referred to the motor rating at 45 °C ambient temperature). However any other value of starting current proposed by Bidder/Contractor during basic/detailed engineering shall be subject to Employer's approval

**B0.6.18.10 . Actuator drives**

As far as applicable the above "Technical conditions for low voltage motors" shall apply.

In addition, all actuators for valves, dampers etc are to be fitted with socket and plug of well-established make to IEC 60309 or equivalent for the power cable connection. For the control cable connection separate socket and plug shall be provided.

Self-cooling at respective ambient temperature conditions is mandatory. Fan cooling is not accepted.

Actuators shall have integrated starters. Regulation type shall be continuous modulation type (min. 3000 starts per minutes).

**B0.6.18.11 Frequency converters****General**

On the basis of the requirements of the driven equipment, the Contractor shall design, supply, install and commission a complete, fully operative, variable-speed converter drive (frequency converter and motor, for motors up to 400 kW, for motors 400 kW and above in addition to the converter a converter transformer shall be provided).

Converters made by reputable manufacturers are to be used.

**Technical requirements**

The design of the converter (maximum continuous rating) is to be based on the maximum shaft output required by the equipment assembly.

Maintenance work and cable connections must always be possible from the front of the converter cubicles

The terminals on the input and output sides are to be rated such that parallel cables can be connected.

The converter allows the speed of three-phase asynchronous motors to be adjusted steplessly. It must be fully equipped for remote control and monitoring in the control room.





An on-load disconnect and a power contactor are to be provided at the power input of the converter.

For motors with a rating up to 400 kW the frequency converter shall be designed in at least a six-pulse circuit on both the line and motor sides.

Frequency converters using Insulated Gate Bipolar Transistors (IGBTs) should preferably be provided on both the line and the motor sides.

For motors with a rating above 400 kW the converter should be designed in a 12 pulse circuit supplied via converter transformer.

The converter is to be disconnected if the voltage drops to less than 80% of the rated voltage or if one or more phases of the line voltages are missed. When the line voltage is restored, the converter is to be connected again automatically, providing the break in the power supply did not last longer preferably than 5 seconds. The Plant check back signals (floating change-over contacts) must continue to be received during this period, while alarms are to be suppressed. It must be possible for the converter to be connected at any coasting-down drive speed and with in-phase voltages. The specified frequency set point is to be resumed automatically.

If the voltage reduction or the power failure lasts for a long time, the drive must remain switched off; in this case, it must subsequently only be possible to switch it on again either manually or by means of the higher order control.

The converters are to be designed for 10% more than the maximum power output required by the system. The purpose of regulating the converter is to ensure that the indirect current and voltage remain within the permissible limits during all control processes. This should apply both when the motor is started up and when the speed is adjusted during operation.

Forced ventilated converters are to be equipped with redundant fans (two double fans).

Flow monitors (not air vanes) are to be used to monitor the fans. Positive control is to be provided for fan drives with a master drive.

#### Converter transformers

The transformer shall meet the requirements in the IEC standards 60076-11 and 60146-1-3, shall be of cast-resin type and are to be installed in protective casings made of sheet steel, cooling method AN, thermal insulation class F (utilized according to class B only), type of protection at least IP 21.

The transformer output shall correspond to the power requirement of the frequency converters.





It should be possible to vary the high-voltage side within a range of  $2 \times \pm 2.5\%$ , by means of reversible clamp connectors.

The connections on the high-voltage side have to be carried out using cables.

Busbar connections with short-circuit protection are to be provided to the current converters on the low-voltage side.

Suitable earthing studs are to be provided for maintenance purposes (earthing and short-circuiting).

All accessories - especially sensors and terminal connections - must be arranged so that they are readily accessible.

The windings must be flame-retardant and self-extinguishing. The cast-resin mixture must not contain any flame-inhibiting additives which develop toxic vapors or gases either under the influence of secondary fires or in the electric arc. A report on this subject has to be enclosed with the bid.

#### **Moisture-proof design:**

It must not be necessary to dry the winding after shut-off periods. The protection against voltage surges and short circuits, the noise levels and the freedom from partial discharges up to twice the rated voltage must be verified by means of type tests.

The windings are to be protected by means of a temperature monitoring system, comprising the following minimum components:

- 3 PTC resistors (1 for each phase)
- 1 tripping unit with isolated change-over contacts for remote signalling (alarms).

• Temperature transmitter to be provided for all temperature measuring devices

#### **Instrumentation and control**

The instrumentation is subdivided into a local Section in the converter cubicle and into a "remote" Section in the control room. All the measures necessary to enable the drive to be remote-controlled and remote-monitored must be implemented, i.e. all the 24 V DC interposing relays which are required to convert the on/off commands from the instrumentation and control system, signal transducers, etc (see also "remote control and remote indications" below).

A suitable automatic compensation facility is to be provided, to ensure that the transfer between LOCAL mode and REMOTE mode is bumpless in both directions. The emergency shutdown function of the equipment must act on the converter directly, regardless of whether 'local' or 'remote' mode is set.





**Local instrumentation and control**

The following are to be provided as a minimum in the converter cubicle:

**Controls**

- a) Local/remote converter control (key-operated switch)
- b) "On" and "off" converter controls
- c) Set point adjuster (speed)
- d) Incoming master switch, "on-off"
- e) All the controls necessary for internal converter settings and adjustments, as specified by the manufacturer

**Indications, signals, monitoring**

- a) Line voltage indicator
- b) Output frequency
- c) Output current
- d) Operating status signals, in accordance with the specifications of the instrumentation and control supplier, though at least "Ready", "Drive running" and "Zero and set speed reached"
- e) Motor temperature monitor - alarm Motor temperature monitor - shut-down
- f) Signals concerning internal operating states of the converter, in accordance with the manufacturer's standards, though at least:
  - Overtemperature
  - Line voltage monitoring
  - Line undervoltage
  - Overcurrent
  - Control voltage monitoring
  - Converter protection
  - Fan monitoring
  - Incoming air temperature
  - Motor feeder interruption
  - Motor feeder short circuit
  - Earth fault
  - Motor blocked
  - Other faults.

**Remote control and remote indications**

Account must be taken of the following types of remote control and indication in the control room, and suitable interposing relays, transducers and switchgears are to be provided in the cubicle:

- a) Converter "on/off" and "local/remote"
- b) Set point adjuster for speed (4 - 20 mA)
- c) Remote indication for speed as 0/4 - 20 mA standard signal
- d) Motor current as 4 - 20 mA standard signal
- e) Combined fault
- f) Remote indication of the set speed potentiometer as a 0/4 - 20 mA standard signal
- g) All Switchgear faults and "Racked-Out" events





## h) Other controls and indications

All event signals and check back signals must be made available on the terminal strip as floating change-over contacts.

**System perturbation**

The perturbation caused by the voltage harmonics in the feeding three-phase system, which are a result of the converter drives, must not exceed the specified limit values, i.e. 5% for the 5th harmonic voltage, 4% for the 7th and 2% for each of the 11th and 13th. IEC 60801.1 - 60801.4 are also to be observed in this connection. The system perturbations are to be curbed by means of suitable measures if necessary. The contractor is responsible for demonstrating conformance with the above-mentioned limit values.

**B0.6.18.12 Cable and cable trays****B0.6.18.12.1 Cable laying and routing requirements**

The Contractor responsible for cable routing and laying has to observe a strict unit separation. The cables must be routed in different cable channels or, as the minimum requirement, on different cable trays, so that in case of a fire or any accident in a cable channel or tray two units will not be affected. Further in case of two critical drives of the same unit with both drives operating in normal conditions cable for the same shall be routed through two completely redundant routes.

On vertical cable risers, walls and ceilings the cables must be secured with corrosion-resistant cable clips (e.g. cable clamps with cable protecting cable sleeves).

Cable risers near gangways or in electrical rooms that are exposed to possible mechanical damage are to be protected up to 1 meter from ground by suitable metal cover.

All holes in ceilings, floors and wall made for cable routing must be sealed fire-resistant, when the cables have been laid. This also applies to switchgear panels and cubicles, passages between cable ducts, at vertical risers etc. As there is an increased danger of fire during the construction period the holes shall be fire-resistant sealed at that stage already. This applies especially to vertical runs.

When the cables are no longer supported on cable trays or risers etc. the power, DC and instrument transformer cables must generally be run singly in galvanized steel conduit. With lighting cables, measuring and control cables and telephone cables, several similar cables can be run in one conduit. Surface-mounted conduits must be secured every 1.5 m.



000173



The control and communication cables must be laid sufficiently apart from the power cables so that no interference will occur and the transmission of fault signals is excluded. For this purpose the following minimum separations are to be observed:

- 300 mm between low voltage power cables and measuring and control cables at voltages of 60 V and below,
- 300 mm between power cables and measuring and control cables at voltages above 60 V,
- 600 mm between medium voltage power cables and measuring and control cables at voltages of 60 V and below.

The laying of cables outside of buildings should be preferably on cable bridges that preferably are to be naturally ventilated. If the cables are laid in the ground, after excavating the trench a layer of sand must be introduced. On the sand the cables are laid separately from each other according to voltage systems. The cables must be laid at a depth of 0.8 m at least. The trench is filled with sand and covered with concrete covers or bricks. The thermal resistance of the backfilling shall not exceed 150 Kcm/W. A ground temperature of 28 °C has to be considered. Where cables have to pass under streets cable duct blocks with a suitable bore(s) should be provided. The marking of cable routes by cable warning tapes must be provided.

When laying the cables on cable trays, cable risers, cable channels, etc. and when choosing the size of the cables care must be taken that sufficient ventilation is available and that there is no possibility of thermal overheating, or strain on the cables.

Cables that must move with connected apparatus owing to thermal expansion (e.g. boilers) must be provided in a flexible form or they must have sufficient slack at the location.

All the ends of the cables must be prepared according to the particular requirements of the manufacturers and connected to existing terminal strips, terminal screws, apparatus terminals, etc.

The necessary cable sealing ends and the stripped and fanned-out cable ends, where no sealing ends are provided, must be fixed to the appropriate supporting structures.

#### B0.6.18.12.2 General cable construction requirements

The medium and low voltage cables shall be of Fire Retardant Low Smoke (FRLS) with XLPE insulation. For cables that are exposed to ambient temperatures above 60°C, teflon or silicone cables are to be provided.

For safety related equipment fire survival cables shall be provided.





The cables must be suitable for laying indoors, in the open (direct or indirect sunlight), in ducts, on trays, in the ground and in water. The cables must be resistant to solar radiation, the effect of oil, seawater, bacterial action, insects and rodents. Outer sheaths are to be manufactured from non-combustible or flame retardant low smoke material.

Manufacturers testing standard related to resistance to solar radiation, effect of oil, seawater, bacterial infection, insects and rodents, will be accepted.

All cables must be provided at both ends, at every 20 m and every bend with identification in the form of numbered labels corresponding to the coding system. The individual cores will be numbered or identified by colour-coding.

The cables must be laid to ensure that they can be replaced or renewed in a simple manner.

#### B0.6.18.12.3 Medium voltage (MV) power cables

The design of the MV cables shall be screened, stranded, single-core or three-core copper conductor cables of FRLS with XLPE insulation. The cable shall be sealed with a red, non-fading PVC outer sheath. Three-core cables shall be designed with individually screened cores.

The MV power cables must be designed for the thermal and short-circuit characteristics of the electrical systems, taking into consideration the following minimum short circuit duration:

- for incoming cables and cables to sub-distribution: fault clearing time of the back-up protection.
- for all other cables: the fault clearing time of the main protection.

The cables must be terminated and connected to the indoor metal-clad switchgear or the sealing ends are installed in cable connection hoods mounted on the power transformers.

In the event of outage of the air-conditioning plants of the switchgear buildings the internal and external conditions will become the same. Therefore, sealing ends are to be used which shall be suitable for the maximum conditions at site.



000175



#### B0.6.18.12.4 Low voltage (LV) power cables

The low voltage power cables shall be standard single and multi-core cables of FRLS with copper conductor and XLPE insulation.

To ensure the elimination of excessive contact potentials on any object, effective earthing must be carried out as a safety measure and suitable 3-core, 4-core and 5-core low voltage power cables must be provided. The minimum conductor cross-section of the low voltage power cables is 2.5 mm<sup>2</sup>. If 3 1/2-core cables are used, the reduced conductor for protective neutral must have a cross-section of at least 16 mm<sup>2</sup>. In lighting systems (especially discharge lighting circuits) the use of a reduced conductor for the protective neutral is to be avoided.

Depending on the site conditions the DC cables must be single-core, 2-core or 4-core. Between batteries or rectifiers and the DC switchgear single-core power cables should in general be used.

The LV power cables must be designed for the dynamic and thermal characteristics of the electrical system and for continuous operation.

#### B0.6.18.12.5 Current carrying capacity of power cables

The ratings for continuous loading of the cables shall be calculated according to the relevant IEC regulations. The Contractor must submit corresponding tabulations for all cables to be used.

The maximum voltage drop under normal conditions shall not exceed 2.5%.

Voltage drop during starting shall be considered as 15% & during running 3%.

The voltage drop between the MCC and the terminal of the load shall not exceed 2.5%. It is assumed that the switchgear and the MCC are connected by bus-bars/- ducts means the voltage drop is very low.

The voltage drop for MV Cable Shall be limited to 3% and for LV Cables:

- The voltage drop on the LV cables from Main Distribution to subdistribution shall not exceed 2.5%
- The voltage drop up to the LV motor terminals shall not exceed 5% at normal operation and 15% during starting.

#### B0.6.18.12.6 Measuring and control cables above 60 V/ instrument transformer cables

For voltages above 60 V the cables shall be of Fire Retardant Low Smoke (FRLS) with PVC insulation and a mini-mum conductor cross-section of





1.5 mm<sup>2</sup>. If they lead to outlying buildings, cables with a common core screen and protection against induction must generally be used.

For instrument transformer cables inside buildings the minimum conductor cross-section must be 2.5 mm<sup>2</sup>.

Instrument transformer cables leading to outlying buildings must have a minimum size of 4 mm<sup>2</sup> and must generally have a common core screen.

The maximum voltage drop shall not exceed 2%.

#### B0.6.18.12.7 Measuring and control cables below 60 V

For voltages up to 60 V, measuring and control cables shall be of FRLS with PVC insulation and shall have stranded or solid copper conductors of minimum 0.8 mm diameter. Multi-pair control cables with paired lay-up of the leads and lay-up of the pairs themselves shall be used.

Instrumentation cables shall be identified by colour codes and bank marking as per VDE 0815.

Wherever necessary, e.g. for all cables leading outside the relay rooms and/or control rooms, the control cables shall have a common screen (Al-foil or Cu-foil).

Cables must generally have appropriate electrical protection against inductive/resistive influences and lightning.

The required compensating wires for temperature measurements must be at least 0.5 mm<sup>2</sup>.

The maximum voltage drop shall not exceed 2%.

The individual cores of the multi-pair control cables shall be identified by numbers or a colour coding system.

Minimum size of 0.5 sq mm shall be considered for wiring including for control cabinets.

#### B0.6.18.12.8 Fiber optic cables (FOC)

All fiber optic cables as well as their deployment and the entire test procedure shall comply with IEC 60794. The cables shall be able to operate continuously in temperatures up to 70°C. The fiber optic cables shall be loose tube type with the fibers fed into tubes. The tubes shall be sufficiently strong to hold their shape and provide protection for the fibers against deformation and friction. Each fiber shall be colour coded acc. to IEC 60304.





Buried fiber optic cables shall always be laid inside adapted conduits. Installation shall ensure rodent protection and be water tight. The conduits system shall supply all equipment necessary for the deployment acc. to FOC manufacturer's specification. Occupancy shall allow future cable installation.

For out-door applications cables shall be suited for out-door deployment, longitudinally water tight, filling material standardized for all cables, yield minimum 3,000 N.

The fiber optic cables shall be complete with non metallic strain relief elements. Fiber optic cables that are installed outdoors shall be armored. Cables used indoors shall be reinforced with a steel wire braid.

Graded index fibers cables and monomode fiber cables shall comply with IEC 24702:

Graded index fibers cables shall consist of always 24 fibers

- fiber - type 50/125  $\mu\text{m}$ , OM-3.

Monomode fiber cables shall consist of always 24 fibers

- fiber - type 9/125  $\mu\text{m}$ , OS-1.

19" patch panels shall be used for termination, connectors shall be LC-Duplex as standardized by IEC 61076-3-106 var. 4. All fibers shall be terminated / connected.

Each fiber of all FOC shall be deployed and tested according to IEC 60794. Resulting test protocols of all single fibers of all FOC shall be handed over to the Employer, stating all details in written.

#### B0.6.18.12.9 Cable supporting structures

##### Construction requirements

Basically, pre-fabricated cable trays, cable risers, hanger rods, screws, clamps and all fixing material of corrosion-resistant finish, hot-dip galvanized, shall be used. If in certain sections the use of trays and risers is not possible, cable racks are to be provided in such places. These shall be made of corrosion-resistant, steel angle Sections, hot dip galvanized. The steel angles must be cut to size on site and exposed cut surfaces must be suitably treated on the spot to prevent corrosion before being fitted. The minimum requirement for this treatment is the application of an anti-corrosion layer of zinc coating.

FICHTNER



B0-165



All cable tray T-junctions, cross-overs, vertical and other shelving, bends, etc. must consist of pre-fabricated tray elements so that crushing of the cables at these transition points is avoided.

The cables laid on the trays must be carefully arranged and ordered. All cable tray routings consisting of several individual cable trays that are located outside buildings and exposed to the sunlight shall be provided with sun-shades made of the material as described for the cable tray equipment. In all areas where an accumulation of coal dust must be expected, e.g. coal handling plant, conveyor belt ways, bunker area, the cable trays shall be installed vertically.

The trays and risers must be installed in such a way that in accessible manways an escape route at least 800 mm wide by 2100 mm high is available for the personnel.

For safety reasons the lower parts of the hanger rods and all other exposed parts in manways and escape routes must be fitted with plastic covers.

In indoor installations hot dip galvanized material with an average coating thickness according to ASTM A123/123M is to be used.

In all external areas, in semi closed buildings and in areas with corrosive gas or steam, Fibre Reinforced Plastic (FRP) cable trays tested according to international standards shall be provided.

The cable trays must be designed to ensure that there is 5% spare space on all trays when commissioning and handing-over is complete.

The fixing materials for the cable trays and risers must be corrosion-resistant or at least be hot-dip galvanized. The rods, brackets and risers must be fitted with appropriate support brackets to be fixed to anchor rails or fixed by dowels and screws in walls and ceilings.

Welding to steel structures and the welding together of hot-dip galvanized cable-laying accessories is not permitted.

After completion of the cable-laying work the maximum deflection of the cable trays shall not exceed 2.5 mm per 1.5 m (specified distance between two hanger rods).

#### B0.6.18.13 EMC measures

All EMC measures shall ensure that during subsequent operation, no impermissible malfunctions or damage to equipment occurs due to violating electromagnetic compatibility.





The description of the measures is not limited to this chapter, but also forms a part of other chapters, in particular "Protective measures", "Earthing and lightning protection" and "Cabling".

The EMC requirements are set out in the following.

Under consideration of the conditions and constraints, the equipment used shall emit the lowest interference signals and exhibit the highest immunity to interference.

All equipment items shall operate properly when connected to networks with a power supply corresponding to the maximum permissible tolerances as laid down in EN 50160 (as regards, harmonics, voltage fluctuations etc.).

Priority is given to reducing sources of interference.

Additionally, by means of high-capacity screening, generation of overvoltages due to inductive or capacitive coupling shall be reduced. Influencing by electrical and magnetic fields shall be reduced.

Earthing and potential equalization systems designed for low-impedance shall reduce generation of overvoltages due to ohmic coupling. If EMC resulting from the measures named above is still not adequate, further measures shall be taken within buildings, for example by isolation and suppressor circuits.

Thanks to the lightning protection and screening measures taken at the buildings, within them an EMC protection zone is formed.

All installations penetrating this protection zone, that is where they pass through the external walls of buildings, shall be incorporated into a lightning protection-potential equalization system as close as possible to the points of entry and exit of the building. This applies also for conductors carrying a potential. At entry or exit, these shall be included in the lightning protection-potential equalization system by way of suppressor circuits.

Cable runs to outdoor plant components and between buildings may also be screened by appropriate measures, and so form a part of the protection zone. If this is done, the suppressor circuit can be dispensed with.

A suppressor circuit shall be provided at all low-voltage main distribution boards.

Overvoltage protection shall be foreseen within the power supply for both central and distributed power supplies to electronic cubicles.

All conductive parts of the structures and installation within the scope of the contract must be connected to the main earthing system.





All steel Sections or frames must be provided with at least two earthing straps for every frame or Section that is fabricated from parts welded together. The earthing straps shall be located at the ends of the beam Section or frame Section in every case.

The Contractor must provide earthing straps in front of and behind the screwed connection in every case and these straps must be interconnected, using stranded copper, and connected, at least at one point, to the main earthing system, except the Contractor verifies that the type of screwed connection applied is a permanent electrically conducting one. Tanks and vessels containing flammable liquids or gas shall be earthed by a connection to the earthing grid or by bonding to earthed metal structures.

Each pipe shall have a minimum of one connection to the earthing system. In areas where flammable vapor-air mixtures may exist, electrically isolated Sections of metallic piping shall be connected to the earthing grid.

All flange connections in these lines shall be bridged by flexible stranded copper. Earthing tabs shall be provided at each flange.

When connecting differing materials together the required material transition plates must, in general, be inserted. All connecting materials must be corrosion-proof and suitable for the conditions prevailing at the installation point.

Railway lines, together with electrically conducting pipelines leading outside the power station place must be insulated or be fitted with intermediate insulating links or elements.


Each cable tray and cable riser of less than 20 m length have to be earthed once; structures of more than 20 m length have to be earthed twice.

#### B0.6.18.14 Requirements for local cubicles and local housings for e.g. switchgear, control, measurement and signalling equipment

Steel-clad cubicles and enclosures with fixed, integral switchgear and apparatus must be provided.

The switchgear cubicles must be partitioned off and incorporate a busbar system, the necessary instruments, control switches, switch panels of the individual switch and apparatus chambers. The main busbars are to be installed on the rear face, top side of the switchgear cubicle in a lockable shuttered compartment.

Connections to switching devices, MCB's fuses etc. are to be made from these busbars. The lower part of the cubicle will house the terminal strips and connecting blocks, the clamps for the cable terminals and, if required parallel connection copper straps for the connection of more than 2 cables in parallel. An adequate number of ball studs must be provided within the





switchgear cubicle suitable for earthing the main and distribution busbars as well as the switchgear itself by means of portable earthing and short circuiting equipment (to be provided once per switchgear panel row).

The space in the interior of the cubicles must be divided into a Section with 'live' parts, 'live' switching elements etc. and a Section with control and measuring equipment. The Sections are to be separated by reinforced sheet-steel.

Care must be taken that in the event of arcing hot gases will not escape to the front of the cubicles (the operational side).

Ammeters are to be provided on the cubicle front panel for the cubicle feeders and the supply outlets for motors higher than 55 kW or motors of lower rating, but particularly important for the process. A single voltmeter with 4-position voltmeter changeover switch must be provided for measurements of busbar voltage between each phase and neutral. Measuring instruments should, in general, be square in shape.

All cubicles, cabinets, panels, etc. shall be designed for an ambient temperature of 40 °C (outside the enclosure) in non-air conditioned areas. Special precautions shall be taken in the design of electronic devices for protection and control systems housed in the cubicle in order to allow for these conditions.

Heating elements are to be provided generally in each local cubicle or cabinet and shall be humidity controlled.

It must be possible to disconnect power supplies to the cabinets by means of manually operated power circuit-breakers (MCBs).

For easy monitoring and a rapid grasp of the operational state, collared mimic diagrams with the required switch position indicators, apparatus symbols and pilot lamps must be provided in every case on main process cubicles and switchgear cubicles. Lamp test facilities for all signed lamps connected shall be provided. All cubicles shall be provided with the required earthing screws.

Plastic-insulated, stranded conductors must be used for wiring within the switchgear cabinets, which must be numbered at each end with special tabs so that change by mistake is impossible.

Preferably plug-in type auxiliary relays are to be used. Apparatus being sensitive to impact must be protected against shock and vibration.

On completion of hand-over the cubicles must contain at least 5% of full fitted spare terminal capacity and 5% of spare space for the future installation of extra equipment. It shall be possible to replace indicating lamps on the front panels of cubicle feeders and motor-supply outlets





without isolating the equipment concerned. Furthermore the control system must be designed in such a way that lamps operate at less than their rated voltage in order to avoid their being overheated.

Incoming and outgoing cables have to be fixed by suitable metallic cable glands.

#### B0.6.18.15 Local control points and level control cabinets

##### B0.6.18.15.1 General

Any electrical consumer unit, which is not controlled automatically or from the central control room, is to be fitted with a suitable local control cabinet. The local control cabinets are to be installed in the immediate vicinity of the motor drive to be controlled.

Pump motors, which are level controlled locally, will be given an automatic and manual control. The respective level control cabinets are to be fitted in the immediate vicinity of the pump motors, gauge glasses or level monitoring instruments.

##### B0.6.18.15.2 Construction requirements

In general local control cabinets and level control cabinets with plastic casings resistant to impact, sand, light and water, mounted on walls or hot-dip galvanized supporting constructions, are to be provided. Hot-dip galvanized casings will be acceptable.

Protection class must be at least IP 54 if installed indoors and IP 55W if located outdoors. The necessary earthing terminals must be provided for earthing purposes.

The cabinets must be equipped with the necessary mini circuit breakers, fuses, auxiliary relays, power contactors, terminal blocks and cable attachment components.

For motors with pre-selection control (operation/stand-by) operation hours counters are to be provided.

In hazardous areas, the necessary explosion proof control cabinets and level control equipment must be provided in accordance with IEC 60079, IEC 61241 and VDE 0165/170/171.





### B0.6.18.15.3 Local control points

The local control points are to be equipped as the minimum requirement with:

- ON button
- OFF button
- Running lamp
- FAULT LAMP
- TRIP HEALTHY indication
- Lamp test.

When two motors are installed, serving as operation and stand-by unit, then in addition to a double set of the above items, the following equipment has to be installed as the minimum requirement:

- MOTOR 1 - MOTOR 2 (running motor/stand-by motor) pre-selection switch,
- automatic transfer to the stand-by motor in case of failure of the running motor.

### B0.6.18.15.4 Level controls

In the case of pump motors controlled by levels, in addition to the level control in each case the MANUAL - AUTOMATIC selector switch and the necessary local points are to be fitted. Control of individual pump motors must be effected as follows as the minimum requirement:

- MANUAL- AUTOMATIC selector switch
- level control with maximum and minimum contacts
- low level contact on motor - OFF
- bottom maximum contact on motor - ON
- top maximum contact as warning to the central control room
- low-low level contact as pump dry-running protection and alarm signal to the central control room
- local control point with ON and OFF button, running and fault lamp.

When two pump motors are installed for the same purpose the control is to be effected as follows, as a minimum requirement:

- MANUAL - AUTOMATIC selector switch
- PUMP 1 - PUMP 2 (running pump / stand-by pump) pre-selection switch
- level control with three high level contacts:
  - first (1): high level contact for pre-selected ON
  - second (2): high level contact for alarm signal to the central control room
- low level contacts for pumps OFF
- low-low level contacts as pump dry-running protection and alarm signal to the central control room



000184



- local control and lamps as listed above for local control cabinets, for each motor

#### B0.6.18.16 Terminal boxes and terminal cabinets

In order to minimize the amount of cables and distribution of signals and to centralize connections in the Plant, terminal boxes or, wherever necessary, by larger amounts of terminals, terminal cabinets shall be fitted on all the necessary

- cable crossover terminal points
- central collecting points for individual analog and binary signals and local transmitters
- signal collecting and distribution points for fire alarm, telephone, loudspeaker and clock system
- central distribution points for local signals.

Terminal boxes and cabinets must at least have class of protection IP 54 if installed indoors and IP 55W if installed outdoors and must be equipped with the necessary terminal strips, cable glands and fittings components for the connection of the cables.

The necessary earthing terminals are to be provided for the earthing of the boxes and cabinets.

In any area subject to the danger of explosion, the necessary explosion-protected terminal boxes and cabinets are to be provided in accordance with IEC 60079 and IEC 61241 and VDE 0165/0170/0171.

#### B0.6.19 Instrumentation and control equipment

##### B0.6.19.1 Main design criteria

This Section applies to the design of the general Instrumentation and Control equipment. The following general requirements shall be strictly observed with regard to design and execution. In the event of contradictions the Contractor shall be responsible for obtaining written clarification from the Employer/Engineer.

Reference within this Section does not automatically indicate that the particular form of instrumentation is required on this project or will be acceptable for a particular application. The particular requirements for control and instrumentation shall take preference in the event of any disagreement between the two Sections.





Only requirements for technical performance of the equipment are stated herein, whilst the detailed requirements of the tasks to be performed by the control systems and the scope of delivery for each individual item of plant is stated in the relevant Sections of this specification.

This specification does not however relieve the Contractor of his responsibility for the basic design and execution of the instrumentation and control system per scope of supply in relevant Sections of this specification. The rules of good engineering practice and the relevant approved standards and regulations shall be observed.


A consistent instrumentation and control philosophy shall apply throughout the Plant and shall be implemented in terms of a range of equipment exhibiting a minimum diversity of type and manufacture. The objective shall be to standardize all measurement and control equipment throughout the Plant in order to rationalize operation, maintenance and reduce spares holding.

Generally equipment shall be supplied from one composite range of measurements and control equipment as marketed by a reputable manufacturer of international standing and shall have a minimum of two years operational use on similar projects. Where particular equipment is not included in the products of the manufacturer thus necessitating diversity of supply, this equipment shall be identified by the Contractor. The equipment shall be of modern, compact design incorporating the latest developments in proven technology. All instruments whether for local indication or remote transmission shall be of good quality and shall have an accuracy and repeatability appropriate to their duty. All fittings shall use metric threads.

Measurement and control instruments shall be matched to the main plant equipment ratings in all aspects. Instrument ranges, installation codes of practice and precautionary measures for safety of the Plant and the operating and maintaining personnel shall be observed.

Special attention shall be paid to the Plant safety. As a general rule, measuring points and measuring equipment for critical protection shall be separate from and not combined with measuring equipment for the automatic control equipment.

The material of all equipment installed in pipes, tanks, etc., shall correspond to the material of the relevant pipes, tanks etc. and shall fully meet the requirements regarding safety and operational conditions of the media to be measured. All the equipment shall be suitable for the location in which it is to be mounted and in particular all outdoor equipment shall be suitable for the prevailing climatic conditions.





The diversity of makes and types shall be kept to a minimum. The Employer/Engineer reserves the right to stipulate make and type following award of contract.

Any equipment to be installed within potentially explosives atmospheres shall comply with the requirements of international standards and codes, e.g. IEC-60079, NEC 500 etc.

The instrumentation and control equipment shall have high electro-magnetic and radio frequency interference immunity and shall not be affected by portable radio transmitters operated in the vicinity of the equipment. Any limitations shall be stated.

All instruments shall be protected by cases. The cases shall have enclosure classification not less than IP 42 according to EN 60529 when mounted indoors in totally enclosed rooms with provision for limited ingress of dust, IP 54 else in a enclosed building and IP 55W for mounting outdoors.

Electronic instruments shall not be located close to hot lines, vessels or other hot equipment. Ambient sun temperatures exceeding 80 °C shall not result in calibration difficulties or rapid deterioration of electronic components.

#### B0.6.19.2 Distributed Digital Control, Monitoring and Information System (DDCMIS)

The Plant will be controlled generally through a DDCMIS. The DDCMIS contains of process stations, operator workstations, engineering workstations, archiving facilities and signal exchange to management and third party systems. In general the DDCMIS will be DCS based hardware only in some exceptions PLC based systems may be applied.

For detailed technical specification and design requirements please refer to **Section B8** of this technical specification.

#### B0.6.19.3 Programmable logic controllers

Programmable logic controllers (PLC) shall be deployed in subsidiary installations and systems of higher complexity and shall provide a more open access for operation. Standard products of PLC manufacturers shall be used for which software developed by the process suppliers and proven for the specialized process is available.

The diversity of makes and types shall be kept to a minimum. The Employer/Engineer reserves the right to stipulate make and type following award of contract.



The use of auxiliary packages with PLCs or local controls for ancillary plants or systems shall be limited and minimized. Only some special cases can be considered subject to the Employer/Engineer's approval.

Typical and acceptable reasons for a specialized control system can be high speed of response or special safety requirements, which may require a separate safety-related system.

For signal exchange with the main DCS, PLCs shall be compatible with this system. Depending on the amount of information to be exchanged, parallel or serial interfacing shall be considered. The sequence of events signals should be directly physically connected to Sequence of Events Recording System (SER).

If only few signals are to be exchanged, parallel interfacing is preferred. Binary signals shall be exchanged via volt free signals. Analogue signals (4 - 20 mA) must be suitably decoupled.

If serial interfacing is used, the interface equipment between the PLC and the DCS must be capable of communication using an industrial standard protocol. The transmission baud rate shall be selected dependent on the application (minimum 19200 baud or higher). If commands are issued from the DCS to the PLC, the time between operator command input and PLC signal output shall not be more than 1.5 seconds. The same requirement goes for answer back signals from the PLC and updating of displays of analogue values coming from the PLC on the DCS monitor displays.

As a minimum requirement, the offered serial link shall have a data integrity checking and retransmission facility in case of error detection, independent of the DCS or external system software. Hardware and software failures during data transmission shall be monitored and alarmed onto the DCS.

The communication link shall be redundant. In case of failure in the communication, quick manual automatic switch-over to the standby communication link shall be possible with automatic switchover and fault reporting and diagnostic facilities.

The functions realized in the PLC and the method by which they are invoked shall be represented graphically similar to IEC 61131-3.

Additionally, a verbal program description supported where required for easy understanding of complex functions with functional diagrams according to IEC 60848 shall be provided.

Programming devices with keyboard, VDU and printer for ease of programming, effective on-line monitoring and diagnostic functions, together with the necessary equipment to write in and to erase EPROMs shall be provided.

The Contractor shall guarantee that spare parts for the offered PLC system will be available for at least 15 years after commissioning of the Power





Plant as well as upward/forward compatibility for future upgrades of the system. If necessary, the Contractor shall provide successive system upgrades to ensure spare part compatibility for that time span.

For local operation and monitoring a panel or desk mounted Human Machine Interface (HMI) unit, operable by keypad or touch screen with LED-displays shall be provided. Protection class of panel mounted HMI (front side) shall be IP 22 according to IEC 60529.

#### B0.6.19.4 Control cubicles

DCS, PLC hardware and other associated control equipment shall be installed in suitable control cubicles. The cubicles shall be set up in local switchgear/ electronic rooms (CER or LER) or in local control centers (LCC). The protection class required is specified under **Section B0.6.18**.

Outdoor installed cubicles shall be provided with thermostatically controlled heating elements in order to prevent the formation of condensate which may occur due to large variations of ambient conditions, if necessary. Adequate lighting and sockets for hand tools protected by 30 mA Residual Current Differential Switch (RCDS) shall also be provided for cubicles and panels, if necessary.

The cubicles shall be secured in such a way that failure of one node cannot cause the failure of the whole system.

The required control elements and displays (annunciation and status lights, analogue displays, switches etc.) shall be so configured that as far as possible they can be viewed from the associated secondary system. Should it be necessary to place the control and monitoring elements in the field, these shall be installed in separate, robust housings (protection class IP 55W). All alarms/ annunciations shall as well be available in DCS.

In preference LED displays shall be used. Ease of access and operation of the equipment shall be ensured.

Visual display unit (VDUs) will be employed for field operation and monitoring.

All cubicles shall be adequately ventilated in order that the heat generated by the equipment mounted there shall remain within the specified limits, even in the case of high ambient temperatures that may occur in the event of failure of the air-conditioning system.

Locally installed cubicles shall be suitable for the location in which they are situated and shall provide adequate protection against dust, moisture or mechanical damage for the equipment mounted therein. Cubicles shall be designed in such a way that vibrations of the building shall be absorbed to a large extent. Sunshades shall be provided for all cubicle located outdoors.





Cable connections to cubicles, panels and desks shall be made via suitable seals so as to prevent the ingress of dust, vermin or the propagation of a possible fire. During installation period, a provisional sealing of cable penetrations shall be ensured.

#### B0.6.19.5 Racks, junction boxes

##### **Marshalling racks**

Separate cubicle type marshalling/ termination panels shall be provided, i.e. field signals shall not be terminated in the rear side of the system cabinets.

Open type racks constructed of angle steel may be used for the marshalling and termination of low voltage control cables within the Central Electronics Rooms (CER & LER). Cubicle type marshalling racks may also be considered.

For voltages exceeding 60 V, a suitably separated Section with isolation cover shall be provided.

##### **Instrument racks**

Wherever possible, instruments and devices, e.g. transmitters, thermo element cold junctions, terminal boxes, located in the field, shall be mounted on local instrument racks. The instrument racks shall be installed with due regard to control engineering needs, material-saving assembly and easy accessibility for maintenance and checking work, and shall be constructed of standard angle Section steel.

##### **Junction boxes**

In order to simplify local collection of cables and distribution of signals and to centralize connections in the Plant the junction boxes shall be fitted on all the necessary:

- cable crossover terminal points,
- electrical actuators,
- central collecting points for individual analog and binary signals and local transmitters,
- central distribution points for local signals.

The necessary intermediate terminal boxes must at least have degree of protection IP 55 in accordance with EN 60529 and must be equipped with the necessary terminal strips and attachment components for the connection of the cables. The necessary earthing terminals shall be provided for the earthing of the boxes. In hazardous areas, terminal boxes shall be in accordance with EN 50019 or 50020, depending on zone classification.

After commissioning, the junction boxes, marshalling racks, instrument racks, etc. must contain at least 10% of spare space. The Contractor shall furthermore provide at least 10% of fully fitted spare terminal capacity.





#### B0.6.19.6 Mimic diagrams

Mimic diagrams shall be offered where specified or alternatively where their presence would assist Plant operators in assimilating the operational state of the Plant.

Where used, the mimic diagram shall harmonize with the other equipment in the control room. Mimic diagrams shall be of the mosaic type.

On mimic diagrams for electrical systems, the different voltage levels shall be distinguished by the use of mosaic elements having an inlaid coloured strip. These elements shall be fitted together to show the location of the different busbars. The operational position of circuit breakers and isolators shall be indicated by semaphore indicators, and the operation of switchgear from the mimic diagram shall be by means of discrepancy switches or pushbuttons designed to operate in a similar manner.

On process mimic diagrams, methods shall be used to clearly indicate the path of the various media, the preferred technique being by means of raised plastic strips which shall have a distinctive colour. Also a uniform scheme of colours for different media shall be adopted.

Where pushbuttons are proposed for operation, enabling pushbuttons shall also be provided and it shall require the operation of both the pushbutton actuating the device and the enabling pushbutton to operate the device.

The Contractor shall propose the mimic colour code for process and electric system identification of the P&ID and electric single line mimics in the VDU or mimic panel.

#### B0.6.19.7 Power supply and fusing

The power supply for the equipment requiring uninterrupted supply (UPS) (e.g. emergency valves, flame monitors, measuring and control system, recorders, printers, VDUs, OWS and servers) shall be taken from the safe AC as described in other parts of the specification, especially **Section B0** and **Section B7**.

The 24 V DC independent supply systems shall be provided for the control cubicles of independent control systems. Ni-Cd or lead-acid planté batteries shall be used in the main plant area whereas in offsite plant areas only Ni-Cd batteries shall be used.

The 24 V DC systems shall consist of 2 sets of power supply with each set consisting of 1 x 100% battery charger, 1 x 100% batteries for 1 hour duty and 1 x 100% DC distribution board.





Each individual consumer shall be provided with an infeed from each set with diode decoupling at the consumer.

The supply voltages for the control cubicles within the central electronic rooms (CER & LER) shall preferably be 24 V DC and must be arranged as separately fused double infeeds. The individual feeders can serve either a single cubicle or several cubicles combined as a logical group.

Intelligent Battery health management system shall be provided for each set of 24VDC power supply system and UPS batteries (except mini-UPS). It shall be connected to DCS.

All battery systems shall be provided with a manual discharge resistance bank.

All equipment shall be adequately protected against overcurrent by means of fuses or other current protection devices. The main power supply fuses shall be located in functional groups within separate power distribution cubicles. Fuse ratings and time characteristics shall be such that in all cases, a fault within an individual item will cause the fuse associated with that item to rupture and thus disconnect that item from the power supply, before the main fuse is affected.

Failure of a main fuse shall affect the overall operation of the Plant as little as possible and shall be indicated in the central control room (CCR) by means of an alarm. This alarm shall state the identity of the failed main fuse.

Failure of an individual cubicle, module or component fuse shall be indicated by a general alarm and a detailed diagnostic message. The Section of the control cubicle in which the fuse is located shall be indicated. It shall also be possible to locate visually the fuse that has failed.

The design of the electrical power supplies and fusing system must ensure that any faults in modules or other devices, which may block sequence logic interlocks, automatic control systems or other control systems, are restricted to the system in which the fault has occurred.

All electronic devices shall be protected against transient voltage levels which would otherwise damage the device.

#### B0.6.19.8 Transmitters

All transmitters shall have an impressed output signal of 4 - 20 mA corresponding to zero to full range input. However, digital communication shall also be acceptable.

Generally, 2-wire transmitters shall be used. If for some special purposes (e.g. analyzers) 230 V AC power supply is required, the output circuit shall be isolated.





As far as possible, all transmitters shall be of the SMART-type. This applies also to field mounted temperature transmitters.

All transmitters shall be fitted with a local analog or digital indicator displaying appropriate physical units which may be read clearly from an easily accessible position.

Transmitters with accuracy class "0.5" or better must be used. The repeatability shall be within a range of  $\pm 0.1\%$  of full span.

The output signal of all transmitters must be independent of the burden of the transmitter output circuit including cable resistance over a wide range.

The removal of connected devices must not open the transmitter output circuit or cause malfunction of this circuit. In the case of failure and return of the supply voltage within a measuring circuit, no false signals endangering the system shall be issued. All transmitters shall be individually fused. If not specified otherwise, local parameterization at the transmitter or via modem and PC/laptop or hand held communicator using HART-protocol shall be possible.

For the continuous remote position indication of valves, dampers etc. also transmitters with impressed output signal of 4- 20 mA shall be employed.

All transmitters shall be suitable for field installation and shall have strong, moisture and dustproof cases of IP 65 or better according to EN 60529. This applies also for temperature transmitters when installed in the field.

Diaphragm seals shall be provided to serve as a barrier for corrosive process fluids, slurries or highly viscous oils. The seal shall be of the flanged type, suitable for the same conditions as those for the transmitter. The material selection shall be according to the requirements of the fluids to be measured. The seal shall be provided with a flushing connection.

Transmitters to be used in hazardous areas shall be explosion proof. Suitable intrinsically safe circuits are to be provided in accordance with EN 60079-11.

All transmitters potentially subjected to vacuum shall be capable of withstanding 100% vacuum without damage.

No stress shall be imposed through the connections between Plant and the transmitter. As far as possible, the transmitters shall be grouped together into enclosed racks or panels for easy access. Sunshades shall be provided for all outdoor panels.

Individually installed transmitters shall have their own weather proof enclosure of robust construction and be suitable for the proposed





environment. All field equipment terminals shall be wired to a terminal box using screwed connections.

Transmitters shall be provided with all necessary isolating, vent and blow-down valves and facilities shall be provided for the connection of test instruments at the input and output of each transmitter, to enable calibration to be carried out.

In general limits (for alarms or switching actions) shall be derived from the analogue measurement value in the DCS (use of switches shall be avoided). Where binary signals cannot be derived from an analog value, **binary transmitters** e.g. temperature switches, pressure switches etc. may be used. Indicators with integrated limit switches are allowed within package units. Preferably limit switches shall be of the proximity type.

All switches shall be of robust design and reliable performance. Temperature switches, pressure switches, level switches, and etc. shall be of the snap-action and change over type. The switches shall have an adjustable switching hysteresis. Parity checks shall be supplied for switches. (Note: Parity checks refer to the supervision of switches, i.e. it shall be supervised that switches have one defined state and are not undefined e.g. neither open nor closed. Finally this means that there have to be 2 DI to be used for each switch, one for "open" detection and one for "closed" detection.)

The set point and the deadband (reset point) of each switch shall be adjustable from inside the case, over the full range specified. The set point and reset point shall be indicated on the adjusting mechanism.

For the sensing of level in tanks, vessels or bunkers float switches, vibration level switches or other suitable switching devices with conductive or capacitive electrodes shall be provided.

For monitoring of machine coolant or lubricant flow (dry running protection) suitable flow or level sensors shall be employed.

The switches shall be housed in robust, dust and moisture proof cases having glanded cable entries and shall be suitable for the ambient conditions local to the equipment on which they are mounted.

#### B0.6.19.9 Temperature measurements

Glass thermometers, bi-metallic and capillary remote thermometers are used for local temperature measurement. For both, class 1.0 shall be provided.

Glass thermometers are to be inserted into pockets provided for the purpose. The use of mercury is forbidden.

Capillary remote thermometers shall be with a case diameter of preferably 160 mm and must be mounted on fixtures or instrument panels in such a





way that they are protected from vibration, jarring and sprayed water. The capillary tube must be laid in a protected position.

If possible, resistance thermometers (Pt-100) in accordance with IEC 60751 shall be used for remote measurements. All resistance thermometers shall be wired according to the four-conductor principle.

Otherwise, thermocouples with appropriate heat resistance in accordance with DIN IEC 60584-1 or equivalent may be used for remote measurements.

All thermocouples shall be of the quick response type, ungrounded and preferably of double element type.

Thermocouples shall be arranged in such a way that the ambient temperature of the head is lower than 100 °C, and that the measuring inserts can easily be exchanged.

All thermocouples and extension leads shall be terminated with a suitable gland and the conductor to sheath resistance shall be greater than 100 M-Ohms when tested after termination.

Thermometers and thermocouples shall generally be fitted in protective wells. They shall be provided with weatherproof terminal heads and shall be installed so as to totally prevent the ingress of foreign matter.

High speed response pockets shall be provided for all applications involving control of critical process temperatures. Thermowells with high speed of response shall be used.

Where more than one temperature measurement e.g. for redundant loops, recording, indication, automatic control is to be made at one location, individual protective wells with sensors shall be provided at the common place of measurement. Protective wells for unoccupied test measuring points shall be arranged with the opening inclined downwards wherever possible and shall be provided with a screw-on protection cover.

Insofar as local conditions or extreme temperature do not require otherwise, screw-in immersion wells for exhaust gas and air shall meet the following requirements:

- nominal length not less than 0.5 m
- attachment of the well in the wall of the exhaust gas channel or air duct must be gas-proof.

For the measurement of temperature of other media the following requirements shall be observed:

For all pipework a minimum immersion depth of 55 mm in the internal pipeline cross-section and a minimum distance of 15 mm from the opposite





pipe wall must be provided. If the diameter of the pipeline does not allow the thermometer to be inserted perpendicular to the pipe axis while still maintaining the above mentioned measurements, another solution must be found in cooperation with the Employer/ Engineer. When determining the lengths of the insertion and connecting tubes the insulation thickness is to be taken into consideration.

For all remote temperature measurements (i.e. for RTDs and TCs) transmitters shall be installed locally in a transmitter protecting box on a DIN rail.

#### B0.6.19.10 Pressure measurements

Pressure gauges of class 1.6 or better must be used. The standard measuring ranges must be selected with regard to the maximum operating pressure.

A pressure instrument installed for measurement of steady pressure at varying pressure shall operate in a band centered on 60% of its maximum range.

When the pressure impulse line is liquid filled the measuring unit shall be compensated for static head. The head correction shall be stated on the unit.

Pressure gauges shall have a dial size of 160 mm and shall be located in such a way that they can be easily observed or shall be combined in groups on local gauge boards or cubicles.

Pressure gauges shall be resistant against vibrations. Furthermore, pressure gauges shall be designed in such a way that the measured value may reach the end of the indicating range without affecting the calibration of the gauge.

Pressures to be remotely indicated, recorded or used for automatic control loop inputs shall be measured by means of pressure transmitters (refer to relevant part of **Section B0**).

Pressure measurement tapping points shall generally be in accordance with the specification for the pipeline in which they are installed and shall be equipped with one, and for high pressure installations (45 bar) two, isolating valves arranged directly at the tapping point. Excluded from this stipulation are measuring points for vacuum and measuring points for combustion air and exhaust gas.

Piping shall be of approved quality and sized for the particular service. In all cases the pipe size shall be chosen to ensure strength and freedom from blockage. Instrument impulse pipework shall be manufactured from a suitable grade of stainless steel to the approval of the Employer/Engineer.

Pressure transmitters for remote measurement shall not be mounted directly at the tapping point, but shall be arranged at a distance from the tapping



point by means of enclosures. The impulse line between tapping point and transmitter shall be arranged in such a way as to form a siphon loop, when steam pressure measurements are involved.

A valve combination or multiway cock shall be provided directly on each pressure gauge or transducer connection. They shall be equipped with a connection for test gauges, and it shall be possible to shut off the test connection without isolating the service pressure gauge at the same time.

Open blowdown / drain connections shall not be arranged within panels and local equipment. Instead it shall be led to a drain external to the panel. All valves shall be installed so that they are accessible for in-situ maintenance from a floor or permanent structure landing.

Transmitters are to be protected from the measuring media, if required.

In addition to the above requirements, special valve block equipment shall be provided, where differential pressure is to be measured. Alternatively, differential pressure type transmitter can be considered.

#### B0.6.19.11 Flow measurements

Remote flow measurements of water, steam, combustion air, flue gas etc. shall, unless otherwise specified, be carried out by means of differential pressure, ultrasonic, electromagnetic, annubar, coriolis, turbine meters, oval-wheel flow meters.

The transmitters shall be as specified under **Section B0**. Changes in density, pressure or temperature of the measured medium shall be compensated wherever necessary.

Tags on orifice plates shall be stamped with the basic design information (i.e. flow rate, pressure and temperature of the passing fluid, the orifice diameter and the pressure differential generated).

Primary elements such as orifices or nozzles located in steam or high pressure feed water pipes shall be of the weld-in type. Material, dimensions and installation of orifices, nozzles and tapping points etc. shall be in accordance with the specification for the pipes in which they are installed.

Orifice Plate installation using Weldneck Flange assemblies shall be offered. Tappings shall be on the flange and not on pipe.

Isolating valves shall be provided at the tapping points of the orifices/nozzles. In the case of steam flow measurements condensing vessels (steam traps) shall be provided between the tapping point and the isolating valve.





The material and dimensions of the piping shall conform to those laid down for the piping concerned. The welds shall be executed in such a manner as to avoid turbulence that can affect the measurement.

In order to achieve exact installation, the vendor supplying the orifice plate or nozzle for high pressure pipes shall install the orifice plate or nozzle in its own works in a Section of pipe of about 3.5 times the pipe diameter (1.0 x NB in the outlet, 2.5 x NB in the inlet). For orifice plates or nozzles installed in pipes with a nominal bore smaller than 80 mm, complete meter runs shall be supplied.

Orifice plates and nozzles shall be manufactured of ANSI 316 Stainless Steel unless specified otherwise. Orifice plates shall be sized according ISO 5167-2.

Orifice plates shall be sized for a  $d/D$  ratio not less than 0.20 and not greater than 0.70. Higher rather than lower  $d/D$  ratio are preferred to minimize line restrictions. All sizing calculations shall be submitted to the Employer/Engineer for approval.

Tags on orifice plates shall be stamped with the basic design information (i.e. flow rate, pressure and temperature of the passing fluid, the orifice diameter and the pressure differential generated).

Venturi tubes according to ASME MFC-3M shall only be considered when operating economy requires low permanent pressure losses.

The erection welding seams shall be executed in such a manner that no turbulence, which will affect the measurement, can occur.

Rectangular venturi tubes may be considered where other measuring devices are impossible or impractical (e.g. in large rectangular air duct of boilers).

For flow measurements in LP-systems e.g. water or condensate, orifice plate installation using slip-on orifice flanges shall be provided. All orifice plates for installation between flanges shall have their own tapings for differential pressure measurements incorporated in the plate. Simple orifice plates with the tapings situated in the pipe are not allowed. The flow direction shall be consistently marked on the orifice or nozzle by means of an arrow.

Special conditions may dictate the use of devices such as:

- venturi tubes for low pressure gases
- pitot tubes such as Annubar.

Ultrasonic flow sensors shall provide a double transmitter/ receiver system and be for installation with a calibrated pipe. The tube lining material shall be as required for the fluid and its temperature and be as specified in other chapters of this **Section B0**. The use of ultrasonic clamp on flow meters shall be avoided and requires dedicated approval of the Employer/Engineer.





The accuracy shall be 1% of the calibrated span. An overpressure security shall be provided of 50% above the maximum pressure range.

Electromagnetic measurements may be used for flow measurements of inhomogenous liquids with or without solids content in completely filled pipes. The limits of application of the measuring system due to the medium parameters planned on a case-by-case basis shall be observed. Inductive flow sensors shall be of alternating field or pulsating DC field type and be for inline installation with a pipe.

The tube lining material shall be as required for the fluid and its temperature and be as specified in other chapters of this **Section B0**. The accuracy shall be 1% of the calibrated span. An overpressure security shall be provided of 50% above the maximum pressure range.

Coriolis measurements shall be used for mass flow measurements of homogenous liquids and gases without solids content in completely filled pipes, in particular for natural gases, fuel oils and solvents as well as other media with fluctuating densities. The accuracy shall be typically at 0.5% of the measured value.

#### B0.6.19.12 Level measurements

Where detection of discrete levels is required, the simple float operated switch should be used, however each switch shall have snap action with limited hysteresis to prevent contact bounce caused by small fluctuations in level. For sumps the level should be measured using non-contactive measuring principles such as ultra sonic with local control box.

Switches used for level detection shall provide facilities for testing the mechanical and electrical operation of the switch without its removal from the process. Isolation by means of shut-off valve will be allowable during testing.

Generally, the use of switches shall be avoided. Instead limit values shall be derived from analog transmitters.

For measurement of large storage tanks, the load indication and transmitting mechanism shall be located at the base of the tank.

For the measurements of boiler separator water level, feed water tank levels etc., differential pressure transmitters shall preferably be used.

The transmitters shall be as specified under **Section B0**.

For special applications such as chemical tanks, techniques such as ultrasonic, radar, capacitance probes, etc. should be considered. For level measurement in tanks with underpressure (vacuum) guided wave radar shall be used.

For level measurement of the fabric filter (FF) hopper dust radio frequency (RF) / Capacitance type level switch can be considered.





For measurements where a reference leg of process fluid is used, the design of the system shall ensure that the reference leg is fully maintained at its prescribed height during all conditions of process level change and changes in process conditions and the density of the reference leg does not vary from that of the process fluid due to temperature changes or other reasons.

All measurement transmitters for differential pressure shall be provided with:

- a. shut-off valves to be arranged directly at the condensing vessels and active pressure tapping points
- b. valve blocks enabling the transmitter to be isolated from the active pressure and enabling the transmitter zero point to be checked
- c. separate blow-off valves for cleaning the active pressure tubes.
- d. 2 ways for relative pressure, 5 ways for DP.

The aforementioned valves shall be of the weld-in type.

Where a standpipe exists, the level transmitters or level switches must be connected to the standpipe by means of shut-off valves, so that the units can be replaced easily in service.

Local level indicators for water shall be provided with an illumination device and indicators shall be designed so that the water column can be seen as whole, i.e. level indicators only showing the level as a point will not be accepted. Level indicators shall be equipped with shut-off valves which permit exchange or replacement of glasses or mica during operation.

The indicating range of local level indicators shall cover all switching points of level switches mounted on the tank or similar as a minimum requirement.

On all forms of measurement all parts of the switch, transmitter, etc. in contact with the process fluid shall be made of material compatible with the process fluid. Stainless steel shall normally be used for all corrosive duties.

#### B0.6.19.13 Analysers and monitoring systems



##### B0.6.19.13.1 Analyses of steam and water (SWAS)

The steam and water analyzer core instruments shall comply with EPRI (Electric Power Research Centre Inc.) guidelines.



The main analyzers for steam and water shall be arranged in groups in such a way that excessively long process pipes will not be necessary.



If required by the medium to be analyzed, all samples shall be adequately cooled and pressure reducing devices shall be provided where necessary. Manual sampling shall be possible.

A protective device shall be incorporated in the sample cooler to isolate the analyzer in the event of excessive temperature.

In order to eliminate the influence of conditioning agents on the conductivity measurement, cation filters shall be provided. The cation filters shall have visible colour indicators to show when they have to be regenerated.

For all analyzers temperature compensation shall be provided, with the temperature sensor being an integral part of the probe.

Chlorine residual monitors and hypochlorite concentration meters shall preferably be able to measure high and low concentrations. Measurement of hypochlorite concentration shall not be affected by the presence of other oxidizing components in the sample.

Individual or multiple prefabricated analyzer installations shall be used to reduce site installation work. This prefabrication shall include sample conditioners, analyzers, air and electrical distribution, cooling water distribution or coolant circulating system all piped and wired on a common frame. Interconnecting pipework and accessories shall be of stainless steel. The arrangement shall permit testing of the entire assembly before dispatch to site and shall be arranged for convenient removal from on-line operation to facilitate routine maintenance and calibration.

The sampling system shall include but not be limited to all probes, valves, filters, coolers, drainage facilities, flow regulators, flow meters, piping and pumps as necessary, to give the analyzer a representative and suitably conditioned sample.

Analyzers shall be provided as follows:


#### Sample Point

Condenser make up water  
Condensate pump discharge water  
Condensate at deaerator inlet water  
Deaerator effluent water  
Economizer inlet water  
Boiler blow down steam  
Saturated steam  
Main steam  
HP5 heater drain water  
Closed cooling water

#### Analyzing Required

specific Conductivity  
pH, cation Conductivity, DO  
pH, specific Conductivity  
pH, DO  
pH, cation Conductivity, DO  
pH, specific Conductivity  
cation Conductivity, SiO<sub>2</sub>, Na  
cation Conductivity  
pH, specific Conductivity  
pH, specific Conductivity

Note:





**DO: Dissolved Oxygen**

Chemical reagent for the sampling system commissioning period but not exceeding 180 days shall be provided.

Each automatic analysis sampling point shall be provided with a manual sampling point to permit a sample to be easily taken. Manual sampling shall not interrupt automatic sampling. All sampling lines shall be run to common sampling racks on which shall be fitted all the analysis associated equipment.

The sampled points of analyzers shall be indicated and monitored at the local panel.

The corresponding analogue measuring signals (4-20 mA) and the status signals (24V DC) shall be transmitted over serial link to the DCS.

The SWAS system, for both Units should be located at  $\pm 0.0$  meters in an air conditioned room.

**B0.6.19.13.2 Effluent Monitoring**

The operational philosophy of water supply/ distribution system shall be based on a continuous Possur river water quality analysis, potable water quality monitoring, sampling and analyzing concept and shall consider preventive and active measures against water pollution and adaption of operating mode(s) to changes in water conditions.

**Sample Extraction for Laboratory Analyses:**

A tapping shaft for extraction of samples for laboratory test shall be provided and installed at the various measuring locations, before the waste waters are mixed with the circulating cooling water and discharged to the sea.

**Continuous Effluent Monitoring:**

A continuous monitoring shall also be implemented for water quality measurements of all kinds of discharges to the river.

The sensors for continuous monitoring of effluent parameters shall be located within the sample-tapping shaft. Additionally flow and temperature sensors shall be mounted within the discharge lines.

Following kind of analyzers shall be considered at least:

- pH analyzer
- conductivity analyzer
- chemical oxygen demand (COD) analyzer
- biological oxygen demand (BOD) analyzer





- total suspended solid (TSS) analyzer
- oil in water (OIW) analyzer

Continuous quality monitoring system shall be installed at the CES. The corresponding electronic equipment shall be mounted in a weatherproof container to be located nearby the point of measurement at the discharge pipes of waste water.

The corresponding analogue measuring signals (4-20 mA) and the status signals (24V DC) shall be transmitted by multicore cables to the DCS.

#### B0.6.19.13.3 Potable water quality monitoring system

Water quality control and monitoring of the Plant's drinking water shall be performed at the Plant interface (downstream the potable water tanks).

The water quality monitoring system shall at least consist of, but not be limited to the following online metering, measurement, sampling and analyzing equipment, including data acquisition and data storage facilities:

- alkalinity
- conductivity metering
- pH monitoring
- temperature measurement
- turbidity monitoring
- residual chlorine monitoring
- TDS (computed value)
- LSI (computed value)
- sampling points and equipment for potable water sampling at the online measuring units.

#### B0.6.19.13.4 Quality monitoring for fuel

For fuel oil a sampling point for discontinuous manual analysis shall be provided for the facility at the fuel oil storage tanks.



#### B0.6.19.13.5 Analysis of exhaust gas (CEMS)

The analysis of O<sub>2</sub>, CO, CO<sub>2</sub>, NO<sub>x</sub>, SO<sub>2</sub>, particulate matter (opacity) in the exhaust gas shall be performed by appropriate analyzers of proven type.

The equipment shall be constructed for operation in dusty and humid environments at high ambient and exhaust gas temperatures. The use of equipment capable of multi-parameter measurement shall be considered.

The reliability and response time of the O<sub>2</sub>-analyzer shall be of the quality required for closed-loop control. The accuracy of the system shall be better



than 2.0% of the span and the drift shall be not more than 0.1% O<sub>2</sub> per week. A zirconium oxide measuring cell shall be used. Maintenance shall not be more than once a week.

Analyzers provided shall have auto-calibration for zero and span as well as self-diagnostic functions. Analyzers and sensors can be of extraction or insitu type.

All equipment of the continuous emission monitoring system (CEMS) shall be suitable for operation in dusty and humid environments at high ambient and flue gas temperatures. Continuous Emission Monitoring System (CEMS) shall be provided for each unit.

If sampling of exhaust gas is used, sampling probes shall preferably be vertically installed on the top of horizontal exhaust gas ducts, in order to avoid blockages.

In order to keep the sampling lays to acceptable limits the analyzers shall be located close to their sample take-off point, so that easy access to the sample take-off point and to the analyzers shall be provided for maintenance.

The exhaust gas sampling lines shall be heated to prevent condensation and shall not form a siphon in the case where condensate may be collected during heater failure. Condensate drainage facilities shall be provided at the analyzers.

Generally, the analyzers and the sampling probe equipment shall be suitable for mounting in ambient plant conditions, e.g. within a standard cubicle. However, if this is not feasible, the equipment shall be mounted in an air-conditioned room or container.

Power failure and system failures of analyzers shall be monitored in the DCS by a group alarm.

Measured values and certain status signals shall be processed by an emission evaluation computer via serial interface, to be installed within the central control room. The emission data shall be calculated, converted, printed out and stored according to the governmental requirements. Possibilities for line data readout for authorities shall be provided.



#### B0.6.19.13.6 Ambient air quality monitoring system (AAQMS)



An ambient air quality monitoring system shall be provided consisting AAQMS stations and metrological stations. A centralized data acquisition PC shall be installed to collect all information from the AAQMS. The AAQMS stations shall be suitably distributed on the Plant area.

The AAQMS stations shall contain at least the following:



- Analyzers for SO<sub>x</sub>, NO<sub>x</sub>, CO, O<sub>3</sub>, mercury
- Multi gas calibration system
- PC based data logger
- UPS
- Suspended particulate monitors (TSP)
- Sampling inlet heads

Metrological station shall include at least:

- Metrological sensors such as wind speed, wind direction, air temperature, relative humidity (rH), solar radiation, rain gauge
- Metrological mast

All ambient gas analyzers and dust monitors shall conform to the US EPA reference of equivalent method. A proof of approvals and certificates of the compliance of internationally reputed agencies such as US EPA, German TUV, etc shall be provided.

A sampling system compatible with the analyzers shall be provided. The system shall be compatible with analyzers for Pb (which the Employer may procure in the future). The system shall have the facility for moisture removal.

Built-in calibration facilities shall be provided for all analyzers. To cross check the built-in calibration facilities of the analyzers/ monitors, a standard multi-gas calibration system for each AAQMS station with fast response time shall be provided.

The metrological sensors for wind speed and wind direction shall have an accuracy of 2% of full scale. The accuracy of the relative humidity sensor shall be 3% for the range between 10 and 90% rH.

The rain gauge shall be of self recording type and of reputed make. Electronic recording facilities shall be provided. The instrument shall have automatic functions for computing rainfall for pre-set time periods. The gauge shall be rugged and be of material resistant to atmospheric corrosion. The accuracy shall be 1% for rainfall ranges above 125 mm/hr and 5% below this value.

A metrological mast shall be provided for mounting of the metrological sensors. It shall be complete with all necessary hangers and holders along with electrical earthing for the installation of the sensors. Material and construction of the mast shall be robust and shall be resistant to atmospheric corrosion.

There shall be PC based data loggers for each AAQMS station. The entire data capture and mean value calculation as well as control of analyzers shall be through user friendly software and operate on the latest Windows operating system. Diagnostic features shall be included in the software and





any unauthorized access shall be prevented by appropriate measures such as password protection.

Data loggers for the metrological station shall be provided with the necessary analogue and digital inputs and internal memory for all collected parameters. The data loggers shall have the capacity for future extension with additional sensors.

Location for centralized data collection PC stations shall be decided during basic/detailed design stage

#### B0.6.19.14 .Electrical value measurements

For the processing of electrical values such as voltage, current, power, frequency etc. electronic type transmitters shall be provided to convert the output of current and voltage transformers into an impressed direct current in the range 4 - 20 mA. The transmitters shall be housed in the switchgear.

For power measurements precision electricity meters for asymmetrical three-phase networks are to be supplied. Connection of the meters shall generally be to 3 x 1 A current transformers and 3 x 110/√3 V voltage transformers. The meter accuracy class is to be approximate to the respective transformer classes. Instrument transformers with an accuracy class of 0.5 or better shall be used for metering purposes.


For the purpose of billing for electrical energy and for acceptance tests, an instrument transformer of at least class 0.2 (precision) accuracy and high precision electricity meters of class 0.2 have to be provided. Meters for billing purposes shall be of the approved calibrated type (certified by independent testing stations). All meters for billing purposes are to be provided as double 2 x 100% meters.

At all points where power direction reversal is possible, the necessary meters for both directions are to be provided.

The meters in the local switchgear are to be arranged behind the clear plastic fronts of the cubicle doors so that the counter readings can be taken without opening the doors.

#### B0.6.19.15 Control valves

Control valve spindles and internals shall be made of chromium steel and shall have a high resistance to wear and corrosion. Cones and seats shall be hard faced with materials with a high resistance to wear and corrosion. Housings shall be made of forged or cast steel. A hand wheel, with provision for switching to manual operation and a local position indicator shall also be provided.



000206



All control valves, orifices and nozzles shall comply with the relevant international standards such as DIN, BS or any other which may be agreed to by the Employer/Engineer.

Control valve characteristic shall allow smooth and continuous control of the control parameter.

Valves shall not generate noise in excess of 85 dB(A), measured at a point 1 meter downstream of the valve outlet and 1 meter from the pipe centerline. Where this requirement must be exceeded because of physical limitation, suitable sound attenuators shall be provided in terms of special valve trim, in-line attenuators, isolators and enclosures to satisfy the noise requirement.

Valves shall have trim designed to avoid cavitation damage. If an application cannot avoid cavitation entirely, material selection shall be such as to withstand the effects without damage.

Line strainers shall be provided upstream of control valves where required.

The valve sizing shall be suitable for obtaining maximum flow conditions with valve opening at approximately 80% of total valve stem travel and minimum flow conditions with valve stem travel not less than 10% of total valve stem travel. All the valves shall be capable of handling at least 120% of the required maximum flow. The design pressure drop across the valve should be 15 to 20% of the total available pressure drop at no flow.

Although control valves shall not be used for shut-off service, to provide reasonable shut-off performance, leakage through a closed control valve shall not exceed 1% for single ported valves or 2% for balanced ported valves.

All control valve materials shall be compatible with the fluid handled. Materials shall be in accordance with the piping materials standard and/or as approved by the Employer/Engineer.

Valve characteristics shall be selected to suit the process and control system dynamics.

All the control valves for boiler feedwater services should be of anti-cavitation type with flash-flow trims and cage type to avoid cavitation problems.

The installation shall include upstream and downstream isolating valves and, for critical control valves, a bypass valve for each control valve on all services. Unless otherwise agreed by the Employer/Engineer the bypass valve shall have a similar characteristic as the control valve but shall provide tight shut-off. Any exceptions or variations to the requirement shall be subject to the approval of the Employer/Engineer. Where a service is subject to a pressure above 3 bar a 25 mm vent valve shall be provided, between the upstream and downstream isolating valves, in order to relieve the pressure to enable maintenance to be carried out on the control valve.





Control valves shall be adequately supported in all cases and shall be accessible for maintenance. Local pressure gauges shall be provided upstream and downstream of each control valve.

If as per steam turbine OEM's proven design, isolating valves or bypass valves are not envisaged for control valves of internal piping, same is also acceptable.

For normal duty globe type valves shall be used.

The use of butterfly valves shall be avoided in the main plant. Where very large sizes are involved (on high flows), or low pressure drops and low static pressure are a determining factor, making globe valves unattractive or impossible, butterfly valves may be used. They shall be of the "balanced torque" type disc usable to the fully open position (90° opening). The overall shaft rating shall be at least 25 % above the static pressure as differential across the closed valve.

Multi-stage valves (e.g. multi seat or multi cage valves) shall be used on services, e.g. steam and gas, having very high pressure drops which would result in supersonic velocity inside a conventional body and shock waves in the piping, creating unacceptable noise levels.

Angle valves shall be provided.

- for steam pressure reducing de-superheating stations of the "combination" type,
- for erosive services, e.g. slurries,
- on applications where solid contaminants might settle in the valve body,
- on hydrocarbon services with a tendency for "coking".

Ball valves shall be used for on-off and throttling services under moderate operating conditions.

The control valves must be provided with all data important for their identification, such as flow direction, type, nominal diameter, nominal pressure, seating, CV value.



#### B0.6.19.16 Actuators

Intelligent drives with integrated power switch unit and further electronics shall be installed. Actuators equipped with integral controls shall be supplied which can be operated via the operation elements on the local controls as soon as power is connected. Only operation commands and feedback signals shall be exchanged between the control system and the actuator. Motor switching shall be performed within the device and virtually without delay.

*Signature*



FICHTNER

000208

B0-195



Unless otherwise specified actuators for modulating valves and dampers shall either be pneumatic or electrically operated. Self contained sealed hydraulic units may be considered where high thrusts or high speeds of operation are required.

Actuators for ON/OFF duty or manually positioned units shall generally be electrical motor and/or pneumatic driven, however the use of solenoid types on small valves shall be allowed dependent on duty.

The various types and sizes of actuators shall be rationalized and as far as possible each type shall be from a common manufacturer to facilitate interchangeability and spares.

In order to prevent the risk of fire or explosion pneumatic actuators shall be used in hazardous areas and associated equipment (e.g. positioners) must be intrinsically safe in accordance with IEC 60079-11.

Pneumatic actuators must be designed in such a way that in the event of air failure the actuator will remain in the position immediately prior to loss of power, or assume a position which is safe for the process.

With either action the failure mode shall be suitably monitored and the Plant operator informed by some form of alarm. The failure response of all actuators in the event of the loss of the prime mover (air pressure, oil pressure, electrical power) shall be indicated on the Piping and Instrumentation (P&I) diagrams, valve schedules, etc.

All pneumatic tubing to control drives or actuators shall, unless otherwise agreed to by the Employer/Engineer, be in copper which shall be sheathed in PVC or alternatively in stainless steel.

For all actuators of control valves and dampers of main systems local indicating pointer and position transmitters for remote indication and closed loop feedback shall be provided in accordance with the most severe operating conditions to be expected. The transmitters shall be designed to withstand conditions such as high temperature, vibrations and leakage of steam and of hot water wherever required. The protection class shall be IP 65 according to IEC 60529.

All actuators shall have a handwheel for direct manual operation. The diameter of the handwheel and geared effort shall be such that they can be reasonably operated by one man. A lockable mechanical clutch mechanism shall be provided to inhibit power control of the actuators when the handwheel is operated.

The speed of response of actuators used for modulating control shall be chosen to suit each particular application. Facilities shall be provided for limiting the actuator movement in each direction.



000209



Special attention must be paid to adequately dimensioned drives and care must be taken to avoid any unintended displacement of the actuator on sudden rises of pressure in the piping.

Actuators shall have fail safe operation and actuator locking device in the event of abnormal conditions. Any abnormality on the valve shall be transmitted to the DCS.

All electrical actuator drives necessary for the safe operation and shut-down of the Plant in the event of 0.4 kV switchgear failure shall be connected to the UPS.

#### B0.6.19.17 Solenoid valves

In lines with nominal diameters of up to DN 25, as well as for piloting pneumatic actuators, suitable solenoid valves shall be used. Valves with power ratings up to 30 W shall be controlled directly at 24 V DC from the DCS. For powers over 30 W, solenoid valves for 230 V AC shall be employed. Solenoid valves for 110 V, 230 V AC and above shall be secured with blade fuses. Electrical connections are made by means of plug connectors, with the mating connector forming part of the scope of supplies.

#### B0.6.19.18 Cabling and wiring

The general requirements for cabling are as stated under relevant chapter in Section B0.

In particular, wiring within desks and panels shall be supported on trays and shall be segregated according to voltage level. Wiring carrying AC and D.C. voltage shall also be segregated.

All desks, panels, cubicles and racks shall be factory-wired with regard to the internal connections. Where desks or panels will be supplied in more than one Section, electrical connections between the Sections shall be by terminal strips provided for this purpose.

All cables must be provided at both ends, at every 20 m and every bend with identification with identification in the form of numbered labels corresponding to the coding system. The individual cores will be numbered or identified by colour-coding.

Instrumentation cables will be identified by colour codes and band marking, follow VDE 0815. The cables must be laid to ensure that they can be replaced or renewed in a simple manner.

Spare cores shall be terminated at terminal strips in such a way as to give a maximum length of core and shall be ferruled in such a way as to indicate that they are spare cores.





All instrumentation cables including both prefabricated and non-prefabricated type shall be with Fire Retardant Low Smoke (FRLS) type Poly Vinyl Chloride (PVC) overall sheath. For cables that are exposed to ambient temperatures above 60°C, teflon or silicone cables are to be provided. For safety related equipment fire survival cables shall be provided. The cables must be suitable for laying indoors, in the open (direct or indirect sunlight), in ducts, on trays, in the ground and in water. The cables must be resistant to solar radiation, the effect of oil, seawater, bacterial action, insects and rodents. Shields for individual pair and overall shield shall be provided for cables for analogue signals. Cables for binary signals shall have an overall shield. Multipair cables of 0.5 sq. mm, shall be used extensively for I&C cables, wherever required, prefabricated cables may also be used.

For thermocouple measurements compensation cable NiCr-Ni 2x0.5sq. mm or 4x0.5 sq. mm with silicone insulation and pair screen will be used. Fiber optic cables shall be provided for Remote I/O bus, CCTV, Station LAN etc.

The fiber and cable specifications shall comply with ITU-T Recommendation G652 and the relevant IEC standards. Each fiber cable shall be supplied with at least 50% spare cores. A minimum number of four spare cores are required.

Suitable fiber optic cable junction boxes, patch panels and patch leads shall be provided. These shall conform to the following:

- They shall support, organize, and protect the optical fibers and the fiber splices whilst ensuring that the optical fiber minimum-bending radius is not exceeded.
- The splice tray shall not have any sharp edges or protrusions that may damage the optical fiber cable.
- They shall provide entry for all cables.
- Include number tags for tube and fiber identification.
- They shall provide mounting positions for the bulkhead mounted connectors on which the cable will be terminated.
- They shall allow patching of fibers.
- Outdoor mounted boxes shall be rated to IP65 in accordance with IEC 60529.

The junction boxes/ patch panels shall have a fiber capacity equal to the total number of fibers (connected and spares) for all cables to be connected. Patch panels shall be designed for 19-inch rack mounting within a standard equipment cabinet.

All unused couplings shall have protective dust covers. The patch area in patch panels shall be accessible and covered behind a door or removable cover.





Sufficient factory manufactured patch cords with suitable colour coding shall be provided.

Fiber optic connectors shall be standardized for ease of maintenance.

#### B0.6.19.19 Instrument and measuring impulse piping

Instrument impulse piping shall be supported at intervals as defined in BS 6739. The correct size of tube clips shall be used to suit the tube outside diameter.

The Contractor shall fabricate and erect all mounting brackets for control and monitoring apparatus including all pressure switches and miscellaneous instrumentation. If it is found after commissioning that any mounting frame vibrates excessively under operating conditions, instruments within the frames shall be isolated with vibration dampers by the Contractor or moved to areas of low vibration.

Impulse lines shall have venting, draining and blowdown facilities. Impulse lines between process and sensor shall be as direct as possible and shall include allowance for vibration and vertical and horizontal movement. Joints in impulse lines shall be kept to a minimum.

All pneumatic instrument lines shall be soap tested and any leakage shall be rectified.

While process instrument lines are being pressure tested all instruments shall be completely isolated or disconnected.



### B0.7 Inspection and Testing

#### B0.7.1 General

This Section contains general requirements for inspection of material, parts, equipment and workmanship of the Plant during manufacture, assembling and erection and upon completion to demonstrate compliance with specification, codes and standards and to ensure overall reliability of Plant operation and performance.

Development and implementation of test procedures for the construction inspection, start-up and performance testing and capacity demonstration of the Plant shall be the responsibility of the Contractor.

The Contractor shall be responsible for providing all supplies required for carrying out such tests, except to the high speed diesel and coal used during Reliability Test Run and Performance Tests.



The overall testing program for the Project shall consist of the following:

- workshop inspections and testing
- construction inspections, and testing
- mechanical completion
- pre-commissioning tests
- tests on completion
- reliability test run and performance tests.

The Employer shall have the right to have their representatives present during inspections and tests of Plant equipment and systems in the workshops and during construction. The presence of the Employer's representatives during any inspection or test shall in no way relieve the Contractor of its responsibility for supplying the equipment or systems in accordance with the milestone dates.

The Employer will be notified by the Contractor in writing at least ten (10) days prior to such testing and inspection at workshop and two (2) days for test at site.

Three (3) months after effective date of Contract, the Contractor shall submit to the Employer all relevant test documents, which shall include:

- inspection and test program
- test standards
- type of inspection and tests
- tests which are to be witnessed by third parties.

Six (6) months prior to the proposed start of commissioning the Contractor shall submit to the Employer:

- commissioning test program
- commissioning procedures
- tests on completion.



Six (6) months after effective date of Contract the Contractor shall submit to the Employer for the Performance Tests:

- test program
- test standards
- manpower and deployment schedule of the Contractor for performing the tests forms of test records and report
- description of instrumentation to be used, including accuracy, and calibration test results
- method of data recording
- method and equations/correction curves used for adjustment of recorded data to the design conditions.



The results of all tests shall be certified by the manufacturer, Contractor or independent agency as appropriate.

Document files containing material certificates, welding procedures, test report etc. shall be compiled for each item of plant and shall be suitably identified (including equipment classification reference) and bound.

## B0.7.2 Testing during manufacturing

### B0.7.2.1 Material tests

#### Major steel forgings

Purchase specifications shall clearly state the quality and inspection requirements and should include:

- a. Chemical composition range
- b. Heat treatment
- c. Mechanical test specimen locations
- d. Mechanical properties
- e. Magnetic properties (when applicable)
- f. Non-destructive testing
  - methods and procedures
  - stage and extent of application
  - recordable indication size
  - allowable indication size

g. Thermal stability test (HP and reheat turbine shafts only).

Each forging shall be suitably marked with an identification number which shall transfer throughout all machining stages. The identification number shall be indicated on all documents relating to the forging.

Repair welding will not be permitted on rotating parts and on other components the proposal will be subject to approval by the Employer's Representative.

#### Rotor forgings

The profile of forgings at the stage of final ultrasonic inspection should be such as to minimize the regions where complete coverage is not possible. Ultrasonic indications should be measured by the equivalent flat bottomed hole or AVG (DGS) method.

The toughness of rim and core (where applicable) material shall be evaluated by testing Charpy V impact specimens over a range of temperatures and thus determining the 50% fibrosity fracture appearance temperature (FATT).





Allowable indication size and material toughness are interdependent design related criteria and the Contractor must be prepared, if requested by the Employer's Representative, to justify his proposals by reference to fracture mechanics calculations.

Bores, when provided, shall be magnetic particle inspected and a suitable intrascope used for examination.

Residual stress measurement shall be provided for rotor forgings.

#### Major steel castings

Purchase specifications shall clearly state the quality and inspection requirements and should include:


- a. Chemical composition range
- b. Heat treatment
- c. Mechanical test specimen locations
- d. Mechanical properties
- e. Non-destructive testing
  - methods and procedures
  - stage and extent of application
  - recordable indication size
  - allowable indication size
- f. Other tests
- g. Standard weld repair-procedure

Each casting shall be identified by hand stamped or cast-on reference numbers which shall be indicated on all documents relating to the casting.

#### Non-destructive testing

Minimum requirements are as follows:

- a. Crack detection of critical areas of castings which in the case of castings to operate at high temperature or high pressure shall consist of 100% of all accessible areas. Magnetic particle inspection shall be used for ferritic steel castings.
- b. Ultrasonic inspection of all surfaces of castings to operate at high temperature or high pressure.
- c. Ultrasonic thickness check of critical areas.
- d. Radiographic examination adjacent to future butt weld regions (Acceptance Standard Level ) of ASTM E446 or E186 as appropriate).
- e. Radiographic examination shall also be used to assist in defining defects indicated by ultrasonic inspection.
- f. Blue matching on the parting plane between upper half and lower of the turbine casing
- g. Creep test shall apply for high chrome casting and forging, in particular when used for more than 540°C.





In addition to being applied as necessary quality control on as cast items, inspections outlined in a) and b) above shall be applied to the finally heat treated casting.

Prior to non-destructive testing all surfaces shall be satisfactorily prepared and visually examined.

Either colour matching of casting by putting two halves together or feeler gauge thickness check from outside to ensure required contact area and joint tightness are acceptable

### Repair Welding

Unacceptable defects observed by visual examination or indicated by non-destructive testing shall be excavated by chipping or thermal gauging and grinding and their complete removal proved by crack detection.

In the case of excavations which penetrate more than 25 mm or 50% of the wall thickness or cover more than 10,000 mm<sup>2</sup> area the Employer's Representative written approval of the proposed repair must be obtained.

Only welders qualified by performance tests on similar cast materials shall be used.

On completion of repair welded areas shall be ground smooth and carefully blended into the surrounding material. The repaired areas shall be surface crack detected; magnetic particle inspection being used for ferritic steel castings and in addition ultrasonic inspection shall be used on castings to operate at high temperature or high pressure.

After repair weldings hardness shall be checked.

### Steel Plates and Sections

The following requirements, which may be supplementary to the applicable material standards, shall be considered when selecting material grades:

- impact testing of plate or Sections over 50 mm thick (impact requirements to be dependent on application).
- ultrasonic testing of plate where the presence of non-metallics may interfere with the interpretation of ultrasonic testing of future welds;
- ultrasonic testing and through thickness ductility measurement, where the application involves the risk of lamellar tearing in the material at regions of high restraint (e. g. at set-on nozzle locations or cruciform joints);
- ultrasonic testing clad materials to detect lack of bonding. (Proposed rectification procedures shall be submitted for the approval of the Employer's Representative).

### Reinforced Thermosetting Resin Pipes

Checks shall be made on all raw materials to ensure that they comply with the relevant ASTM Standard.






All deliveries of resin shall be checked for consistency by viscosity and reactivity. Any resins deviating from the manufacturer's published figures shall not be used.

Testing of reinforced thermosetting resin pipes:

- Long term hoop strength (type test for pressure pipes only)
- In accordance with ASTM D2992 Procedure B with the exception that the test results shall be extrapolated to determine the stress which the pipe can withstand for a period of 60 years without failure. The lower 95 % confidence limit at 60 years shall also be calculated.
- Hydraulic test
  - 100 % of the pipes shall be subjected to an internal hydraulic pressure test at the manufacturer's works prior to delivery. The test shall be applied to a pressure equal to 1.5 times the maximum working pressure stated for each classification of pipe. The test pressure shall be applied for a minimum period of 5 minutes without signs of leakage. In addition to the above the first pipe and every thirtieth thereafter of each class and diameter shall be maintained at test pressure for a minimum of 4 hours without signs of leakage.
- Each pipe and fitting shall be subjected to an internal low pressure air test at the manufacturer's works prior to delivery. The test pressure shall be an overpressure of 0.1 bar and this shall be applied for a minimum period of 5 minutes without signs of leakage or distress. Fittings which are of mitred construction shall be manufactured from pipes which have successfully passed the tests defined above.
- Dimensions
  - The dimensions and tolerances of all pipes shall be determined in accordance with the relevant standards (e.g. DIN 16965, DIN 16964, DIN 16867, DIN 16868, DIN EN 14364)
- Stiffness
  - A minimum of one pipe for every 30 pipes manufactured shall be tested for stiffness in accordance with AD 2000 HP110R and N1. A minimum of one pipe of each class and diameter of pipe shall be tested.
- Longitudinal and hoop tensile strength
- The tensile strength properties of a minimum of one pipe for every 100 pipes manufactured shall be measured in accordance with AD 2000 HP110R and N1. A minimum of one pipe of each class and diameter of pipe shall be tested.
- Cure
  - Curing, to be tested by the Barcol Hardness test determined in accordance with DIN EN 59; 100% of the produced pieces. Minimum acceptable hardness is 90% of the value recommended by the resin manufacturer of the particular resin used, when non-reinforced.
  - The sample pipe shall also withstand a commercial acetone test on the internal portion of the laminate.





- Loss on ignition  
A minimum of one pipe for every 30 pipes manufactured shall be tested in accordance with ASTM-D 2584 "Standard Method of Test for Ignition Loss of Cured Reinforced Resins".
- Joint tests  
A minimum of two pipes in every 100 pipes manufactured shall be jointed and tested in accordance with the requirements of **Section 7.2 of ASTM-D 3262**.
- Visual inspection  
Each pipe and fitting shall be subjected to a complete visual inspection before shipment in accordance with ASTM-D 2563.
- Vacuum test  
Vacuum test for those piping Sections being operated under vacuum shall be carried out for each diameter once at beginning of production. The vacuum to be applied shall be equivalent to the condition which occurs during full vacuum. The corresponding derated vacuum for this test shall be proved by the pipe manufacturer.
- Failure of tests on completed pipes  
In the event of a specimen not fulfilling the minimum requirements for strain corrosion resistance, all pipes of that class and diameter which have been manufactured shall be rejected and shall be replaced entirely.

Any pipe or fitting which fails any of the quality control tests which are to be carried out on each and every pipe or fitting shall be rejected. In the event of any pipe failing any of the remaining tests outlined above that pipe shall be rejected and the relevant test shall be carried out on a further ten pipes of that class and diameter. If any one of these ten pipes fails then the manufacture of pipes of that class and diameter shall cease and the Employer reserves the right to reject all the pipes of that class and diameter.

#### **Thermal insulating materials**

Materials shall be tested for bulk density, specific heat, compressive strength, fire resistance under pressure, service temperature limit in accordance with VDI 2055 or equivalent standards.

#### **HP Piping**

Ultrasonic inspection of all HP piping shall be performed at manufacturers place and proven by certificates.

#### **B0.7.2.2 Manufacturing tests**

RT is not carried out for pulverizer component.

#### **B0.7.2.2.1 Welding tests**

#### **Non destructive examination of pressure and vacuum containment welds**

Welds shall be non-destructively tested in accordance with the construction





standard applicable to the item of plant. In addition the requirements of the following Table 1 shall be observed. Table 1 shall also apply in cases where the standards used for design and construction of an item of plant does not specify the quality requirements for welds. Fault limitations to be subject of agreement with the Employer's Representative prior to fabrication. Hardness testing shall determine the hardness for welds and heat affected zone according to all scale i.e Vickers (HV10) , HRC and HB.

Non destructive examinations of steam turbine internal piping will be performed by Radiographic examinations.

The Bidder/Contractor has to fulfil the requirements specified in ASME B31.1 and the stricter requirements of the VGB Guideline R 503. For turbine internal piping 15% of welds will be checked by radiographic testing. If failures are detected the intensity of testing will be increased which means even more than 15% of the welds will be tested.

Hydraulic tests for steam turbine internal prefabricated pipe systems must not be executed, in case equivalent non destructive examinations of steam turbine internal piping are performed by radiographic examinations. The requirements specified in ASME B31.1 and the stricter requirements of the VGB Guideline R 503 shall be fulfilled.

The test procedure ISO 6507-1 or equivalent shall be used. Minimum 3 hardness locations shall be tested for the weld. On circumferential welds the test locations shall be located at 120° distance. Hardness tests shall be conducted after PWHT.

Following percentages of welds shall be hardness tested.

|                                           |      |
|-------------------------------------------|------|
| Carbon steels or low alloy steels (<2%Cr) | 10%  |
| 2.5% Cr steels                            | 50%  |
| 9 - 12% Cr steels                         | 100% |
| Austenitic steels                         | -    |





TABLE I

| Type of Steel                                                                                                                               | Design factor<br>(shell) | Wall<br>thickness<br>(mm) | Inside diam<br>(mm)   | Type and Extent of non destructive testing |          |        | Remarks                                                                                                                   |
|---------------------------------------------------------------------------------------------------------------------------------------------|--------------------------|---------------------------|-----------------------|--------------------------------------------|----------|--------|---------------------------------------------------------------------------------------------------------------------------|
|                                                                                                                                             |                          |                           |                       | Butt                                       | Nozzle   | Fillet |                                                                                                                           |
| C and C-Mn steels with C<br>content not exceeding 0.25%                                                                                     | $\leq 0.85$              | $\leq 10$                 | all                   | -                                          | -        | -      | Only applicable to:<br>Atmospheric systems (excluded<br>systems, which handle chemicals,<br>toxics or inflammable media). |
|                                                                                                                                             |                          |                           |                       | 20% R                                      | -        | -      |                                                                                                                           |
|                                                                                                                                             |                          |                           |                       | 100% R                                     | 10% M    | 10% M  |                                                                                                                           |
|                                                                                                                                             |                          |                           |                       | 20% R                                      | -        | -      |                                                                                                                           |
| C-Mn steels with C content<br>0.25 to 0.35%, CrMoV steels,<br>C 1/2 Mo steels, low alloy<br>steels, and CrMo steels<br>except 12% Cr steels | $> 0.85$                 | $\leq 40$                 | $\leq 100$            | 100% R                                     | 10% M    | 10% M  | Test after stress relief                                                                                                  |
|                                                                                                                                             |                          |                           |                       | 100% R                                     | 100% M   | 100% M |                                                                                                                           |
|                                                                                                                                             |                          |                           |                       | 20% R                                      | 10% M    | 10% M  |                                                                                                                           |
|                                                                                                                                             |                          |                           |                       | 100% R                                     | 100% M   | 100% M |                                                                                                                           |
| Low alloy steels except<br>CrMoV and 2 CrMo                                                                                                 | all                      | $> 30$                    | all                   | 100% R                                     | 100% M   | 100% M | Test after stress relief<br>Test after stress relief                                                                      |
|                                                                                                                                             |                          |                           |                       | 100% R                                     | 100% U** | 100% M |                                                                                                                           |
|                                                                                                                                             |                          |                           |                       | 100% R                                     | 100% M   | 100% M |                                                                                                                           |
|                                                                                                                                             |                          |                           |                       | 100% R                                     | 100% M   | 100% M |                                                                                                                           |
| 12% Cr ferritic/martensitic<br>steels                                                                                                       | all                      | all                       | $\leq 100$<br>$> 100$ | 100% R                                     | 100% M   | 100% M | Test after stress relief<br>Test after stress relief                                                                      |
|                                                                                                                                             |                          |                           |                       | 100% R*                                    | 100% M   | 100% M |                                                                                                                           |
|                                                                                                                                             |                          |                           |                       | 100% U                                     | 100% U   | 100% U |                                                                                                                           |
|                                                                                                                                             |                          |                           |                       | 100% U                                     | 100% U   | 100% U |                                                                                                                           |

\* Radiographic examination may be omitted if done on as-welded joint

\*\* If feasible, otherwise 100% M

8140A01/FICHT-15702705-v5  
BIFPCL/EPC-Main Plant/2015/1/

FICHTNER

B0-207

000220



| Type of Steel               | Design factor | Wall thickness | Inside diam | Type and Extent of non destructive testing |        |        | Remarks                                                                                               |
|-----------------------------|---------------|----------------|-------------|--------------------------------------------|--------|--------|-------------------------------------------------------------------------------------------------------|
|                             | (shell)       | (mm)           | (mm)        | Butt                                       | Nozzle | Fillet |                                                                                                       |
| Austenitic Stainless Steels | ≤ 0.85        | ≤ 15           | all         |                                            |        |        | Not applicable to<br>Butt welds made from one side only<br>Operating temperatures exceeding<br>200 °C |
|                             |               | ≤ 30           | all         | 20% R                                      |        |        |                                                                                                       |
|                             |               | > 30           | all         | 20% R                                      | 10% D  | 10% D  |                                                                                                       |
|                             | > 0.85        | ≤ 30           | ≤ 100       | 20% R                                      |        |        |                                                                                                       |
|                             |               |                | > 100       | 100% R                                     | 10% D  | 10% D  |                                                                                                       |
|                             |               | > 30           | all         | 100% R                                     | 100% D | 100% D |                                                                                                       |

Legend: R = Radiographic examination  
 U = Ultrasonic examination  
 M = Magnetic particle examination  
 D = Dye penetrant examination

**Note:**

- Where 10% examinations are shown for pipework under 100 mm diam bore this shall be the circumference of 10% of the welds by each welder selected at random with a minimum of one per welder.
- Where 10% examinations are shown for vessels or large diameter pipework this shall be 10% of each weld length and must include all intersections of longitudinal and circumferential welds.
- Where partial examinations reveal rejectable defects, adjacent welds or areas of weld shall be examined. In the event of rejectable defects being found welds shall be subject to 100% examination.
- Welds in clad materials shall be tested in accordance with the requirements of the base material and the surface of the overlaid welds shall be dye penetrant tested throughout their length.



8140A01/FICHT-15702705-V5  
 BIFPCL/EPC-Main Plant/2015

FICHTNER

B0-208

000221



#### Non-destructive examination of structural welds

Welds shall be non-destructively tested in accordance with the construction standard applicable to the item of plant. Where appropriate, the following requirements shall also be observed:

- magnetic particle testing of the tension side welds in major fabricated girders and Sections,
- ultrasonic examination of heavily restrained welds (e. g. cruciform joints) where there is a risk of lamellar tearing in the parent material.

#### Weld Repairs

Unacceptable defects observed by visual examination or indicated by non-destructive testing shall be completely removed by chipping or thermal gouging and grinding. The resulting excavation shall be crack detected prior to rewelding.

Details of the original defects and repair shall be recorded.

Repaired welds shall be subjected as a minimum requirement to the same inspection requirements as the original welds and test records should indicate that a repaired weld is referred to.

#### B0.7.2.2.2 Pressure testing

All items subjected in service to internal pressure or vacuum shall, unless otherwise agreed, be pressure tested in the manufacturer's works and at site and prior to any internal or external coating.

In case pressure test can't be executed at site NDT checking of welding shall be 100%.

Pulverizer assembly shall be excluded from Pressure testing. Required NDT will be carried out during manufacturing stage to ensure quality. (RT will not be carried out for Pulveriser Component)

#### Hydrostatic testing

Suitable water shall be used as the test media unless otherwise agreed. The test pressures shall be in accordance with ASME.

The test pressure shall be no less than the greater of

- the pressure corresponding to the maximum loading to which the pressure equipment may be subject in service, taking into account its maximum allowable pressure and its maximum allowable temperature multiplied by the coefficient 1.25

$$p_{\text{test}} = 1.25 * PS * f_{\text{test}}/f$$

- maximum allowable pressure, multiplied by the coefficient 1.43,





$$p_{\text{test}} = 1.43 * PS * f_{\text{test}}/f$$

Where:

- $p_{\text{test}}$  test pressure (hydrostatic)
- PS design pressure
- $f_{\text{test}}$  nominal design stress for design conditions at test temperature
- $f$  nominal design stress for design condition at design temperature

The design pressure shall be in any case not less than 3.5 bar overpressure.

Test pressure of vacuum containment items shall be agreed with the Employer's Representative. Any local legal requirement prevails.

The test pressure shall be maintained for sufficient time to permit complete visual examination of all surfaces and joints and in no cases less than specified in the applicable construction standard.

The chloride content of water used for testing austenitic stainless steel items shall not exceed 30 ppm unless immediate flushing with water of this quality is done after the test.

#### **Pneumatic testing**

The Contractor shall apply pneumatic testing in cases where hydrostatic testing is impractical or undesirable (e.g. oil pipes). Safety precautions, test pressures/duration and degree of prior non-destructive examination of the subject items shall be agreed with the Employer's Representative.

Pneumatic or gas leak testing supplementary to hydraulic testing shall be applied in appropriate cases where specified by the applicable construction standard.

### **B0.7.2.2.3 Testing of corrosion protection**

#### **Surface coatings**

Following tests have to be performed before, during and after coating:

- visual inspection of blasted surfaces according to ISO 12944
- test the blast profile with a profile gauge
- checking of coating material
- measurement of air humidity, air temperature and coating substrate temperature and determination of dew point
- visual inspection of coating
- checking of dry film thickness (DFT); All zinc rich paint used for such repairs must contain a minimum of 81% by mass of zinc in the dry film.





- checking of adhesion with a dolly pull adhesion tester in accordance with ASTM D4541-09 type A1

#### **Galvanized zinc coatings**

Surfaces shall be visually inspected. Bare patches, lumps blisters or inclusions of foreign matter shall be cause for rejection.

Zinc coating thickness shall be determined non-destructively in accordance with ISO 2178 or coulometrically in accordance with ISO 2177 (or ASTM equivalent). For coatings with a weight exceeding 900 g/m<sup>2</sup> the coulometric test method specified in ISO 2177 shall be used.

#### **Hard rubber linings**

Surfaces shall be visually inspected. Uneven surfaces, splits, blisters or inclusion of foreign matter shall be cause for rejection.

The thickness of linings shall be measured in accordance with EN 14879 or equivalent. A tolerance of + 10 % is permitted for rubber coatings of 3 mm nominal thickness.

Hardness tests shall prove compliance with the rubber manufacturer's standards.

The absence of pores shall be proved by the induction sparking test method. The potential used shall be 5000 Volts for each mm of thickness plus an additional 5000 Volts (i. e. potential of 20,000 Volts for 3 mm thick lining).

#### **B0.7.2.2.4 Testing of pressure part assembly**

Trial assembly shall be checked at the manufacturing place before shipment.

#### **B0.7.2.2.5 Testing of auxiliary and ancillary systems**

The Contractor shall provide in his ITPs the specialised checks for various equipments like idlers, pulleys, conveyor belts, coal crusher, stacker reclaimer, coal unloaders, vacuum pumps, air compressors, bottom ash handling equipments, pumps, valves, pipes, EOT & hoists, inert gas system, deluge valves, foam system

The Contractor shall also follow the requirements for testing in the Sections B1 to B12.

#### **B0.7.2.2.6 Hangers**

Load Test for hangers (in particular spring type) and supports in particular for HP piping shall be executed. All hangers shall be pre-loaded at the manufacturing place.





### B0.7.2.3 Mechanical equipment

#### Rotating units

##### Balance testing of rotating units

Each rotating unit shall be first statically balanced and then dynamically balanced according to ISO 1940 (in the case of impellers this shall be done before and after mounting of the service rotor shaft). However, Generator rotor will be dynamically balanced according to ISO 11342. A check balance of items that have undergone overspeed test shall also be made.

##### Vibration testing of rotating units

The vibration characteristics of rotating units shall be measured during performance tests. Locations of measurement and standards to be achieved shall, on request, be subject to agreement by the Employer's Representative.

#### Pumps

Running tests and performance tests shall be conducted on all pumps: Performance tests shall be conducted through the full operation range of the pump to closed valve conditions. Graphs indicating flow/head, flow/ power absorbed, flow/ efficiency, flow/NPSH and speed shall be produced. Results for feedpumps shall be assessed with reference to ISO 9906 class I (without construction tolerances), and results for other pumps to class II or III as agreed. No negative tolerance on head, capacity and efficiency and no positive tolerance on power are accepted.

The lubricating oil used in the test shall be of the same brand and grade as that recommended by the manufacturer for service use.

Dismantling of the pump for visual examination of parts for damage following test shall be done when required by the inspection standard, when considered necessary by the manufacturer, or when requested by the Employer's representative witnessing the running or performance tests. Replacement of parts following test shall necessitate repeat testing.

Clearance check of the pumps and balancing test of the impeller (acc. to VDI 20160 or eq.) shall be conducted before pump commissioning.

Pump tests shall be carried out with the motor, as supplied with the pump. In case several pumps of same size and typ are supplied, test can be carried out with the same motor.

Pumps under the scope of auxiliary package/systems shall be tested with calibrated shop motor. The high energy pumps including turbine lube oil and control oil pumps shall be tested with job motor (with the motor, as supplied with the pump).

Full load full speed/back to back locked rotor torque test for one gearbox shall be ensured.





No-load mechanical run test for boiler feed pump drive turbine as per API 612 / ISO 10437 to be ensured.

### Steam turbines

The turbines shall be completely assembled with their control; on a suitable erection rig at the manufacturer's works and shall be carefully inspected and measured for manufacture and assembly tolerances.

Stop and governing valves shall be delivered and installed separately. Therefore stop and governing valves will be inspected and measured for manufacture and assembly tolerance separately.

Functional tests shall be performed on the safety equipment (running with steam is not requested).

Important items of turbine control equipment which cannot be adequately tested during the main tests shall be separately bench tested. Furthermore, testing shall be in accordance with IEC 60953-1 and comprise:

- balancing and overspeed test of the assembled rotor,
- measurement of radial and axial clearances,
- assembling inspection.

Minimum clearances between shaft seal casing and shaft seal ring, radial and axial blade clearances in blading section, axial and radial alignment of rotor in respect of shaft seals, alignment of overspeed governor etc. shall be ensured and verified by Bidder/Contractor.

Testing of free standing blades natural frequency and moment weight shall be performed for IP & LP blades.

All moving blades over 225 mm of active length shall be moment weighed and assembled on shaft in a prescribed sequence to ensure optimum balancing of rotor. Natural frequency of LP turbine blades shall be determined before mounting on rotors to ensure that the same are outside operating frequency range.

No load run test or a rig test at the workshop as per Bidder's/Contractor's/OEM's practice for the two main turbines is acceptable.

### Air compressors

Air compressors shall be tested in accordance with the requirements of ISO 1217 or equivalent standards. Any request for deviation from the test conditions shall be accompanied by the manufacturers' proposals for the adjustment of the correction factors contained in the standard. Tolerances will be allowed according to ISO 5167-1.





**Cooling towers**

One Cooling Tower per unit shall be tested on site to an appropriate CTI standard. Any request for deviation from the test conditions shall be accompanied by the manufacturers' proposals for the adjustment of the correction factors contained in the standard.

In addition performance testing to be carried out for the whole system (all cells).

**Cranes and hoists**

Where size permits cranes and hoists shall be completely assembled at the manufacturers works and functional tests without load conducted.

**Flue gas (IDF) and air fans (IDF, PAF, SAF)**

Axial and radial fans shall be tested in accordance with the requirements of ISO 14694 or equivalent standards for vibration. ISO 12499 shall also apply. Any request for deviation from the test conditions shall be accompanied by the manufacturers' proposals for the adjustment of the correction factors contained in the standard.

Performance tests shall follow VDI 2044, ISO 5801 or equivalent standard.

Before commissioning, the following tests shall be conducted: NDT, trial assembly of casing, blue matching, and clearances.

**Dampers and Gates**

Large dampers and valves shall be leakage / tightness tested (type test) in the workshop and at site the whole system shall be tested.

**Rotary air preheater (RAPH)**

Before commissioning, the following tests shall be conducted: NDT, trial assembly of casing, blue matching, and clearances.

**Coal Pulverizer**

Before commissioning, the following tests shall be conducted: NDT, trial assembly, blue matching, and clearances. The tests will be carried out during manufacturing stage wherever possible.

**B0.7.2.4 Electrical equipment**

Electrical equipment and material which is not covered by the tests specified elsewhere in this document shall be inspected and tested in accordance with the latest edition of standards listed hereafter. Alternatively, equivalent standards approved by the Employer's Representative may be used. Type tests shall be carried out if type test certificates certified by an independent test authority are not available.

**Installation Material**

IEC 60130

Connectors for frequencies below 3 MHz



|           |                                                                             |
|-----------|-----------------------------------------------------------------------------|
| IEC 60364 | Low voltage electrical installations/ Electrical installations of buildings |
| IEC 60423 | Conduits for electrical purposes                                            |

#### Materials for earthing and lightning protection

|          |                                                                                                        |
|----------|--------------------------------------------------------------------------------------------------------|
| IEEE 80  | Guide for safety in AC Substation Grounding                                                            |
| IEEE 81  | Guide for Measuring Earth Resistivity, Ground Impedance and Earth Surface potentials for Ground system |
| NFPA 780 | Installation of lightning protection systems                                                           |

#### Insulators and Bushings

|           |                                                                                |
|-----------|--------------------------------------------------------------------------------|
| IEC 60383 | Insulators for overhead lines with a nominal voltage above 1000 V              |
| IEC 60507 | Artificial pollution tests on high voltage insulators to be used on AC systems |
| IEC 60137 | Insulating bushings for AC voltages above 1000 V                               |

#### Surge Protection Equipment

The surge protection equipment shall be tested in accordance with IEC 60099.

#### AC Switchgear for voltages above 1 kV

|            |                                                                                        |
|------------|----------------------------------------------------------------------------------------|
| IEC 62271  | High-voltage switchgear and control gear                                               |
| IEEC37.013 | IEEE standard for AC-High-Voltage generator circuit breakers on a symmetrical current. |

At least the following tests shall be performed in the manufacturer's workshop on the individual apparatus and on the complete installation, respectively, all in accordance with IEC Standards:

- Visual inspection
- Power frequency HV tests
- Dielectric tests of the auxiliary circuits
- Measurement of the main contacts resistance with dc
- Temperature rise test on circuit breakers (type test certificate)
- Test of mechanical endurance (type test certificate)
- Measurement of the contact opening period (type test certificate)
- Functional tests of the control circuits
- Check of the operational sequence
- Measurement of the instrument transformer's angle and ratio errors (according to IEC-standards 60044)
- Check of the denominations.



**Note 1:** All MV switchgear shall be type tested according IEC 62271-1, IEC62271-100 and IEC 62271-200 including internal arc classification IAC



= AFLR. Related type test certificates shall be provided with the Tender. If the test has already been carried out on similar type switchgear, type test certificates may also be accepted.

**Note 2:** All GIS above 52 kV shall be tested according IEC 62271-1, IEC 62271-203.

Type tests shall be carried out, at the expense of the Contractor and without any impact on the projects overall time schedule, if type test certificates certified by an independent test authority are not available.

**Note 3:** Generator circuit breakers shall be tested according IEEE Std C37.013.

#### High voltage fuses

IEC 60282 High voltage fuses

IEC 60644 Specification for high voltage fuse links for motor circuit applications

#### Oil-immersed power transformers

IEC 60076 Power transformers

IEC 60214 On-load tap-changers

IEC 60404-2 Magnetic materials

##### a) Tanks

- Inspection of weld preparations, approved crack detection of major strength welds.
- Hydraulic test and vacuum test
- Visual and dimensional checks
- Certification of test results.

##### b) Cores

###### • Material

- Checks on flatness
- Checks for absence of burrs such as may be caused by slitting, cropping and punching
- Electrical insulated tests
- Visual and dimensional checks.

###### • Assembly

- Inspection during assembly stage, whilst core is still horizontal
- Visual and dimensional checks on complete core
- Checks on straightness of clamps
- Checks on clamp welding
- High voltage tests between core packets, clamps and belts in all relevant combinations
- Check actual weight of core steel in magnetic circuit against design weight
- Check that all block and sheet insulation and all spacers are in position
- Check earthing of core packets to clamps.





## c) Windings

- Windings
  - Copper checks
  - Fewest possible number of welds
  - Quality of weld and finishing
  - Insulation on copper
  - Check for correct material
  - Check correct application to conductor
  - Visual and dimensional checks
- Winding of turns
  - Checks during winding of different Sections of winding
  - Checks on positions of starts and finishes of Sections
  - Checks on correct directions of windings of turns (Polarity)
  - Visual checks
- Assembly of windings together
  - Check on relative positions and numbers of leads
  - Check that vertical and horizontal coolant ducts are clear and to full design dimensions
  - Visual checks
- Assembly of windings on core
  - Visual and dimensional checks.

## d) Leads

- Checks on disposition, insulation and support of tapping leads
- Checks on insulation support and positioning of bushing leads and provision for connection to bushings
- Checks on lead connections (crimping, brazing etc.)
- Checks on interphase connections
- General visual checks.

## e) Insulation

- Checks on arrangement of petalling
- Checks on inter-phase and earth barriers
- Checks on shields
- Checks on clearance and creepage distances
- General visual checks.

## f) Coolant flow ducts

- Check that vertical and horizontal passages are clear and to full design dimensions
- General visual checks.

## g) Current transformers, links and connections

- Check that built-in current transformers are in the correct leads
- Check that the connections and alternative connections are clearly marked and that the marked ratios are correct.





- h) Assembly of transformer in Tank
- Check insulation between transformer and tank
  - Check security of fixing of transformer in tank and of any packing used
  - Check electrical clearances between tank and leads and windings
  - Checks for cleanliness and freedom from debris of inside of tank
  - General visual check.
- i) Valves
- Check action of valves after welding into position (especially butterfly valves)
  - Checks for leaks under pressure.
- j) Paint work
- Checks for preparation of surfaces
  - Checks for use of correct paint system
  - Visual checks on general finish.
- k) Conservator
- Check for leakage
  - Check capacity
  - Visual checks.
- l) Bushings
- Check against standards
  - Check that routine tests have been done
  - Checks for leakage when mounted on transformer
  - Checks for distortion, flaws and chips.
- m) Tap-changers (on-load and off-circuit as appropriate)
- Inspection on completion of manufacture, including a review of manufacturer's stage test records and procedures
  - Mechanical and electrical checks in the manufacturer's works
  - Tests in accordance with the appropriate IEC or other standard as applicable
  - Check ten complete cycles from end to end of the range
  - Check five cycles on full current
  - Check five cycles at full voltage
  - Check transmitters for correct number of steps and impedance values
  - Check interlocks
  - Check warning, alarm and trip contacts
  - Visual and dimensional checks.
- n) Pumps and fans
- Checks for direction of rotation against motor terminal markings





- Visual and dimensional checks.

o) Heat exchangers

- Checks on radiators for leaks
- Checks on radiators for paint finish and inner cleanliness
- Checks on oil-to-water heat exchangers for leaks at manufacturer's works
- Checks on oil-to-water heat exchangers for cleanliness of oil chambers and passages
- General visual and dimensional checks.

p) Processing

- Checks on pressures and temperatures with manufacturer's process charts available.

q) Control cubicles, kiosks and terminal boxes

- Checks on functioning of contactors, overloads isolators and general operation of control circuits for cooling gear
- Checks on operation of circuits for thermometers, thermal images, pressure relief valves, oil and gas operated relays, flow detectors, heaters, lights and power output sockets
- Checks on wiring arrangements and terminal boards
- Checks on weather sealing of doors, cable glands and other external features
- Visual and dimensional checks.

r) Workshop tests on complete transformer

The following routine test in accordance with IEC 60076:

- Measurement of winding resistance
- Measurement of voltage ratio and check of voltage vector
- Measurement of impedance voltage, short circuit impedance and load loss
- Measurement of no-load loss and current at  $U_r$ ,  $1.05 \times U_r$  and  $1.1 \times U_r$
- Dielectric routine tests in accordance with IEC 60076-3
- Test on on-load tap changers
- Insulation resistance
- Separate source voltage withstand test
  - Induced overvoltage test to be carried out on all main transformers (see item 3) acc. to IEC 60076-3, table 1 (ACLD/ACSD).
  - PD test to be carried out for all generator transformers, interconnecting transformers and start-up/standby transformer together with ACLD.
- Frequency response analysis.
- FRA test to be carried out on all main transformers (see item 3).

The above tests shall be carried out on all transformers.






The following tests in accordance with IEC to be carried out as type tests (type tests shall not be repeated if type test certificates of an identical/similar rated transformer issued by a recognized test laboratory are available):

- Temperature rise test including direct measurement of hot-spot temperature
- Measurement of the harmonics of the no-load current
- Dielectric type tests in accordance with IEC 60076-3
- Measurement of zero sequence impedance
- For the above type tests, test certificates may be accepted at the discretion of the Employer/Engineer, in place of tests on the first transformer of each basic type excepting the generator transformer. In the case of generator transformers the type tests must be carried out
- Noise measurements.
- The generator step-up transformer, the 400/230 kV interconnection transformer, the unit auxiliary and the auxiliary transformers shall be dynamic short circuit withstand tested according IEC 60076-1 & -5 either in the manufacturers workshop or in a recognized 3<sup>rd</sup> party test lab (as special test).

In addition to the above tests, the following tests shall be made as routine tests:

- Tangent delta measurements on the insulation, the method to be agreed with the Employer/Engineer
- Core insulation test on magnetic circuit
- On windings of 30 kV rating or above either:
  - ration influence voltage tests, the method to be agreed with the Employer/Engineer or
  - partial discharge measurements in accordance with IEC
- Transformer oil analysis according to IEC 60296, IEC 60567 and according IEC 62535 for detection of potential corrosive sulphur in mineral oils
- Transformer tanks, conservators, oil pipework and air cooled cooling plant shall withstand without leaking or permanent distortion, the application for 24 hours of a pressure which is such that the test pressure at any point in the equipment is twice the working pressure at that point or 0.7 kg/cm<sup>2</sup> plus the working pressure at the point or 0.3 kg/cm<sup>2</sup> plus the pressure exerted at that point when the pressure relief is opened slowly by oil pressure whichever is the greatest.
- Tank vacuum & pressure test
- Pressure test of radiators
- Oil leakage test
- Pressure relief device, Buchholz relay, oil, winding meters, oil level indicator, dry cool breather, dissolved gas analyzer test / check.





Fault withstand (fault versus time) curve for all transformers shall be submitted by the Contractor.

Over-excitation curves shall be provided by the manufacturers for the station transformers.

Separate type and routine tests shall be carried out for all accessories like bushings, bushings CTs, tap changers, cooling fans, control panels, etc.

#### **Dry type transformers**

The following routine tests in accordance with IEC 60076 shall be carried out on all transformers:

- Measurement of winding resistance
- Measurement of voltage ratio and phase displacement
- Measurement of short circuit impedance and load loss
- Measurement of no-load loss and current
- Separate source AC withstand test
- Induced AC voltage test
- Lightning Impulse test
- Partial discharge measurement.

The following tests in accordance with IEC 60076 to be carried out as type tests (type tests shall not be repeated if type tests certificates of an identical transformer issued by a recognized test laboratory are available):

- Temperature rise test
- Measurement of sound level
- Short circuit test
- Environmental Test according Class E2
- Climatic test according Class C1
- Fire behaviour test according to Class F1.



Also, Lightning impulse test shall be a type test.

Fault withstand (fault versus time) curve for all transformers shall be submitted by the Contractor.

Separate type and routine tests shall be carried out for all accessories like bushings, bushings CTs, tap changers, etc.

#### **Current and voltage transformers**

The current and voltage transformer shall be tested in accordance with IEC 61869

#### **Generators**

IEC 60034, IEEE 115, ISO 1680 and ISO 10816.





## a) Generator test report

Comprehensive test reports for the generators are to be compiled and submitted by the Contractor, which shall include:

- Description of the test method, equipment used and any limitations of the test plant.
- Copies of the oscillographs recorded with appropriate calibration data
- Open circuit saturation, short circuit and loss curves for the generator
- A performance chart of the generator (being a diagram of constant stator and rotor current curves plotted on rectangular axis of MVar and MW load) The recommended loading, stator core end heating and stability limits shall be shown on the chart.
- Calculations of full load temperature rise for the stator, rotor and exciter. Any correction factors used to allow for different voltage current and cooling conditions shall be justified by reference to published literature or to previous type tests.
- Calculations of the efficiency of the complete generator at 100%, 75% and 50% load. Any correction factors for losses that could not be measured at routine tests shall be justified by reference to published literature or to previous type tests.
- Calculations of machine parameters (according to IEC 60034-4) such as transient reactance and time constant, sub-transient reactance and time constant, short circuit ratio, synchronous reactance, negative phase sequence reactance, zero sequence reactance, capacitance and also the harmonic analysis of the neutral current.
- Calculation of full load excitation of the machine at rated power factor lagging and at unity power factor, excitation V curves.

## b) Routine tests on generator

- Generator stator frame
  - hydrostatic test (if H2 cooling)
  - resistance check of temperature detectors
- Generator rotor
  - ultrasonic examination
  - mechanical balance
  - over-speed test
  - measurement of 50 Hz rotor impedance (at 3000 RPM).
- Stator core laminations
  - Magnetization of stator core lamination layer resistance between the layers of the core
- Generator H2 cooler (if H2 cooling)
  - hydrostatic test
- Generator assembled:
  - three phase short circuit characteristic test and current balance check
  - dielectric test





- measurement of insulation resistance
  - measurement of winding resistance
  - open circuit characteristic test and voltage balance, phase sequence check
  - segregation of mechanical loss and core loss
  - segregation of stray load loss
  - efficiency calculation
  - unbalanced load test for negative-phase sequence and zero sequence reactance
  - shaft voltage measurement
  - oscillographing of verified voltage wave form and harmonic analysis
  - measurement of vibration
  - polarization index
  - tan delta measurement of complete winding
  - bearing insulation resistance.
- c) Type tests on generator (as far as type test certificates are not available)
- Sudden short circuit test at reduced voltage (30%, 50% and 70% of rated voltage), extrapolated to 100% voltage
  - Equivalent heat run test consisting of:
    - windage and friction heat run, open circuit heat run at 105% rated voltage, short-circuit heat run at rated line current, open-circuit heat run at rated line voltage
    - measurement of open-circuit direct-axis transient time constant
    - noise measurement
    - moment of inertia
  - Measurement of excitation response time\*)
    - overall characteristic coupled with generator and AVQC cubicle at no load\*)

\*) applicable to assembled unit consisting of generator, exciter and voltage regulator, may be carried out on site

Type tests shall be carried out if type test certificates (Not older than 5 years as on date of bid opening) certified by an independent test authority are not available.

Sudden short circuit test shall be carried out in line with IEC at voltage level to be finalized during detailed engineering.

d) Routine tests on generator exciter

- Resistance of windings
- Insulation resistance
- High voltage tests
- Short-circuit characteristic
- No-load characteristic.





**Motors**

IEC 60034, ISO 1680, ISO 10816

- Type tests (each motor type) as far as type test certificates are not available
  - measurement of starting (locked rotor) current and torque
  - power factor and efficiency measurement
  - heat run test
  - noise measurement
  - temperature rise measurement
- Routine tests (each motor)
  - measurement of winding resistances
  - measurement of shaft current
  - no-load and current measurement
  - no-load short circuit measurement
  - open circuit secondary induced voltage test at stand still (wound rotor)
  - dielectric test (high voltage test)
  - measurement of insulation resistance
  - overspeed tests (120% for 2 minutes)
  - check of motor vibrations
  - oscillographic measurement of starting current.

**Emergency diesel sets**

All relevant routine and type tests according to:

|          |                                                                |
|----------|----------------------------------------------------------------|
| ISO 3046 | Reciprocating internal combustion engines - Performance        |
| ISO 8528 | Generating sets with reciprocating internal combustion engines |


**a) Type tests**

The diesel generator unit (DGU) and all auxiliary equipment shall be fully type tested. These tests shall include all type tests as defined in the relevant latest IEC and ISO recommendation (as a minimum requirement).

Evidence shall be given that the DGU together with the auxiliary equipment to be provided, under these specifications, have successfully passed all type tests of design, service frequency, impulse, insulation level, dynamic operating range, and electrical and mechanical endurance performance, as appropriate and as specified.

However, if deemed necessary, the Employer shall decide if additional tests are required to be performed by the Tenderer/Contractor.

The Tenderer/Contractor shall supply certified copies of type test certificates covering the proposed DGU of similar capacity or higher, operating range, data features, design and construction.





## b) Sample tests

Sample Tests shall be performed, comprising as a minimum the following tests:

- Visual checks and measurements of dimensions
- Functional tests.

## c) Routine tests

The Tenderer/ Contractor is required to carry out routine tests on each assembled and finished diesel generator unit and its relevant auxiliary equipment to demonstrate the integrity of the system.

Routine test certificates shall be submitted for the Employer's review and approval before shipment of the DGU.

The DGU shall pass all the routine tests as laid down in the relevant latest revisions of IEC & ISO Standards. In addition, the visual Inspection, which shall determine conformity of the DGU & the relevant equipment with the requirement, shall be part of the routine tests.

The acceptance test for the diesel engine at the Manufacturer's workshop test bed shall include the measurements, calculations and functional checks stated in ISO 3046-1 (F).

A test report in English shall be issued according to ISO 3046-1 (E) giving evidence of the following data:

- Engine model, order No., rated output, operating speed, number of cylinders, bore, stroke, compression ratio, cylinder displacement, no. of strokes, date of test, the Employer's name, inspector's name, ambient air temperature, relative humidity, barometric pressure, fuel specific gravity, fuel net calorific value, setting data of injection pump, firing sequence, valve timings, type of fuel oil filter, type of lube oil filter, type of turbocharger and inter-cooler, type of governor, type of injectors.

The Tenderer/Contractor shall submit together with the test report a certificate showing the emission levels of the exhaust gases: NOx, CO and PM (particulate matter).

The diesel engine shall be proven to be capable of operating in steady state condition on all above mentioned loads. If the diesel engine fails to operate in steady state condition on one or more loads, this engine type shall be not accepted for the scope of the diesel generator units.

## d) Special tests

The diesel engine shall be at least tested in total for one hour at the following loads:

- |                                |             |
|--------------------------------|-------------|
| • Warm-up of the diesel engine | as required |
| • 25 % load operation          | 10 minutes  |
| • 50 % load operation          | 10 minutes  |





- 75 % load operation 10 minutes
- Full load operation 20 minutes
- 110 % load operation 20 minutes
- Cool down of the diesel engine.

During the test run, temperatures, pressures and fuel consumption shall be measured and recorded.

The diesel engine shall be proven to be capable for operation in steady state condition on all above mentioned loads. If the diesel engine fails to operate in steady state condition on one or more loads, this engine type shall not be accepted.

#### Low voltage switchgear

The following standards and regulations or equivalent shall be used:

|           |                                                            |
|-----------|------------------------------------------------------------|
| IEC 60947 | Low-voltage switchgear and control gear                    |
| IEC 61439 | Low-voltage switchgear and control gear assemblies         |
| IEC 60529 | Degrees of protection provided by enclosures (IP Code)     |
| IEC 60898 | Specifications for circuit-breakers                        |
| IEC 60079 | Electrical apparatus for potentially explosive atmospheres |
| IEC 60947 | Regulations for low-voltage switchgear                     |

The "Design Verification" of all low voltage switchgears/ motor control centers shall be carried out by following methods:

- "Testing" for the Pos. No. 1., 2., 3., 4., 5., 9., 10., 11., 12. and 13 of IEC 61439-1/Annex D, Table D.1
- "Assessment" for the Pos. No. 6., 7. and 8 of IEC 61439-1/Annex D, Table D.1

In addition to the above tests for which certificates shall be submitted, at least the following tests shall be performed in the manufacturer's workshop on the individual apparatus and on the complete installation, respectively, all in accordance with IEC Standards:

- Visual inspection
- Power frequency HV tests at main circuit
- Dielectric tests of the auxiliary and control circuits
- Functional test of the control circuits
- Check of the operational sequence.





**Capacitors**

|     |       |                                                  |
|-----|-------|--------------------------------------------------|
| IEC | 60831 | Shunt power capacitors                           |
| IEC | 60871 | Shunt capacitors for A.C. power systems          |
| IEC | 60931 | Shunt power capacitors                           |
| IEC | 60143 | Series capacitors for power systems              |
| IEC | 60358 | Coupling capacitors and capacitor dividers       |
| IEC | 60384 | Fixed capacitors for use in electronic equipment |

**Batteries, charging equipment inverters and DC/DC converters**

|     |       |                                                                                  |
|-----|-------|----------------------------------------------------------------------------------|
| IEC | 60086 | Primary batteries                                                                |
| IEC | 60119 | Recommendations for polycrystalline semiconductor rectifier stacks and equipment |
| IEC | 60146 | Semiconductor converters                                                         |
| IEC | 60896 | Stationary lead-acid batteries                                                   |
| IEC | 61204 | Low voltage power supply devices DC output                                       |

Chargers and batteries shall be tested together in the factory. Testing of chargers and batteries together at site will also be accepted. All factory tests shall be repeated at site.

**Chargers**

- Visual inspection (to be repeated on site)
- Functional tests (to be repeated on site)
- Heat run (type test)
- Output voltage stability measured for 25% load steps
- Ripple voltage measurement without connected battery
- Ripple measurement (voltage and current) with connected battery (at site will also be accepted).
- Insulation test (to be repeated on site).

**Batteries**

- Visual inspection (to be repeated on site)
- Insulation test (to be repeated on site)
- Charge test and discharge tests

**Fuse Box**

- Visual inspection (to be repeated on site)
- Functional tests (on site)
- Insulation test (on site)

**Inverters and DC/DC converters**

- Visual inspection (to be repeated on site)
- Functional tests (to be repeated on site)
- Heat run (type test)
- Insulation test (to be repeated on site).





**Lamps and accessories**

|         |       |                                                                                                     |
|---------|-------|-----------------------------------------------------------------------------------------------------|
| IEC     | 60081 | Double-capped fluorescent lamps                                                                     |
| IEC     | 61347 | Lamp control gear                                                                                   |
| IEC     | 60921 | Ballasts for tubular fluorescent lamps                                                              |
| IEC     | 60155 | Glow starters for fluorescent lamps                                                                 |
| IEC     | 60598 | Luminaries                                                                                          |
| IEC     | 60188 | High-pressure mercury vapor lamps                                                                   |
| IEC     | 60400 | Lampholders and starter holders for tubular fluorescent lamps                                       |
| IEC     | 60901 | Single-capped fluorescent lamps                                                                     |
| IEC     | 60662 | High pressure sodium vapor lamps                                                                    |
| IEC     | 60192 | Low pressure sodium vapor lamps                                                                     |
| IEC     | 60923 | Auxiliaries for lamps                                                                               |
| IEC     | 61347 | Part 2-13: lamp control gear for LED Modules                                                        |
| IEC     | 62031 | LED modules for general lighting - Safety specifications                                            |
| IEC     | 62560 | Self-ballasted LED-lamps for general lighting services by voltage > 50 V - Safety specifications    |
| IEC     | 62612 | Self-ballasted LED-lamps for general lighting services by voltage > 50 V - Performance requirements |
| IEC     | 62471 | Photobiological safety                                                                              |
| IEC     | 62384 | DC or AC supplied electronic control gear for LED modules - Performance requirements                |
| IEC     | 60838 | Part 2-2: miscellaneous lampholders - Connectors for LED-modules                                    |
| IEC/PAS | 62717 | LED Modules for general lighting - Performance requirements                                         |
| IEC/PAS | 62722 | Luminaires Performance                                                                              |

**HV-, MV- and LV-cables**

All relevant routine and type tests according to:

|     |       |                                                                                                          |
|-----|-------|----------------------------------------------------------------------------------------------------------|
| IEC | 60060 | High voltage test techniques                                                                             |
| IEC | 60071 | Insulation co-ordination                                                                                 |
| IEC | 60230 | Impulse tests on cables and their accessories                                                            |
| IEC | 60811 | Common test methods for insulating and sheathing materials of electric cables                            |
| IEC | 60840 | Power cables with extruded insulation and their accessories for rated voltages above 30 kV up to 150 kV  |
| IEC | 62067 | Power cables with extruded insulation and their accessories for rated voltages above 150 kV up to 500 kV |
| IEC | 60502 | Power cables with extruded insulation and their accessories for rated voltages from 1 kV up to 30 kV     |



**a) LV-cables**

LV cables shall be workshop tested as per IEC 60502-1 with the following tests as a minimum:

Type tests:

- electrical type tests acc. to: IEC 60502 - 1 Clause 17
- non electrical type tests acc. to: IEC 60502 - 2 Clause 18.

Also following additional type tests shall be carried by the Contractor at their own cost prior to the first shipment of all offered cable if no type test certificates of identical cables are available:

- Fire Resistant according to IEC 60331, BS 6387
- Flame Retardant according to IEC 60332
- Low Smoke Test according to IEC 61034
- Halogen Content Test according IEC 60754
- Water Tree Test of XLPE Insulation (accelerated)
- Test voltage =  $3 \times U_0$
- Test frequency = 500 Hz
- Core environment = 400C water
- Duration of test = 4 month
- Test after 4 months: Dielectric stress withstand  $>14\text{kV/mm}$ .

Moreover, test certificates shall be provided, proving that each cable type to be used has successfully passed type tests as required by the applicable standards during the last 12 months before award of contract. Otherwise, these tests have to be repeated on sample Sections.

Routine tests: according IEC 60502 – 1, Clause 15

- measurements of electrical resistance of conductors according to Clause 15.2
- voltage tests according to clause 15.3.

Sample tests: according IEC 60502 – 1, Clause 16

- conductor examination according Clause 16.4
- check of dimensions according Clause 16.5 to 16.8
- hot set test for EPR, HEPR and XLPE insulations and elastomeric sheath according Clause 16.9.

**b) MV-cables**

MV cables shall be workshop tested as per IEC 60502-2 with the following tests as a minimum:

Type tests:

- electrical type tests acc. to: IEC 60502 - 2 Clause 18
- non electrical type tests acc. to: IEC 60502 - 2 Clause 19.



Also following additional type tests shall be carried by the Contractor at their own cost prior to the first shipment of all offered cable if no type test certificates of identical cables are available:

- Fire Resistant according to IEC 60331, BS 6387
- Flame Retardant according to IEC 60332
- Low Smoke Test according to IEC 61034
- Halogen Content Test according IEC 60754
- Water Tree Test of XLPE Insulation (accelerated)
- Test voltage =  $3 \times U_0$
- Test frequency = 500 Hz
- Core environment = 400C water
- Duration of test = 4 month
- Test after 4 months: Dielectric stress withstand  $>14\text{kV/mm}$ .

Moreover, test certificates shall be provided, proving that each cable type to be used has successfully passed type tests as required by the applicable Standards during the last 12 months before award of contract. Otherwise, these tests have to be repeated on sample Sections.

Routine tests: according IEC 60502 – 2, Clause 16

- measurements of electrical resistance of conductors according to Clause 16.2
- partial discharge test according to Clause 16.3 on cables having cores with conductor screens and insulation screens in accordance with Clause 7.1 and 7.2
- voltage tests according to clause 16.4.

Sample tests: according IEC 60502-2 Clause 17

- conductor examination according Clause 17.4
- check of dimensions according Clause 17.5 to 17.8
- voltage test for cables of rated voltages above 3.6/6 (7.2) kV according to Clause 17.9
- hot set test for EPR, HEPR and XLPE insulations and elastomeric sheath according Clause 17.10.

#### c) HV-cables

The 230 kV XLPE-Insulated Single-Core Underground Cables and Accessories shall be tested as per latest IEC 62067 including all subsequent amendments and relative standard. The Employer/Engineer shall witness the required Type and Sample tests.

The approval of the Employer/ Engineer or the passing of any such inspection or test will not however, prejudice the right of the Employer/ Engineer to reject the 230 kV XLPE-Insulated Single-Core Cables and accessories if it does not comply with the Specification.





Defects discovered during the type/routine/sample tests shall entitle the Employer/Engineer to reject the cables/accessories fabricated for this Project.

The Tenderer/ Contractor shall fabricate without additional cost the cable lengths and accessories necessary for the tests, over and above those required to complete the Works at Site.

*For the definitions of the Type Tests, Sample Tests, Routine Tests and Tests after installation, reference shall generally be made to the relevant IEC Standards.*

HV cables and accessories shall be workshop tested as per IEC 62067 with the following tests as a minimum:

*Type tests on cable systems: according clause 12:*

- Electrical type test according Clause 12.4
  - Check of insulation thickness acc. to Clause 12.4.1
  - Bending test on the cables acc. to Clause 12.4.4 followed by installation of accessories and a partial discharge test acc. to Clause 12.4.5
  - Tan  $\delta$  measurement acc. to Clause 12.4.6
  - Heating cycle voltage test acc. Clause 12.4.7
  - Partial discharge test acc. to Clause 12.4.5 (at ambient and at high temperature)
  - Switching impulse voltage test acc. to Clause 12.4.8
  - Lightning impulse voltage test followed by a power frequency voltage test acc. to Clause 12.4.9
  - Test of outer protection for joints
  - Examination of cable system with cable and accessories after completion of tests acc. to Clause 12.4.10.
  - Testitivity of semi-conducting screen acc. to Clause 12.4.11.
- Non electrical type tests according to Clause 12.5
  - Check of dimensions acc. to Clause 12.5.1
  - Tests for determination the mechanical properties of insulation acc. to Clause 12.5.2
  - Tests for determination the mechanical properties of oversheats acc. to Clause 12.5.3
  - Aging tests acc. to Clause 12.5.4
  - Pressure test at high temperature on oversheats acc. to Clause 12.5.6
  - Other test on oversheats according to the type used.
  - Hot set test for XLPE insulation acc. to Clause 12.5.10
  - Measurement of carbon black of black PE oversheats acc. to Clause 12.5.12
  - Water penetration test acc. to Clause 12.5.14.

Also following additional type tests shall be carried by the Contractor at their own cost prior to the first shipment of all offered cable if no type test certificates of identical cables are available:

- Fire Resistant according to IEC 60331, BS 6387
- Flame Retardant according to IEC 60332
- Low Smoke Test according to IEC 61034
- Halogen Content Test according IEC 60754
- Water Tree Test of XLPE Insulation (accelerated)
  - Test voltage =  $3 \times U_0$
  - Test frequency = 500 Hz
  - Core environment = 400C water
  - Duration of test = 4 month
  - Test after 4 months: Dielectric stress withstand  $>14\text{kV/mm}$ .

Cables and accessories shall have passed type approval tests in accordance with IEC Specifications and details of the cable designs offered shall be given in the appropriate place in the Technical Schedules. Type test reports shall include cable design details and design drawings of each jointing accessory included in the type test.

The Tenderer/Contractor shall submit certified copies of type test certificates covering the proposed Cables.

*Routine tests:* according Clause 9

- partial discharge test according to Clause 9.2
- voltage tests according to according to Clause 9.3
- electrical test on oversheath according to Clause 9.4

*Sample tests:* according to Clause 10

- conductor examination according Clause 10.4
- measurement of electrical resistance of conductor according to Clause 10.5
- measurement of thickness of insulation and oversheath according to Clause 10.6
- measurement of thickness of metallic sheath according to Clause 10.7
- measurement of diameters according to Clause 10.8
- hot set test XLPE insulations and elastomeric sheath according Clause 10.9
- measurement of capacitance according to Clause 10.10
- lightning impulse voltage test follows by a power frequency voltage test according to Clause 10.12
- water penetration test according Clause 12.5.14
- Lead alloy composition and behavior (BS 3908, BS EN 12548).



*Type tests of accessories*

All accessories shall be tested as per IEC 62067 and all subsequent amendments and relative standards considering Test of Outer protection for buried joints (if applicable).

*Routine Tests, Insulation Joints*

The insulation flange shall be designed to withstand tests voltages as specified in the Technical Data Sheets and shall be tested accordingly.

*Routine Tests, Bonding/Earthing Leads*

The Bonding/Earthing Leads shall be designed to withstand tests voltages and currents as specified in the Technical Data Sheets and shall be tested accordingly.

**Telecommunication installations**

IEC 60215 Safety requirements for radio transmitting equipment

**Aerials**

IEC 60169 Radio-frequency connectors

**Power installations up to 1000 V**

IEC 60364 Electrical installations of buildings

IEC 61439-4 Particular requirements for assemblies for construction sites (ACS)

**Power installation above 1000 V**

IEC 60060 High-voltage test techniques

IEC 62271 HV switchgear and control gear  
(incl. Appendix AA "Internal Arc Test")

**Protection equipment**

Equipment for modular static protection systems (e.g. generator, distance, busbar, protection, etc.) pre-assembled in the relevant standardized boards/cubicles etc. shall be tested in the manufacturers' workshops according to IEC 60255 as far as wiring and proper function is concerned. Simulated inputs (binary signals, current and voltage inputs from test power supplies) shall be used.

**Fire alarm system**

All relevant routine and type tests according to:

NFPA National Fire Protection Association

DIN VDE 0800 Telecommunications

DIN VDE 0833 Alarm systems for fire, intrusion and hold-up



### B0.7.2.5 Control and monitoring equipment

All control and monitoring equipment shall be tested at the manufacturers' works before dispatch to site. Certificates shall be issued for

- synchronizing units
- flow evaluators

On request the correct operation of equipment with specified temperature and humidity limits shall be demonstrated by tests conducted within the limits.

#### Electrical measuring instruments

All electrical measuring instruments shall be tested in accordance with the following rules and regulations. Alternatively, equivalent standards approved by the Employer's Representative may be used.

|           |                                                                                                     |
|-----------|-----------------------------------------------------------------------------------------------------|
| IEC 60051 | Recommendations for direct-acting indicating electrical measuring instruments and their accessories |
| IEC 60258 | Direct acting recording electrical measuring instruments and their accessories                      |
| IEC 61036 | Alternating current static watt-hour meters for active energy                                       |
| IEC 61010 | Safety requirements for electrical equipment for measurement, control and laboratory use            |

#### Electrical remote indication

Meters for active power, reactive power and similar remote indication equipment:

|           |                                             |
|-----------|---------------------------------------------|
| VDE 0418  | Regulations for electric integrating meters |
| IEC 60338 | Telemetry for consumption and demand        |

#### Calibration Tests

The Contractor shall conduct calibration tests of the following instruments and equipment:

- all local indicators over the full range of the indicator
- all transmitters over the full range of the transmitter
- all binary transmitters over the full range including initial setting
- all remote indicators over the full range of the indicator
- all recorders over the full range of the recorder
- one of each type of indication loop with circuit resistance of the loop increased to a value which is equal to the highest value expected, and under worst case operating conditions
- all superheated steam thermocouples
- one of each type of thermocouple or resistance element
- all kinds of analogue transmitters over the full measuring range





- all modules and subassemblies for measuring and control e.g. analogue limit monitors, flow evaluators, function generators
- all quantity meters
- all synchronizing units according to IEC standards
- the actual dimensions of all orifices, nozzles, Venturi nozzles have to be checked as per ISO5167.

#### **Closed-loop control systems**

All main closed-loop control systems shall be tested for polarity and function in accordance with the applicable standards. Control valves shall be tested in accordance with mechanical functional tests on control valves and shall be performed with the actuator mounted (open to closed position and vice-versa). Actuators shall be subject to mechanical and electrical function tests.

#### **Sequence logic equipment**

All sequence logic equipment shall be tested using simulated inputs.

#### **Alarm annunciator and fault printing system**

The alarm annunciator and fault printing system shall be tested using simulated inputs.

#### **DCS system**

The system shall be thoroughly tested at the manufacturers' workshops before dispatch to site. Test programs shall be devised and these shall subsequently be made available to the Employer's Representative. Tests shall be made to ensure that the system operates correctly within the ambient conditions as specified by the manufacturer and that if these conditions are exceeded, i.e. in the case of failure of the air-conditioning system, that the system will automatically fail safe and that neither hardware nor software will be damaged.

#### **Further I&C equipment**

Type test reports shall be provided for the following:

- UPS
- 24 V DC battery chargers
- Batteries
- Control valves
- Instrumentation cables
- Flow nozzle orifice plates
- Measuring instruments
- Local instrument enclosures
- Local instrument racks
- PLCs
- Etc.



**Type test reports**

The minimum type test reports for each of the major I&C systems shall be as follows:

1. Surge Withstand Capability (SWC) for solid state equipment/ systems  
All solid state systems/ equipment shall be able to withstand the electrical noise and surges as encountered in actual service conditions and inherent in a Power Plant. All the solid state systems/ equipment shall be provided with all required protections that needs the surge withstand capability as defined in ANSI 37.90.1/ IEEE-472. Hence all front end cards which receive external signals like analogue input & output modules, binary input & output modules, etc. including power supplies, data highway, data links shall be provided with protections that meet the surge withstand capability as defined in ANSI 37.90.1/ IEEE-472. Complete details of the features incorporated in electronic systems to meet this requirement, the relevant tests carried out, the certificates etc. shall be submitted with the proposal. As an alternative to above, suitable class of EN61000-4-12 which is equivalent to ANSI 37.90.1/ IEEE-472 may also be adopted for SWC test.
2. Dry heat test as per IEC 60068-2-2 or equivalent
3. Damp heat test as per IEC 60068-2-3 or equivalent
4. Vibration test as per IEC 60068-2-6 or equivalent
5. Electrostatic discharge tests as per EN 61000-4-2 or equivalent
6. Radio frequency immunity test as per EN 61000-4-6 or equivalent
7. Electromagnetic field immunity as per EN 61000-4-3 or equivalent

Tests as listed under items number 5 to 7 as applicable for electronic cards only as defined under item 1 above.

**B0.7.3 Testing at site****B0.7.3.1 Civil works testing**

The Contractor shall carry out all required civil construction tests. Thereby part of the test like concrete and earthwork tests have to be carried out at site, other tests have to be performed in the manufacturer workshops.

The Contractor shall submit all test certificates of materials subject to approval and shall arrange for tests of all materials to be carried out in laboratories on site or elsewhere. The cost of all test equipment, samples, tests and transport to the laboratory shall be borne by the Contractor.

The testing operations shall be performed in accordance with the relevant codes and standards and under the supervision of the Employer.



Where in the specifications materials are specified to be approved samples shall be submitted for approval at the earliest possible date and strictly before any purchasing or delivery to the site is made. The individual tests and inspection for the materials, supply and execution shall be carried out in compliance with the requirements of the individual technical specifications. In the case of rejection, further samples of the rejected materials shall be submitted to SC until they are approved or the material is replaced. The Employer may reject any material which in his opinion is not in accordance with the approved standard. All samples shall be submitted free of charge to the Employer.

The characteristics as determined in the samples which are approved shall indicate the standard to be maintained in the materials used in the execution of the works.

The test samples of materials subject to approval by the Employer shall be kept in a safe place and protected against damage or deterioration until completion of the works.

For materials (e.g. steelwork, pipes, ducts, etc.) to be manufactured in workshops respective manufacturer test certificates including test results shall be submitted to the Employer subject to approval.

After final completion of certain civil structures/ parts to be ready for erection of further equipment individual "Civil Completion Certificates" shall be issued by the Contractor under the following conditions:

- Except for minor items of work that would not affect the safety, all civil works for applicable parts, structures or buildings have been carried out and tested
- All such civil works are in a manner that does not void any subcontractor or vendor warranties or violate any applicable law or applicable permit
- Punch List has been agreed upon by the Employer and the Contractor
- Contractor warrants that all necessary works have been undertaken and all applicable parts, structures or buildings are ready for erection.

If the Employer is satisfied that the pre-conditions for the issuance of the Civil Completion Certificate for the respective civil structures/ parts have been met the Civil Construction Completion Certificate shall be signed off by the Employer.

Further testing requirements for civil works are specified in **Section B9**.

An indicative field quality plan for civil works to be followed by the Contractor at site is required to be submitted with the Tender.

### B0.7.3.2 Erection tests

#### General

During erection all required erection tests as well as final erection checks of the mechanical completion of the systems and part thereof have to be performed.

The Employer shall have the right to witness on request all tests on site and shall be informed of site test 24 hours in advance.

After successful mechanical completion of each system, Individual Erection Completion Certificates will be issued.

The activities necessary for mechanical completion shall include but not be limited to following testing:

- visual inspection after unloading at site
- checking of completion of relevant systems
- completion of buildings and civil works
- test of ventilating and air-conditioning units
- alignment of rotating equipment coupled on site
- safety audit
- testing of site welds (non-destructive examinations)
- pressure testing, leak tests, tightness tests
- checking of pipe hangers, supports, guides, etc.
- pipe line and equipment flushing and cleaning
- chemical protection of piping systems
- checking of coating
- testing of cranes and hoists.

#### Electrical equipment tests

The following tests or measurements must be made during and after erection but before any item of equipment is put on trial operation:

- design and visual checks
- screwed connections for correct assembly
- terminals and terminal connections for correct assembly
- checking of earthing connections and testing of earthing resistances
- measurement of insulation values (didactic tests)
- verification of earthing conditions
- fire-proof partitioning
- marking, inscription, provision of designation plates
- rotating-field measurement
- phase coincidence with 2 half-busbars
- voltage checks
- polarity checks in the case of DC voltages
- fuses, overcurrent trips, short circuit trips, time settings, relay settings
- oil levels

*Signature*





- status indication, alarm and trip signals
- checks on wiring and cabling for conformity with the constructional circuit drawings and plans
- high voltage tests
- current and voltage transformer circuits
- functional test of all protection relays including winding and oil temperature monitoring as well as Buchholz protection etc.
- interface with the DCS and SCADA.

The tests shall be carried out according to relevant standards.

The Contractor shall submit for each test of all equipment a method statement, with relevant diagrams explaining the procedure of the tests and test criteria supported by relevant standards and test methods.

All major equipment shall have a separate test package.

All high voltage tests shall be carried out at 50 Hz. Equipment for which DC tests is proposed shall be justified and approved by Employer/Engineer. HV tests of switchgears shall be carried out with the relevant circuit breakers in open and closed positions.

Unless otherwise agreed, all erection and civil works related to the equipment shall be completed before starting any site tests.  
All switchgears shall be verified by primary injection in addition to secondary injection.

### Generators

This Section covers the specific requirements for the site tests and performance tests requirements in the turbine plant.

These tests shall include:

- Routine tests as per IEC 60034 - as far as practicable under site condition comprising of:
  - testing of running behaviour (overspeed)
  - determination of temp. rises of coolants and lubricants for bearing and shaft seals
  - determination of friction losses
  - recording of no-load saturation characteristics and determination of core losses
  - measurement of shaft voltage
  - verification of phase sequence and appropriate terminal marking
  - measurement of excitation current and determination of losses at rated current on short circuit
  - calculation of efficiency from sum of individual losses
  - winding insulation measurement
  - HV test on windings
  - functional test of accessories and attachments



8140A01/FICHT-15702705-v5  
BIFPCL/EPC-Main Plant/2015/1/

FICHTNER



B0-239

000252

- measurement of excitation response time – GTG: measuring will be carried out at site during commissioning
- overall characteristics coupled with generator and AVR cubicle at no load (applicable for the assembled unit consisting of generator, exciter and voltage regulator) – GTG: measuring will be carried out at site during commissioning.

The Contractor has to provide a detailed test procedure subject to approval by the Employer/Engineer.

### Motors

Tests at Site (with motor coupled):

- measurement of insulation resistance
- measurement of shaft current
- measurement of motor vibrations
- at motors rated 47 kW or higher, in addition:
  - oscillographic measurement of starting current (if not performed during workshop testing)
  - measurement of starting period.

### Switchgear for Voltages above 1 kV

The complete installation shall be tested at site as follows:

- dielectric test
- visual inspection
- contact resistance/torque test of bus bar joints
- CT's, VT's ratio, magnetisation characteristic and burden measurement
- HV test
- mechanical functioning test
- test of the functional sequence
- testing of all interlocks
- testing of all protection relays and circuits by primary/secondary injection and functional tests of the arc protection
- testing of high speed transfer systems
- testing of all alarms (local and remote).

### LV switchgear (AC and DC)

The complete switchgear and the individual apparatus shall be tested on site as follows:

- visual inspection
- dielectric test
- contact resistance/torque test of bus bar joints
- CT's, VT's ratio, magnetisation characteristic and burden measurement
- testing of all interlocks
- setting and testing of all protection relays and circuits by primary/secondary injection. Test kit of adequate rating to be provided





- testing of automatic change over devices
- testing of all alarms (local and remote)
- functional test
- test of the functional sequence.

Setting and functional test of protection devices (primary injection method). However, test plugs and socket facilities for secondary injection tests shall also be made available. Tests kits of adequate ratings shall be made available for the tests.

### Batteries and chargers

Chargers and batteries shall be tested together in the factory. All factory tests are to be repeated at site.

### Chargers

- visual inspection (to be repeated on site)
- functional tests (to be repeated on site)
- heat run (type test)
- output voltage stability measured for 25% load steps
- ripple voltage measurement without connected battery
- ripple measurement (voltage and current) with connected battery
- insulation test (to be repeated on site).

### Batteries

- visual inspection (to be repeated on site)
- insulation test (to be repeated on site)
- charge test and discharge tests (100%).

### Fuse Box

- Visual inspection (to be repeated on site)
- Functional tests (on site)
- Insulation test (on site).

### Inverters & DC/DC Converters

Following test shall be carried out:

- visual inspection (to be repeated on site)
- functional tests (to be repeated on site)
- insulation test (to be repeated on site).



**Earthing and lightning protection**

The complete earthing and lightning protection systems shall be tested as follows:

- The earthing system as a whole shall be tested and verified before putting any major equipment into operation.
- visual inspection of exposed elements
- Measurement of the earth electrode potential  $U_E$  by the voltmeter/ammeter method, test current 100 300 A or an equivalent, approved method if above will be proved to be not feasible,
- measurement of the touch potential  $U_B$ ,
- measurement of step potential.

**Diesel generator units**

The diesel generator units (DGU) shall be thoroughly tested at site. The acceptance tests shall be performed according to the Technical Specifications and acc. to ISO 8528 6:1993 (E) and ISO 3046-1:1995 (E) and -3:1989 (E) for the diesel engine. At site the diesel engine shall be measured and documented according to the stipulations made in Clause 7.6.20. The exhaust gas shall be invisible when the Unit is operating at loads between 50 and 110%. The diesel engine's filter smoke number shall be measured according to BOSCH Index No. 3 or better within a load range from 60 to 100%. A test report in English language shall be issued according to ISO 8528:1993 (E). Upon full satisfaction of the Employer/Engineer after the successful operation tests, in every respect, and that all components are working properly, the DGU with all ancillaries shall be operated at 100% output for 48 hrs without failure or interruption whatsoever. The performance test measurements of the DGU shall be performed according to ISO 8528 6:1993 (E) for the diesel generator unit, ISO 3046-1:1995 (E) and -3:1989 (E) for the diesel engine and latest issue of IEC 60034-2 for the Generator. All guaranteed values shall be assumed to include all necessary tolerances for accuracy of testing, sampling, instrumentation, notwithstanding the performance test code standard. No further tolerances of any kind shall be permitted.





**230 kV XLPE Cables**

Test after laying is to be recommended by the manufacturer considering the following minimum requirements and recommendations from CIGRE WG.21.9 (Electra No.173 August '97), IEC 62067 and other applicable standards to Employer/ Engineers approval.

- visual and function test of bonding/earthing system
- phase Identification Test
- conductor and screen/sheath Continuity Test
- primary connection check
- cable connection bolt tightness check
- cable supporting check
- cable fixing check
- insulation resistance test before and after installation
- DC conductor resistance test (IEC 60228)
- contact resistance test of connecting bars in link boxes
- capacitance test
- earthing measurements
- positive/negative and zero sequence impedance measurements
- testing of SVL
- cross bonding check, primary injection Subsequent repeat tests (after guarantee period)
- DC sheath test according Clause 5 of IEC 60229 between metallic sheath/screen/armouring including cross bonding system, etc. and ground.
- AC voltage test according IEC 62067 Section 14.2.
- measurements of induced voltages on pilot/telephone cables installed in parallel with the power cables.

**Tests accord the Electricity Transmission Code of Bangladesh and Great Britain**

Any other tests required to demonstrate compliance with the above indicated Grid Codes.

**B0.7.3.3 Pre-commissioning tests**

Preconditions for the pre-commissioning are:

- the issue of the individual Erection Completion Certificates;
- the rectification of all relevant erection punch points; and
- the availability of the accepted commissioning test program and commissioning procedures.



The pre-commissioning tests shall cover mainly the functional tests of the individual items of all mechanical, electrical and I&C systems including their alarm and tripping systems. Following tests shall be included, but not limited to:

#### Mechanical equipment

- Individual pre-commissioning runs of all rotating equipment such as pumps, compressors, dosing equipment etc.
- Functional tests of the mechanical equipment
- Testing and adjustment of safety devices

#### Electrical equipment

As far as not already covered by the erection tests the pre-commissioning tests shall cover:

- Voltage tests
- Generator and transformer protection system checks
- Automatic voltage and reactive power control (AVQC), governor setting and adjustment and response to grid system signals
- Trip tests
- Functional tests of the equipment e.g.:
  - Motor checks
  - Circuit breakers, LV, MV, HV cabling and switchgears checks for operability
  - Batteries, chargers and UPS checks for operability
- Remaining tests on turbine generator: In addition, a repetition of winding resistance and insulation resistance measurement, as well as dielectric tests shall be carried out in any case on each turbine generator.

#### Control equipment

- Comprehensive loop tests shall be performed for all measuring loops at least for 0, 50% and 100% value.
- Closed loop control checks up to DCS (for all functions like indication, control, alarms, etc.):
  - Polarity and function test in accordance with the applicable standards.
  - Control valves shall be tested in accordance with mechanical functional tests on control valves and shall be performed with the actuator mounted (open to closed position and vice-versa)
  - Actuators shall be subject to mechanical and electrical function tests.
- All sequence logic equipment shall be tested using simulated inputs.
- The alarm annunciation and sequence of event recording system shall be tested using simulated inputs.
- Binary field contact circuit fault detection.
- Functional tests of control equipment, interlocks, inter-tripping, protection inputs, etc.
- Test of signal exchange with other systems (also with third parties – like LDC, etc.)
- Archiving system (capacity, consistency, redundancy, access times).





- Reports generation
- Emission analyser calibration and emission evaluation tests
- Calibration of metering system (accuracy shall be proven by certificates)

#### B0.7.3.4 Tests on Completion (Commissioning tests)

Preconditions of the Tests on Completion are:

- the successful completion of the individual erection checks of all items of the whole system;
- the issuing of the Final Erection Completion Certificate; and
- the successful completion of all pre-commissioning test.

Should the Employer decide that the preconditions for the Tests on Completion have not been adequately met, the Employer will advise the Contractor accordingly and withhold the commencement of the the Tests on Completion until the outstanding work is completed.

The Tests on Completion shall prove that the Plant is prepared and adjusted to ensure the correct functioning of the individual components and of the complete Plant.

The Tests on Completion shall cover at least following tests:

- Protection tests
  - Operation of selected turbine train protection devices including the following as a minimum:
    - fire protection
    - boiler protection
    - steam turbine protection
    - generator protection
    - transformer protection.

Method of alarm/ trip condition reset for subsequent starting.

- Operation of auxiliary systems:

Method of changeover of main equipment to stand-by equipment prior to Plant starting (see start-up tests) and during normal operation for fuel oil, coal handling, ash handling, oil lube and cooling systems

- Operation of fire protection systems.

- Isolation procedures

- Method of isolation of plant equipment for safe shut-down and maintenance procedures including as a minimum:
  - HV station and unit supplies
  - LV supplies
  - fuel oil systems
  - coal handling systems
  - ash handling systems



- fire protection systems.
- Protection systems/ settings, in accordance with agreed design and the requirements of the transmission system.
- Start-up tests
  - normal semi-automatic start to preset load
  - staged semi-automatic including start to synchronous speed, manual synchronizing (including synchro-check), automatic synchronizing, manual and automatic loading
  - starting with stand-by auxiliaries
  - operation of all auxiliaries.
- Verification of start-up times and loading rates of power unit and steam generator at various downtime conditions.
- Power unit(s)/Plant, to test partial and full load rejection to demonstrate
  - full load rejection tests to measure transient maximum speed and steady state speed at normal governor droop setting
  - method of resynchronism to be demonstrated steam turbine bypass operation capability.
- Power unit(s)/Plant, to verify and check
  - operating stability when operated between 30% and 100% nominal load conditions with load variations by increasing or decreasing the electric load
  - start-up/main fuel change-over:
    - semi-automatic change-over from fuel oil operation to coal operation
    - semi-automatic change-over from coal operation to fuel oil operation.
- Demonstration of the capabilities of the power unit to operate at rated voltage and frequency, at power factors and reactive conditions between 0.85 (lag) and 0.95 (lead).
- Start-up tests of the Plant equipment, facilities and systems including checking of automatic change-over of standby facilities as well as fuel.
- Verification of vibration guarantees.
- Environmental monitoring equipment; water quality monitoring equipment, functioning tests and verification of guarantees.
- Demonstration of the teledispatching and telemetering systems.
- Verification of Active Power Response and Voltage Control Response according to the requirements specified in the Network Connection Conditions.
- Demonstration of proper controlling, monitoring and recording according to the requirements of the Grid Code, including but not limited to the following tests:
  - Reactive Power
  - Fault Detection and Clearing Limits
  - Load Following Capability
  - Black Start (if applicable)
  - Voltage Following Capability (AVQC)
  - Excitation System and Power System Stabiliser
  - Primary, Secondary and High Frequency MW Response





- Unit Start
- Despatch Ramp Rate
- Protection System
- House Load Operation
- Underfrequency Relay
- Loss of AC Power Supply
- Minimum Load
- Site Test for Validation
- Verification of completeness of scope of supply.

#### B0.7.3.4.1 Additional test in accordance with the PPA

Tests prior to synchronisation of each generating unit of the Plant According to the requirements of the BPDB which are part of the PPA, the Contractor shall carry out the following additional tests prior to synchronisation of each generating unit of the Plant:

- automatic voltage regulator setting and adjusting in stand-still condition and with the generator running at no load
- turbine governor control checks, including (but not limited to) a steam governor overspeed test (This test may be performed after a specified period of running of the Unit on load as per the manufacturer's recommendation)
- open circuit and short circuit tests on the generator
- functional testing and timing of high voltage switchgear in the substation of the Facility
- The Company and BPDB shall verify that the protection level settings for switchyard protection equipment are as agreed by the Joint Coordinating Committee
- Voltage phasing checks will be carried out between the Grid System and the Facility; and

All inter-tripping circuits between the Plant and BPDB equipment shall be proved.

#### Tests for commissioning of each generating unit of the Plant

In addition to the above specified tests and according to the requirements of the BPDB which are part of the PPA, the following tests shall be carried out by the Contractor for commissioning of each generating unit of the Plant after completing the tests set out before:

- a. **Dependable Capacity Test**  
Refer to Section 0.7.4.
- b. **Reliability Run**  
Refer to Section B.0.7.5



**c. Automatic Voltage Regulator ("AVR") Droop Test**

The AVR will be demonstrated to control the steam turbine generator voltage over its entire set range.

**d. Steam Turbine Governor Operation Test**

The operation of the steam turbine speed governor will be demonstrated.

**e. Reactive Capacity Test**

This test will demonstrate the capability of the Plant to operate at rated voltage and frequency at power factors and under reactive conditions in accordance with the manufacturer's generator rating curves to be provided by the Contractor, insofar as these tests can be accommodated within the grid system.

**f. Minimum Load Capability Test**

This test will demonstrate the capability of each Unit to be operated at minimum stable load while the steam turbines, and auxiliaries remain in a stable and controlled condition, see also

**B0.7.3.4.2 72h Full Load Continuous Test Run**

After successful completion of the Tests on Completion and availability of the Commissioning Completion Certificate (CCC), signed by the Employer and the Contractor, the "Authorization to Start the 72 h Full Load Continuous Test" shall be signed.

No trip is admitted during these 72 h. Should the Plant or a Unit, as the case may be, not follow the requested load during the 72 h test, the test shall be restarted.

**B0.7.4 Performance Tests**

**Performance Tests of the Unit(s)**

After successful completion of the 72h Full Load Continuous Test Run and after relevant test protocols have been accepted by the Employer for the Unit(s) and Common Facilities, the Contractor shall be allowed to prepare the Unit(s) for the Performance Tests.

For the Unit(s) following guarantees given in the Technical Schedule B0 shall be tested during the related Performance Test; this includes:

- Performance guarantees of the Unit(s)
- Operating guarantees
- Emission guarantees
- Guarantees of steam generator(s), steam turbine generator(s), flue gas treatment systems etc.





**Performance Test of the Plant**

After completion of the Performance Tests of the Unit(s), the guarantees of the Plant and the common facilities shall be tested in a separate Performance Test; this includes:

- Performance guarantees of the Plant
- Emission guarantees of the Plant
- Emission guarantees of the auxiliary boiler
- Noise guarantees
- Guarantees of the water and waste water treatment systems
- Effluent and water outfall guarantees.

**Dependable Capacity Test according to the PPA**

Dependable Capacity means- means at any given time the net amount of capacity at the tariff metering; either for the first generating unit or for the Plant, as the case may be, as determined by the most recent dependable capacity test which shall be comply with ASME standards and shall be carried out as part of the Reliability Run. The Dependable Capacity of the Plant is measured at the Delivery Point. It equals the average Export Power Output, corrected to Reference Site Conditions using correction factors, delivered during twelve continuous thirty (30) minute periods divided by six (6) hours.

Dependable Capacity is the power output/capacity of a unit or the plant which can be reliable evacuated to the grid and which shall be verified by the "Dependable Capacity Test according to PPA". In addition refer to the definition under B0.2.9.2

The Dependable Capacity Test and the Performance Testing in general will be carried out under the the actual prevail conditions. The measured power output and other guaranteed performance data shall be corrected to the reference conditions using the correction curves to be provided by the Bidder/Contractor.

Performance Tests shall be conducted in accordance with following standards:

- |                   |              |
|-------------------|--------------|
| • the Plant       | ASME PTC 46  |
| • steam generator | ASME PTC 4   |
| • steam turbine   | ASME PTC 6   |
| • cooling tower   | ASME PTC 23  |
| • FGD plant       | ASME PTC 40. |



As for supercritical steam power plants operation without make-up must be possible for a defined time period, the guarantee figures shall not include make-up.

8140A01/FICHT-15702705-v5  
BIFPCL/EPC-Main Plant/2015/1/

FICHTNER



B0-249

000262

The curves required for the correction of the power output and specific heat rate to the site specified ambient conditions shall be listed in the technical schedules of the Plant performance and steam generator and steam turbine performance, and shall be submitted with the Tender. These curves shall be conclusive and no extra correction shall be given.

The margins required for instrument inaccuracies and for all other reasons shall be deemed to be included in the guarantee figures. The actual figures determined during performance tests shall hence be not corrected with any margins due to instrument inaccuracies prior to comparison with the guarantee figures.

Degradation and fouling during commissioning and other operation prior to Provisional Acceptance shall be deemed to be included in the guarantee figures. The actual figures determined during performance tests shall hence be not corrected for any degradation or fouling effect prior to comparison with the guarantee figures.

Degradation curves for the Plant and Unit(s) performance shall be submitted by the Contractor with bid. The curves shall show the equipment's degradation in power output and heat rate versus equivalent operating hours. The curves shall be applicable up to and including final major overhaul.

#### Test program

In due time prior to the tests a detailed procedure covering the testing to be undertaken and the methods to be employed shall be provided by the Contractor. The test procedure shall also detail areas of responsibility and the items that specifically require preparation and agreement before the tests can be carried out.

The test program shall cover the following documents but not be limited to:

- test procedure and standards (including proposed formulae / curves and standards)
- test schedule
- type of test
- manpower and deployment schedule of the Contractor for performing the tests forms of test records and report
- description of instrumentation to be used, including accuracy, and calibration test results
- method of data recording
- list of all auxiliary loads that will be operating during the tests. The list of auxiliary loads shall be provided with the test program and agreed in the Test Procedure.
- method and equations/correction curves used for adjustment of recorded data to the design conditions.





**Test responsibility**

All tests shall be prepared and conducted by the Contractor. The Plant shall be operated by Contractor's operation personnel.

The Employer and/or an independent third party, awarded by the Employer, shall have the right to witness the tests.

Contractor's personnel appointed to carry out the tests shall be adequately skilled and experienced. Information on these personnel shall be provided to the Employer as part of the test program for review.

**Test instrumentation**

The Contractor shall supply and install all test instrumentation needed to conduct the tests. Temporary instrumentation installed for test purposes only and shall be retained at Site upon the satisfactory conclusion of all tests and shall be then removed.

All instruments to be used for the test shall be strictly dedicated calibrated measurement equipment. Each measuring instrument used shall be according to controlled and provided with a valid calibration certificate.

The calibration of PG Test instrument shall be carried out as per PTC-6 by an independent authorised company, which shall have appropriated quality standards and which shall be to be approved by the Employer, except for instruments which are calibrated and certified at a certified laboratory and holding the authorized traceability certificate. The certificate shall not be older than six (6) months.

**Test Duration**

The test shall begin after the Plant or a Unit including common facilities, as the case may be, has established stable operation, as judged by the Employer and/or an independent third party, awarded by the Employer.

The test duration shall be in accordance with the standards and codes.

One 60-minute test run shall be conducted for each guaranteed load point, during which the operating conditions shall remain within the defined plant stability criteria.

**Test conditions**

Performance tests shall be conducted at conditions close to the conditions of the Guarantees. Thereby the boiler and steam turbine cycle shall be adjusted to the conditions of the corresponding heat balance diagram.

Since the accuracy of the test results highly depend on the exact water-steam cycle arrangement respective cycle isolation is required to avoid any unknown cycle leakages. The valve position list has to be provided by the Contractor prior to the performance test. This cycle arrangement shall fully remain during the whole testing period. Any changes of the performance





conditions during the tests are not allowed.

#### Test evaluation

The Contractor shall submit for the acceptance of the Performance Test all detailed measurements, calculations and individual test results (such as, but not limited to turbine efficiency calculations, generator and transformer details, condenser performance, feedwater heaters and deaerator details, boiler efficiency calculations, pulverizing fineness and other results, air heater temperature traverses and leakage results, coal handling system performance, ash characteristics and ash handling systems performance, ESP and FGD performance and emissions, individual auxiliary power consumption figures, major consumers performance, noise and effluents etc.) and the corrections made based on the correction curves."

The Performance Test report shall be submitted by the Contractor. This report shall include, as a minimum, the following:

- description of the test procedures
- instrumentation details and calibrations (not older than six months)
- full process flow diagrams for fuel, air and flue gas and water and steam with indication of instrument position
- standards that were used
- test logs and summary (arithmetic average) of test readings used for performance calculations
- full set of correction curves
- calculations
- instrument calibration certificates
- list of all auxiliary loads that were operated during the tests
- performance tests results for the "As-run" condition and for the "Corrected as-run conditions"
- conclusions of performance tests: test passed or not.

#### B0.7.5 Reliability test run

After successful completion of all Performance Tests the Plant or a Unit including common facilities, as the case may be, shall start the 30 (thirty) days Reliability Test Run.

During the Reliability Test Run the Contractor shall demonstrate that the Plant or a Unit including common facilities, as the case may be, is fit for commercial operation.

During the specified periods, the Plant shall be operated continuously and in accordance with the prevailing power requirements of the Transmission System/BPDB or as required by the Employer.

During the Reliability Test Run the Employer's operation personnel shall operate the Plant under the full supervision and the responsibility of the





Contractor's Personnel and according to the O&M manual as supplied by the Contractor.

For the successful completion of the Reliability Test Run, a maximum of 4 trippings of not more than combined outage of 24 hours are allowed, otherwise the Reliability Test Run will be considered as failed and a new Reliability Test Run will have to be executed until the test has been completed.

At the conclusion of the Reliability Test Run the Contractor shall request from the Employer the issuing of the Provisional Acceptance Certificate (PAC).

A list of minor pending items, which are at the judgment of the Employer do not jeopardize the trouble-free operation of the Plant or a Unit including common facilities, as the case may be, could be attached to that certificate. The envisaged completion date for each item shall be stated in it.

With the issuing of the PAC the Employer takes legal possession of the Plant or a Unit including common facilities, as the case may be, and the Warranty Period will begin.

During the Warranty Period the Contractor has to keep at site at least three Warranty Engineers at Site. Part of their duty shall be inter alia to complete in time the works for the minor punch items mentioned in the PAC. They shall issue, together with the Employer, special reports, should any damages occur to any equipment. Moreover they shall assist the Employer during the daily plant operation and issue additional operational instructions, if requested. They shall assist the Maintenance Superintendent in his work organization and spare part handling procedure.

At the successful conclusion of the Warranty Period, the Contractor shall request the Employer to issue the Final Acceptance Certificate (FAC).

**Additional requirements as per the PPA** The Facility shall operate continuously (without interruption) for Seventy two (72) continuous hours at then demonstrated Dependable Capacity. For ninety six (96) hours the output shall be as requested by BPDB in accordance with the Dispatch provisions as outlined in the PPA.

### Abbreviations

(Please refer also to relevant Sections "Standards and Codes" and "Units of measurement")



AASHTO

AC  
AGC

American Association of State Highway and  
Transportation Officials  
Alternating Current  
Automatic Grid Control



8140A01/FICHT-15702705-v5  
BIFPCL/EPC-Main Plant/2015/1/

FICHTNER

BO-253  
000266

|           |                                                             |
|-----------|-------------------------------------------------------------|
| ASC       | Average Site Conditions                                     |
| ATRS      | Automatic Turbine Run-up System                             |
| ATT       | Automatic Turbine Testing System                            |
| AVQR      | Automatic Voltage and Reactive Power Control                |
| AVT       | All Volatile Treatment                                      |
| BFP       | Boiler Feedwater Pump                                       |
| BIMS      | Building Information Management System                      |
| BMCR      | Boiler Maximum Continuous Rating                            |
| BMS       | Burner Management System                                    |
| BOD       | Biological Oxygen Demand                                    |
| BOP       | Balance of Plant                                            |
| BOQ       | Balance of Quantities                                       |
| BPDB      | Bangladesh Power Development Board                          |
| BPS       | Boiler Protection System                                    |
| CCR       | Central Control Room                                        |
| CCTV      | Closed Circuit Television                                   |
| CD        | Chart Datum                                                 |
| CEMS      | Continuous Emission Monitoring System                       |
| CHP       | Coal Handling Plant                                         |
| CO        | Carbon Monoxide                                             |
| COD       | Commercial Operation Date                                   |
| COD       | Chemical Oxygen Demand                                      |
| CT        | Current Transformer                                         |
| CW        | Cooling Water                                               |
| DAF       | Dry Ash Free                                                |
| DC        | Direct Current                                              |
| DCDB      | DC Distribution Board                                       |
| DCS       | Distributed Control System                                  |
| DDCMIS    | Distributed Digital Control Monitoring & Information System |
| DCS       | Distributed Control System                                  |
| DOE       | Department of the Environment, Bangladesh                   |
| DOSH      | Department of Safety and Health, Bangladesh                 |
| DPC       | Damp Proof Course                                           |
| DWT       | Dead Weight Tons                                            |
| ECP       | Electrochlorination Plant                                   |
| EHG       | Turbine Electro Hydraulic Governor Control System           |
| EHS - TTP | IFC Environmental Health and Safety Guidelines              |
| EHV       | Thermal Power Plants                                        |
| EIA       | Extra High Voltage (500 kV)                                 |
| EMC       | Environmental Impact Assessment                             |
| EPC       | Electro-Magnetic Compatibility                              |
| ESP       | Engineering, Procurement, Construction                      |
| ETP       | Electrostatic Precipitator                                  |
| DF        | Effluent Treatment Plant                                    |
| FEGT      | Forced Draught Fan                                          |
| FGD       | Furnace Exit Gas Temperature                                |
| FTU       | Flue Gas Desulphurization Plant                             |
|           | Field Mounted Termination Unit                              |





|        |                                                       |
|--------|-------------------------------------------------------|
| GCV    | Gross Calorific Value                                 |
| G-EHSG | IFC General Environmental Health and Safety Guideline |
| GJ     | Gigajoule                                             |
| GPS    | Global Positioning System                             |
| GRP    | Glass Fiber Reinforced Piping                         |
| GWh    | Gigawatt hour                                         |
| GSO    | Grid System Operator                                  |
| HART   | Highway Addressable Remote Transducer                 |
| HAZOP  | Hazard and Operability Study                          |
| HCSD   | High Concentration Slurry / Solids Disposal           |
| HDPE   | High Density Polyurethane                             |
| HHV    | Higher Heating Value                                  |
| HMI    | Human Machine Interface                               |
| HRC    | High Ruption Capacity Fuse                            |
| HV     | High Voltage                                          |
| HVAC   | Heating, Ventilation, Air Conditioning                |
| Hz     | Hertz                                                 |
| I&C    | Instrumentation and Control                           |
| IDF    | Induced Draught Fan                                   |
| IOD    | Initial Operation Date                                |
| IP     | Intermediate Pressure                                 |
| IPL    | Independent Protection Layer                          |
| IPP    | Independent Power Producer                            |
| IR     | Infrared                                              |
| kV     | Kilovolt                                              |
| kW     | Kilowatt                                              |
| LAN    | Local Area Network                                    |
| LCC    | Local Control Center                                  |
| LCV    | Lower Calorific Value                                 |
| HSD    | High Speed Diesel                                     |
| LHV    | Lower Heating Value                                   |
| LIE    | Local Instrument Enclosure                            |
| LIR    | Local Instrument Rack                                 |
| LP     | Low Pressure                                          |
| LV     | Low Voltage                                           |
| LVS    | Large Video Screen                                    |
| MCC    | Motor Control Center                                  |
| MCL    | Maximum Continuous Load                               |
| MCR    | Maximum Continuous Rating                             |
| MCWP   | Main Cooling Water Pump                               |
| MDBFP  | Motor Driven Boiler Feed Pump                         |
| MLSD   | Land Survey Datum                                     |
| MNCL   | Minimum Continuous Load                               |
| MNCR   | Minimum Continuous Rating                             |
| MOV    | Motor Operated Valve                                  |
| MV     | Medium Voltage                                        |
| MVA    | Megavolt Ampere                                       |
| MVAR   | Megavolt Ampere Reactive                              |
| MWh    | Megawatt hour                                         |



|                 |                                                               |
|-----------------|---------------------------------------------------------------|
| MWQCS           | Marine Water Quality Criteria and Standards                   |
| NCC             | Network Control Center                                        |
| NDE             | Non Destructive Examination                                   |
| NFPA            | National Fire Protection Association                          |
| NLDC            | National Load Dispatch Centre                                 |
| NO <sub>x</sub> | Nitrogen Oxides                                               |
| NOR             | Notice of Readiness                                           |
| NPSH            | Net Positive Suction Head                                     |
| NRV             | Non Return Valve                                              |
| O&M             | Operation and Maintenance                                     |
| OEM             | Original Equipment Manufacturer                               |
| OHL             | Over head line                                                |
| P&I             | Piping and Instrumentation                                    |
| P&ID            | Piping and Instrumentation Diagram                            |
| PA              | Public Address                                                |
| PABX            | Private Automatic Branch Telephone Exchange                   |
| PA              | Primary Air                                                   |
| PADO            | Plant Performance Analysis, Diagnosis and Optimization System |
| PAF             | Primary Air Fan                                               |
| PC              | Pulverized Coal                                               |
| PCDD            | Polychlorinated Dibenzodioxins                                |
| PCDF            | Polychlorinated Dibenzofurans                                 |
| PF              | Performance Fuel                                              |
| PLC             | Programmable Logic Controller                                 |
| PPA             | Power Purchase Agreement                                      |
| PQR             | Procedure Qualification Record                                |
| PSS             | Power System Stabiliser                                       |
| PVC             | Polyvinyl Chloride                                            |
| PWD             | Public Works Department                                       |
| PWHT            | Post welding heat treatment                                   |
| QA              | Quality Assurance                                             |
| RAPH            | Regenerative Air Preheater                                    |
| RC              | Reinforced Concrete                                           |
| RSC             | Reference Site Conditions                                     |
| SA              | Secondary Air                                                 |
| SAH             | Steam Air Heater                                              |
| SCADA           | Supervisory Control and Data Acquisition                      |
| SCAPH           | Steam Coil Air Heater                                         |
| SCS             | Substation Control System                                     |
| SER             | Sequence of Events Recording                                  |
| SG              | Steam Generator                                               |
| SI              | Soil Investigation                                            |
| SIL             | Safety Integrity Level                                        |
| SO <sub>2</sub> | Sulphur Dioxide                                               |
| SOE             | Sequence of Events                                            |
| SSC             | Summer Site Conditions                                        |
| ST              | Steam Turbine                                                 |
| STG             | Steam Turbine Generator                                       |





|      |                                   |
|------|-----------------------------------|
| SWAS | Steam and water analyses system   |
| TCS  | Technical Comment Sheet           |
| TDS  | Total dissolved solids            |
| TEFC | Totally enclosed Fan cooled       |
| TG   | Turbine Generator                 |
| TIG  | Tungsten Inert Gas                |
| TLA  | Three-Letter Abbreviation         |
| TMC  | Turbine Maximum Capacity          |
| TMCR | Turbine Maximum Continuous Rating |
| TSCS | Turbine Stress Control System     |
| TSI  | Turbine Supervisory Instruments   |
| UHF  | Ultra High Frequency              |
| UV   | Ultraviolet                       |
| VDU  | Video Display Unit                |
| VT   | Voltage Transformer               |
| VMS  | Vibration monitoring system       |
| VWO  | Valves Wide Open                  |
| WSC  | Winter Site Conditions            |
| WPS  | Welding procedure specification   |
| WTP  | Water Treatment Plant             |
| WWD  | Weather Working Days              |
| WWTP | Waste Water Treatment Plant       |





**TITLE** 2X660 MW BIFPCL MAITREE  
**TECHNICAL SPECIFICATION FOR**  
**WORKSHOP EQUIPMENT (CIVIL AND**  
**GARDNER EQUIPMENT)**

SPECIFICATION NO. PE – TS - 421 - 568 – A012

SECTION III

REV 0

SHEET OF

### **SECTION-III**

## **DOCUMENTS TO BE SUBMITTED ALONG WITH BID**

**SUB-SECTION IIIA – Documents Furnished along with offer**

**SUB-SECTION IIIB – Compliance cum confirmation certificate**

**SUB-SECTION IIIC – Electrical Load Data**

**SUB-SECTION IIID – Pre Bid Clarification**





|       |                                                                                    |  |                                              |   |
|-------|------------------------------------------------------------------------------------|--|----------------------------------------------|---|
| TITLE | 2X660 MW BIFPCL MAITREE                                                            |  | SPECIFICATION NO. PE – TS - 421 - 568 – A012 |   |
|       | TECHNICAL SPECIFICATION FOR<br>WORKSHOP EQUIPMENT (CIVIL AND<br>GARDNER EQUIPMENT) |  | SECTION III                                  |   |
|       |                                                                                    |  | SUB SECTION IIIA                             |   |
|       |                                                                                    |  | REV                                          | 0 |
|       |                                                                                    |  | SHEET OF                                     |   |

**DOCUMENTS TO BE FURNISHED WITH OFFER FOR TECHNICAL EVALUATION**

1) SCHEDULE OF TECHNICAL DEVIATION (IF ANY)

OR

'NO DEVIATION CERTIFICATE' – Clearly mentioning that bidder has considered 'No - Deviation' from the technical specification provided by BHEL.

2) SIGNED AND STAMPED COPY OF COMPLIANCE CUM CONFIRMATION CERTIFICATE.

3) Credentials with reference to technical pre-qualification requirement.

4) Filled up Electrical load list, duly signed and stamped.

5) Un priced copy of price format indicating Quoted / Not quoted against each Row / column.

**NOTE:**

i) NO OTHER DOCUMENTS OTHER THAN THOSE LISTED ABOVE ARE REQUIRED TO BE SUBMITTED FOR TECHNICAL EVALUATION. IN CASE ANY OTHER DOCUMENT IS FURNISHED, THE SAME WILL NOT BE TAKEN INTO CONSIDERATION FOR TECHNICAL EVALUATION.

|                                                                                  |                                                                                                                                                                                |                                                                                      |
|----------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------|
|  | <b>TITLE: 2X660 MW BIFPCL MAITREE<br/>TECHNICAL SPECIFICATION FOR<br/>WORKSHOP EQUIPMENT<br/>(CIVIL AND GARDNER EQUIPMENT)<br/>COMPLIANCE CUM CONFIRMATION<br/>CERTIFICATE</b> | SPEC. NO.: PE-TS-421-568-A012<br>VOLUME: III<br>SECTION: IIIB<br>REV. NO. 0<br>Date: |
|----------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------|

### **COMPLIANCE CUM CONFIRMATION CERTIFICATE**

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate (every sheet) and furnish same with the offer.

- a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions other than those mentioned under "exclusion" in section C and those resolved as per 'Schedule of Deviations', if applicable, with regard to same.
- b) There are no other deviations w.r.t. specifications other than those furnished in the 'Schedule of Deviations'. Any other deviation, stated or implied, taken elsewhere in the offer stands withdrawn unless specifically brought out in the 'Schedule of Deviations'.
- c) Bidder shall submit QP in the event of order based on the guidelines given in the specification & QP enclosed therein. QP will be subject to BHEL/ CUSTOMER approval & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc. This shall be within the contracted price with no extra implications to BHEL after award of the contract.
- d) All drawings/ data-sheets/ calculations etc. submitted along with the offer shall be considered for reference only, same shall be subject to BHEL/ CUSTOMER approval in the event of order.
- e) The offered materials shall be either equivalent or superior to those specified in the specification & shall meet the specified/ intended duty requirements. In case the material specified in the specifications is not compatible for intended duty requirements then same shall be resolved by the bidder with BHEL during the pre - bid discussions, otherwise BHEL/ Customer's decision shall be binding on the bidder whenever the deficiency is pointed out.

For components where materials are not specified, same shall be suitable for intended duty, all materials shall be subject to approval in the event of order.

- f) The commissioning spares shall be supplied on 'As Required Basis' & prices for same included in the base price itself.
- g) All sub vendors shall be subject to BHEL/ CUSTOMER approval in the event of order.
- h) Guarantee for plant /equipment shall be as per relevant clause of GCC /SCC /Other Commercial Terms & Conditions.
- i) In the event of order, all the material required for completing the job at site shall be supplied by the bidder within the ordered price and within purview of the tender specification even if the same are additional to approved billing break up, approved drawing or approved Bill of quantities.
- j) Schedule of drawings submissions, comment incorporations & approval shall be as stipulated in the specifications. The successful bidder shall depute his design personnel to BHEL's/ Customer's/ Consultant's office for across the table resolution of issues and to get documents approved in the stipulated time.



103129/2020/PS-PEM-MAX



**TITLE: 2X660 MW BIFPCL MAITREE  
TECHNICAL SPECIFICATION FOR  
WORKSHOP EQUIPMENT  
(CIVIL AND GARDNER EQUIPMENT)  
COMPLIANCE CUM CONFIRMATION  
CERTIFICATE**

SPEC. NO.: PE-TS-421-568-A012

VOLUME: III

SECTION: IIIB

REV. NO. 0

Date:

- k) As built drawings shall be submitted as and when required during the project execution.
- l) The bidder has not tempered with this compliance cum confirmation certificate and if at any stage any tempering in the signed copy of this document is noticed then same shall be treated as breach of contract and suitable actions shall be taken against the bidder.





103129/2020/PS-PEM-MAX

PEM-6666-0



TITLE **2X660 MW BIFPCL MAITREE**  
**TECHNICAL SPECIFICATION FOR**  
**WORKSHOP EQUIPMENT (CIVIL AND**  
**GARDNER EQUIPMENT)**

SPECIFICATION NO. PE-TS-421-568-A012

SECTION III

SUB SECTION III D

REV 00

SHEET 1 OF 1

## PRE-BID CLARIFICATION SCHEDULE

| S. No. | Section/Clause /Page No. | Statement of the referred clause | Clarification Required |
|--------|--------------------------|----------------------------------|------------------------|
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |
|        |                          |                                  |                        |

The bidder hereby certifies that above mentioned are the only clarifications required on the technical specification for the subject package.

SIGNATURE: \_\_\_\_\_

NAME: \_\_\_\_\_

DESIGNATION: \_\_\_\_\_

COMPANY: \_\_\_\_\_

DATE: \_\_\_\_\_

COMPANY SEAL